

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 05/Aug/2019 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 72.984         | 329.894         | 1) Gujrat                      | -0.795         | -8.136          |
| 2) Hydro            | 7.722          | 39.072          | 2) Madhya Pradesh              | 7.910          | 45.974          |
| 3) Gas              | 9.317          | 37.927          | 3) Chattisgarh                 | 2.660          | 15.450          |
| <b>Total MSPGCL</b> | <b>90.023</b>  | <b>406.893</b>  | 4) Maharashtra                 | 90.070         | 423.095         |
| B) 1) APLM          | 47.207         | 303.271         | 5) Goa (Amona)                 | -0.616         | -3.762          |
| 2) JSWEL            | 23.694         | 115.069         | <b>Total</b>                   | <b>99.229</b>  | <b>472.621</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 20.419         | 101.366         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 25.855         | 129.794         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 12.086         | 51.994          |
| 6) Other IPP        | 2.040          | 11.836          | Include PX                     | -2.386         | -21.537         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 20.419         | 101.366         |
| C) 1) TPCL Thermal  | 10.355         | 58.397          | Include PX                     | 3.436          | 21.205          |
| 2) TPCL Hydro       | 7.403          | 23.245          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.224          | 16.682          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.009         | 47.713          | 1) MSEDCL                      | 300.620        | 1502.851        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 56.846         | 275.830         |
| 1) Thermal          | 166.289        | 866.180         | <b>TOTAL STATE</b>             | <b>357.466</b> | <b>1778.681</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 15.125         | 62.317          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 12.541         | 54.609          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 61.488         | 308.949         |                                |                |                 |
| 6) SOLAR            | 2.794          | 14.006          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>258.237</b> | <b>1306.061</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 3046                      | 3076                  | 3169                      | 3015                      |
| MSPGCL Hydro             | 398                       | 265                   | 375                       | 248                       |
| MSPGCL Gas               | 389                       | 397                   | 399                       | 378                       |
| MSPGCL Total Generation  | 3833                      | 3738                  | 3943                      | 3641                      |
| Central Sector Receipt   | 4878                      | 4601                  | 4726                      | 2894                      |
| WIND                     | 2684                      | 2770                  | 2499                      | 2426                      |
| CPP / IPP Thermal        | 3160                      | 2961                  | 3531                      | 2388                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 373                       | 329                   | 0                         | 0                         |
| Exchange with Mumbai     | -1412                     | -1521                 | -1243                     | -612                      |
| <b>MSEDCL DEMAND MET</b> | <b>13516</b>              | <b>12878</b>          | <b>13456</b>              | <b>10737</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 13516                     | 12878                 | 13456                     | 10737                     |
| TPCL GENERATION          | 1001                      | 1005                  | 1022                      | 639                       |
| AEML GENERATION          | 495                       | 412                   | 389                       | 373                       |
| <b>MUMBAI DEMAND</b>     | <b>2908</b>               | <b>2938</b>           | <b>2654</b>               | <b>1624</b>               |
| STATE DEMAND MET         | 16424                     | 15816                 | 16110                     | 12361                     |
| <b>STATE DEMAND</b>      | <b>16424</b>              | <b>15816</b>          | <b>16110</b>              | <b>12361</b>              |
| Frequency (Hz)           | 50.02                     | 50.04                 | 49.94                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 08.03 Hrs | 49.82 Hz at 05.12 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 05/Aug/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| Unit 10            | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 8.54         | 45.22         | 445      | 265      |
| Unit 5             | 8.61         | 45.14         | 430      | 300      |
| <b>Total</b>       | <b>17.15</b> | <b>90.37</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.68         | 6.91          | 130      | 102      |
| Unit 4             | 2.14         | 10.20         | 103      | 69       |
| Unit 5             | 5.92         | 20.84         | 300      | 195      |
| Unit 6             | 7.56         | 31.21         | 358      | 270      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 5.65         | 27.01         | 355      | 0        |
| Unit 9             | 7.62         | 29.31         | 366      | 250      |
| <b>Total</b>       | <b>31.57</b> | <b>125.46</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.81         | 14.24         | 240      | 136      |
| Unit 4             | 3.60         | 12.68         | 195      | 130      |
| <b>Total</b>       | <b>8.41</b>  | <b>26.92</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.22         | 10.02         | 105      | 75       |
| Unit 2             | 2.44         | 12.84         | 140      | 70       |
| Unit 3             | 3.28         | 15.86         | 150      | 101      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 7.48         | 37.41         | 350      | 290      |
| <b>Total</b>       | <b>15.42</b> | <b>76.14</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.44         | 8.18          | 50       | 0        |
| Unit 4             | 0.00         | 0.70          | 0        | 0        |
| Unit 5             | 0.00         | 2.11          | 0        | 0        |
| <b>Total</b>       | <b>0.44</b>  | <b>11.00</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 9.32         | 37.93         | 399      | 377      |
| <b>Total</b>       | <b>9.32</b>  | <b>37.93</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 0.00          | 0        | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 1.64         | 9.46          | 215      | 40       |
| Stage 4         | 0.00         | 1.24          | 0        | 0        |
| Stage 3         | 2.67         | 11.51         | 166      | 0        |
| <b>Total</b>    | <b>4.31</b>  | <b>22.20</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.77         | 3.47          | 32       | 32       |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 1.20         | 4.96          | 61       | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.44         | 2.21          | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 0.00          | 0        | 0        |
| BHANDARDRA      | 0.34         | 2.55          | 15       | 14       |
| ELDARY          | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.47         | 2.17          | 27       | 17       |
| GHATGHAR        | 0.20         | 1.50          | 125      | 0        |
| <b>Total</b>    | <b>3.41</b>  | <b>16.87</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 61.49        | 308.95        | 0        | 0        |
| <b>Total</b>    | <b>61.49</b> | <b>308.95</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 47.21        | 303.27        | 0        | 0        |
| JSWEL(Mus)      | 23.69        | 115.07        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| Other(Mus)      | 2.04         | 11.84         | 0        | 0        |
| <b>Total</b>    | <b>72.94</b> | <b>430.18</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 2.79         | 14.01         | 0        | 0        |
| <b>Total</b>    | <b>2.79</b>  | <b>14.01</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 6.40         | 36.39         | 327      | 235      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 1.93         | 10.02         | 117      | 50       |
| Trombay 7B      | 1.30         | 6.66          | 67       | 42       |
| Trombay 8       | 3.95         | 22.01         | 199      | 141      |
| TATA Hydro      | 7.40         | 23.24         | 462      | 129      |
| <b>Total</b>    | <b>20.98</b> | <b>98.32</b>  |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 10.01        | 47.71         | 495      | 373      |
| <b>Total</b>    | <b>10.01</b> | <b>47.71</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 72.98       | 329.89        | MSPGCL Total        | 90.02       | 406.89        |
|                |             |         | MSPGCL Thml+Gas | 82.30       | 367.82        | Koyna 1,2 & 4 Total | 1.64        | 10.69         |
|                |             |         | MSPGCL Hydro    | 7.72        | 39.07         | State Total         | 258.24      | 1306.06       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 05/Aug/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |       |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 2979        | 253  | 392  | 3624  | 2616  | 2944      | 0    | 0     | 2866        | 2708        | -879                 | 11013                 | 0                    | 11013                     | 1856             | 12869           | 50.05         |
| 2                  | 2957        | 243  | 391  | 3591  | 2561  | 2841      | 0    | 0     | 2627        | 2857        | -747                 | 11103                 | 0                    | 11103                     | 1740             | 12843           | 50.03         |
| 3                  | 3003        | 248  | 388  | 3639  | 2561  | 2813      | 0    | 0     | 2707        | 2702        | -676                 | 11039                 | 0                    | 11039                     | 1667             | 12706           | 50.00         |
| 4                  | 3015        | 248  | 378  | 3641  | 2426  | 2388      | 0    | 0     | 2826        | 2894        | -612                 | 10737                 | 0                    | 10737                     | 1624             | 12361           | 50.02         |
| 5                  | 2993        | 248  | 387  | 3628  | 2442  | 2380      | 0    | 0     | 3305        | 3423        | -623                 | 11250                 | 0                    | 11250                     | 1629             | 12879           | 49.97         |
| 6                  | 2978        | 287  | 399  | 3664  | 2319  | 2376      | 0    | 0     | 4130        | 4355        | -718                 | 11996                 | 0                    | 11996                     | 1716             | 13712           | 49.94         |
| 7                  | 3164        | 323  | 377  | 3864  | 2455  | 2637      | 0    | 20    | 4627        | 4922        | -839                 | 13059                 | 0                    | 13059                     | 1829             | 14888           | 49.94         |
| 8                  | 3123        | 393  | 390  | 3906  | 2457  | 2887      | 0    | 93    | 4920        | 5095        | -1013                | 13425                 | 0                    | 13425                     | 2071             | 15496           | 50.03         |
| 9                  | 3153        | 437  | 380  | 3970  | 2598  | 2945      | 0    | 224   | 4880        | 5112        | -1097                | 13752                 | 0                    | 13752                     | 2426             | 16178           | 50.04         |
| 10                 | 3122        | 448  | 398  | 3968  | 2539  | 3026      | 0    | 307   | 4780        | 5091        | -1246                | 13685                 | 0                    | 13685                     | 2711             | 16396           | 49.99         |
| 11                 | 3046        | 398  | 389  | 3833  | 2684  | 3160      | 0    | 373   | 4906        | 4878        | -1412                | 13516                 | 0                    | 13516                     | 2908             | 16424           | 50.02         |
| 12                 | 3064        | 344  | 377  | 3785  | 2718  | 3222      | 0    | 422   | 4797        | 4667        | -1492                | 13322                 | 0                    | 13322                     | 2987             | 16309           | 50.04         |
| 13                 | 3076        | 265  | 397  | 3738  | 2770  | 2961      | 0    | 329   | 4569        | 4601        | -1521                | 12878                 | 0                    | 12878                     | 2938             | 15816           | 50.04         |
| 14                 | 3083        | 218  | 378  | 3679  | 2752  | 3004      | 0    | 270   | 4271        | 4062        | -1317                | 12450                 | 0                    | 12450                     | 2815             | 15265           | 50.03         |
| 15                 | 3125        | 263  | 386  | 3774  | 2762  | 2973      | 0    | 268   | 4312        | 4132        | -1236                | 12673                 | 0                    | 12673                     | 2805             | 15478           | 49.96         |
| 16                 | 3084        | 290  | 391  | 3765  | 2742  | 3021      | 0    | 263   | 4389        | 4033        | -1194                | 12630                 | 0                    | 12630                     | 2791             | 15421           | 50.02         |
| 17                 | 3032        | 284  | 390  | 3706  | 2805  | 3061      | 0    | 154   | 4037        | 4101        | -1249                | 12578                 | 0                    | 12578                     | 2754             | 15332           | 49.98         |
| 18                 | 3001        | 406  | 390  | 3797  | 2460  | 3174      | 0    | 62    | 4278        | 4427        | -1266                | 12654                 | 0                    | 12654                     | 2725             | 15379           | 49.99         |
| 19                 | 3133        | 371  | 379  | 3883  | 2593  | 3504      | 0    | 9     | 4658        | 4356        | -1264                | 13081                 | 0                    | 13081                     | 2691             | 15772           | 50.02         |
| 20                 | 3169        | 375  | 399  | 3943  | 2499  | 3531      | 0    | 0     | 4735        | 4726        | -1243                | 13456                 | 0                    | 13456                     | 2654             | 16110           | 49.94         |
| 21                 | 2960        | 441  | 388  | 3789  | 2587  | 3548      | 0    | 0     | 4682        | 4511        | -1156                | 13279                 | 0                    | 13279                     | 2561             | 15840           | 49.95         |
| 22                 | 3029        | 287  | 382  | 3698  | 2209  | 3622      | 0    | 0     | 4493        | 4265        | -1060                | 12734                 | 0                    | 12734                     | 2436             | 15170           | 50.04         |
| 23                 | 2916        | 326  | 392  | 3634  | 2437  | 3638      | 0    | 0     | 3985        | 3792        | -1028                | 12473                 | 0                    | 12473                     | 2317             | 14790           | 50.03         |
| 24                 | 2779        | 326  | 399  | 3504  | 2496  | 3285      | 0    | 0     | 3620        | 3519        | -967                 | 11837                 | 0                    | 11837                     | 2195             | 14032           | 50.04         |
| MUs                | 72.98       | 7.72 | 9.32 | 90.02 | 61.49 | 72.94     | 0.00 | 2.79  | 99.40       | 99.23       | -25.85               | 300.62                | 0.00                 | 300.62                    | 56.85            | 357.47          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/Aug/2019**

**Position as on 6.30 Hrs of 06/Aug/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|--------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                            |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |           | Continued. | Annual Overhaul                                                                            |               |
| MSPGCL                | Parli Unit 8            | 250      | 04/06/2019   | 00.00        |           | Continued. | Zero Schedule (converted to AOH from 25/06/2019)                                           |               |
| MSPGCL                | Koyna Unit 12           | 80       | 16/07/2019   | 09.00        |           | Continued. | Annual Overhaul                                                                            |               |
| MSPGCL                | Khaparkhedda Unit 4     | 210      | 17/07/2019   | 21.44        |           | Continued. | Annual Overhaul                                                                            |               |
| MSPGCL                | Koyna STG- IV Unit - 1  | 250      | 18/07/2019   | 14.30        |           | Continued. | Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019 for 60Days) |               |
| MSPGCL                | Koradi Unit 9           | 660      | 19/07/2019   | 17.35        |           | Continued. | Annual Overhaul                                                                            |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 27/07/2019   | 00.00        |           | Continued. | Annual Overhaul                                                                            |               |
| IPP                   | Adani U-2               | 660      | 05/08/2019   | 00.13        |           | Continued. | Annual Overhaul                                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |           | Continued. | Economic shutdown                                                                          |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                    |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                          |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |           | Continued. | Compressor & Turbine Blade Failure.                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | Coal Shortage                                                                              |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |           | Continued. | No Schedule.                                                                               |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |           | Continued. | Zero Schedule.(water shortage from 25/06/2019)                                             |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                              |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                              |               |
| MSPGCL                | Parli Unit 7            | 250      | 25/06/2019   | 09.45        |           | Continued. | Water Shortage                                                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 28/06/2019   | 18.35        |           | Continued. | Zero schedule.                                                                             |               |
| IPP                   | Dhariwal                | 300      | 01/07/2019   | 00.01        |           | Continued. | NO SCHEDULE                                                                                |               |
| IPP                   | RPL(AMT) U-2            | 270      | 25/07/2019   | 02.00        |           | Continued. | Zero Schedule                                                                              |               |
| IPP                   | RPL(AMT) U-1            | 270      | 25/07/2019   | 08.00        |           | Continued. | Zero schedule.                                                                             |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/07/2019   | 18.00        |           | Continued. | Zero Schedule                                                                              |               |
| MSPGCL                | Koradi Unit-8           | 660      | 26/07/2019   | 00.15        |           | Continued. | Air heater problem                                                                         |               |
| IPP                   | RPL(AMT) U-4            | 270      | 26/07/2019   | 01.09        |           | Continued. | Zero Schedule By MSEDCL.                                                                   |               |
| IPP                   | RPL(AMT) U-5            | 270      | 26/07/2019   | 20.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 27/07/2019   | 15.32        |           | Continued. | Zero Schedule.                                                                             |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/07/2019   | 15:47        |           | Continued. | Zero Schedule.                                                                             |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/Aug/2019**

**Position as on 6.30 Hrs of 06/Aug/2019**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                     | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------|---------------|
| MSPGCL             | Koradi Unit 10          | 660      | 30/07/2019   | 23.37        |            | Continued. | ZERO SCHEDULE.                                       |               |
| MSPGCL             | Nasik Unit 4            | 210      | 01/08/2019   | 05.30        |            | Continued. | Wet Coal(Converted into Zero Schedule from 16.00Hrs) |               |
| MSPGCL             | Nasik Unit 5            | 210      | 01/08/2019   | 22.45        |            | Continued. | Wet,Sticky & Poor Quality coal                       |               |
| IPP                | Adani U-3               | 660      | 05/08/2019   | 03.01        | 05/08/2019 | 09.15      | Turbine protection shift protection act.             |               |
| MSPGCL             | Nasik Unit 3            | 210      | 05/08/2019   | 09.15        |            | Continued. | Due to PA fan tripping on DC voltage failure.        |               |
| MSPGCL             | Chandrapur Unit-8       | 500      | 05/08/2019   | 19.49        | 06/08/2019 | 00.11      | On IPT bearing temp high (Turbine problem) fault.    |               |
| MSPGCL             | Koyna Unit 10           | 80       | 05/08/2019   | 20.05        |            | Continued. | Stator Earth Fault                                   |               |
| MSPGCL             | Paras Unit 3            | 250      | 06/08/2019   | 03.55        |            | Continued. | Furnace Pressure High                                |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/Aug/2019**

**Statement-VII**

Position as on 6.30 Hrs of 06/Aug/2019

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                               |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                |
| Karad Solapur (PG)                         | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                       |
| Dhule Sar'Sarovar II                       | InterState                | 26/07/2019   | 19.03        |            | Continued. | HT          | Over Voltage                                                                   |
| Padgha Tarapur I                           | InterState                | 05/08/2019   | 03.46        | 05/08/2019 | 09.09      | T           | Over Voltage                                                                   |
| Padghe - Kalwa- I                          | IntraState                | 13/07/2019   | 10.48        | 05/08/2019 | 08.28      | PO          | MMRDA Work Tower Height Raising Work At Location 1142/1142.                    |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 22/07/2019   | 18.20        |            | Continued. | T           | Over Voltage                                                                   |
| Dhule- Bableshwar - I                      | IntraState                | 25/07/2019   | 21.47        | 05/08/2019 | 11.46      | HT          | Over Voltage                                                                   |
| Chandrapur-II - Nanded ckt II              | IntraState                | 30/07/2019   | 23.38        |            | Continued. | T           | Over Voltage                                                                   |
| Karad - Jaigad - II                        | IntraState                | 31/07/2019   | 21.46        |            | Continued. | HT          | Over Voltage                                                                   |
| Akola-Nandgaonpeth (RPL)                   | IntraState                | 01/08/2019   | 02.48        | 05/08/2019 | 08.18      | T           | Over Voltage                                                                   |
| Lonikand I - Koyna stage-IV                | IntraState                | 04/08/2019   | 00.53        | 05/08/2019 | 08.51      | HT          | Over Voltage                                                                   |
| Bus Coupler @ Karad                        | IntraState                | 04/08/2019   | 20.19        | 05/08/2019 | 14.16      | T           | Tripped ONM PDR.                                                               |
| Padghe - Kalwa-II                          | IntraState                | 05/08/2019   | 12.58        | 05/08/2019 | 16.50      | EO          | Attending Hot Spot At Padgha End.                                              |
| Dhule - Bableshwar - II                    | IntraState                | 05/08/2019   | 13.13        |            | Continued. | HT          | Over Voltage                                                                   |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe        | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                      |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2 | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 are Damaged.                         |
| 400/220kv 500MVA ICT-1 @ TAPTITANDA        | IntraState                | 04/08/2019   | 20.40        | 05/08/2019 | 00.23      | T           | 220kv Bus Bar-1 Protection.                                                    |
| 400/220 Kv 600 MVA ICT-II @Kalwa           | IntraState                | 05/08/2019   | 17.11        | 05/08/2019 | 18.25      | EO          | Oil Top Work.                                                                  |
| <b>220 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                |
| Talandage - Chikodi                        | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                    |
| Mudshingi - Chikodi                        | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                   |
| Mahalakshmi Amona                          | InterState                | 05/08/2019   | 07.41        | 05/08/2019 | 09.14      | T           | On CB PDR Operated,E/F,Distn OPTD-1.25KM From MAHALAKSHMI.                     |
| Tillari Amona                              | InterState                | 05/08/2019   | 07.41        |            | Continued. | PO          | Under Break Down.                                                              |
| PARLY (PG) - OLD GCR PARLI                 | InterState                | 05/08/2019   | 14.01        | 05/08/2019 | 15.21      | EO          | To attend Sparking on Isolator                                                 |
| BOISAR BORIVALI                            | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                   |
| Taptitanda-Jalna ckt II                    | IntraState                | 04/08/2019   | 20.40        | 05/08/2019 | 03.30      | T           | Bus Bar Protection Operated                                                    |
| Nalasopara-Boisar                          | IntraState                | 05/08/2019   | 03.23        | 05/08/2019 | 05.03      | T           | Distance Protection                                                            |
| Nalasopara-Boisar                          | IntraState                | 05/08/2019   | 05.03        | 05/08/2019 | 16.36      | T           | Distance Protection, work permit for attending fault (Decapping) at LOC no.20. |
| 220kv Halkarni- Tillary                    | IntraState                | 05/08/2019   | 07.41        | 05/08/2019 | 08.25      | T           | Distance Protection                                                            |
| 220kv Halkarni- Tillary                    | IntraState                | 05/08/2019   | 08.25        | 05/08/2019 | 08.56      | T           | Distance Protection                                                            |
| Kalwa1 - Taloja                            | IntraState                | 05/08/2019   | 10.06        | 05/08/2019 | 14.46      | T           | Tripped at Taloja end only on B PH Earth Fault                                 |
| Uran - Apta III                            | IntraState                | 05/08/2019   | 10.35        | 05/08/2019 | 14.58      | PO          | Bypassing Wave Trap Due To Heavy Noise At Apta End.                            |
| Paras-Chikhali Ckt No-Ii                   | IntraState                | 05/08/2019   | 11.52        | 05/08/2019 | 16.22      | PO          | DC Separation Work.                                                            |
| Kalwa 52B Interconnector CB                | IntraState                | 05/08/2019   | 14.51        | 05/08/2019 | 10.40      | HT          | For Load Management.(Taken In 10.40)(Taken Out 14.51).                         |
| Uran - Hoc 1                               | IntraState                | 05/08/2019   | 15.24        | 05/08/2019 | 18.43      | PO          | Routine Maintenance Work                                                       |
| Virur - Gadchiroli                         | IntraState                | 05/08/2019   | 21.43        | 05/08/2019 | 22.10      | T           | V-Distance Protection,Z1,R-PH.49.6KM.2.27KA.                                   |
| <b>220 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/Aug/2019**

**Statement-VII**

Position as on 6.30 Hrs of 06/Aug/2019

| Name of Line                            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                            |
|-----------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-------------------------------------------------------------|
| 220/100 Kv 100 MVA ICT II @Vasai-<br>li | IntraState                   | 04/08/2019      | 06.55           | 05/08/2019 | 11.07         | HT             | For Safety Due To Water<br>Accumulation In 100Kv S/S Vasai. |