

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Sep/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	113.882	583.165	1) Gujrat	13.173	69.299
2) Hydro	16.541	81.851	2) Madhya Pradesh	10.706	42.506
3) Gas	6.412	31.805	3) Chattisgarh	4.480	24.380
Total MSPGCL	136.835	696.821	4) Maharashtra	149.866	707.699
B) 1) APML	45.460	155.784	5) Goa (Amona)	-0.926	-5.411
2) JSWEL	19.424	92.495	Total	177.299	838.473
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.035	115.600
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	26.784	121.708
5) WPCL	2.707	13.449	c) MSEDCL Bilateral *	37.745	186.429
6) Other IPP	8.337	43.284	Include PX	14.205	65.858
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.035	115.600
C) 1) TPCL Thermal	9.761	48.220	Include PX	17.132	71.942
2) TPCL Hydro	4.754	27.759	Standby	0.000	0.000
3) TPCL Gas	4.407	18.601	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.837	28.583	1) MSEDCL	373.595	1789.804
D) STATE			2) Mumbai Discoms	51.543	244.871
1) Thermal	205.408	964.980	TOTAL STATE	425.138	2034.675
(A1+C1+C4+(B1-B6))					
2) Hydro	21.295	109.610			
(A2+C2)					
3) Gas	10.819	50.406			
(A3+B7+C3)					
4) Wind	4.177	40.001			
6) SOLAR	6.140	31.205			
TOTAL STATE	247.839	1196.202			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4733	4710	4722	4825
MSPGCL Hydro	700	719	1931	191
MSPGCL Gas	253	253	255	289
MSPGCL Total Generation	5686	5682	6908	5305
Central Sector Receipt	8360	8537	6709	6326
WIND	233	215	166	101
CPP / IPP Thermal	3053	3017	3223	3053
CPP / IPP Gas	0	0	0	0
SOLAR	853	872	0	0
Exchange with Mumbai	-1485	-1455	-1049	-958
MSEDCL DEMAND MET	16700	16868	15957	13827
Load Shedding	0	0	0	0
MSEDCL DEMAND	16700	16868	15957	13827
TPCL GENERATION	746	751	1041	500
AEML GENERATION	252	252	253	195
MUMBAI DEMAND	2483	2458	2343	1653
STATE DEMAND MET	19183	19326	18300	15480
STATE DEMAND	19183	19326	18300	15480
Frequency (Hz)	49.99	50.00	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 17.06 Hrs	49.84 Hz at 22.12 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 05/Sep/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.12	55.34	542	430
Unit 9	11.66	53.32	505	426
Unit 10	9.78	43.37	417	400
Total	33.56	152.02		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	41.92	0	0
Unit 5	11.04	53.33	500	435
Total	11.04	95.25		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.62	19.19	244	227
Total	5.62	19.19		
Chandrapur				
Unit 3	4.09	20.58	174	157
Unit 4	0.00	0.00	0	0
Unit 5	9.82	48.37	410	405
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.08	54.63	480	445
Unit 9	11.28	45.46	480	460
Total	36.27	169.04		
Paras				
Unit 3	3.83	21.05	200	125
Unit 4	1.34	16.43	130	0
Total	5.17	37.48		
Khaparkheda				
Unit 1	2.76	13.28	150	95
Unit 2	3.25	15.22	150	120
Unit 3	3.40	17.44	155	130
Unit 4	3.32	16.75	150	130
Unit 5	9.48	47.49	445	335
Total	22.22	110.18		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.41	31.80	289	253
Total	6.41	31.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.25	6.06	53	51

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.25	6.06		
Koyna				
Stage 1-2	4.52	23.62	535	40
Stage 4	7.26	34.22	948	0
Stage 3	2.37	12.98	288	0
Total	14.15	70.82		
Hydro				
KDPH	0.00	0.50	0	0
VTRNA	0.25	0.25	62	0
TILLARI	0.29	1.00	58	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.37	1.97	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.34	1.72	15	14
ELDARY	0.42	2.41	18	16
SMLHY_PTN	0.27	2.46	15	6
GHATGHAR	0.45	0.73	125	0
Total	2.39	11.04		
Wind				
Total	4.18	40.00	0	0
Total	4.18	40.00		
CPP				
APML(Mus)	45.46	155.78	0	0
JSWEL(Mus)	19.42	92.50	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.71	13.45	0	0
Other(Mus)	8.34	43.28	0	0
Total	75.93	305.01		
SOLAR				
Total	6.14	31.20	0	0
Total	6.14	31.20		
Tata				
Trombay 5	9.76	48.22	446	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	11.48	117	116
Trombay 7B	1.60	7.12	68	66
Trombay 8	0.00	0.00	0	0
TATA Hydro	4.75	27.76	459	3
Total	18.92	94.58		
AEML				
DTPS U-1&2	5.84	28.58	253	193
Total	5.84	28.58		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	113.88	583.16	MSPGCL Total	136.84	696.82
			MSPGCL Thml+Gas	120.29	614.97	Koyna 1,2 & 4 Total	11.78	57.83
			MSPGCL Hydro	16.54	81.85	State Total	247.84	1196.20

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 05/Sep/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4842	330	268	5440	176	3234	0	0	6301	6097	-920	14027	0	14027	2058	16085	49.98
2	4822	141	277	5240	188	3180	0	0	6390	6368	-881	14095	0	14095	1916	16011	49.99
3	4818	141	281	5240	189	3214	0	0	6476	6132	-896	13879	0	13879	1808	15687	50.03
4	4832	141	280	5253	154	3164	0	0	6516	6379	-930	14020	0	14020	1694	15714	50.00
5	4825	191	289	5305	101	3053	0	0	6637	6326	-958	13827	0	13827	1653	15480	49.99
6	4643	654	280	5577	140	3118	0	0	6890	7155	-836	15154	0	15154	1693	16847	50.01
7	4725	397	280	5402	153	3171	0	23	7990	8023	-735	16037	0	16037	1712	17749	49.97
8	4736	109	269	5114	238	3150	0	194	8641	8532	-819	16409	0	16409	1774	18183	50.01
9	4760	329	278	5367	207	3017	0	522	8484	8423	-1055	16481	0	16481	1951	18432	49.98
10	4758	380	277	5415	204	3190	0	747	8247	8124	-1195	16485	0	16485	2183	18668	50.01
11	4720	380	266	5366	231	3198	0	897	8373	8289	-1384	16597	0	16597	2377	18974	50.00
12	4733	700	253	5686	233	3053	0	853	8295	8360	-1485	16700	0	16700	2483	19183	49.99
13	4710	719	253	5682	215	3017	0	872	8565	8537	-1455	16868	0	16868	2458	19326	50.00
14	4705	468	253	5426	178	3093	0	729	8356	8348	-1402	16372	0	16372	2404	18776	50.08
15	4636	544	253	5433	115	3190	0	586	8283	8259	-1425	16158	0	16158	2429	18587	50.00
16	4594	1203	263	6060	168	3206	0	353	8170	8101	-1417	16471	0	16471	2419	18890	49.98
17	4658	1268	253	6179	100	3188	0	253	7697	7691	-1212	16199	0	16199	2384	18583	50.01
18	4666	1163	254	6083	106	3115	0	106	7929	7911	-1327	15994	0	15994	2306	18300	50.06
19	4700	1570	265	6535	162	3226	0	5	7128	6981	-1098	15811	0	15811	2264	18075	50.01
20	4722	1931	255	6908	166	3223	0	0	6839	6709	-1049	15957	0	15957	2343	18300	50.01
21	4779	1355	266	6400	139	3231	0	0	6431	6446	-1014	15202	0	15202	2302	17504	50.02
22	4789	1169	266	6224	120	3226	0	0	6507	6643	-1010	15203	0	15203	2298	17501	50.01
23	4841	882	267	5990	229	3242	0	0	6760	6818	-1110	15169	0	15169	2313	17482	49.98
24	4868	376	266	5510	265	3229	0	0	6991	6647	-1171	14480	0	14480	2321	16801	50.02
MUs	113.88	16.54	6.41	136.84	4.18	75.93	0.00	6.14	178.90	177.30	-26.78	373.60	0.00	373.60	51.54	425.14	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Sep/2020

Position as on 6.30 Hrs of 06/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U4	300	20/08/2020	15.57		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
IPP	Adani U-5	660	04/06/2020	12.29		Continued.	Zero Schedule.	
AEML	AEML Unit 1	250	27/06/2020	23.55		Continued.	Zero schedule.	
MSPGCL	Chandrapur Unit 7	500	06/08/2020	03.33		Continued.	Sparkling in generator R phase winding.	
CPP	SWPGL U-3	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
CPP	SWPGL U-4	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Sep/2020

Position as on 6.30 Hrs of 06/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Ghatghar Unit-1	125	27/08/2020	05.25		Continued.	Runner band Drainage valve Leakage	
MSPGCL	Chandrapur Unit 6	500	27/08/2020	10.55		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 4	210	27/08/2020	18.00		Continued.	Boiler Tube Leakage	
IPP	Adani U-2	660	01/09/2020	19.41		Continued.	Air pre-heater PA Bellow leakage.	
MSPGCL	Bhusawal Unit 4	500	04/09/2020	21.41	06/09/2020	19.39	Boiler validity work	
MSPGCL	Paras Unit 4	250	05/09/2020	05.00	05/09/2020	16.22	Auxiliary supply failure	
MSPGCL	Khaparkheda Unit 2	210	06/09/2020	21.57		Continued.	Air Filter Problem.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 05/Sep/2020

Statement-VII

Position as on 6.30 Hrs of 06/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	06/09/2020	06.59	06/09/2020	13.12	PO	String Replacement.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Padgha Tarapur II	InterState	05/09/2020	15.22	05/09/2020	19.31	T	Distance Protection
Dhule Sar'Sarovar I	InterState	06/09/2020	20.08		Continued.	HT	Over Voltage
BABHALESHWAR - RPL(NASHIK) CKT - 1	IntraState	11/06/2020	10.40		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/08/2020	23.23		Continued.	HT	Over Voltage
N.Koyna-Karad -Ckt I	IntraState	04/09/2020	09.44	05/09/2020	09.46	PO	Replacement of polymer Insulators at Various cut point
Khadka-Aurangabad (Waluj)	IntraState	04/09/2020	18.15		Continued.	HT	Over Voltage
Dhule - Bableshwar - II	IntraState	04/09/2020	21.33	05/09/2020	10.24	HT	Over Voltage
Padghe - Kalwa- I	IntraState	04/09/2020	22.56	05/09/2020	09.53	HT	Over Voltage
Babhaleshwar - Bhusawal II	IntraState	05/09/2020	02.49	05/09/2020	09.19	T	Distance Protection
Dhule - Bableshwar - II	IntraState	05/09/2020	21.09		Continued.	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	06/09/2020	17.21		Continued.	T	Distance Protection
Akola II - RPL(Rattaniandia) Ckt I	IntraState	06/09/2020	20.57		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	06/09/2020	21.01		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement Of Existing 315 MVA ICT By 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	05/09/2020	01.10	05/09/2020	05.38	T	Buccholz Protection Optd
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	05/09/2020	09.05	05/09/2020	20.22	PO	For overhauling of NIPFS System of ICT.
400/132 KV 200MVA ICT II @Bhusawal	IntraState	05/09/2020	09.05	05/09/2020	20.22	PO	Overhauling of nipfs system and testing work etc.
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	05/09/2020	09.12	05/09/2020	17.55	PO	Quarterly Maintenance work & Relay Testing and other diagnostic testing.
400/220 Kv 500 MVA ICT II @Lamboti	IntraState	05/09/2020	13.41	05/09/2020	14.15	T	LBB Operated.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Kharghar-Borivali ckt II	IntraState	11/08/2020	08.45		Continued.	T	Cable Faulty
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage arrangement HTLS work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage arrangement HTLS work.
Lonikand1 (400 Kv)-Theur I	IntraState	14/08/2020	10.38		Continued.	PO	Replacement of Existing 0.4 DEER Conductor, hardware & Insulator to HTLS Conductor.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower due to Railway crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower due to Railway crossing
Sawantwadi-Bidri	IntraState	04/09/2020	09.48	06/09/2020	10.30	T	Distance protection(Bus B operated due to Fault on Talangade-Sawantwadi line)

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Sep/2020

Statement-VII

Position as on 6.30 Hrs of 06/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Talandage(kolh'r)- Sawantwadi II	IntraState	04/09/2020	09.48	05/09/2020	15.08	T	Distance protection Bus B operated due to Fault on Talangade-Sawantwadi line
Colourchem - Temghar	IntraState	05/09/2020	09.22	05/09/2020	16.11	EO	For attending R ph hotspot on the jumper near gantry string and stub bus entry.
Sawantwadi-Bidri	IntraState	05/09/2020	09.25	05/09/2020	15.08	T	Finding fault.
Kalwa - Mulund 1	IntraState	05/09/2020	09.36	05/09/2020	20.46	PO	R ph, Y Ph & B ph CT Replacement work.
Bableshtar- Bableshtar-II	IntraState	05/09/2020	10.25	05/09/2020	12.45	PO	Attending red hot on CT CB.
Kolshet-Roma	IntraState	05/09/2020	10.36	05/09/2020	14.27	PO	Insulator replacement to be done on 100kV Kolshet Vasai line .Outage on this line required for safety purpose only being multicircuit tower.
Chalisingaon - Deepnagar	IntraState	05/09/2020	11.11	05/09/2020	12.55	PO	Tree cutting work between loc. no.216 to 217.
EKLAHRE (GCR)Nashik-Airoli Knowledge Park	IntraState	05/09/2020	11.31	05/09/2020	15.54	T	Distance Protection
Halkarni-Hemrus line	IntraState	05/09/2020	12.48	05/09/2020	13.55	HT	C.B. and relay testing works.
BHALVANI VARKUTI MALWADI	IntraState	05/09/2020	13.26	05/09/2020	14.04	T	Tripped on overcurrent.
Lamboti(solapur)-Karkamb	IntraState	05/09/2020	13.41	05/09/2020	15.47	T	Distance Protection
Tembhurni - Jeur	IntraState	05/09/2020	13.48	05/09/2020	14.12	T	Tripped on overcurrent.
Lonikand2 - Bhosari1	IntraState	05/09/2020	15.12	05/09/2020	18.25	PO	Restraining work betn loc no 22 to 36 for increasing ground clearance & double jumpering work.
EKLAHRE (GCR)Nashik-Airoli Knowledge Park	IntraState	06/09/2020	10.56	06/09/2020	21.16	T	Distance Protection
Yeotmal- Pusad	IntraState	06/09/2020	13.15	06/09/2020	19.25	T	Distance Protection
Roma-Bhavegar	IntraState	06/09/2020	13.20	06/09/2020	14.47	T	Distance Protection
Padghe - Kambha	IntraState	06/09/2020	13.21	06/09/2020	15.51	T	Distance Protection
Pargaon(Kathapur)-Lonikand	IntraState	06/09/2020	14.52	06/09/2020	16.14	EO	Tree Cutting.
New Koyana - Niwali	IntraState	06/09/2020	18.52	06/09/2020	21.07	T	Distance Protection
Niwali - Pawas Line	IntraState	06/09/2020	18.53	06/09/2020	20.15	T	Distance Protection
Kharepatan -Pawas Line	IntraState	06/09/2020	18.55	06/09/2020	19.50	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132 Kv 100 Mva Ict 1 @Yavatmal	IntraState	06/09/2020	13.15	06/09/2020	14.25	T	Without Indication only Annunciation.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage