

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Oct/2021 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	105.842	539.306	1) Gujrat	-6.447	-34.297
2) Hydro	39.125	159.160	2) Madhya Pradesh	10.869	51.908
3) Gas	4.212	24.924	3) Chattisgarh	5.940	26.680
Total MSPGCL	149.179	723.390	4) Maharashtra	142.308	717.702
B) 1) APML	52.483	247.607	5) Goa (Amona)	-1.375	-5.704
2) JSWEL	20.477	93.683	Total	151.295	756.289
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.992	108.166
4) RPL(AMT)	14.240	76.082	b) Mumbai Drawl	26.413	124.272
5) SWPGPL	3.795	17.666	c) MSEDCL Bilateral *	41.658	201.357
6) Other IPP	5.408	24.612	Include PX	12.370	61.911
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.992	108.166
C) 1) TPCL Thermal	16.781	82.090	Include PX	1.154	14.558
2) TPCL Hydro	6.659	23.933	Standby	0.000	0.000
3) TPCL Gas	2.395	11.019	H) ENERGY CATERED (MUs)		
4) AEML Thermal	12.039	55.319	1) MSEDCL	384.925	1875.343
D) STATE			2) Mumbai Discoms	64.287	296.633
1) Thermal	231.065	1136.365	TOTAL STATE	449.212	2171.976
(A1+C1+C4+(B1-B6))					
2) Hydro	45.784	183.093			
(A2+C2)					
3) Gas	6.607	35.943			
(A3+B7+C3)					
4) Wind	6.586	24.999			
6) SOLAR	7.875	35.287			
TOTAL STATE	297.917	1415.687			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4354	4607	4829	4166
MSPGCL Hydro	1344	2306	2222	1129
MSPGCL Gas	155	205	241	139
MSPGCL Total Generation	5853	7118	7292	5434
Central Sector Receipt	7452	6336	6818	5120
WIND	120	144	515	237
CPP / IPP Thermal	3787	4218	4405	4022
CPP / IPP Gas	0	0	0	0
SOLAR	1022	83	0	0
Exchange with Mumbai	-1488	-1262	-1116	-631
MSEDCL DEMAND MET	16746	16637	17914	14182
Load Shedding	0	0	0	0
MSEDCL DEMAND	16746	16637	17914	14182
TPCL GENERATION	1119	1290	1295	866
AEML GENERATION	503	501	500	502
MUMBAI DEMAND	3110	3053	2911	1999
STATE DEMAND MET	19856	19690	20825	16181
STATE DEMAND	19856	19690	20825	16181
Frequency (Hz)	49.99	49.92	49.98	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.1 Hz at 09.00 Hrs	49.67 Hz at 22.09 Hrs	49.94	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 05/Oct/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.26	16.76	210	135
Unit 7	0.00	0.00	0	0
Unit 8	12.60	63.24	572	485
Unit 9	12.40	55.78	541	500
Unit 10	0.00	0.00	0	0
Total	29.25	135.79		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	6.98	36.85	350	280
Unit 5	6.98	37.60	360	275
Total	13.96	74.46		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	4.32	22.05	248	166
Unit 8	4.29	20.98	201	169
Total	8.61	43.03		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	6.10	28.65	305	228
Unit 6	4.09	22.94	210	130
Unit 7	6.95	33.14	299	273
Unit 8	8.31	38.00	400	284
Unit 9	7.99	40.39	401	270
Total	33.45	163.12		
Paras				
Unit 3	4.74	21.51	207	182
Unit 4	0.00	0.00	0	0
Total	4.74	21.51		
Khaparkheda				
Unit 1	2.68	12.55	130	90
Unit 2	3.39	14.78	150	130
Unit 3	3.30	15.39	150	128
Unit 4	3.39	17.01	165	123
Unit 5	0.00	25.18	0	0
Total	12.75	84.91		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.09	16.49	138	119
Unit 5	0.00	0.00	0	0
Total	3.09	16.49		
Uran				
All Units	4.21	24.92	242	136
Total	4.21	24.92		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.72	2.23	44	0
Total	0.72	2.23		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	9.55	34.14	590	45
Stage 4	16.55	65.44	1025	28
Stage 3	5.34	21.17	320	0
Total	31.44	120.75		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	1.46	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.41	1.84	40	0
SMLHY_PTN	5.91	30.96	260	238
GHATGHAR	1.36	4.15	250	0
Total	7.68	38.41		
Wind				
Total	6.59	25.00	0	0
Total	6.59	25.00		
CPP				
APML(Mus)	52.48	247.61	0	0
JSWEL(Mus)	20.48	93.68	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	14.24	76.08	0	0
SWPGPL-Mus	3.80	17.67	0	0
Other(Mus)	5.41	24.61	0	0
Total	96.40	459.65		
SOLAR				
Total	7.88	35.29	0	0
Total	7.88	35.29		
Tata				
Trombay 5	11.52	56.07	483	453
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.35	6.04	99	48
Trombay 7B	1.05	4.98	61	40
Trombay 8	5.26	26.02	221	217
TATA Hydro	6.66	23.93	434	60
Total	25.84	117.04		
AEML				
DTPS U-1&2	12.04	55.32	503	500
Total	12.04	55.32		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	105.84	539.31	MSPGCL Total	149.18	723.39
			MSPGCL Thml+Gas	110.05	564.23	Koyna 1,2 & 4 Total	26.10	99.58
			MSPGCL Hydro	39.12	159.16	State Total	297.92	1415.69

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 05/Oct/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4200	1610	139	5949	584	4011	0	0	5536	5265	-930	14879	0	14879	2419	17298	49.99
2	4187	1202	139	5528	450	4005	0	0	5416	5265	-776	14472	0	14472	2238	16710	50.00
3	4216	1166	150	5532	238	4023	0	0	5390	5284	-699	14378	0	14378	2095	16473	50.00
4	4166	1129	139	5434	237	4022	0	0	5340	5120	-631	14182	0	14182	1999	16181	49.99
5	4172	1188	139	5499	228	4047	0	0	5592	5344	-610	14508	0	14508	1969	16477	49.90
6	4267	1425	138	5830	202	4053	0	0	5953	5872	-667	15290	0	15290	2020	17310	49.81
7	4338	2005	138	6481	145	4016	0	40	6221	6048	-698	16032	0	16032	2084	18116	49.85
8	4437	2331	149	6917	112	3975	0	245	6495	6530	-816	16963	0	16963	2249	19212	49.98
9	4241	1916	138	6295	103	3948	0	611	6921	6954	-1043	16868	0	16868	2559	19427	50.00
10	4213	1780	136	6129	116	3893	0	827	7164	7003	-1273	16695	0	16695	2877	19572	50.03
11	4354	1344	155	5853	120	3787	0	1022	7465	7452	-1488	16746	0	16746	3110	19856	49.99
12	4443	996	224	5663	91	3754	0	1156	7669	7482	-1589	16557	0	16557	3194	19751	49.93
13	4380	686	193	5259	115	3742	0	1100	7715	7478	-1597	16097	0	16097	3184	19281	49.96
14	4443	434	202	5079	88	3751	0	1017	7559	7347	-1547	15735	0	15735	3098	18833	49.99
15	4419	1136	191	5746	93	3818	0	819	7357	7309	-1526	16259	0	16259	3174	19433	49.86
16	4408	1666	203	6277	111	3908	0	629	7067	6850	-1479	16296	0	16296	3204	19500	49.90
17	4461	1998	193	6652	128	3935	0	325	6586	6714	-1371	16383	0	16383	3145	19528	49.88
18	4607	2306	205	7118	144	4218	0	83	6519	6336	-1262	16637	0	16637	3053	19690	49.92
19	4854	2181	227	7262	178	4361	0	1	7021	6887	-1188	17501	0	17501	2983	20484	49.87
20	4829	2222	241	7292	515	4405	0	0	6883	6818	-1116	17914	0	17914	2911	20825	49.98
21	4684	2059	242	6985	395	4451	0	0	6016	5971	-1041	16761	0	16761	2787	19548	50.00
22	4553	2109	230	6892	559	4175	0	0	5589	5563	-1011	16178	0	16178	2685	18863	49.92
23	4485	2164	151	6800	683	4138	0	0	5244	5399	-1027	15993	0	15993	2629	18622	49.87
24	4485	2072	150	6707	951	3967	0	0	5222	5004	-1028	15601	0	15601	2621	18222	49.91
MUs	105.84	39.13	4.21	149.18	6.59	96.40	0.00	7.87	153.94	151.29	-26.41	384.92	0.00	384.92	64.29	449.21	49.94

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Oct/2021

Position as on 6.30 Hrs of 06/Oct/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 3	210	04/09/2021	23.58		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	SWPGPL U-4	135	05/08/2021	03.04		Continued.	Turbine Vibration High.	
MSPGCL	Parli Unit 6	250	26/08/2021	21.06		Continued.	Coal Shortage (Converted to AOH 00.00Hrs from Dt.01/09/2021)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Chandrapur Unit 4	210	15/09/2021	23.54		Continued.	Poor coal receipt	
MSPGCL	Bhusawal Unit 3	210	18/09/2021	03.30		Continued.	Coal Shortage	
IPP	Adani U-5	660	19/09/2021	03.47		Continued.	Abnormal Sound in Turbine governing system.	
MSPGCL	Nasik Unit 5	210	19/09/2021	20.50		Continued.	Coal Shortage.	
IPP	RPL(AMT) U-5	270	23/09/2021	00.44		Continued.	Bottom Ash Prob.(conv. to coal shortage 18.00hrs,28.09.2021)	
MSPGCL	Paras Unit 4	250	26/09/2021	07.47		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 10	660	28/09/2021	22.46		Continued.	Poor coal receipt	
IPP	RPL(AMT) U-2	270	29/09/2021	01.15		Continued.	Coal Shortage	
IPP	SWPGPL U-2	135	01/10/2021	15.30	05/10/2021	13.59	ID Fan Problem	
MSPGCL	Uran Unit 5	108	02/10/2021	20.45		Continued.	Gas shortage	
MSPGCL	Khaparkhedha Unit 5	500	03/10/2021	15.02	06/10/2021	03.38	Boiler Tube Leakage	
IPP	RPL(AMT) U-3	270	04/10/2021	22.14	05/10/2021	13.14	Withdrawn on Turbine Vibrations High.	
IPP	RPL(AMT) U-1	270	05/10/2021	22.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	05/10/2021	22.18	06/10/2021	06.51	Gas shortage	
MSPGCL	Koradi Unit 6	210	06/10/2021	03.22		Continued.	sparkling at exciter of the generator	
MSPGCL	Khaparkhedha Unit 5	500	06/10/2021	11.15		Continued.	Y-ph PRV of GT operated.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Oct/2021

Position as on 6.30 Hrs of 06/Oct/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 5	500	06/10/2021	21.05		Continued.	Poor coal receipt.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 06/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT II @ Aurangabad (Ektuni)	IntraState	06/10/2021	10.45	06/10/2021	15.37	PO	Diagnostic testing & Routine maintenance work.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	05/10/2021	23.47	06/10/2021	06.07	EO	Radiator pump problem rectification
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	05/10/2021	09.34	05/10/2021	17.30	PO	Line Maintenance work
Koradi 2-IEPL	IntraState	26/09/2021	07.00		Continued.	PO	For for height raising work across.
koaradi II - Wardha(PG)	IntraState	26/09/2021	07.29		Continued.	PO	For for height raising work across Samruddhi highway at chainage No.23+650 (tower no 192 & 193)
Khadka-Aurangabad (Waluj)	IntraState	02/10/2021	20.04	05/10/2021	11.04	HT	Over Voltage
Babhaleshwar - Padghe-II	IntraState	05/10/2021	17.12	05/10/2021	22.05	T	Distance Protection
Khadka- Deepnagar Ckt 2	IntraState	06/10/2021	10.22	06/10/2021	14.34	PO	DCRM testing of own CB of 400KV deepnagar-2.
Jejuri- Koynastage-IV	IntraState	06/10/2021	21.22		Continued.	T	Distance Protection
Bhusawal-Aurangabad	IntraState	06/10/2021	22.31	06/10/2021	Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 2 @Padghe	IntraState	04/10/2021	22.01	05/10/2021	09.28	HT	Replacement of Y-Ph Bushing due to Oil Leakage.
400/220/33kv, 500 Mva Ict-2 @Khaparkheda	IntraState	05/10/2021	10.00	05/10/2021	17.30	PO	Testing Work
400/220 KV 500MVA ICT-I @ Alkud	IntraState	05/10/2021	12.05	05/10/2021	12.27	PO	Quarterly Maintenance Work
400/220/33 Kv 315 Mva ICT I @ Akola (M)	IntraState	06/10/2021	18.48	06/10/2021	19.54	T	LBB Protection malfunction at 220KV side.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
A'bad(PG)-Shendra Ckt II	InterState	05/10/2021	16.57	05/10/2021	19.50	HT	To control Overdrawal
PARLY (PG) - OLD GCR PARLI	InterState	05/10/2021	19.02	05/10/2021	20.19	HT	To control Overdrawal
BADNERA - WARDHA (PG) (Deoli)	InterState	05/10/2021	22.23	05/10/2021	23.41	HT	To control Overdrawal
A'bad(PG)-Shendra Ckt II	InterState	06/10/2021	04.41	06/10/2021	23.13	HT	To Control OD.
Solapur (Pg) South Solapur I	InterState	06/10/2021	11.22	06/10/2021	16.38	PO	Quarterly Maintenance Work
Aurangabad PG (Chitepimpalgaon)-Chitegaon Ckt-II	InterState	06/10/2021	11.46	06/10/2021	14.48	PO	Replacement of TNC switch
Aurangabad PG (Chitepimpalgaon)-Chitegaon Ckt-I	InterState	06/10/2021	21.47	06/10/2021	23.08	HT	TO Control OD.
PARLY (PG) - OSMANABAD	InterState	06/10/2021	21.55	06/10/2021	22.58	HT	To Control OD.
Chandrapur MIDC - GEPL Ckt I	IntraState	02/10/2021	18.36		Continued.	HT	Energy bill pending at GEPL end.
AKOLA ANJANGAON (VIHIGAON) CKT-II	IntraState	04/10/2021	09.35	05/10/2021	19.55	PO	Testing Work
Balapur-Akola li	IntraState	04/10/2021	09.54	05/10/2021	19.53	PO	Bus section outage at Akola
Khadka-Bhadli-1	IntraState	05/10/2021	08.32	05/10/2021	16.15	PO	MTAMC work
Pophali - Pedambe II	IntraState	05/10/2021	08.40	05/10/2021	14.25	PO	To attend cut and unwound strands of B phase Breaker
Kamba - Kolshet	IntraState	05/10/2021	09.46	05/10/2021	21.35	PO	Metro work
Chandrapur(MIDC)-Ballarshah II	IntraState	05/10/2021	10.00	05/10/2021	15.38	PO	Testing Work
Vita Alkud	IntraState	05/10/2021	10.15	05/10/2021	17.27	T	Distance Protection
VSNL - STT 1 GIS	IntraState	05/10/2021	10.18	05/10/2021	15.10	PO	Testing Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 05/Oct/2021

Statement-VII

Position as on 6.30 Hrs of 06/Oct/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Topworth - Kharghar	IntraState	05/10/2021	10.52	05/10/2021	17.21	PO	Routine Maintenance Work
Lamboti -Solapur li(Bale) Ckt- II	IntraState	05/10/2021	11.24	05/10/2021	13.24	EO	CB Compressor faulty and CB is in Lockout condition
Nanded - Parli Ext. Ckt I	IntraState	05/10/2021	11.25	05/10/2021	21.47	T	Distance Protection
sawangi-Phulambri	IntraState	05/10/2021	13.10	05/10/2021	17.52	PO	Testing Work
Uran - Apta IV	IntraState	05/10/2021	13.14	05/10/2021	17.18	T	Distance Protection
Nagothane - ACCIL	IntraState	05/10/2021	14.30	05/10/2021	15.09	T	Bus Fault at ACCIL
ACCIL - Apta	IntraState	05/10/2021	14.30	05/10/2021	17.36	T	Bus Fault at ACCIL end
VSNL - STT 2 GIS	IntraState	05/10/2021	15.46	05/10/2021	19.47	PO	Testing Work
Uran - Apta II	IntraState	05/10/2021	17.48	05/10/2021	22.04	T	Distance Protection
Uran - Kharghar I	IntraState	05/10/2021	18.54	05/10/2021	22.55	T	Distance Protection
Pusad-WardhaPG(Deoli)	IntraState	05/10/2021	22.23	05/10/2021	23.39	HT	To control Overdrawal
Lonand Sona Alloys	IntraState	06/10/2021	02.48	06/10/2021	09.08	T	Distance Protection
Kandalgaon - Sona Alloys	IntraState	06/10/2021	02.50	06/10/2021	04.12	T	Distance Protection
Karad - Vita Ckt- II	IntraState	06/10/2021	09.01	06/10/2021	17.09	PO	Conversion of SSN to DSN work.
Lamboti(solapur)-Karkamb	IntraState	06/10/2021	10.00	06/10/2021	13.47	PO	Quarterly Maintenance Work
Kandalgaon - Sona Alloys	IntraState	06/10/2021	10.02	06/10/2021	18.05	PO	Replacement of polymer insulators by long rod porcelain insulators or conductor restringing work.
Ambazari-Kalmeshwar	IntraState	06/10/2021	10.02	06/10/2021	17.12	HT	Replacement of flashover string at various location.
Uran - Ongc Uran	IntraState	06/10/2021	10.52	05/10/2021	18.55	PO	Testing Work
Balapur-Malegaon	IntraState	06/10/2021	10.53	06/10/2021	18.58	EO	Safety, Ckt 1 work.
Eklahara(Gcr)(Nasik)- Bableswhar-I	IntraState	06/10/2021	14.24	06/10/2021	14.34	T	Distance Protection
Ghatghar - Jindal	IntraState	06/10/2021	16.34	06/10/2021	17.52	T	Distance Protection
Apta - Taloja	IntraState	06/10/2021	18.04	06/10/2021	18.25	T	Distance Protection
ANANDNAGAR - PALAVA	IntraState	06/10/2021	18.28	06/10/2021	19.44	T	Distance Protection
Bapgaon - Kalwa	IntraState	06/10/2021	18.49	06/10/2021	19.01	T	Distance Protection
Chikhli-Jalna-I	IntraState	06/10/2021	19.15	06/10/2021	20.05	HT	Control ICT loading.
Chikhli-Jalna-II	IntraState	06/10/2021	19.15	06/10/2021	20.05	HT	Control ICT loading.
Bhugaon-WardhaPG (Deoli)	IntraState	06/10/2021	21.15	06/10/2021	22.54	HT	To Control OD.
Pusad-WardhaPG(Deoli)	IntraState	06/10/2021	21.23	06/10/2021	22.52	HT	To Control OD.
PANDHARPUR BHALVANI	IntraState	06/10/2021	21.26		Continued.	T	CC Burst.
Trombay-Salsette II	IntraState	06/10/2021	23.12		Continued.	PO	Metro work.
220 KV ICT Outages/Trippings							
220/132kv 200mva Emco ICT-1 @Kurkumbh	IntraState	06/10/2021	12.15	06/10/2021	13.47	PO	replacement of old Al cable by Cu cable of CT circuit.
220/100 Kv 100 Mva Vijai Ict 1 @Jambhul	IntraState	06/10/2021	19.20	06/10/2021	20.00	T	Overcurrent & Earthfault protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage