

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Nov/2020 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	133.900	670.021	1) Gujrat	3.436	9.767
2) Hydro	5.547	25.986	2) Madhya Pradesh	7.591	36.857
3) Gas	6.639	33.176	3) Chattisgarh	6.260	32.020
Total MSPGCL	146.086	729.183	4) Maharashtra	121.438	612.337
B) 1) APLM	66.871	324.237	5) Goa (Amona)	-1.069	-6.005
2) JSWEL	14.893	84.497	Total	137.656	684.976
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.333	126.410
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.511	128.600
5) WPCL	7.355	36.634	c) MSEDCL Bilateral *	25.703	139.194
6) Other IPP	13.672	58.449	Include PX	-0.025	1.667
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.333	126.410
C) 1) TPCL Thermal	16.378	76.099	Include PX	15.721	82.173
2) TPCL Hydro	4.169	15.996	Standby	0.000	0.000
3) TPCL Gas	4.363	21.933	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.301	25.307	1) MSEDCL	376.925	1872.286
D) STATE			2) Mumbai Discoms	54.722	267.935
1) Thermal	258.370	1275.244	TOTAL STATE	431.647	2140.221
(A1+C1+C4+(B1-B6))					
2) Hydro	9.716	41.982			
(A2+C2)					
3) Gas	11.002	55.109			
(A3+B7+C3)					
4) Wind	7.833	49.916			
6) SOLAR	7.070	32.994			
TOTAL STATE	293.991	1455.245			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6005	6018	6157	4712
MSPGCL Hydro	185	175	375	59
MSPGCL Gas	266	267	268	282
MSPGCL Total Generation	6456	6460	6800	5053
Central Sector Receipt	6726	6801	5332	5072
WIND	311	149	251	455
CPP / IPP Thermal	4396	4328	4774	3714
CPP / IPP Gas	0	0	0	0
SOLAR	1012	1003	0	0
Exchange with Mumbai	-1425	-1359	-1005	-751
MSEDCL DEMAND MET	17476	17382	16152	13543
Load Shedding	0	0	0	0
MSEDCL DEMAND	17476	17382	16152	13543
TPCL GENERATION	1050	1055	1317	877
AEML GENERATION	249	248	248	144
MUMBAI DEMAND	2724	2662	2570	1772
STATE DEMAND MET	20200	20044	18722	15315
STATE DEMAND	20200	20044	18722	15315
Frequency (Hz)	50.02	50.00	49.97	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 06.02 Hrs	49.68 Hz at 17.20 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 05/Nov/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.36	55.76	592	296
Unit 9	11.84	21.66	565	372
Unit 10	8.47	44.40	380	320
Total	31.66	121.82		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.22	47.44	460	280
Unit 5	0.00	32.00	0	0
Total	9.22	79.44		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	8.84	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.34	17.59	249	190
Total	5.34	26.43		
Chandrapur				
Unit 3	3.64	19.16	174	115
Unit 4	3.52	18.17	163	117
Unit 5	9.02	46.04	420	275
Unit 6	8.94	46.64	425	279
Unit 7	0.00	0.00	0	0
Unit 8	11.24	56.17	485	415
Unit 9	11.41	55.93	490	425
Total	47.77	242.11		
Paras				
Unit 3	5.52	28.36	252	180
Unit 4	5.74	27.97	253	180
Total	11.26	56.33		
Khaparkheda				
Unit 1	3.26	17.94	160	90
Unit 2	3.91	19.73	180	140
Unit 3	3.99	19.81	185	140
Unit 4	4.03	20.30	185	140
Unit 5	9.89	49.82	455	320
Total	25.07	127.60		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.58	16.30	191	120
Unit 5	0.00	0.00	0	0
Total	3.58	16.30		
Uran				
All Units	6.64	33.18	292	255
Total	6.64	33.18		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.32	0.81	53	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.32	0.81		
Koyna				
Stage 1-2	2.22	13.84	295	40
Stage 4	0.88	1.87	493	0
Stage 3	1.04	3.95	80	0
Total	4.14	19.66		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.11	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.24	0.82	40	0
RNGR+BHTSA	0.35	1.77	15	14
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.93	0	0
SMLHY_PTN	0.00	0.00	0	0
GHATGHAR	0.81	2.70	225	0
Total	1.41	6.33		
Wind				
Total	7.83	49.92	0	0
Total	7.83	49.92		
CPP				
APML(Mus)	66.87	324.24	0	0
JSWEL(Mus)	14.89	84.50	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	7.36	36.63	0	0
Other(Mus)	13.67	58.45	0	0
Total	102.79	503.82		
SOLAR				
Total	7.07	32.99	0	0
Total	7.07	32.99		
Tata				
Trombay 5	10.86	49.40	464	397
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	14.02	119	114
Trombay 7B	1.58	7.92	67	65
Trombay 8	5.52	26.70	232	228
TATA Hydro	4.17	16.00	459	2
Total	24.91	114.03		
AEML				
DTPS U-1&2	5.30	25.31	250	144
Total	5.30	25.31		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	133.90	670.02	MSPGCL Total	146.09	729.18
			MSPGCL Thml+Gas	140.54	703.20	Koyna 1,2 & 4 Total	3.10	15.71
			MSPGCL Hydro	5.55	25.99	State Total	293.99	1455.24

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Nov/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4928	64	292	5284	418	3722	0	0	5329	5269	-1042	13651	0	13651	2133	15784	50.02
2	4745	59	282	5086	439	3719	0	0	5190	5332	-979	13597	0	13597	2000	15597	50.02
3	4716	59	292	5067	412	3722	0	0	5082	5121	-822	13500	0	13500	1842	15342	50.02
4	4712	59	282	5053	455	3714	0	0	5034	5072	-751	13543	0	13543	1772	15315	50.03
5	5051	69	282	5402	451	3716	0	0	4992	5322	-708	14183	0	14183	1729	15912	50.03
6	5628	54	292	5974	458	4066	0	0	5237	5608	-752	15354	0	15354	1768	17122	50.01
7	5866	468	292	6626	476	4546	0	10	5620	5647	-795	16510	0	16510	1832	18342	50.02
8	5878	883	282	7043	420	4768	0	191	5739	5539	-815	17146	0	17146	1939	19085	50.00
9	5939	358	282	6579	261	4825	0	494	6036	6175	-958	17376	0	17376	2134	19510	49.99
10	5986	158	279	6423	361	4670	0	763	6470	6256	-1247	17226	0	17226	2430	19656	49.98
11	5997	180	268	6445	402	4403	0	917	6607	6689	-1506	17350	0	17350	2717	20067	49.99
12	6005	185	266	6456	311	4396	0	1012	6694	6726	-1425	17476	0	17476	2724	20200	50.02
13	6018	175	267	6460	149	4328	0	1003	6719	6801	-1359	17382	0	17382	2662	20044	50.00
14	6031	200	255	6486	84	4160	0	936	6536	6443	-1180	16929	0	16929	2485	19414	50.00
15	6055	285	256	6596	68	4362	0	812	6605	6542	-1262	17118	0	17118	2566	19684	49.93
16	6056	277	266	6599	92	4705	0	569	6527	6374	-1296	17043	0	17043	2602	19645	49.99
17	5997	388	266	6651	101	4712	0	317	6164	5874	-1064	16591	0	16591	2620	19211	49.95
18	6129	525	278	6932	155	4760	0	46	5729	5564	-998	16459	0	16459	2581	19040	49.84
19	6157	375	268	6800	251	4774	0	0	5682	5332	-1005	16152	0	16152	2570	18722	49.97
20	6098	291	270	6659	348	4669	0	0	5747	5226	-1034	15868	0	15868	2549	18417	50.02
21	5262	180	280	5722	363	4081	0	0	5667	5369	-899	14636	0	14636	2420	17056	49.99
22	4837	140	291	5268	312	4052	0	0	5180	5227	-816	14043	0	14043	2293	16336	50.04
23	4909	60	270	5239	488	4014	0	0	5146	5160	-805	14096	0	14096	2196	16292	50.01
24	4900	55	281	5236	558	3907	0	0	5171	4988	-993	13696	0	13696	2158	15854	50.00
MUs	133.90	5.55	6.64	146.09	7.83	102.79	0.00	7.07	138.90	137.66	-24.51	376.92	0.00	376.92	54.72	431.65	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Nov/2020

Position as on 6.30 Hrs of 06/Nov/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Ghatghar Unit-1	125	30/09/2020	18.05		Continued.	Turbine Guide Bearing problem	
MSPGCL	Parli Unit 7	250	22/10/2020	20.00		Continued.	Zero Schedule By MSEDCL	
AEML	AEML Unit 2	250	31/10/2020	18.47		Continued.	Milling system problems	
IPP	JSW (J) U2	300	01/11/2020	04.44		Continued.	No Schedule	
MSPGCL	Parli Unit 6	250	02/11/2020	23.28		Continued.	Excess DM water consumption.	
MSPGCL	Bhusawal Unit 5	500	04/11/2020	08.30		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 06/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	19/10/2020	23.01		Continued.	PO	Abnormal sound from main tank of smoothing reactor at Chandrapur end
Chandrapur - Padghe Hvdc Pole 1	IntraState	05/11/2020	15.53		Continued.	T	D.C. Differential Z Block.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	03/11/2020	19.31		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Khadka-Aurangabad (Waluj)	IntraState	04/11/2020	19.26	05/11/2020	07.09	HT	Over Voltage
Dhule - Bableshtar - II	IntraState	04/11/2020	20.00	05/11/2020	09.19	HT	Over Voltage
Deepnagar Taptitanda	IntraState	05/11/2020	07.21	05/11/2020	15.10	PO	Replacement Of Disc Insulator.
Pune(GIS)-A'bad(Waluj) Ckt 1	IntraState	05/11/2020	11.41	05/11/2020	20.10	T	Work at PG end.
Akola - Bhusawal	IntraState	05/11/2020	12.24	05/11/2020	18.18	PO	Tan Delta Of CT and maintenance of Tie Bay With Line.
Akola - Bhusawal	IntraState	05/11/2020	18.56	06/11/2020	06.21	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	01/11/2020	03.34		Continued.	T	Differential protection
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Tillari Amona	InterState	02/11/2020	14.30		Continued.	PO	220 kv Amona Bay old CB Replacement (civil,Erection & Commissioning,testing)Work at 220 kv Tillari Switch yard.
BADNERA - WARDHA (PG) (Deoli)	InterState	05/11/2020	10.27	05/11/2020	17.28	PO	Diagnostic Testing Work.
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Special Repair Cable work.
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Lonikand1 (400 Kv)-Theur II	IntraState	06/10/2020	08.54		Continued.	PO	HTLS Stringing work
Aurangabad (waluj)-Taptitanda ckt-1	IntraState	04/11/2020	09.42		Continued.	PO	To Facilities Construction Work Of 1200KV Wardha-Aurangabad Line.
Kharepatan -Pawas Line	IntraState	05/11/2020	09.12	05/11/2020	17.53	PO	Tan Delta Diagnostic Testing Of Line.
Balapur-Akola li	IntraState	05/11/2020	09.27	05/11/2020	15.11	PO	Routine Maintenance Work
Nagothane-Wadkhal II	IntraState	05/11/2020	09.55	05/11/2020	16.28	PO	Routine Maintenance Work
Uran - Apta III	IntraState	05/11/2020	10.03	05/11/2020	18.17	PO	Attending Hot Spot
Peth- Mudshingi -I	IntraState	05/11/2020	10.10	05/11/2020	12.55	PO	Quarterly Maintenance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 06/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Deoli(Pgcil)-Badnera	IntraState	05/11/2020	10.27	05/11/2020	17.28	PO	Annual Maintenance Work
Paras-Chikhali Ckt No-Ii	IntraState	05/11/2020	10.30	05/11/2020	20.25	PO	Diagnostic testing work.
Eklahara(Gcr)(Nasik)- Bableshtar 2	IntraState	05/11/2020	10.32	05/11/2020	15.59	PO	Attending Red Hot spot & Flash Over String Replacement Work.
Wardha-Yeotmal	IntraState	05/11/2020	11.18	05/11/2020	18.07	PO	Diagnostic Testing Work.
Bhosari- Bhosari 2	IntraState	05/11/2020	11.35	05/11/2020	16.25	PO	CT Tan Delta Measurement Work.
Nanded- Bhokar I	IntraState	05/11/2020	11.53	05/11/2020	14.20	T	Repeat crm testing of cb due to higher values.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	05/11/2020	12.10	05/11/2020	12.55	PO	Relay Testing Work.
220 KV DEEPNAGAR - VIRODA	IntraState	05/11/2020	12.24	05/11/2020	16.16	PO	Diagnostic testing c.b. timing , crm work & c.t. tan delta work and bus isolator alignment (89a) work.
Aurangabad (waluj)-Taptitanda ckt-2	IntraState	05/11/2020	13.16	05/11/2020	18.16	PO	Diagnostic testing work.
Kharghar-Borivali ckt I	IntraState	05/11/2020	14.40	05/11/2020	17.20	PO	Testing Work
Vsnl-512 Khadki	IntraState	05/11/2020	17.24	05/11/2020	19.04	PO	Attending Hot Spot
220 KV ICT Outages/Trippings							
220/100 Kv 200MVA ICT-I @Padghe	IntraState	03/11/2020	10.18		Continued.	PO	Testing Work,filtration Work Going On.
220/132-110/11kv 200MVA ICT 1 @Miraj	IntraState	04/11/2020	09.25		Continued.	PO	OLTC overhauling work.
220/100 kv 200 MVA ICT-II @Kalwa	IntraState	05/11/2020	09.10	05/11/2020	17.04	PO	Diagnostic Testing Work.
220/132 Kv 100 Mva Bhel Ict 1 @Padegaon	IntraState	05/11/2020	09.25	05/11/2020	18.45	PO	Diagnostic testing work and other maintenance work.
220/33 Kv 50 Mva Cgl Ptr 2 @Boisar -Ii	IntraState	05/11/2020	09.50	05/11/2020	11.30	PO	Routine Maintenance Work
220/132 Kv Ict 2 200 Mva @Parbhani	IntraState	05/11/2020	10.10	05/11/2020	14.54	PO	Diagnostic Testing Work.
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	05/11/2020	10.11	05/11/2020	19.55	PO	Annual Maintenance Work
220/22 Kv 50 Mva Emco Ptr 3 @Colourchem	IntraState	05/11/2020	10.15	05/11/2020	18.00	PO	Diagnostic Testing Work.
220/33kv 50mva Bbl @Oglewadi	IntraState	05/11/2020	10.23	05/11/2020	18.16	PO	Quarterly Maintenance Work
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	05/11/2020	10.23	05/11/2020	17.40	PO	HV/LV Bushing, Winding,CT Tan Delta.
220/132 KV 100MVA ICT-I @ Walchandnagar	IntraState	05/11/2020	11.10	05/11/2020	15.56	PO	Diagnostic Testing Work.
220/132 Kv 150 MVA ICT @Boisar-II	IntraState	05/11/2020	13.30	05/11/2020	19.02	PO	Annual Maintenance Work
220/33KV 100MVA ICT II @ chakan	IntraState	05/11/2020	15.01	05/11/2020	19.24	PO	RTF Work Maintenance And Testing Work.
220/132 KV 100MVA ICT-II @ Walchandnagar	IntraState	05/11/2020	16.02	05/11/2020	16.46	PO	Diagnostic Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage