

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Nov/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.089	705.334	1) Gujrat	-11.658	-49.843
2) Hydro	8.949	41.450	2) Madhya Pradesh	-3.323	-4.979
3) Gas	0.510	9.167	3) Chattisgarh	5.690	29.180
Total MSPGCL	151.548	755.951	4) Maharashtra	160.914	806.564
B) 1) APLM	67.840	281.033	5) Goa (Amona)	-1.457	-7.865
2) JSWEL	11.643	63.626	Total	150.166	773.057
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.800	157.050
4) RPL(AMT)	25.540	127.523	b) Mumbai Drawl	33.922	177.941
5) SWPGPL	5.708	27.638	c) MSEDCL Bilateral *	62.475	323.962
6) Other IPP	29.619	130.758	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.800	157.050
C) 1) TPCL Thermal	11.956	52.625	Include PX	0.000	0.000
2) TPCL Hydro	3.945	20.022	Standby	0.000	0.000
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.385	42.397	1) MSEDCL	425.166	2067.675
D) STATE			2) Mumbai Discoms	59.208	299.975
1) Thermal	303.780	1430.934	3) Other Discoms	9.243	46.994
(A1+C1+C4+(B1-B6))			TOTAL STATE	493.617	2414.644
2) Hydro	12.894	61.472			
(A2+C2)					
3) Gas	0.510	16.157			
(A3+B7+C3)					
4) Wind	14.392	70.892			
6) SOLAR	11.875	62.132			
TOTAL STATE	343.451	1641.587			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6191	6212	6300	5224
MSPGCL Hydro	236	139	1683	143
MSPGCL Gas	0	0	0	60
MSPGCL Total Generation	6427	6351	7983	5427
Central Sector Receipt	7484	7284	5463	5300
WIND	364	279	405	1155
CPP / IPP Thermal	6160	5735	6389	5433
CPP / IPP Gas	0	0	0	0
SOLAR	1607	1319	4	0
Exchange with Mumbai	-1659	-1488	-1267	-1358
MSEDCL DEMAND MET	19950	19082	18555	15627
Load Shedding	0	0	0	0
MSEDCL DEMAND	19950	19082	18555	15627
TPCL GENERATION	674	813	1095	438
AEML GENERATION	499	488	493	289
MUMBAI DEMAND	2832	2789	2855	2085
OTHER DISCOM DEMAND	433	398	422	330
STATE DEMAND MET	23215	22269	21832	18042
STATE DEMAND	23215	22269	21832	18042
Frequency (Hz)	49.99	49.95	49.91	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 06:01 Hrs	49.45 Hz at 17:42 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.06	22.30	205	120
Unit 7	0.00	0.00	0	0
Unit 8	11.61	58.58	533	431
Unit 9	12.17	60.12	561	396
Unit 10	9.04	45.18	402	321
Total	36.88	186.19		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.13	44.18	405	280
Unit 5	9.74	47.34	460	280
Total	18.87	91.52		
Parli				
Unit 6	4.48	16.34	230	148
Unit 7	4.24	15.11	227	141
Unit 8	0.00	12.02	0	0
Total	8.72	43.47		
Chandrapur				
Unit 3	3.45	16.22	168	123
Unit 4	2.98	14.84	153	107
Unit 5	6.80	34.25	310	250
Unit 6	7.95	29.02	400	260
Unit 7	6.36	35.32	288	242
Unit 8	9.19	45.67	436	282
Unit 9	8.60	44.27	411	299
Total	45.32	219.58		
Paras				
Unit 3	4.63	25.96	205	172
Unit 4	0.00	0.00	0	0
Total	4.63	25.96		
Khaparkheda				
Unit 1	2.68	13.56	120	100
Unit 2	2.24	13.42	110	75
Unit 3	3.34	16.72	161	124
Unit 4	2.89	15.60	143	103
Unit 5	10.17	47.99	490	275
Total	21.32	107.28		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.32	16.28	173	113
Unit 5	3.03	15.04	160	109
Total	6.34	31.32		
Uran				
All Units	0.51	9.17	61	0
Total	0.51	9.17		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.94	4.85	40	38
Total	0.94	4.85		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.02	12.93	450	40
Stage 4	1.93	8.68	739	0
Stage 3	1.06	4.88	240	0
Total	6.02	26.48		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.22	0.70	77	0
SMLHY_PTN	1.47	8.05	66	58
GHATGHAR	0.30	1.36	125	0
Total	2.00	10.11		
Wind				
Total	14.39	70.89	0	0
Total	14.39	70.89		
CPP				
APML(Mus)	67.84	281.03	0	0
JSWEL(Mus)	11.64	63.63	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.54	127.52	0	0
SWPGPL-Mus	5.71	27.64	0	0
Other(Mus)	29.62	130.76	0	0
Total	140.35	630.58		
SOLAR				
Total	11.88	62.13	0	0
Total	11.88	62.13		
Tata				
Trombay 5	8.19	35.81	454	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	3.94	20.02	423	8
Trombay 8	3.76	16.82	229	130
Total	15.90	79.64		
AEMIL				
DTPS U-1&2	9.38	42.40	500	283
Total	9.38	42.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.09	705.33	MSPGCL Total	151.55	755.95
			MSPGCL Thml+Gas	142.60	714.50	Koyna 1,2 & 4 Total	4.95	21.60
			MSPGCL Hydro	8.95	41.45	State Total	343.45	1641.59

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 05/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5016	143	61	5220	1127	5366	0	0	5782	5811	-1397	15774	0	15774	2234	353	18361	49.96
2	5224	143	60	5427	1155	5433	0	0	5601	5300	-1358	15627	0	15627	2085	330	18042	50.00
3	5291	148	61	5500	1160	5457	0	0	5523	5287	-1271	15830	0	15830	1964	303	18097	49.99
4	5228	143	60	5431	1055	5465	0	0	5434	5596	-1194	16049	0	16049	1884	304	18237	49.98
5	5671	143	61	5875	1057	5626	0	0	5399	5480	-1160	16564	0	16564	1854	314	18732	49.98
6	6041	143	61	6245	1058	6138	0	0	5599	5676	-1218	17548	0	17548	1914	351	19813	50.01
7	6180	527	60	6767	863	6229	0	34	5842	5764	-1234	18046	0	18046	1978	377	20401	49.96
8	6205	753	60	7018	684	6228	0	372	5939	6163	-1174	18907	0	18907	2086	384	21377	50.00
9	6116	327	26	6469	438	6251	0	878	6255	6585	-1341	18861	0	18861	2324	419	21604	50.05
10	6056	236	0	6292	364	6183	0	1277	6829	7316	-1455	19562	0	19562	2608	415	22585	49.99
11	6191	236	0	6427	364	6160	0	1607	7442	7484	-1659	19950	0	19950	2832	433	23215	49.99
12	6127	141	0	6268	399	6050	0	1693	7560	7059	-1716	19342	0	19342	2909	411	22662	50.00
13	5954	137	0	6091	384	5462	0	1694	7541	7351	-1605	18979	0	18979	2885	398	22262	50.00
14	5930	137	0	6067	309	5295	0	1559	7363	7314	-1459	18696	0	18696	2757	389	21842	49.99
15	6212	139	0	6351	279	5735	0	1319	7192	7284	-1488	19082	0	19082	2789	398	22269	49.95
16	6332	139	0	6471	262	5996	0	892	7144	7116	-1544	18787	0	18787	2764	406	21957	49.95
17	6356	401	0	6757	215	6084	0	475	6896	6632	-1493	18241	0	18241	2884	429	21554	49.83
18	6300	1003	0	7303	278	6346	0	71	5986	5536	-1266	17848	0	17848	2796	420	21064	49.75
19	6300	1683	0	7983	405	6389	0	4	5593	5463	-1267	18555	0	18555	2855	422	21832	49.91
20	6188	1073	0	7261	477	6243	0	0	5974	6060	-1350	18276	0	18276	2792	415	21483	50.03
21	5906	294	0	6200	505	5918	0	0	6225	6240	-1571	16882	0	16882	2670	410	19962	49.95
22	5845	223	0	6068	478	5499	0	0	5939	6239	-1603	16280	0	16280	2547	401	19228	49.97
23	5797	288	0	6085	524	5386	0	0	5875	5839	-1559	15880	0	15880	2426	395	18701	49.91
24	5623	346	0	5969	552	5411	0	0	5824	5574	-1540	15602	0	15602	2371	364	18337	49.94
MUs	142.09	8.95	0.51	151.55	14.39	140.35	0.00	11.87	150.76	150.17	-33.92	425.17	0.00	425.17	59.21	9.24	493.62	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Nov/2022

Position as on 6.30 Hrs of 06/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	14/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	14/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-3	135	21/10/2022	01:33		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	22/10/2022	16:51		Continued.	Turbine Vibration	15/11/2022
IPP	SWPGPL U-1	135	23/10/2022	20:29		Continued.	PA Fan Vibration Problem	06/11/2022
MSPGCL	Uran Unit 5	108	02/11/2022	17:35		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/11/2022	10:50	06/11/2022	12:14	MOT level fluctuate and fire protection operate turbine tripped and boiler hand tripped.	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Nov/2022

Position as on 6.30 Hrs of 06/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	05/11/2022	08:29	06/11/2022	15:22	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 06/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
Tie bay (705) of Ektuni ckt - 1 & Koradi - 3 ckt - 1 @ Akola - 2	IntraState	05/11/2022	11:35	05/11/2022	19:35	PO	Annual Maintenance of Bay Equipment
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21			PO	Annual Maintenance work AC & DC yard Equipment, Valve Hall,Diagnostic testing, Line Maintenance, etc.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/10/2022	10:27		Continued.	HT	For Load management
TBC @ KOLHAPUR(TALANDGE)	IntraState	03/11/2022	16:15			PO	Overhauling of A bus, B Bus, C Bus PG isolators.
KHADKA-AURANGABAD (WALUJ)	IntraState	04/11/2022	20:37	05/11/2022	08:15	HT	H/T DUE TO O/V
JAIGAD - KARAD CKT - 2	IntraState	04/11/2022	21:20	05/11/2022	10:04	HT	H/T DUE TO O/V
PADGHE - NAGOTHANE CKT - 1	IntraState	04/11/2022	21:25	05/11/2022	07:55	HT	H/T DUE TO O/V
NEW KOYNA - DABHOL CKT - 2	IntraState	05/11/2022	09:05	05/11/2022	18:43	PO	Cold washing work
PADGHE - PADGHE HVDC CKT- 2	IntraState	05/11/2022	12:21			PO	1. Bay maint. work 2. Diagnostic testing work 3. Bhel CB Pole Overhauling work 4. A bus PG Isolator Replacement work under LES 5. If pole Overhauling work not completed due to any reason line will be charge on TBC. 6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator 7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change .
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	05/11/2022	22:02	06/11/2022	06:22	EO	89C B-Phase Hot spot on IPS tube nut bolt
NEW KOYNA - STAGE IV CKT - 1	IntraState	05/11/2022	22:21	06/11/2022	09:44	PO	400 KV Breaker Time Testing
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	05/11/2022	10:57	05/11/2022	20:20	PO	DIAGNOSTIC TESTING AND MAINTENANCE WORK.
220 KV LINE Outages/Trippings							
ACCIL - APTA	IntraState	02/11/2022	15:57		Continued.	EO	CB DC leakage attending work by testing divison panvel.
EKLAHARE (OCR) - PADGHE	IntraState	04/11/2022	09:39	05/11/2022	22:41	HT	For load management
EKLAHARE (OCR) - PADGHE	IntraState	05/11/2022	09:43	05/11/2022	22:41	HT	Load management
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	05/11/2022	10:19	05/11/2022	15:13	PO	Routine maintenance work & tree cutting work
SADAWAGHAPUR KARAD CKT 1	IntraState	05/11/2022	10:20	05/11/2022	14:21	PO	Annual Relay Testing Work
WASHALA - GHATGHAR	IntraState	05/11/2022	10:25	05/11/2022	14:23	PO	CT Tan Delta & R&M Works.
SAHARA-URSE	IntraState	05/11/2022	11:15	05/11/2022	22:32	HT	For load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 06/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DASTURI-KANDALGAON LINE	IntraState	05/11/2022	12:05	05/11/2022	22:00	T	Tripped on DP
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	05/11/2022	13:38	05/11/2022	22:24	PO	FOR AMP WORK
SADAWAGHAPUR KARAD CKT 2	IntraState	05/11/2022	15:02	06/11/2022	00:47	PO	Annual Relay Testing Work
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	05/11/2022	15:30	05/11/2022	18:52	PO	Routine maintenance work & tree cutting work
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	05/11/2022	17:13	05/11/2022	20:31	EO	1) Attending the damaged conductor in between loc.no.105B and 106.
KANDALGAON - PIRANGUT	IntraState	06/11/2022	08:30	06/11/2022	15:42	PO	Replacement of Flashover & deteriorated polymer insulator at Loc.No.33 & 32 and other line maintenance work.
CHALISGAON -BABHALESHWAR	IntraState	06/11/2022	08:43	06/11/2022	17:29	HT	For load management
BABHALESHWAR - UTECH SUGAR	IntraState	06/11/2022	09:00	06/11/2022	17:20	PO	220 Kv BBLR Utech Line For replacement of faulty DISC insulator string as per PID report under LMSD BBLR.
EKLAHARE (OCR) - PADGHE	IntraState	06/11/2022	09:20	06/11/2022	21:42	HT	HT for load management
KAMBA - VASAI	IntraState	06/11/2022	09:25	06/11/2022	11:11	EO	For Y- phase identified LA IR test.
GHODBUNDER - MSETCL BORIVALI	IntraState	06/11/2022	10:18	06/11/2022	13:43	PO	Annual Diagnostic testing.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/11/2022	15:31	06/11/2022	18:55	HT	Line loading control
TROMBAY - MULUND	IntraState	06/11/2022	16:32	06/11/2022	18:45	HT	Emergency outage to release stuck isolator
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	04/11/2022	08:48	05/11/2022	14:09	PO	For replacement of 70KN suspension & Tension type Disc of insulator by 120KN Disc insulator of 220/100Kv 200MVA ICT-1 HV Bay
220/22 KV 50 MVA PTR 2 @ PADGHE	IntraState	04/11/2022	08:48	05/11/2022	02:37	PO	For replacement of 70KN suspension & Tension type Disc of insulator by 120KN Disc insulator of 220/22kv 50MVA T&R make Tf
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	05/11/2022	11:26	05/11/2022	14:34	PO	ICT Bushing and winding,HV & LV CTs tan delta measurement work and Bay maintenance work
220/33 KV 25 MVA PTR @ RAYMOND	IntraState	05/11/2022	12:00	05/11/2022	13:40	PO	Attending red hot spot of Y ph HV bushing
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	05/11/2022	13:38	05/11/2022	17:16	PO	HV CB replacement work
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	05/11/2022	15:12	05/11/2022	17:12	PO	ICT Bushing and winding,HV & LV CTs tan delta measurement work and Bay maintenance work
220/22 KV 25 MVA PTR 1 @ WASHALA	IntraState	05/11/2022	15:30	05/11/2022	17:03	PO	Winding, Bushing & CT TanD, IR/PI measurementworks. R&M Works.
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ TOPWORTH	IntraState	06/11/2022	08:15	06/11/2022	18:35		Post-monsoon Maintenance, red-hotspot attending work and Diagnostic Tesing Work of metering CT, PT.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 06/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
100 KV LINE Outages/Trippings							
KALWA - SALSETTE CKT - 2	IntraState	05/11/2022	09:58	05/11/2022	13:47	EO	To attend Hot spot at 100kV Kalwa- Salsette-II line isolator Rph extension jumper nut bolt aux side.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage