

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Jan/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	158.710	961.737	1) Gujrat	-3.732	-28.479
2) Hydro	7.137	56.188	2) Madhya Pradesh	4.629	16.928
3) Gas	7.168	37.459	3) Chattisgarh	5.290	37.970
Total MSPGCL	173.015	1055.384	4) Maharashtra	175.022	1077.833
B) 1) APML	60.552	322.614	5) Goa (Amona)	-1.677	-9.297
2) JSWEL	24.478	146.644	Total	179.532	1094.955
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.529	179.634
4) RPL(AMT)	19.244	138.105	b) Mumbai Drawl	32.219	205.142
5) SWPGPL	11.828	72.020	c) MSEDCL Bilateral *	66.040	377.503
6) Other IPP	44.844	269.521	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.529	179.634
C) 1) TPCL Thermal	12.271	77.847	Include PX	0.000	0.000
2) TPCL Hydro	3.378	25.199	Standby	0.000	0.000
3) TPCL Gas	2.866	11.287	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.883	30.272	1) MSEDCL	490.927	2950.312
D) STATE			2) Mumbai Discoms	55.621	349.753
1) Thermal	336.810	2018.760	3) Other Discoms	10.071	61.304
(A1+C1+C4+(B1-B6))			TOTAL STATE	556.619	3361.369
2) Hydro	10.515	81.387			
(A2+C2)					
3) Gas	10.034	48.746			
(A3+B7+C3)					
4) Wind	8.606	44.272			
6) SOLAR	11.118	73.243			
TOTAL STATE	377.083	2266.408			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	7183	6596	7311	5611
MSPGCL Hydro	797	152	583	148
MSPGCL Gas	297	289	294	307
MSPGCL Total Generation	8277	7037	8188	6066
Central Sector Receipt	9218	8872	7741	6072
WIND	250	168	291	427
CPP / IPP Thermal	6983	6505	6974	6438
CPP / IPP Gas	0	0	0	0
SOLAR	1487	1730	0	0
Exchange with Mumbai	-1487	-1681	-1274	-1176
MSEDCL DEMAND MET	24297	22191	21439	17471
Load Shedding	0	0	0	0
MSEDCL DEMAND	24297	22191	21439	17471
TPCL GENERATION	1055	876	1189	498
AEML GENERATION	216	229	218	181
MUMBAI DEMAND	2758	2786	2681	1855
OTHER DISCOM DEMAND	431	440	481	356
STATE DEMAND MET	27486	25417	24601	19682
STATE DEMAND	27486	25417	24601	19682
Frequency (Hz)	50.00	49.84	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.29 Hz at 07.03 Hrs	49.96 Hz at 22.50 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Jan/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.38	25.62	190	170
Unit 8	13.88	84.58	627	497
Unit 9	12.78	75.10	622	423
Unit 10	14.20	84.68	625	510
Total	45.25	269.98		
Bhusawal				
Unit 3	3.49	21.23	180	120
Unit 4	8.90	57.40	490	285
Unit 5	8.78	55.74	485	280
Total	21.18	134.37		
Parli				
Unit 6	4.46	27.06	250	144
Unit 7	3.27	25.85	241	0
Unit 8	3.91	19.18	211	135
Total	11.64	72.09		
Chandrapur				
Unit 3	3.25	20.45	160	115
Unit 4	1.98	11.27	147	0
Unit 5	8.20	51.60	425	270
Unit 6	7.30	44.40	345	280
Unit 7	0.00	0.00	0	0
Unit 8	7.93	45.44	360	282
Unit 9	10.00	51.09	480	283
Total	38.66	224.26		
Paras				
Unit 3	5.50	32.44	241	209
Unit 4	5.77	34.38	250	188
Total	11.27	66.82		
Khaparkheda				
Unit 1	3.95	23.96	190	120
Unit 2	2.56	16.84	123	81
Unit 3	3.70	23.09	178	130
Unit 4	4.06	24.95	195	126
Unit 5	9.37	61.64	460	290
Total	23.65	150.48		
Nasik				
Unit 3	0.00	2.70	0	0
Unit 4	3.70	22.34	188	124
Unit 5	3.37	18.70	162	118
Total	7.07	43.75		
Uran				
All Units	7.17	37.46	312	284
Total	7.17	37.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	0.67	23	0
Total	0.06	0.67		
Koyna				
Stage 1-2	1.66	14.28	270	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.34	14.53	504	0
Stage 3	0.67	6.38	240	0
Total	3.66	35.19		
Hydro				
KDPH	0.43	3.02	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.30	12.25	99	94
GHATGHAR	0.68	5.06	185	0
Total	3.42	20.33		
Wind				
Total	8.61	44.27	0	0
Total	8.61	44.27		
CPP				
APML(Mus)	60.55	322.61	0	0
JSWEL(Mus)	24.48	146.64	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.24	138.10	0	0
SWPGPL-Mus	11.83	72.02	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.25	33.17	266	150
Other(Mus)	37.68	223.48	0	0
JPL	1.91	12.88	131	0
Total	160.95	948.90		
SOLAR				
Total	11.12	73.24	0	0
Total	11.12	73.24		
Tata				
Trombay 5	8.14	51.48	455	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.68	7.24	108	38
Trombay 7B	1.18	4.05	65	36
TATA Hydro	3.38	25.20	353	9
Trombay 8	4.14	26.37	237	132
Total	18.52	114.33		
AEML				
DTPS U-1&2	4.88	30.27	238	155
Total	4.88	30.27		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	158.71	961.74	MSPGCL Total	173.02	1055.38
			MSPGCL Thml+Gas	165.88	999.20	Koyna 1,2 & 4 Total	3.00	28.80
			MSPGCL Hydro	7.14	56.19	State Total	377.08	2266.41

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Jan/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5789	157	304	6250	490	6387	0	0	6380	6072	-1282	17535	0	0	17535	1996	382	19913	50.01
2	5611	148	307	6066	427	6438	0	0	6404	6072	-1176	17471	0	0	17471	1855	356	19682	49.99
3	5716	154	306	6176	428	6454	0	0	6252	6045	-1074	17705	0	0	17705	1745	324	19774	50.01
4	5805	158	306	6269	466	6467	0	0	6283	6161	-1002	18041	0	0	18041	1684	320	20045	50.01
5	5989	153	306	6448	515	6486	0	0	6663	6421	-1010	18519	0	0	18519	1687	341	20547	49.98
6	6331	169	306	6806	489	6481	0	0	7266	7066	-1066	19389	0	0	19389	1797	387	21573	49.98
7	6759	157	312	7228	440	6753	0	25	7575	7658	-1096	20600	0	0	20600	1927	408	22935	50.03
8	7009	570	311	7890	440	6989	0	160	7182	7710	-881	21888	0	0	21888	2061	420	24369	50.04
9	7094	885	310	8289	290	7034	0	496	7684	7960	-1005	22635	0	0	22635	2305	429	25369	49.97
10	7169	1143	304	8616	254	6970	0	986	8073	8466	-1234	23617	0	0	23617	2559	441	26617	49.99
11	7183	797	297	8277	250	6983	0	1487	8925	9218	-1487	24297	0	0	24297	2758	431	27486	50.00
12	7196	165	287	7648	194	6883	0	1761	9146	8739	-1628	23181	0	0	23181	2814	416	26411	49.97
13	6596	152	289	7037	168	6505	0	1730	9054	8872	-1681	22191	0	0	22191	2786	440	25417	49.84
14	6589	152	284	7025	113	6478	0	1660	8682	8628	-1663	21810	0	0	21810	2652	431	24893	50.01
15	6940	152	284	7376	109	6545	0	1356	8834	8926	-1896	21989	0	0	21989	2645	427	25061	50.06
16	7405	155	288	7848	115	6652	0	942	8750	8603	-1806	21896	0	0	21896	2654	458	25008	50.05
17	7511	155	288	7954	114	6908	0	433	7868	7605	-1412	21139	0	0	21139	2641	463	24243	49.99
18	7408	190	291	7889	181	6939	0	82	7349	7470	-1275	20807	0	0	20807	2633	479	23919	49.94
19	7311	583	294	8188	291	6974	0	0	7661	7741	-1274	21439	0	0	21439	2681	481	24601	50.01
20	7235	329	296	7860	470	6992	0	0	7550	7396	-1269	20984	0	0	20984	2630	465	24079	50.02
21	6787	155	299	7241	510	6875	0	0	7007	6485	-1480	19170	0	0	19170	2489	461	22120	50.02
22	6157	154	298	6609	604	6625	0	0	7038	6672	-1575	18479	0	0	18479	2339	456	21274	49.95
23	5614	152	300	6066	627	6547	0	0	6997	6931	-1522	18207	0	0	18207	2200	442	20849	49.92
24	5506	152	301	5959	621	6581	0	0	6546	6615	-1425	17938	0	0	17938	2079	413	20430	49.96
MUs	158.71	7.14	7.17	173.01	8.61	160.95	0.00	11.12	181.17	179.53	-32.22	490.93	0.00	0.00	490.93	55.62	10.07	556.62	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jan/2024

Position as on 6.30 Hrs of 07/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	15/01/2024
MSPGCL	Koyna STG-IV Unit-3	250	24/11/2023	08:00		Continued.	Capital Overhauling	24/01/2024
MSPGCL	Chandrapur Unit 7	500	25/12/2023	15:28		Continued.	Air heater basket replacement work(converted to planned outage from 00.00Hrs DT. 30-12-2023)	07/01/2024
Total Capacity MSPGCL		938						
AEML								
AEML	AEML Unit 2	250	20/12/2023	10:54		Continued.	Annual Overhaul	20/01/2024
Total Capacity AEML		250						
IPP								
IPP	Adani U-3	660	31/12/2023	23:59		Continued.	COH activities	05/02/2024
Total Capacity IPP		660						
Total Capacity PLANNED OUTAGE		1848						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Nasik Unit 3	210	01/01/2024	20:30		Continued.	Boiler Tube Leakage(converted to tolling from 00.00Hrs DT.	
MSPGCL	Chandrapur Unit 4	210	04/01/2024	00:08	06/01/2024	06:55	Boiler Furnace Pressure High.	05/01/2024
MSPGCL	Uran Unit 6	108	04/01/2024	20:03		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Parli Unit 7	250	06/01/2024	17:37	06/01/2024	23:14	Drum level high	
Total Capacity MSPGCL		898						
IPP								
IPP	RPL(AMT) U-2	270	30/12/2023	13:30		Continued.	Hydrogen leakage in Generator.	12/01/2024
IPP	RPL(AMT) U-1	270	04/01/2024	17:30		Continued.	Bottom Ash evacuation Problem.	08/01/2024
IPP	JPL Unit 1	150	06/01/2024	20:56		Continued.	Low net sales realisation.	
IPP	IEPL Unit 1	270	07/01/2024	21:30		Continued.	ID Fan Problem	10/01/2024
Total Capacity IPP		960						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket	01/05/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jan/2024

Position as on 6.30 Hrs of 07/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2178						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 07/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Trippings							
709 LR (AKOLA CKT - 1) REACTOR @ KORADI 3	IntraState	07/01/2024	12:15		Continued.	PO	Six monthly changeover of B-Ph Reactor to be taken in service in place of Spare Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 09.07.2023.
765 KV LINE Outages/Trippings							
KORADI III - AKOLA II Ckt - 1	IntraState	07/01/2024	12:15		Continued.	PO	Six monthly changeover of B-PH Reactor to be taken in service in place of Spare Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 09.07.2023.
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-2	InterState	20/12/2023	12:11			HT	For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS�
CHAKAN - TALEGAON(PG)	InterState	07/01/2024	23:18		Continued.	HT	Attending Hotspot and Unwinding conductor works at Talegaon PG
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/11/2023	19:17			HT	HT Load Management
PADGHE - KALWA CKT - 2	IntraState	30/12/2023	22:01			PO	During the outage on Dtd: 30.12.2023 temporary tapping arrangement on 400kV Kalwa-Padgha Ckt.2 line will be done by making a bunching arrangement from loc no 3 to loc 132 of 400Kv Padgha-Kharghar (dead line) line at Padgha substation premises. By this bunching arrangement, line will be diverted from loc no.132 to loc.No .09. Due to this tapping of 400Kv Kalwa-Padgha Ckt.2-line section b/w loc no 3 to Kalwa Substation (loc1135) will become dead. And this dead Ckt. will be free for completion of the balance HTLS conversion work i.e between Loc no. 61-62 to 1012 (approximately 2.7 km).
KHARGHAR - VIKHROLI GIS CKT - 1	IntraState	30/12/2023	22:43			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	30/12/2023	22:44			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
MAIN BUS - 1 @ KALWA	IntraState	05/01/2024	11:28	07/01/2024	22:41	PO	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-2 line above live 400kV RS Kalwa over 400kV Bus-1 & 2 by Hotline stringing method
PARLI - KARJAT CKT - 2	IntraState	06/01/2024	17:21	06/01/2024	22:39	T	Tripped on R ph to Y ph fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 07/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NAGOTHANE - DABHOL CKT - 2	IntraState	07/01/2024	07:27	07/01/2024	08:33	T	Tripped on Distance protection from Dabhol end only.
PARLI - KARJAT CKT - 1	IntraState	07/01/2024	17:07	07/01/2024	22:11	PO	(1) CT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work
JAIGAD - KARAD CKT - 1	IntraState	07/01/2024	21:20		Continued.	HT	For voltage management
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	30/12/2023	23:20			T	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	30/12/2023	23:21			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	30/12/2023	23:22			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400KV/21KV GT - 3 @ TIRORA	IntraState	01/01/2024	10:45			PO	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.
GTR - 7 @ CHANDRAPUR	IntraState	01/01/2024	11:11				1) Measurement of CB timing, CRM & DCRM. 2) Measurement of tandelta & capacitance of CT & Sych CVT 2) Maintenance and alignment of Isolators. 3) Bay routine maintenance work.
400/220KV 167 MVA SPARE ICT @ DHULE	IntraState	06/01/2024	10:07	06/01/2024	15:15	PO	For Diagnostic testing and Routine maintenance work
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV MAINBAY Outages/Trippings							
132 KV BORVIHIR TSS CKT	IntraState	07/01/2024	10:14	07/01/2024	13:27	PO	For Diagnostic Testing Work.
220 KV LINE Outages/Trippings							
BAPGAON - KALWA	IntraState	31/12/2023	18:05			T	Distance Protection
DAHANU - VERSOVA	IntraState	02/01/2024	08:04			PO	Tranmission Line Project: High speed train project work ADTPS: Bay 04 Overhauling of Isolator -C Bus 02 Isolator OH and Breaker PM
DAHANU - VIRAJ	IntraState	02/01/2024	08:30			PO	Transmission Line Project : High speed train project work ADTPS: Bay 03 Overhauling of Isolator -C Bus 02 Isolator Overhauling Breaker PM PM & tan delta testing of Line CT / CVT LA Replacement
220 KV PARTUR - NAGEWADI CKT 1	IntraState	05/01/2024	21:05	07/01/2024	16:45	T	Distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 07/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TAMBATI - ADLABS	IntraState	06/01/2024	07:20	06/01/2024	10:53	PO	Twin jumpering work at Cut point locations
POPHALI - KDPH	IntraState	06/01/2024	10:10	06/01/2024	14:50	PO	For replacement of damaged conductor at loc no 4 09B Y ph KDPH side, loc no 4 20 R ph KDPH side.
BADNERA - AMRAVATI	IntraState	06/01/2024	11:54	06/01/2024	13:11	EO	For removing cloth
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	06/01/2024	17:19			PO	C.B Overhauling, Diagnostic Testing work.
GANGAPUR-VALVE	IntraState	06/01/2024	17:34	06/01/2024	19:24	EO	Replacement of 220KV Bus coupler B Phase Jump
SHIVAJINAGAR - GANGAPUR	IntraState	06/01/2024	17:34	06/01/2024	19:32	EO	Replacement of 220KV Bus coupler B Phase Jump
SATANA - GANGAPUR	IntraState	06/01/2024	17:34	06/01/2024	20:06	EO	Replacement of 220KV Bus coupler B Phase Jump
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	07/01/2024	10:28	07/01/2024	16:11	PO	Replacement of PID faulty insu. String at loc 32-B (Normal),54-R (CP) & 61-R(CP)
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	07/01/2024	13:41	07/01/2024	16:01	T	Tripped on Distance protection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	IntraState	07/01/2024	05:53	07/01/2024	06:13	T	220kv Bus-bar operated
220/132 KV 200MVA ICT NO 1 @ THEUR	IntraState	07/01/2024	11:32	07/01/2024	18:10	PO	High Tan delta CT replacement work (R & B ph)
220 KV BUSBAR Outages/Trippings							
BUS SECTION - 4 (7M5) @ CHINCHWAD	IntraState	06/01/2024	23:51	07/01/2024	05:51	PO	Earth wire replacement work on 220KV Bus and 220KV Bus isolator maintenance work
BUS SECTION - 4 (7M5) @ CHINCHWAD	IntraState	06/01/2024	23:51	07/01/2024	05:51	PO	Earth wire replacement work on 220KV Bus and 220KV Bus isolator maintenance work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KHOPOLI - KARANJADE	IntraState	07/01/2024	07:47	07/01/2024	10:16	PO	FOR TREE TRIMMING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage