

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Feb/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	152.215	894.502	1) Gujrat	-7.062	-40.626
2) Hydro	12.401	59.605	2) Madhya Pradesh	4.162	31.521
3) Gas	5.738	34.052	3) Chattisgarh	4.530	27.430
Total MSPGCL	170.354	988.159	4) Maharashtra	183.806	1059.372
B) 1) APML	70.098	415.057	5) Goa (Amona)	-1.851	-9.826
2) JSWEL	18.996	105.557	Total	183.585	1067.871
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.120	181.897
4) RPL(AMT)	31.090	184.496	b) Mumbai Drawl	34.618	209.505
5) SWPGPL	9.664	57.523	c) MSEDCL Bilateral *	66.122	440.540
6) Other IPP	41.532	268.826	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.094	181.806
C) 1) TPCL Thermal	4.018	23.178	Include PX	0.000	0.000
2) TPCL Hydro	5.022	25.372	Standby	0.026	0.092
3) TPCL Gas	1.928	12.788	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.000	57.187	1) MSEDCL	499.947	2969.794
D) STATE			2) Mumbai Discoms	55.586	328.030
1) Thermal	337.613	2006.326	3) Other Discoms	9.908	59.000
(A1+C1+C4+(B1-B6))			TOTAL STATE	565.441	3356.824
2) Hydro (A2+C2)	17.423	84.977			
3) Gas (A3+B7+C3)	7.666	46.840			
4) Wind	4.385	63.090			
6) SOLAR	14.769	87.720			
TOTAL STATE	381.856	2288.953			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6578	6463	6834	5664
MSPGCL Hydro	507	325	917	268
MSPGCL Gas	231	230	238	244
MSPGCL Total Generation	7316	7018	7989	6176
Central Sector Receipt	9555	9044	6480	6773
WIND	128	130	345	64
CPP / IPP Thermal	7432	7283	7560	6395
CPP / IPP Gas	0	0	0	0
SOLAR	2067	2112	0	0
Exchange with Mumbai	-1893	-1822	-1360	-1297
MSEDCL DEMAND MET	24153	23352	20563	17747
Load Shedding	0	0	0	0
MSEDCL DEMAND	24153	23352	20563	17747
TPCL GENERATION	493	487	746	245
AEML GENERATION	492	492	495	344
MUMBAI DEMAND	2878	2801	2601	1886
OTHER DISCOM DEMAND	452	413	451	364
STATE DEMAND MET	27483	26566	23615	19997
STATE DEMAND	27483	26566	23615	19997
Frequency (Hz)	50.03	50.06	49.98	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.38 Hz at 16.05 Hrs	49.69 Hz at 18.41 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.94	28.96	210	195
Unit 8	14.01	81.60	603	551
Unit 9	13.30	80.05	586	525
Unit 10	5.70	63.14	610	0
Total	37.96	253.75		
Bhusawal				
Unit 3	3.10	18.67	150	110
Unit 4	9.40	58.72	470	275
Unit 5	9.03	56.16	435	280
Total	21.54	133.55		
Parli				
Unit 6	4.58	25.43	234	146
Unit 7	4.30	10.54	220	138
Unit 8	3.48	22.53	175	132
Total	12.36	58.50		
Chandrapur				
Unit 3	3.37	20.00	170	120
Unit 4	2.97	17.91	140	100
Unit 5	6.77	41.35	295	265
Unit 6	8.57	48.46	425	285
Unit 7	0.00	0.00	0	0
Unit 8	10.49	63.94	500	284
Unit 9	9.09	23.93	482	169
Total	41.27	215.58		
Paras				
Unit 3	5.16	25.81	228	202
Unit 4	5.49	33.67	237	218
Total	10.65	59.48		
Khaparkheda				
Unit 1	2.69	15.98	120	100
Unit 2	2.56	15.52	114	98
Unit 3	3.65	20.45	173	126
Unit 4	3.74	21.09	191	125
Unit 5	9.94	61.99	470	280
Total	22.57	135.03		
Nasik				
Unit 3	3.66	21.15	181	110
Unit 4	0.00	2.54	0	0
Unit 5	2.22	14.93	170	0
Total	5.88	38.61		
Uran				
All Units	5.74	34.05	248	227
Total	5.74	34.05		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.76	3.03	45	23
Total	0.76	3.03		
Koyna				
Stage 1-2	3.20	15.22	400	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.88	8.76	425	0
Stage 3	1.18	5.38	240	0
Total	6.26	29.36		
Hydro				
KDPH	0.86	3.61	36	36
VTRNA	0.42	2.91	60	0
TILLARI	0.46	1.62	58	0
BHIRA T.R.	0.26	1.60	77	0
SMLHY_PTN	2.53	13.91	109	100
GHATGHAR	0.84	3.56	125	0
Total	5.38	27.22		
Wind				
Total	4.38	63.09	0	0
Total	4.38	63.09		
CPP				
APML(Mus)	70.10	415.06	0	0
JSWEL(Mus)	19.00	105.56	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.09	184.50	0	0
SWPGPL-Mus	9.66	57.52	0	0
Dhariwal	0.00	18.40	0	0
IEPL	5.18	28.25	264	194
Other(Mus)	36.35	222.18	0	0
Total	171.38	1031.46		
SOLAR				
Total	14.77	87.72	0	0
Total	14.77	87.72		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.04	7.00	55	36
Trombay 7B	0.89	5.79	44	32
TATA Hydro	5.02	25.37	438	9
Trombay 8	4.02	23.18	223	134
Total	10.97	61.34		
AEML				
DTPS U-1&2	10.00	57.19	499	326
Total	10.00	57.19		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	152.22	894.50	MSPGCL Total	170.35	988.16
			MSPGCL Thml+Gas	157.95	928.55	Koyna 1,2 & 4 Total	5.08	23.98
			MSPGCL Hydro	12.40	59.60	State Total	381.86	2288.95

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5664	268	244	6176	64	6395	0	0	6725	6773	-1297	17747	0	17747	1886	364	19997	50.01
2	5801	207	247	6255	40	6641	0	0	6731	6622	-1145	18069	0	18069	1737	344	20150	50.03
3	5821	206	245	6272	85	6699	0	0	6798	6699	-1066	18369	0	18369	1657	320	20346	50.01
4	5884	200	247	6331	85	6745	0	0	6752	6506	-1020	18338	0	18338	1603	309	20250	50.00
5	6109	203	246	6558	97	6769	0	0	6981	6892	-1052	18924	0	18924	1623	340	20887	50.02
6	6119	692	248	7059	121	7108	0	0	6963	7233	-1156	19992	0	19992	1750	373	22115	49.97
7	6547	866	246	7659	161	7528	0	2	7163	7190	-1229	20915	0	20915	1941	396	23252	49.95
8	6542	1355	248	8145	118	7550	0	201	7523	7629	-1210	22021	0	22021	2132	412	24565	49.99
9	6607	954	247	7808	113	7556	0	806	8255	8186	-1411	22621	0	22621	2417	437	25475	50.05
10	6671	1012	244	7927	91	7538	0	1424	8287	8428	-1524	23445	0	23445	2665	439	26549	49.95
11	6637	766	238	7641	97	7425	0	1819	9347	9379	-1759	24157	0	24157	2838	445	27440	50.03
12	6578	507	231	7316	128	7432	0	2067	9477	9555	-1893	24153	0	24153	2878	452	27483	50.03
13	6463	325	230	7018	130	7283	0	2112	9179	9044	-1822	23352	0	23352	2801	413	26566	50.06
14	5894	415	228	6537	133	6959	0	2020	9107	9154	-1775	22605	0	22605	2692	423	25720	50.04
15	6211	416	228	6855	195	6824	0	1813	9112	9432	-1777	22920	0	22920	2711	422	26053	49.95
16	6537	511	229	7277	182	7203	0	1432	9007	9208	-1758	23097	0	23097	2730	447	26274	50.01
17	6606	308	227	7141	222	7380	0	822	8690	8696	-1746	22053	0	22053	2697	462	25212	50.06
18	6673	448	228	7349	291	7466	0	251	7787	7693	-1569	21020	0	21020	2650	461	24131	50.05
19	6689	703	236	7628	359	7543	0	0	6978	6877	-1426	20531	0	20531	2627	450	23608	49.90
20	6834	917	238	7989	345	7560	0	0	6775	6480	-1360	20563	0	20563	2601	451	23615	49.98
21	6755	309	239	7303	343	7430	0	0	6737	6112	-1355	19380	0	19380	2440	453	22273	50.05
22	6341	275	240	6856	289	6952	0	0	6570	6493	-1308	18836	0	18836	2294	446	21576	49.97
23	6310	210	242	6762	318	6726	0	0	6821	6729	-1506	18601	0	18601	2170	428	21199	49.92
24	5922	328	242	6492	378	6668	0	0	6730	6575	-1454	18249	0	18249	2046	410	20705	49.90
MUs	152.21	12.40	5.74	170.35	4.38	171.38	0.00	14.77	184.50	183.58	-34.62	499.96	0.00	499.96	55.59	9.90	565.44	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Feb/2023

Position as on 6.30 Hrs of 07/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	22/02/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
IPP	Dhariwal	300	05/02/2023	00:00		Continued.	Annual Overhaul	22/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/02/2023
IPP	JSW (J) U3	300	28/01/2023	06:38		Continued.	Non availability of load schedule	
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24		Continued.	NASHIK TPS U#4 TOLLING FROM DATED 02.02.2023 at 03.43 A.M	
MSPGCL	Koradi Unit-10	660	06/02/2023	05:05	06/02/2023	16:49	Flame Failure	
MSPGCL	Nasik Unit 5	210	06/02/2023	16:55		Continued.	Boiler Tube Leakage	09/02/2023
MSPGCL	Chandrapur Unit 9	500	07/02/2023	00:26		Continued.	Boiler Tube Leakage	09/02/2023
MSPGCL	Khaparkheda Unit 4	210	07/02/2023	09:56		Continued.	Boiler Tube Leakage	10/02/2023
MSPGCL	Koyna Unit 1	70	07/02/2023	15:30	07/02/2023	16:05	Due to Bus Section 1 tripped on ABB Protection.	
MSPGCL	Koyna Unit 2	70	07/02/2023	15:30	07/02/2023	16:08	Due to Bus Section 1 tripped on ABB Protection.	
MSPGCL	Koyna Unit 3	70	07/02/2023	15:30	07/02/2023	16:15	Due to Bus Section 1 tripped on ABB Protection.	
MSPGCL	Koyna Unit 4	70	07/02/2023	15:30	07/02/2023	17:25	Due to Bus Section 1 tripped on ABB Protection.	
MSPGCL	Uran Unit 6	108	07/02/2023	16:25		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	07/02/2023	21:58		Continued.	Bottom Ash Problem	10/02/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 06/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 07/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Tripping							
Tie bay (705) of Ektuni ckt - 1 & Koradi - 3 ckt - 1 @ Akola - 2	IntraState	06/02/2023	09:17	07/02/2023	14:09	PO	CB Mechanism checking by OEM
400 KV TIEBAY Outages/Tripping							
TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	IntraState	02/02/2023	17:54	06/02/2023	13:32	PO	For servicing & overhauling of 400KV AREVA make STN-4A Tie C.B. Mechanism
400 KV MAINBAY Outages/Tripping							
MAIN BAY- 404 OF 400/220/33 KV 501 MVA ICT - 2 @ LAMBOTI	IntraState	06/02/2023	10:23	06/02/2023	18:20	PO	Overhauling/servicing of 404-52 CB
MAIN BAY (419) OF STATION TF 4B@ DEEPNAGAR	IntraState	06/02/2023	15:01			PO	For servicing & overhauling of 400KV AREVA make STN-4B Main C.B. Mechanism
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
DEEPNAGAR - THAPTI TANDA	IntraState	06/02/2023	06:28	06/02/2023	18:21	PO	For string replacement & Chemical Washing..
JAIGAD - KARAD CKT - 1	IntraState	06/02/2023	09:24	06/02/2023	17:39	PO	For CB & CT Diagnostic testing and routine maintenance work.
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	06/02/2023	09:46	06/02/2023	17:28	PO	(1) Reactor testing work. (2) Bay maintenance work.
MAIN BUS - 1 @ LAMBOTI	IntraState	06/02/2023	10:23	06/02/2023	18:53	PO	To remove IPS tube between 404-52 Bus Isolator and 404-52CB for overhauling of 404-52 CB.
NAGOTHANE - DABHOL CKT - 2	IntraState	06/02/2023	14:07	06/02/2023	16:30	T	Tripped on Distance Protection.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	06/02/2023	14:47	06/02/2023	18:55	T	Tripped on Distance Protection.
JAIGAD - KARAD CKT - 2	IntraState	07/02/2023	09:12	07/02/2023	18:12	PO	For CT Diagnostic Testing & Routine maintenance work.
AKOLA - KHADKA (BHUSAWAL)	IntraState	07/02/2023	12:12	07/02/2023	18:35	PO	For String replacement work
PARLI-SOLAPUR (LAMBOTI)	IntraState	07/02/2023	12:14	07/02/2023	18:45	PO	String replacment work & Hardware Tightening & Fitting Work
NAGOTHANE - DABHOL CKT - 1	IntraState	07/02/2023	12:23	07/02/2023	20:49	EO	For emergency fixing of spacerS at loc. no. 304 & 305
400 KV ICT Outages/Tripping							
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	03/02/2023	12:46	06/02/2023	00:19	PO	for oil filtration, Dagonostic testing and maintenance work
500 MVA 400/220 KV ICT - 2 @ CHANDRAPUR 2	IntraState	06/02/2023	09:17	07/02/2023	17:41	PO	For diagnostic testing and maintenance work of 400/220/33KV ICT-II
400/220/33KV 315MVA ICT - 2 @ LONIKAND	IntraState	06/02/2023	09:25	07/02/2023	17:12	PO	O/H & Servicing of 29A PG Isolator and replacement of PGI mechanism box work done. Load shifted on TBC
105 MVA SPARE ICT @ CHAKAN	IntraState	06/02/2023	11:11	06/02/2023	18:54	PO	Annual testing and maintenance work
400/220/33 KV 500MVA ICT - 1 @ WARORA	IntraState	07/02/2023	11:14	07/02/2023	16:34	PO	Line CT, Sync CVT Tan delta, IR values & Routine maintenance and isolater maintenance work .
220 KV TBC Outages/Tripping							
BUS COUPLER @ MULUND	IntraState	07/02/2023	11:45			EO	CB Overhauling work due to SF6 gas leakage.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 06/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 07/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV MAINBAY Outages/Tripping							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	06/02/2023	08:30	06/02/2023	08:50	PO	For Breaker Control circuit remote operation fault checking and attending work.
220 KV LINE Outages/Tripping							
NIGADE- PETH LINE	IntraState	30/01/2023	12:32	06/02/2023	16:28	PO	For erection of new DXS tower at Loc. No. 81(220KV Karad-Mudshingi ckt) for 132KV Peth-Borgaon Line crossing & dismantling of existing D/C tower loc. No. 81 of old Karad - Mudshingi Ckt. 1 & 2 line.
PADGHE - TEMGHAR - 2	IntraState	04/02/2023	10:20	06/02/2023	00:55	HT	HT for Load management
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	04/02/2023	18:33			HT	For load management
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/02/2023	05:25			PO	1.Bunching at Loc No.329. 2.Erection - 4 Nos. Of Monopole and 1 No. Of Lattice Pole. 3.Stringing- 6 spans. 4.Dismantling - 3 Nos. Of lattice tower. 5.Destrining- 4 Spans
GHATGHAR - BAPGAON	IntraState	06/02/2023	05:41			PO	1.Bunching at Loc No.329. 2.Erection - 4 Nos. Of Monopole and 1 No. Of Lattice Pole. 3.Stringing- 6 spans. 4.Dismantling - 3 Nos. Of lattice tower. 5.Destrining- 4 Spans
BOISAR II - TARAPUR	IntraState	06/02/2023	10:32	07/02/2023	18:53	PO	Annual Maintenanceof the feeder equipments
KARAD -MUDSHINGI CKT 2-TAK	IntraState	06/02/2023	11:14	06/02/2023	15:04	PO	For reconnecting removed jumps at Loc No.76 & 83 after erection of new DXS tower near Loc No.81 without coss arm for making crossing arrangement of EHV lines.
KANDALGAON - BHIRA	IntraState	06/02/2023	13:45	06/02/2023	15:20	T	Tripped on Distance Protection.
KALMESHWAR-PANDHURNA	IntraState	06/02/2023	14:44	06/02/2023	15:26	T	Due to compressor problem.
KALMESHWAR-PANDHURNA	IntraState	06/02/2023	15:26	07/02/2023	15:14	HT	On TBC due to C.B problem at Kalmeshwar end.
MIRAJ - ICHALKARANJI	IntraState	07/02/2023	09:23	07/02/2023	18:25	PO	For cold line cleaning of line insulators
POPHALI - KDPH	IntraState	07/02/2023	09:50	07/02/2023	18:20	EO	For replacement of damaged conductor at loc no.6B Yph, 11B bottom phase.
TOPWORTH - Vile - bhagad	IntraState	07/02/2023	10:05			PO	Cold washing of insulator string, outage tree cutting work and other line maintenance work
MAIN BUS - 1 @ VERSOVA	IntraState	07/02/2023	10:11	07/02/2023	17:52	PO	Annual Maintenance of Main Bus 1, Bus side isolator along with Bus Coupler.
BELEWADI - MUMEWADI LINE	IntraState	07/02/2023	10:47	07/02/2023	16:19	PO	For Quarterly & Annualy Maintenance of Bay Equipments
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	07/02/2023	10:48	07/02/2023	18:45	PO	cold line Insulators cleaning & Tree pruning.
PADGHE - NALASOPARA	IntraState	07/02/2023	14:27	07/02/2023	15:43	T	TRIPPED ON DISTANCE PROTECTION
MAIN BUS SECTION - 1 @ POPHALI	IntraState	07/02/2023	15:30	07/02/2023	16:00	T	TRIPPED DUE TO LBB OPERATED

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 07/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KANDALGAON - KOYNA (POPHALI)	IntraState	07/02/2023	15:30	07/02/2023	16:12	T	BUS SECTION -1TRIPPED DUE TO LBB OPERATED
POPHLI PEDHMBE LINE- 1	IntraState	07/02/2023	15:30	07/02/2023	16:00	T	BUS SECTION -1TRIPPED DUE TO LBB OPERATED
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/33 KV 50 MVA PTR - 7 @ WATHAR	IntraState	06/02/2023	10:10	06/02/2023	17:16	PO	Diagonstic testing work.
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	06/02/2023	10:16	06/02/2023	19:50	PO	Work of conversion of single to twin conductor from LV bushing to LV CT
220/33 kv 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	06/02/2023	10:21	06/02/2023	18:02	PO	Quarterly maintenance work.
220/132KV 100 MVA ICT NO 1 @ MAGARPATTA	IntraState	07/02/2023	09:50	07/02/2023	17:58	PO	Diagnostic Testing Work and routine maintenance.
220/33 KV 50 MVA PTR 2 @ KHARGHAR	IntraState	07/02/2023	10:05	07/02/2023	13:51	PO	For Diagnostic testing and Routine Maintenance work
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	07/02/2023	12:01	07/02/2023	15:43	EO	To attend red hot & HV-LV CB timing & CRM work
220/100 KV 200 MVA ICT 1 @ KOLSHET	IntraState	07/02/2023	12:45	07/02/2023	15:50	EO	Work for CTR operation, testing and is to be taken in service on priority. Agency has informed its availability for tomorrow.
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	07/02/2023	15:50	07/02/2023	17:59	PO	Work of conversion of single to twin conductor from LV bushing to LV CT
110 KV LINE Outages/Trippings							
BHIRA (T) - DAVDI	IntraState	06/02/2023	10:15	06/02/2023	17:58	PO	Routine Maintenance, Structure painting & Testing work
WAGHIVALI - MANKHURD	IntraState	06/02/2023	14:56	06/02/2023	15:15	EO	Removal of bird nest of A-Phase from tower no 73

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage