

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Mar/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	172.065	1046.432	1) Gujrat	2.121	23.627
2) Hydro	7.724	59.338	2) Madhya Pradesh	3.794	20.497
3) Gas	2.307	25.823	3) Chattisgarh	3.540	21.930
Total MSPGCL	182.096	1131.593	4) Maharashtra	163.646	1003.955
B) 1) APLM	69.725	394.574	5) Goa (Amona)	-1.644	-6.831
2) JSWEL	25.772	155.815	Total	171.457	1063.178
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.849	172.761
4) RPL(AMT)	30.506	186.448	b) Mumbai Drawl	37.056	222.655
5) SWPGPL	10.874	60.616	c) MSEDCL Bilateral *	87.962	526.900
6) Other IPP	43.668	269.466	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.849	172.761
C) 1) TPCL Thermal	10.946	68.928	Include PX	0.000	0.000
2) TPCL Hydro	3.429	17.849	Standby	0.000	0.000
3) TPCL Gas	1.858	15.105	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.035	68.649	1) MSEDCL	511.509	3130.900
D) STATE			2) Mumbai Discoms	64.324	393.186
1) Thermal	374.591	2250.928	3) Other Discoms	9.983	60.367
(A1+C1+C4+(B1-B6))			TOTAL STATE	585.816	3584.453
2) Hydro	11.153	77.187			
(A2+C2)					
3) Gas	4.165	40.928			
(A3+B7+C3)					
4) Wind	12.380	72.310			
6) SOLAR	12.070	79.922			
TOTAL STATE	414.359	2521.275			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7754	7411	7382	5470
MSPGCL Hydro	225	320	240	215
MSPGCL Gas	88	95	91	158
MSPGCL Total Generation	8067	7826	7713	5843
Central Sector Receipt	8953	9274	6345	4891
WIND	290	237	587	888
CPP / IPP Thermal	7787	7592	7785	7465
CPP / IPP Gas	0	0	0	0
SOLAR	1773	1862	5	0
Exchange with Mumbai	-1982	-1915	-1658	-1369
MSEDCL DEMAND MET	24447	24429	20308	17308
Load Shedding	0	0	0	0
MSEDCL DEMAND	24447	24429	20308	17308
TPCL GENERATION	734	766	810	584
AEML GENERATION	484	497	437	455
MUMBAI DEMAND	3200	3178	2905	2408
OTHER DISCOM DEMAND	441	447	469	410
STATE DEMAND MET	28088	28054	23682	20126
STATE DEMAND	28088	28054	23682	20126
Frequency (Hz)	49.98	49.98	50.09	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.38 Hz at 18:02 Hrs	49.76 Hz at 22:22 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.61	28.90	210	135
Unit 8	12.19	83.59	549	371
Unit 9	13.30	83.00	620	389
Unit 10	12.98	77.44	610	390
Total	43.08	272.94		
Bhusawal				
Unit 3	3.28	20.72	160	115
Unit 4	10.28	61.06	475	280
Unit 5	11.14	66.49	500	275
Total	24.69	148.27		
Parli				
Unit 6	4.81	28.88	250	146
Unit 7	4.45	29.02	245	144
Unit 8	3.67	20.60	174	131
Total	12.93	78.50		
Chandrapur				
Unit 3	3.80	22.75	178	125
Unit 4	3.38	19.92	153	122
Unit 5	4.38	4.38	340	0
Unit 6	8.38	54.42	390	290
Unit 7	8.87	50.98	427	290
Unit 8	10.87	70.01	500	272
Unit 9	11.03	69.06	500	320
Total	50.71	291.53		
Paras				
Unit 3	4.98	29.89	228	147
Unit 4	5.13	32.61	234	167
Total	10.11	62.50		
Khaparkheda				
Unit 1	2.44	17.23	115	90
Unit 2	3.33	19.15	149	121
Unit 3	3.99	24.37	182	130
Unit 4	3.75	23.91	181	127
Unit 5	10.04	64.36	475	276
Total	23.56	149.01		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.52	22.00	177	118
Unit 5	3.46	21.69	176	113
Total	6.98	43.70		
Uran				
All Units	2.31	25.82	158	76
Total	2.31	25.82		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	0.96	40	0
Total	0.13	0.96		
Koyna				
Stage 1-2	2.13	15.21	360	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.80	12.99	241	0
Stage 3	0.74	5.91	160	0
Total	3.67	34.10		
Hydro				
KDPH	0.86	4.74	36	36
VTRNA	0.97	5.88	60	0
TILLARI	0.00	0.29	0	0
BHIRA T.R.	0.12	0.90	40	0
SMLHY_PTN	1.97	12.46	85	79
GHATGHAR	0.00	0.00	0	0
Total	3.92	24.27		
Wind				
Total	12.38	72.31	0	0
Total	12.38	72.31		
CPP				
APML(Mus)	69.72	394.57	0	0
JSWEL(Mus)	25.77	155.82	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.51	186.45	0	0
SWPGPL-Mus	10.87	60.62	0	0
Dhariwal	6.14	37.47	292	227
IEPL	5.73	34.27	267	172
Other(Mus)	31.80	197.72	0	0
Total	180.54	1066.92		
SOLAR				
Total	12.07	79.92	0	0
Total	12.07	79.92		
Tata				
Trombay 5	7.28	45.16	396	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.96	9.09	54	35
Trombay 7B	0.89	6.01	47	34
TATA Hydro	3.43	17.85	341	13
Trombay 8	3.66	23.77	223	132
Total	16.23	101.88		
AEML				
DTPS U-1&2	11.04	68.65	497	372
Total	11.04	68.65		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	172.06	1046.43	MSPGCL Total	182.10	1131.59
			MSPGCL Thml+Gas	174.37	1072.26	Koyna 1,2 & 4 Total	2.93	28.20
			MSPGCL Hydro	7.72	59.34	State Total	414.36	2521.28

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7417	192	97	7706	452	7246	0	0	6660	6537	-1417	20162	0	20162	2480	362	23004	49.99
2	7451	157	97	7705	352	7184	0	0	6724	6667	-1308	20277	0	20277	2311	323	22911	50.00
3	7259	155	98	7512	414	7167	0	0	6664	6550	-1223	20104	0	20104	2177	316	22597	50.02
4	7325	161	98	7584	518	7147	0	0	6616	6016	-1142	19812	0	19812	2083	311	22206	50.03
5	7341	160	98	7599	636	7182	0	0	6715	6425	-1100	20403	0	20403	2062	339	22804	50.02
6	7401	190	97	7688	755	7314	0	0	6716	6375	-1074	20687	0	20687	2150	371	23208	50.01
7	7563	428	98	8089	901	7496	0	23	6518	6440	-1056	21509	0	21509	2259	384	24152	50.01
8	7616	673	96	8385	787	7481	0	224	6638	6785	-1105	22140	0	22140	2402	417	24959	50.04
9	7567	456	97	8120	524	7497	0	642	7525	7897	-1516	22722	0	22722	2655	442	25819	50.06
10	7584	612	93	8289	363	7651	0	1067	7604	7940	-1563	23302	0	23302	2933	445	26680	50.02
11	7695	623	91	8409	341	7895	0	1476	8330	8609	-1810	24467	0	24467	3130	453	28050	50.01
12	7754	225	88	8067	290	7787	0	1773	9093	8953	-1982	24447	0	24447	3200	441	28088	49.98
13	7411	320	95	7826	237	7592	0	1862	9043	9274	-1915	24429	0	24429	3178	447	28054	49.98
14	7401	248	76	7725	230	7586	0	1764	8902	8822	-1873	23798	0	23798	3082	456	27336	50.00
15	7702	413	86	8201	188	7632	0	1397	9164	9391	-2118	24244	0	24244	3145	447	27836	49.95
16	7760	556	86	8402	235	7788	0	1070	9185	9020	-2167	23884	0	23884	3228	464	27576	50.02
17	7923	462	88	8473	410	7894	0	582	8149	8245	-2056	23075	0	23075	3164	473	26712	50.14
18	7782	332	89	8203	465	7718	0	185	8325	7235	-1830	21493	0	21493	3042	483	25018	50.11
19	7382	240	91	7713	587	7785	0	5	7089	6345	-1658	20308	0	20308	2905	469	23682	50.09
20	6349	240	90	6679	664	7678	0	0	6936	6509	-1523	19553	0	19553	2800	454	22807	50.02
21	5853	215	91	6159	620	7732	0	0	6344	5778	-1476	18377	0	18377	2627	436	21440	50.04
22	5538	215	95	5848	724	7484	0	0	5997	5461	-1384	17706	0	17706	2488	427	20621	50.04
23	5521	235	114	5870	799	7144	0	0	5918	5293	-1391	17302	0	17302	2415	413	20130	49.91
24	5470	215	158	5843	888	7465	0	0	5799	4891	-1369	17308	0	17308	2408	410	20126	49.96
MUs	172.06	7.72	2.31	182.10	12.38	180.55	0.00	12.07	176.65	171.46	-37.06	511.51	0.00	511.51	64.32	9.98	585.82	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 06/Mar/2023

Position as on 6.30 Hrs of 07/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05	06/03/2023	08:04	Boiler validity work	06/03/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	boiler tube leakage (under tooling from dtd-27.2.2023 @ 16:00 hrs	
IPP	Adani U-4	660	02/03/2023	00:00	06/03/2023	08:18	APH-A Hot PA bellow leakage	06/03/2023
MSPGCL	Uran Unit 8	108	04/03/2023	23:58	06/03/2023	21:42	Maintenance work	06/03/2023
MSPGCL	Uran Unit B0	120	04/03/2023	23:58	07/03/2023	04:15	Maintenance work	06/03/2023
MSPGCL	Uran Unit B0	120	07/03/2023	17:37	07/03/2023	21:31	NDE Bearing Vibrations High.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 06/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BR Outages/Tripping							
BUS REACTOR (240 MVar) @ AKOLA 2	IntraState	06/03/2023	11:23	06/03/2023	17:36	T	System under voltage.
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	07/03/2023	18:32		Continued.	EO	For Replacement of 3 nos fan in Pole-2 R-ph and 1 nos fan in Pole-2 B-ph and 4 nos MCB replacement work.
400 KV LR Outages/Tripping							
400KV AKOLA-BHUSAWAL (Bhusawal end)	IntraState	06/03/2023	19:28		Continued.	T	Tripped from Akola end only. AR success at Khadka end
400 KV LINE Outages/Tripping							
LONIKAND I - TALEGAON (PGCIL)	InterState	05/03/2023	18:45	06/03/2023	01:04	PO	Bay ISO Copper contact cleaning work and Relay Testing Works.
DHULE - SSNNL CKT - 2	InterState	06/03/2023	19:55	06/03/2023	20:28	T	Tripped at ssnl.
CHAKAN - TALEGAON(PG)	InterState	06/03/2023	22:35	07/03/2023	06:27	EO	Since 09.02.2022 no maintenance carried out on 400 kV Chakan-Talegaon(PGCIL) line due to non receipt of approval from LD Kalwa. It is very critical and important source line to feed power to Chakan MIDC and Pune ring main. To have reliable service of line following very important maintenance activities need to be carried. 1. Chemical washing of insulator strings from loc. no. 1A, 1-53. 2. PID detected insulator strings replacement at loc. no. 12 B phase Cut point, Loc. no. 21 Y phase SSN, loc. no. 24 Y phase SSN. 3. Spacers installation. 4. Diagnostic testing by testing unit Chakan, 5. Bay maintenance activities by maintenance unit Chakan.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
KHADKA-AURANGABAD (WALUJ)	IntraState	06/03/2023	19:23		Continued.	HT	For Overvoltage control
KARAD - TALANDGE CKT - 1	IntraState	07/03/2023	06:44	07/03/2023	10:31	EO	attending hot spot at R ph 29C PG Isolator IPS clamp towards CT side Temp-444 degree
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	IntraState	06/03/2023	17:49	07/03/2023	00:26	PO	1. C & tan delta testing of 33kV bushings 2. Annual Maintenance Work 3. PID faulty strings replacement work at 220kv side
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	06/03/2023	21:39	07/03/2023	00:32	T	OLTC Bucholz Protection
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	07/03/2023	08:53	07/03/2023	19:58	PO	1. The erection work 220kv D-type tower. 2. Ten delta of LV CT & routine maintenance work
220 KV LINE Outages/Tripping							
NALASOPARA - BOISAR PG	InterState	06/03/2023	03:25	06/03/2023	13:04	T	Tripped On Distance Protection.
NALASOPARA - BOISAR PG	InterState	07/03/2023	06:54	07/03/2023	11:29	EO	Replacement of Broken Disc Insulator String at Loc No.140 B-Ph Nalasopara side.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
APTA - KALWA	IntraState	02/03/2023	21:01	06/03/2023	23:11	EO	Shifting of Kalwa-Apta line from TBC to own CB at Kalwa end. 220kV Kalwa Panchanand Line (under outage) differential relay will be tested by testing team in co-ordination with 220kV TBC. 220KV Kalwa-Panchanand line will be shifted on TBC after outage of Project Dn.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	05/03/2023	08:39	06/03/2023	00:21	HT	For load management
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
PADGHE - NALASOPARA	IntraState	06/03/2023	03:25	06/03/2023	04:43	T	Tripped on Backup Protection at Padghe and Vasai Ss.
SADAWAGHAPUR KARAD CKT 1	IntraState	06/03/2023	08:59	06/03/2023	18:46	PO	Cold washing of insulator
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/03/2023	09:34	07/03/2023	15:54	HT	For load management
TALANDGE - ICHALKARANJI 2	IntraState	06/03/2023	09:36	06/03/2023	12:05	EO	For attending hot spots at T.L No 40 Rph -109C, T.L No 42 Ybh 90C, T.L No 24 Bph- 70C
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	06/03/2023	10:43	06/03/2023	16:59	PO	Annual Diagnostic Testing Work
ALEPHATA-PARGAON(KATHAPUR)	IntraState	06/03/2023	10:55	06/03/2023	18:25	HT	For load management
GHATODI-NANDED	IntraState	06/03/2023	12:30	06/03/2023	15:34	HT	Flash over disc Replacement work at location no. 92 b- phase.
BOISAR II - BOISAR (PG) CKT - 3	IntraState	06/03/2023	13:12	06/03/2023	13:44	T	CB TRIPPED AT BOISER MSETCL END.
BOISAR II - BOISAR (PG) CKT - 3	IntraState	06/03/2023	13:46	06/03/2023	18:05	T	Again CB tripped at Boiser MSETCL end
KARAD - VITA CKT- 1	IntraState	06/03/2023	13:49	06/03/2023	17:26	PO	CB timing & CRM measurement & Quarterly Maint work
CHAKAN -BRIDGESTONE	IntraState	06/03/2023	15:51	06/03/2023	14:46	PO	Diagnostic testing (CRM) work .
MAIN BUS - 2 @ TALANDGE	IntraState	06/03/2023	16:30	07/03/2023	00:54	PO	1. PID faulty string replacement work of 220 kV ICT 1 critical gantry. 2. PID faulty string replacement work of various bays. 3. Annual maintenance of Bus and Bus isolator
KALWA - PANCHANAND	IntraState	06/03/2023	16:47	06/03/2023	23:04	EO	For taking Trip trail of own CB due to relay replacement.
PARGAON(KATHAPUR)-LONIKAND	IntraState	06/03/2023	19:57	07/03/2023	01:24	T	Tripped on Distance Protection.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 06/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GHATGHAR - BAPGAON	IntraState	06/03/2023	22:48	07/03/2023	04:05	T	Tripped on Distance Protection.
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	06/03/2023	22:57	07/03/2023	06:57	T	Distance Protection
GHATODI-NANDED	IntraState	07/03/2023	01:10	07/03/2023	16:15	T	Distance Protection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	07/03/2023	06:15	07/03/2023	08:05	EO	Emergency outage is required on 220 kV AKP-Nashik line to replace burst pilot insulator string of bottom ph at loc no. 401.
EKLAHARE (GCR) - GHATGHAR	IntraState	07/03/2023	09:50	07/03/2023	18:53	PO	For flashover insulator replacement and cold washing work.
PETH- MUDSHINGI 1 LINE	IntraState	07/03/2023	10:09	07/03/2023	14:41	PO	Rph CT replacement work and Quarterly maint work
PETH- MUDSHINGI 1 LINE	IntraState	07/03/2023	10:09	07/03/2023	14:41	PO	Quarterly maintenance work & R Ph CT Oil leakage attending work.
GHATGHAR - BAPGAON	IntraState	07/03/2023	10:25	07/03/2023	19:45	PO	For flashover insulator replacement and cold washing work.
SADAWAGHAPUR KARAD CKT 1	IntraState	07/03/2023	10:39	07/03/2023	18:45	PO	Cold washing of insulator
CTRLS - NET MAGIC GIS	IntraState	07/03/2023	12:43			T	Distance Protection.
BORIVALI - CTRLS CKT	IntraState	07/03/2023	12:43	07/03/2023	13:37	T	Y-ph trip
CHIKHALI-JALNA II	IntraState	07/03/2023	16:03	07/03/2023	20:19	HT	In view of Akola ICT 2 outage
CHIKHALI-JALNA I	IntraState	07/03/2023	16:03	07/03/2023	20:19	HT	In view of Akola ICT 2 outage
PARGAON(KATHAPUR)-LONIKAND	IntraState	07/03/2023	23:52		Continued.	T	Line tripped on R-ph-Earth, Kathapur end, 3.9 k Amp, String Flash over at Loc no-3
220 KV ICT Outages/Tripping							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	06/03/2023	08:02	06/03/2023	09:31	EO	Air release of ICT -1 after 04 days outage (02.03.2023 to 05.03.2023)
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	06/03/2023	10:32	06/03/2023	17:29	PO	for inspection of nitrogen injection fire protction system (sergi make)
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	06/03/2023	12:58	06/03/2023	13:41	PO	Diagnostic testing (CRM) work .
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	06/03/2023	14:00	06/03/2023	14:56	PO	Diagnostic testing (CRM) work .
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	06/03/2023	16:58	06/03/2023	17:41	PO	Diagnostic testing (CRM) work .
132 KV LINE Outages/Tripping							
132 KV DEEPNAGAR - SUPREME CKT	IntraState	06/03/2023	00:50	06/03/2023	01:27	T	Tripped on b/u protection at supreme only.
132KV WARUD-WARUD(220KV)BENODA CKT	IntraState	06/03/2023	13:07	06/03/2023	16:56	HT	1) for replacement of backup relay 2) flash over disc replacement at l.no.250 (y) phase.
110 KV LINE Outages/Tripping							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
100 KV LINE Outages/Tripping							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHAHAPUR - BHATSA	IntraState	05/03/2023	14:24			PO	1. Restoration of the line from ERS system to newly erected tower between Pillar No.10-1 1.of 100KV Bhatsa-Shahapur @Ch.No.667 +197 2) Shifting of the line to ERS system on 100KV Bhatsa - Salambe (Phutali) between Pillar No. 19-20.LILO line @ Ch.No 667+298.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage