

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Mar/2024 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.087	951.432	1) Gujrat	2.572	28.617
2) Hydro	7.319	41.319	2) Madhya Pradesh	14.163	73.083
3) Gas	7.124	39.451	3) Chattisgarh	5.960	25.630
Total MSPGCL	165.530	1032.202	4) Maharashtra	174.796	1029.306
B) 1) APLM	57.410	324.705	5) Goa (Amona)	-1.788	-11.968
2) JSWEL	25.612	149.454	Total	195.703	1144.668
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.098	179.273
4) RPL(AMT)	31.231	185.606	b) Mumbai Drawl	30.982	200.332
5) SWPGPL	10.910	71.404	c) MSEDCL Bilateral *	104.223	613.617
6) Other IPP	46.449	281.316	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.098	179.273
C) 1) TPCL Thermal	10.777	64.078	Include PX	0.000	0.000
2) TPCL Hydro	3.540	19.184	Standby	0.000	0.000
3) TPCL Gas	3.793	21.070	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.385	49.509	1) MSEDCL	522.783	3110.064
D) STATE			2) Mumbai Discoms	57.477	354.169
1) Thermal	341.861	2077.504	3) Other Discoms	10.945	64.440
(A1+C1+C4+(B1-B6))			TOTAL STATE	591.205	3528.673
2) Hydro (A2+C2)	10.859	60.503			
3) Gas (A3+B7+C3)	10.917	60.521			
4) Wind	14.530	84.393			
6) SOLAR	17.335	101.088			
TOTAL STATE	395.502	2384.009			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5938	5741	7253	6309
MSPGCL Hydro	553	335	499	185
MSPGCL Gas	292	280	292	308
MSPGCL Total Generation	6783	6356	8044	6802
Central Sector Receipt	9910	9385	7347	6872
WIND	127	407	1081	476
CPP / IPP Thermal	7099	6808	7924	7200
CPP / IPP Gas	0	0	0	0
SOLAR	2103	2385	3	0
Exchange with Mumbai	-1775	-1860	-1387	-877
MSEDCL DEMAND MET	23775	22979	22530	20100
Load Shedding	0	0	0	0
MSEDCL DEMAND	23775	22979	22530	20100
TPCL GENERATION	797	718	979	612
AEML GENERATION	316	326	354	310
MUMBAI DEMAND	2888	2904	2720	1799
OTHER DISCOM DEMAND	471	502	482	373
STATE DEMAND MET	27135	26385	25732	22272
STATE DEMAND	27135	26385	25732	22272
Frequency (Hz)	50.01	49.95	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 15:03 Hrs	49.73 Hz at 09:05 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.18	25.20	185	130
Unit 8	14.34	84.32	660	463
Unit 9	12.51	74.29	567	457
Unit 10	11.27	73.73	480	433
Total	42.30	257.54		
Bhusawal				
Unit 3	3.21	17.92	185	120
Unit 4	9.22	51.65	500	285
Unit 5	9.79	51.24	500	285
Total	22.22	120.81		
Parli				
Unit 6	3.65	21.62	238	144
Unit 7	3.60	21.43	223	133
Unit 8	3.68	21.44	236	140
Total	10.93	64.50		
Chandrapur				
Unit 3	3.08	18.24	151	113
Unit 4	3.17	18.70	166	120
Unit 5	7.59	43.79	440	275
Unit 6	7.38	43.52	420	271
Unit 7	7.83	44.88	457	286
Unit 8	9.14	51.05	425	280
Unit 9	10.15	44.56	496	284
Total	48.34	264.74		
Paras				
Unit 3	5.46	32.14	242	171
Unit 4	5.85	33.26	254	161
Total	11.31	65.40		
Khaparkheda				
Unit 1	2.76	20.86	145	90
Unit 2	2.92	22.56	152	100
Unit 3	3.38	21.90	149	128
Unit 4	3.32	23.42	145	130
Unit 5	0.00	54.04	0	0
Total	12.38	142.78		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.61	19.98	179	123
Unit 5	0.00	15.68	0	0
Total	3.61	35.66		
Uran				
All Units	7.12	39.45	310	280
Total	7.12	39.45		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	0.38	23	0
Total	0.04	0.38		
Koyna				
Stage 1-2	1.32	8.58	170	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.50	2.97	202	0
Stage 3	0.48	2.69	150	0
Total	2.29	14.24		
Hydro				
KDPH	0.86	5.18	36	36
VTRNA	0.69	3.85	60	0
TILLARI	0.27	2.73	63	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.60	14.00	115	101
GHATGHAR	0.57	0.94	125	0
Total	4.99	26.70		
Wind				
Total	14.53	84.39	0	0
Total	14.53	84.39		
CPP				
APML(Mus)	57.41	324.70	0	0
JSWEL(Mus)	25.61	149.45	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.23	185.61	0	0
SWPGPL-Mus	10.91	71.40	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.88	34.56	259	206
Other(Mus)	36.45	222.12	0	0
JPL	4.11	24.64	199	145
Total	171.61	1012.48		
SOLAR				
Total	17.34	101.09	0	0
Total	17.34	101.09		
Tata				
Trombay 5	7.18	42.78	375	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.34	12.80	108	39
Trombay 7B	1.45	8.27	65	36
TATA Hydro	3.54	19.18	375	24
Trombay 8	3.60	21.30	201	132
Total	18.11	104.33		
AEML				
DTPS U-1&2	8.38	49.51	476	285
Total	8.38	49.51		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.09	951.43	MSPGCL Total	165.53	1032.20
			MSPGCL Thml+Gas	158.21	990.88	Koyna 1,2 & 4 Total	1.82	11.55
			MSPGCL Hydro	7.32	41.32	State Total	395.50	2384.01

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5967	187	305	6459	428	7174	0	0	7350	7387	-938	20114	0	0	20114	1919	396	22429	49.98
2	6309	185	308	6802	476	7200	0	0	7139	6872	-877	20100	0	0	20100	1799	373	22272	49.99
3	6345	183	307	6835	550	7177	0	0	7106	7083	-787	20492	0	0	20492	1711	366	22569	49.97
4	6276	190	309	6775	577	7134	0	0	7114	7088	-768	20427	0	0	20427	1668	378	22474	49.99
5	6313	179	309	6801	673	7186	0	0	7347	7276	-787	20745	0	0	20745	1690	404	22839	49.96
6	6607	227	310	7144	626	7220	0	0	7863	7963	-852	21697	0	0	21697	1803	404	23904	49.92
7	7061	469	309	7839	493	7439	0	7	8121	8169	-766	22755	0	2	22755	2006	426	25187	49.99
8	7212	374	310	7896	328	7763	0	289	8219	8310	-955	23183	0	2	23183	2210	448	25841	50.01
9	6643	304	306	7253	141	7363	0	956	8832	9053	-1138	23154	0	0	23154	2506	474	26134	49.94
10	6116	361	295	6772	121	7176	0	1624	9553	9744	-1524	23438	0	3	23438	2737	474	26650	49.92
11	5938	553	292	6783	127	7099	0	2103	10143	9910	-1775	23775	0	92	23775	2888	471	27135	50.01
12	5883	576	287	6746	226	7081	0	2342	9855	9571	-1814	23674	0	80	23674	2942	478	27094	50.00
13	5741	335	280	6356	407	6808	0	2385	9582	9385	-1860	22979	0	19	22979	2904	502	26385	49.95
14	5625	253	285	6163	772	6669	0	2349	9122	8718	-1837	22358	0	17	22358	2769	476	25603	50.07
15	5352	251	282	5885	994	6444	0	2073	9336	9236	-1850	22278	0	20	22278	2790	504	25572	50.02
16	5746	237	280	6263	983	6616	0	1644	9154	8897	-1745	22148	0	11	22148	2824	511	25482	50.03
17	5819	256	286	6361	803	6885	0	1072	9033	8846	-1641	21832	0	10	21832	2805	494	25131	50.01
18	6275	286	286	6847	741	7055	0	442	8590	8213	-1563	21233	0	5	21233	2748	502	24483	50.04
19	6903	402	291	7596	905	7355	0	46	7896	7864	-1462	21795	0	0	21795	2701	510	25005	50.01
20	7253	499	292	8044	1081	7924	0	3	7846	7347	-1387	22530	0	0	22530	2720	482	25732	50.03
21	6336	311	296	6943	1029	7455	0	0	7693	7429	-1256	21118	0	0	21118	2576	482	24176	50.01
22	6430	280	298	7008	811	7123	0	0	7262	7216	-1155	20525	0	0	20525	2402	478	23405	49.98
23	6557	191	300	7048	617	7166	0	0	7492	7061	-1162	20264	0	0	20264	2245	467	22975	49.93
24	6380	230	301	6911	621	7099	0	0	7443	7065	-1083	20171	0	0	20171	2114	442	22727	49.93
MUs	151.09	7.32	7.12	165.53	14.53	171.61	0.00	17.34	199.09	195.70	-30.98	522.78	0.00	0.26	522.78	57.48	10.94	591.21	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

132kV BBLR-rahuri line overload

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Mar/2024

Position as on 6.30 Hrs of 07/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	08/03/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Khaparkheda Unit 5	500	05/03/2024	18:04	07/03/2024	08:54	Boiler Tube Leakage	08/03/2024
MSPGCL	Nasik Unit 5	210	05/03/2024	23:45		Continued.	For attending boiler feed pump common discharge header line leakage.	08/03/2024
MSPGCL	Parli Unit 8	250	07/03/2024	03:06		Continued.	Air heater problem	08/03/2024
Total Capacity MSPGCL		1188						
IPP								
IPP	SWPGPL U-1	135	06/03/2024	14:40		Continued.	Boiler Tube Leakage	08/03/2024
Total Capacity IPP		135						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1643						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Mar/2024

Position as on 6.30 Hrs of 07/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TBC @ PADGHE	IntraState	06/03/2024	12:01			PO	1. Replacement of CT with New ratio of 3000/1 Amp. 2. Diagnostic Testing work. 3. Bay Maintenance Work.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (406) OF FUTURE CKT @ KUDUS	IntraState	06/03/2024	10:16	06/03/2024	17:25	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV LINE Outages/Trippings							
CHAKAN - TALEGAON(PG)	InterState	07/03/2024	00:17	07/03/2024	05:15	PO	Cold line washing, replacement of PID detected strings
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar-Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
JAIGAD - NEW KOYNA CKT - 1	IntraState	05/03/2024	09:43	06/03/2024	13:54	PO	Diagnostic testing & Relay testing work , Routine maint. Work
CHANDRAPUR 2 - WARORA CKT-2	IntraState	06/03/2024	11:02	06/03/2024	20:14	PO	For Conductor and Earthwire Hardware Nutbolt tightening & Fitting work at various locations.
PARLI-SOLAPUR (LAMBOTI)	IntraState	06/03/2024	11:35	06/03/2024	18:32	PO	Cleaning and hardware tightening
KHADKA - BABLESHWAR	IntraState	06/03/2024	14:05	06/03/2024	16:31	T	Tripped on Distance protection.
JEJURI- KOYNA STAGE-IV	IntraState	06/03/2024	19:14	06/03/2024	19:57	T	Tripped on distance protection
DABHOL - NEW KOYNA CKT - 2	IntraState	07/03/2024	06:03			T	Tripped on Overvoltage
DABHOL - NEW KOYNA CKT - 1	IntraState	07/03/2024	06:03	07/03/2024	07:08	T	Distance Protection
NAGOTHANE - DABHOL CKT - 1	IntraState	07/03/2024	09:03			PO	for cold washing work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	IntraState	06/03/2024	07:32			PO	Diagnostic testing & allied bay maintenance work
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	06/03/2024	09:36	06/03/2024	16:58	HT	Capacitance and tan delta testing of bushing , winding , s fra, dfr testing and nifps system preventative maintenance works.
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	IntraState	06/03/2024	09:54	06/03/2024	17:55	PO	For attending oil leakage of HV side bushing of ICT unit

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	06/03/2024	10:24	06/03/2024	18:37	PO	1) Diagnostic Testing and routine maintenance work. 2) 220kV IV side Isolator overhauling work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	06/03/2024	10:43	06/03/2024	13:18	PO	For verification of dimensions of HV Neutral Bushing according to the drawing and capturing images of Bushing
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
400KV 125MVar BUS REACTOR @ 400KV KUMBHARGAON SS	IntraState	06/03/2024	10:55	06/03/2024	17:00	PO	Reactor Isolator 89R R-Phase alignment work.
220 KV TIEBAY Outages/Trippings							
TBC @ KARKAMB	IntraState	06/03/2024	11:50	06/03/2024	15:31	PO	Quarterly Maintenance.
220 KV MAINBAY Outages/Trippings							
220 KV BUS COUPLER	IntraState	06/03/2024	13:00	06/03/2024	15:54	HT	CT tan-delta testing.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
SADAWAGHAPUR KARAD CKT 1	IntraState	05/03/2024	07:03			PO	For replacement work of Main Distance Relay.
BABLESHWAR -BHENDA	IntraState	06/03/2024	08:26	06/03/2024	20:50	PO	Replacement of the disc insulator with porcelain long rod under scheme
KALMESHWAR-KALMESHWAR RLY TSS 2	IntraState	06/03/2024	11:16	06/03/2024	18:31	HT	1)diagnostic testing of bay equipments 2) line isolator and bus isolator overhauling and porcelian portion washing and cleaning 3) general maintenance.
LAMBOTI - KARKAMB	IntraState	06/03/2024	11:50	06/03/2024	19:43	PO	Cold line cleaning of Disc insulator from Loc No. 393 to 457 and replacement of faulty string.
PADEGAON-SAWANGI	IntraState	06/03/2024	12:29	06/03/2024	21:16	HT	Retrofitting work of back up relay at 220kv padegaon s/s.
AMRAPUR - TAPTITANDA CKT - 2	IntraState	06/03/2024	13:14	06/03/2024	15:15	PO	Outage is required to carry out Testing work of circuit breaker of 220 KV Amrapur-Thaptitanda line II by testing subdivision kedgaon(Ahmadnagar).
PARANDA - OSMANABAD	IntraState	06/03/2024	16:25	06/03/2024	20:14	HT	CT tan-delta testing.
TALANDGE - BIDRI	IntraState	06/03/2024	16:26	06/03/2024	19:22	T	Tripped on distance protection
MAHALAXMI - AMONA	IntraState	06/03/2024	17:14			T	Tripped on distance protection.
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	07/03/2024	01:45	07/03/2024	04:36	PO	METRO-4 PROJECT WORK IN VICINITY
WAGHIVALI - DHARAVI 7	IntraState	07/03/2024	01:45	07/03/2024	04:36	PO	METRO-4 PROJECT WORK IN VICINITY
POPHLI PEDHMBE LINE- 1	IntraState	07/03/2024	08:13			PO	For Bay P/M work
BABLESHWAR -BHENDA	IntraState	07/03/2024	08:14			PO	Replacement of the disc insulator with porcelain long rod under scheme
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 07/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	05/03/2024	07:40			PO	ICI 1 overhauling ,Testing ,CRP replacement of CPLR 1-2 ,ICT 1
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	06/03/2024	09:25	06/03/2024	19:02	PO	For Diagnostic testing work and CB pole overhauling work and CTR servicing work
220/132 KV 200 MVA ICT 2	IntraState	06/03/2024	11:17	06/03/2024	18:32	HT	Body inspection plate heavy oil leakage attend work by agency.
220 KV BUSBAR Outages/Trippings							
BUS-1@GIS BHANDUP	IntraState	06/03/2024	11:22			PO	F9 and F10 Bay Connection to Main Bus
220KV BUS BAR PROTECTION @ KALWAN (BHENDI)-220 KV	IntraState	06/03/2024	12:50	06/03/2024	18:10	PO	220kV Busbar scheme testing work by testing team.
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	06/03/2024	10:41	06/03/2024	17:57	PO	For earthwire replacement & other Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	06/02/2024	19:55	06/03/2024	00:31	PO	PROJECT WORK-Conductor replacement
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage