

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Apr/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	165.954	994.762	1) Gujrat	-4.137	-27.239
2) Hydro	43.808	196.297	2) Madhya Pradesh	10.552	65.410
3) Gas	4.379	36.485	3) Chattisgarh	4.610	30.800
Total MSPGCL	214.141	1227.544	4) Maharashtra	158.923	1003.694
B) 1) APML	76.410	449.632	5) Goa (Amona)	-1.728	-10.552
2) JSWEL	19.199	101.789	Total	168.220	1062.113
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.254	176.694
4) RPL(AMT)	31.805	176.311	b) Mumbai Drawl	33.124	194.669
5) SWPGPL	9.424	52.271			
6) Other IPP	35.579	211.405	c) MSEDCL Bilateral *	57.452	406.506
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	16.516	90.857	d) Mumbai Bilateral *	29.254	176.694
2) TPCL Hydro	4.170	15.814	Include PX	0.000	0.000
3) TPCL Gas	4.198	16.399	Standby	0.000	0.000
4) AEML Thermal	11.912	68.565			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	366.799	2145.592	1) MSEDCL	536.428	3167.424
2) Hydro (A2+C2)	47.978	212.111	2) Mumbai Discoms	69.920	386.307
3) Gas (A3+B7+C3)	8.577	52.884	3) Other Discoms	9.143	53.488
4) Wind	14.697	79.565			
6) SOLAR	9.220	54.951	TOTAL STATE	615.491	3607.219
TOTAL STATE	447.271	2545.103			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 7 Hrs
MSPGCL Thermal	6969	6948	6874	6954
MSPGCL Hydro	2041	2155	2214	1628
MSPGCL Gas	150	140	279	150
MSPGCL Total Generation	9160	9243	9367	8732
Central Sector Receipt	9012	9005	6267	6003
WIND	175	395	772	517
CPP / IPP Thermal	6791	6796	7142	7126
CPP / IPP Gas	0	0	0	0
SOLAR	1273	1080	0	25
Exchange with Mumbai	-1955	-1873	-1352	-993
MSEDCL DEMAND MET	24179	24378	21903	21172
Load Shedding	0	305	467	0
MSEDCL DEMAND	24179	24683	22370	21172
TPCL GENERATION	988	1017	1210	900
AEML GENERATION	481	490	501	493
MUMBAI DEMAND	3424	3380	3063	2386
OTHER DISCOM DEMAND	411	402	423	371
STATE DEMAND MET	28014	28160	25389	23929
STATE DEMAND	28014	28465	25856	23929
Frequency (Hz)	49.99	49.85	49.74	49.90

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 13:03 Hrs	49.58 Hz at 19:11 Hrs	49.88	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.66	16.12	205	185
Unit 7	0.00	0.00	0	0
Unit 8	12.93	81.73	560	461
Unit 9	13.07	80.21	570	513
Unit 10	9.47	57.86	442	350
Total	40.14	235.92		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.26	61.10	465	350
Unit 5	8.80	59.50	395	350
Total	18.06	120.60		
Parli				
Unit 6	0.00	21.75	0	0
Unit 7	4.29	21.95	205	126
Unit 8	3.46	20.86	157	133
Total	7.75	64.56		
Chandrapur				
Unit 3	4.59	27.05	194	188
Unit 4	4.10	24.41	175	155
Unit 5	9.27	53.03	390	370
Unit 6	9.44	30.81	409	373
Unit 7	9.08	51.68	425	318
Unit 8	10.46	61.01	457	415
Unit 9	9.42	60.23	421	377
Total	56.35	308.21		
Paras				
Unit 3	5.07	33.36	216	205
Unit 4	5.03	31.17	216	204
Total	10.10	64.53		
Khaparkheda				
Unit 1	3.48	20.12	155	130
Unit 2	3.47	20.64	150	130
Unit 3	4.17	24.53	192	140
Unit 4	4.10	24.49	187	139
Unit 5	10.03	65.67	450	400
Total	25.26	155.45		
Nasik				
Unit 3	4.29	21.13	196	140
Unit 4	4.01	24.34	189	124
Unit 5	0.00	0.00	0	0
Total	8.30	45.48		
Uran				
All Units	4.38	36.48	290	130
Total	4.38	36.48		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.08	0.73	23	0
Total	0.08	0.73		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	8.29	39.74	555	35
Stage 4	21.47	82.61	1015	245
Stage 3	6.06	26.29	320	80
Total	35.82	148.64		
Hydro				
KDPH	0.86	5.18	36	36
VTRNA	0.85	4.06	59	0
TILLARI	0.52	3.13	58	0
BHIRA T.R.	0.12	0.72	60	0
SMLHY_PTN	5.55	33.84	245	214
GHATGHAR	0.00	0.00	0	0
Total	7.91	46.93		
Wind				
Total	14.70	79.56	0	0
Total	14.70	79.56		
CPP				
APML(Mus)	76.41	449.63	0	0
JSWEL(Mus)	19.20	101.79	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.80	176.31	0	0
SWPGPL-Mus	9.42	52.27	0	0
Other(Mus)	35.58	211.40	0	0
Total	172.42	991.41		
SOLAR				
Total	9.22	54.95	0	0
Total	9.22	54.95		
Tata				
Trombay 5	11.00	61.97	481	433
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.64	9.41	114	104
Trombay 7B	1.55	6.99	66	62
TATA Hydro	4.17	15.81	382	28
Trombay 8	5.52	28.88	243	201
Total	24.88	123.07		
AEML				
DTPS U-1&2	11.91	68.56	502	481
Total	11.91	68.56		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	165.95	994.76	MSPGCL Total	214.14	1227.54
			MSPGCL Thml+Gas	170.33	1031.25	Koyna 1,2 & 4 Total	29.76	122.35
			MSPGCL Hydro	43.81	196.30	State Total	447.27	2545.10

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6912	2006	150	9068	857	7252	0	0	6576	6765	-1224	22382	11	22393	2779	336	25508	49.85
2	6887	2030	130	9047	909	7259	0	0	6445	6616	-1106	22410	12	22422	2565	315	25302	49.82
3	6901	2035	150	9086	837	7239	0	0	6178	6472	-971	22364	12	22376	2412	299	25087	49.95
4	6919	2021	150	9090	726	7251	0	0	6058	6525	-877	22421	12	22433	2290	294	25017	49.90
5	6918	2041	140	9099	596	7306	0	0	6020	6538	-843	22391	181	22572	2234	305	25111	49.86
6	6910	1963	140	9013	580	7296	0	0	6108	6244	-873	21919	242	22161	2324	341	24826	49.76
7	6954	1628	150	8732	517	7259	0	25	6241	6003	-993	21172	0	21172	2386	371	23929	49.90
8	7055	1344	150	8549	417	7299	0	245	6468	6695	-1048	21766	0	21766	2483	391	24640	49.99
9	7051	782	150	7983	260	7277	0	584	7068	7128	-1260	21560	0	21560	2756	412	24728	49.99
10	7033	1037	130	8200	214	7182	0	907	7970	8185	-1622	22642	0	22642	3057	424	26123	49.89
11	7030	1606	140	8776	216	6946	0	1118	8679	8947	-1778	23823	0	23823	3282	402	27507	49.99
12	6969	2041	150	9160	175	6925	0	1273	9065	9012	-1955	24179	0	24179	3424	411	28014	49.99
13	6945	1773	130	8848	226	6924	0	1279	9329	9176	-1925	24120	0	24120	3392	408	27920	49.99
14	6842	1921	140	8903	265	6925	0	1216	8921	8971	-1857	24009	0	24009	3326	414	27749	50.00
15	6948	2155	140	9243	395	6930	0	1080	8867	9005	-1873	24378	305	24683	3380	402	28465	49.85
16	6930	2047	143	9120	507	7091	0	815	8099	7940	-1755	23306	893	24199	3410	412	28021	49.85
17	6807	2067	171	9045	630	7208	0	480	7083	7312	-1604	22647	467	23114	3353	424	26891	49.79
18	6807	1652	266	8725	615	7219	0	176	6463	6162	-1597	20867	348	21215	3222	433	24870	49.95
19	6850	2008	269	9127	688	7246	0	22	5906	5836	-1425	21065	28	21093	3085	429	24607	49.89
20	6874	2214	279	9367	772	7272	0	0	5849	6267	-1352	21903	467	22370	3063	423	25856	49.74
21	6864	1645	280	8789	1065	7283	0	0	5652	5339	-1309	20767	506	21273	2989	400	24662	49.92
22	6847	1835	270	8952	1196	7281	0	0	5619	5567	-1252	21353	0	21353	2911	391	24655	49.74
23	6857	2090	290	9237	1118	7302	0	0	5819	5932	-1299	21925	93	22018	2893	365	25276	49.70
24	6844	1867	271	8982	916	7245	0	0	6060	5583	-1326	21061	304	21365	2904	339	24608	49.80
MUs	165.95	43.81	4.38	214.14	14.70	172.42	0.00	9.22	166.54	168.22	-33.12	536.43	3.88	540.31	69.92	9.14	619.37	49.88

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Apr/2022

Position as on 6.30 Hrs of 07/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25		Continued.	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	12/04/2022
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Bhusawal Unit 3	210	20/03/2022	07:00	07/04/2022	05:57	Coal Shortage	
MSPGCL	Nasik Unit 5	210	22/03/2022	23:40		Continued.	Withdrawn	
MSPGCL	Uran Unit B0	120	01/04/2022	19:02		Continued.	Filter Replacement work(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Uran Unit 8	108	01/04/2022	19:21		Continued.	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Parli Unit 6	250	05/04/2022	05:29	07/04/2022	06:35	Drum level low	
MSPGCL	Uran Unit 5	108	05/04/2022	13:47	06/04/2022	15:27	Gas shortage	
MSPGCL	Koyna Unit 4	70	06/04/2022	05:05	06/04/2022	10:15	T/F differential protection	
MSPGCL	Bhusawal Unit 3	210	07/04/2022	06:34	07/04/2022	08:09	Drum Level High	
MSPGCL	Koradi Unit-10	660	07/04/2022	08:08		Continued.	Condenser Cleaning work.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 701 OF 765/400kV 1500MVA ICT-1 @ KORADI 3	IntraState	06/04/2022	10:04	06/04/2022	19:40	PO	Annual Maintenance of Bay equipment
765 KV ICT Outages/Trippings							
TIE BAY - 709 OF 765/400kV ICT-1 @ EKTUNI	IntraState	06/04/2022	10:24	06/04/2022	19:08	PO	Diagnostic Testing of CB & Routine Maintenance
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	29/03/2022	13:28			T	HT FOR LOAD MANAGEMENT
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	02/04/2022	12:00		Continued.	T	TRIPPED ON DIST. PROTN
WARORA - IEPL	IntraState	06/04/2022	13:23	06/04/2022	19:45	PO	Routine Maintenance & Dignostic testing work.
NEW KOYNA - DABHOL CKT - 2	IntraState	07/04/2022	00:20	07/04/2022	00:56	T	Tripped at Dabhol end
PADGHE - NAGOTHANE CKT - 1	IntraState	07/04/2022	08:53	07/04/2022	20:43	PO	for jumper tightening and string replacement work
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	07/04/2022	11:18	07/04/2022	17:53	PO	PG Isolator overhauling work) Line maintenance work & replacement of PID faulty String
TBC @ KOLHAPUR(TALANDGE)	IntraState	07/04/2022	12:15	07/04/2022	14:45	PO	QM Work
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	07/04/2022	16:21	07/04/2022	22:11	T	Distance Protection
CHANDRAPUR-PARLI CKT-3	IntraState	07/04/2022	16:21		Continued.	T	Distance Protection
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	07/04/2022	17:48		Continued.	EO	The Rectification/ replacing work of jointing plate of cross arm of twin monopole for Samruddhi Mahamarg Crossing work.
400 KV ICT Outages/Trippings							
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	23/03/2022	10:14			EO	Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in iCT-I R ph unit
220 KV TBC Outages/Trippings							
TBC @ BIDRI	IntraState	07/04/2022	12:30	07/04/2022	14:27	PO	For PID testing Work
TBC @ AAREY	IntraState	07/04/2022	12:50	07/04/2022	17:21		For Annual maintenance of 189C side isolator during opportunity outage of Bay-1 i.e 220kV aarey Goregaon Line-1
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GOREGAON - AAREY CKT - 1	IntraState	31/03/2022	10:50		Continued.	PO	Under MMRC Line Diversion scheme for Metro-3 project, 220kV Outdoor termination at 220kV AEML Aarey and
AEML BORIVALI - TPC BORIVALI LINE	IntraState	31/03/2022	11:18	06/04/2022	02:35	PO	For shifting on 220 KV NEW GIS
TROMBAY - MULUND	IntraState	02/04/2022	08:58	06/04/2022	17:24	PO	For replacement of existing conductor by HTLS conductor in BARC area.
EKLAHARE (GCR) - GHATGHAR	IntraState	02/04/2022	12:29		Continued.	PO	Samruddhi Highway Monopole work, 13 No.s (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	02/04/2022	12:51		Continued.	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
KADEGAON-MIRAJ	IntraState	06/04/2022	09:33	06/04/2022	09:33	PO	Tower Painting work
IPCL - SPCL	IntraState	06/04/2022	09:40	07/04/2022	18:23	PO	CT TAN DELTA AND BAY MAINTENANCE
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	06/04/2022	10:35	06/04/2022	13:09	PO	An outage is required for Quarterly Maintenance
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	06/04/2022	10:51	06/04/2022	16:25	PO	An outage is required for Quarterly Maintenance
WARDHA (PG) - BADNERA	IntraState	06/04/2022	11:20	06/04/2022	14:08	PO	For Hot line Work, Replacement of Broken Disc , Shifting of auto reclose switch to non auto mode.
MAIN BUS - 1 @ SOUTH SOLAPUR	IntraState	06/04/2022	11:24	06/04/2022	17:19	PO	An outage is required for Quarterly Maintenance
MUMEWADI -HALKARNI 1 LINE	IntraState	06/04/2022	13:03	07/04/2022	16:42	PO	245kv CGL make CB overhauling work
GHATGHAR - BAPGAON	IntraState	06/04/2022	13:20	06/04/2022	16:04	T	O/C, E/F Optd.
GOREGAON - AAREY CKT - 2	IntraState	06/04/2022	22:51	07/04/2022	02:17	EO	Hot spot observed on B phase on Gantry near Pylon termination yard(Temp is above 100 degree.)
HINJEWADI 2 - PEGASUS	IntraState	06/04/2022	23:10	07/04/2022	03:51	EO	Pegasus substations ¿ Cable OET, LA & BPI connections to bus ¿ Releasing overhead line connections& Re-energising the cable on load.
TROMBAY - KALWA	IntraState	07/04/2022	09:00		Continued.	PO	Stringing of HTLS conductor from Loc no.76 to 220KV Trombay ss Gantry.
JEJURI-PHURSUNGI 2	IntraState	07/04/2022	11:25	07/04/2022	17:55	PO	1) Replacement of Disc insulators at L.N. 11 (R ph) due to flashover (SP). 2)Replacement of Disc insulators at L.N. 05 (Jejuri Side, R Ph) due to Disc Broken (CP).
LONAND-BARAMATI	IntraState	07/04/2022	11:27	07/04/2022	15:55	PO	REPL. OF FLASHOVER STRING AT LOC 71 B-PH
KARAD - VITA CKT- 1	IntraState	07/04/2022	14:56	07/04/2022	18:18	T	Distance Protection
PETH- MUDSHINGI 1 LINE	IntraState	07/04/2022	16:04	07/04/2022	20:14	EO	For repairing of damaged R & B ph conductor due to stone mine blasting at Loc no-164 to 165
CHINCHWAD-2 - TELCO	IntraState	07/04/2022	16:08	07/04/2022	23:39	PO	245kV CT replacement due to higher tab delta value and CT tan delta testing work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 06/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	25/03/2022	11:32		Continued.	PO	1.Retrofitting of 86M Relay, BO/BI LVCT/PT connection to BCU under MTAMC work. 2.Arresting oil leakage from Top cover of Body by replacing all gaskets at site by opening /dismantling of accessories & installation of DM of 50MVA BHEL make Tf. 3.After complete work oil filtration & vacuum cycle will be done by pursing/injecting N2 gas .
220 / 110 / 33kV 315 MVA ICT 6 @ CARNAC	IntraState	03/04/2022	11:00			PO	FOR SHIFTING ON NEW 110 KV GIS
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	04/04/2022	15:35	07/04/2022	17:35	PO	REPLACEMENT OF 29(A) BUS ISOLATOR
220/132KV 100 MVA ICT NO 1 @ MAGARPATTA	IntraState	06/04/2022	10:19	06/04/2022	18:23	PO	For installation of Qualitrol make online DGA Monitoring system
220/100 KV 100 MVA ICT 1 @ TALOJA	IntraState	06/04/2022	11:39	07/04/2022	18:43	PO	EMCO ICT Painting work
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	07/04/2022	09:10	07/04/2022	18:43	PO	1. Diagnostic Testing of ICT, HV & LV bays. 2. Routine Maintenance activities.
220/22 KV 50 MVA PTR 2 @ CHAKAN	IntraState	07/04/2022	11:02	07/04/2022	17:33	EO	For attending oil Leakage from Y phase CT of 220/22 KV 50 MVA Power transformer no. 2
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	07/04/2022	11:06	07/04/2022	17:30	PO	For replacement of faulty relays and alignment of 29D , 132kV Isolator
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	07/04/2022	11:50	07/04/2022	17:35	PO	LOW OIL LEVEL.AIR CELL COMMISSIONING WORK.
110 KV LINE Outages/Trippings							
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	07/04/2022	09:10	07/04/2022	17:44	PO	FOR BMC END WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage