

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Apr/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.003	932.512	1) Gujrat	-2.866	-13.139
2) Hydro	29.454	125.650	2) Madhya Pradesh	9.769	56.699
3) Gas	2.717	16.321	3) Chattisgarh	5.210	29.440
Total MSPGCL	192.174	1074.483	4) Maharashtra	188.344	1087.467
B) 1) APML	74.328	440.149	5) Goa (Amona)	-1.271	-7.428
2) JSWEL	24.472	135.361	Total	199.186	1153.039
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.178	189.356
4) RPL(AMT)	29.798	177.871	b) Mumbai Drawl	36.338	209.787
5) SWPGPL	9.314	70.230	c) MSEDCL Bilateral *	110.762	618.435
6) Other IPP	23.029	141.669	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.178	189.356
C) 1) TPCL Thermal	10.753	60.347	Include PX	0.000	0.000
2) TPCL Hydro	5.669	26.786	Standby	0.000	0.000
3) TPCL Gas	2.549	12.577	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.013	61.882	1) MSEDCL	533.149	3107.928
D) STATE			2) Mumbai Discoms	66.322	371.379
1) Thermal	342.710	2020.021	3) Other Discoms	10.332	60.781
(A1+C1+C4+(B1-B6))			TOTAL STATE	609.803	3540.088
2) Hydro	35.123	152.436			
(A2+C2)					
3) Gas	5.266	28.898			
(A3+B7+C3)					
4) Wind	12.997	86.532			
6) SOLAR	14.521	99.162			
TOTAL STATE	410.617	2387.049			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6711	6642	6772	6375
MSPGCL Hydro	432	1400	2006	1001
MSPGCL Gas	115	114	112	113
MSPGCL Total Generation	7258	8156	8890	7489
Central Sector Receipt	9786	9927	7098	7952
WIND	425	220	536	888
CPP / IPP Thermal	6697	6746	6645	6743
CPP / IPP Gas	0	0	0	0
SOLAR	1908	1171	0	0
Exchange with Mumbai	-1903	-2066	-1291	-1168
MSEDCL DEMAND MET	23695	23677	21397	21563
Load Shedding	0	0	0	0
MSEDCL DEMAND	23695	23677	21397	21563
TPCL GENERATION	797	726	1191	491
AEML GENERATION	476	483	485	447
MUMBAI DEMAND	3176	3275	2967	2106
OTHER DISCOM DEMAND	476	477	481	341
STATE DEMAND MET	27347	27429	24845	24010
STATE DEMAND	27347	27429	24845	24010
Frequency (Hz)	50.04	49.88	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 18.03 Hrs	49.7 Hz at 22.08 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.94	27.54	210	195
Unit 8	13.90	80.65	612	568
Unit 9	1.60	1.60	480	0
Unit 10	13.72	77.58	600	540
Total	34.17	187.37		
Bhusawal				
Unit 3	3.61	19.99	165	140
Unit 4	9.41	35.50	460	164
Unit 5	11.12	64.06	495	435
Total	24.14	119.55		
Parli				
Unit 6	5.72	29.69	250	132
Unit 7	5.72	29.10	245	227
Unit 8	4.19	22.69	191	133
Total	15.63	81.48		
Chandrapur				
Unit 3	4.00	22.76	170	140
Unit 4	3.44	20.34	150	140
Unit 5	9.60	53.22	410	390
Unit 6	9.44	51.89	405	380
Unit 7	10.00	55.83	430	386
Unit 8	11.57	64.03	492	466
Unit 9	0.00	51.25	0	0
Total	48.06	319.32		
Paras				
Unit 3	5.45	19.80	240	167
Unit 4	0.03	15.95	27	0
Total	5.48	35.75		
Khaparkheda				
Unit 1	2.94	17.18	135	115
Unit 2	2.46	11.17	114	90
Unit 3	4.34	25.11	187	178
Unit 4	4.14	24.82	192	150
Unit 5	10.84	65.45	500	425
Total	24.72	143.73		
Nasik				
Unit 3	4.05	23.62	178	157
Unit 4	0.00	0.00	0	0
Unit 5	3.75	21.70	170	135
Total	7.80	45.32		
Uran				
All Units	2.72	16.32	116	112
Total	2.72	16.32		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.17	0.91	43	0
Total	0.17	0.91		
Koyna				
Stage 1-2	6.76	29.06	520	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	14.25	53.78	1008	0
Stage 3	4.25	17.53	320	0
Total	25.26	100.37		
Hydro				
KDPH	0.86	5.18	36	36
VTRNA	1.10	7.06	61	0
TILLARI	0.00	1.82	0	0
BHIRA T.R.	0.30	1.44	80	0
SMLHY_PTN	1.77	8.86	76	69
GHATGHAR	0.00	0.00	0	0
Total	4.03	24.36		
Wind				
Total	13.00	86.53	0	0
Total	13.00	86.53		
CPP				
APML(Mus)	74.33	440.15	0	0
JSWEL(Mus)	24.47	135.36	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	29.80	177.87	0	0
SWPGPL-Mus	9.31	70.23	0	0
Dhariwal	6.14	34.86	272	236
IEPL	5.14	29.06	269	196
Other(Mus)	11.75	77.75	0	0
Total	160.94	965.28		
SOLAR				
Total	14.52	99.16	0	0
Total	14.52	99.16		
Tata				
Trombay 5	7.10	40.12	389	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.45	6.84	108	43
Trombay 7B	1.10	5.74	65	39
TATA Hydro	5.67	26.79	430	9
Trombay 8	3.65	20.22	213	129
Total	18.97	99.71		
AEML				
DTPS U-1&2	11.01	61.88	501	351
Total	11.01	61.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	160.00	932.51	MSPGCL Total	192.17	1074.48
			MSPGCL Thml+Gas	162.72	948.83	Koyna 1,2 & 4 Total	21.01	82.85
			MSPGCL Hydro	29.45	125.65	State Total	410.62	2387.05

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	6273	1836	112	8221	669	7039	0	0	7587	7655	-1188	21999	0	0	21999	2532	397	24928	50.02
2	6357	1494	113	7964	807	6749	0	0	7785	7713	-1202	21667	0	0	21667	2337	364	24368	50.03
3	6375	1001	113	7489	888	6743	0	0	7898	7952	-1168	21563	0	0	21563	2106	341	24010	49.98
4	6437	942	114	7493	899	6771	0	0	7597	7871	-1056	21645	0	0	21645	2079	333	24057	49.96
5	6539	1290	113	7942	957	6792	0	0	7763	7756	-979	22125	0	0	22125	2060	343	24528	49.95
6	6554	1621	113	8288	1021	6773	0	0	7964	8158	-1036	22836	0	6	22836	2208	368	25412	50.02
7	6665	1691	113	8469	989	6735	0	52	8153	8029	-1091	22788	0	0	22788	2310	395	25493	50.04
8	6675	752	113	7540	713	6714	0	407	8401	8503	-1298	22158	0	0	22158	2420	421	24999	50.02
9	6682	508	112	7302	597	6692	0	948	8543	8537	-1618	21993	0	0	21993	2699	465	25157	49.99
10	6751	394	112	7257	543	6693	0	1508	8914	9100	-1870	22753	0	0	22753	2976	478	26207	50.00
11	6711	432	115	7258	425	6697	0	1908	9474	9786	-1903	23695	0	48	23695	3176	476	27347	50.04
12	6704	511	112	7327	263	6700	0	2093	9720	9648	-1960	23615	0	0	23615	3243	456	27314	49.98
13	6704	680	116	7500	187	6703	0	2037	9450	9629	-1921	23696	0	0	23696	3230	439	27365	49.93
14	6591	837	116	7544	132	6707	0	1870	9553	9424	-2121	23119	0	0	23119	3135	437	26691	49.95
15	6632	1138	114	7884	121	6713	0	1516	9877	9881	-2192	23465	0	0	23465	3226	458	27149	49.95
16	6642	1400	114	8156	220	6746	0	1171	10118	9927	-2066	23677	0	0	23677	3275	477	27429	49.88
17	6572	1131	113	7816	548	6736	0	689	9591	9644	-2029	22920	0	0	22920	3246	484	26650	49.96
18	6638	1202	114	7954	757	6734	0	298	8718	8458	-1934	21777	0	0	21777	3143	490	25410	50.01
19	6655	1345	112	8112	663	6569	0	24	7334	7202	-1625	20446	0	0	20446	3000	499	23945	50.01
20	6772	2006	112	8890	536	6645	0	0	6611	7098	-1291	21397	0	0	21397	2967	481	24845	49.98
21	6919	1555	113	8587	297	6479	0	0	7097	6981	-1353	20530	0	0	20530	2843	461	23834	49.96
22	6941	1814	112	8867	284	6607	0	0	6308	6514	-1165	20659	0	0	20659	2757	448	23864	49.94
23	7068	2020	113	9201	175	6672	0	0	6130	6566	-1061	21135	0	0	21135	2717	418	24270	49.88
24	7146	1854	113	9113	306	6532	0	0	7300	7154	-1211	21492	0	0	21492	2637	402	24531	49.96
MUs	160.00	29.45	2.72	192.17	13.00	160.94	0.00	14.52	197.89	199.19	-36.34	533.15	0.00	0.05	533.15	66.32	10.33	609.80	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

- 1.Due to over loading of 132 kv sangamner-BBLR line
- 2.132 kv Ranwad load on GCR s/s BBLR I & II loading 800 Apm./ 292 mw.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Apr/2023

Position as on 6.30 Hrs of 07/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Bhira PSU	150	07/04/2023	08:01	07/04/2023	17:40	for Trouble shooting communication problem of PLC	07/04/2023
MSPGCL	Koyna Unit 1	70	07/04/2023	08:05	07/04/2023	19:45	Preventive Maintenance Work	07/04/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 4	210	29/03/2023	04:36		Continued.	Boiler Tube Leakage (Under tolling from 00:00 hrs. from 04.04.23)	
MSPGCL	Uran Unit 6	108	29/03/2023	08:33		Continued.	Zero Schedule	
MSPGCL	Koradi Unit 9	660	31/03/2023	23:45	06/04/2023	18:30	Boiler Tube Leakage	05/04/2023
MSPGCL	Paras Unit 4	250	03/04/2023	20:13	06/04/2023	23:25	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	05/04/2023	13:28		Continued.	Generator rotor earth fault	10/04/2023
IPP	SWPGPL U-1	135	05/04/2023	22:30		Continued.	ID Fan Problem	
IPP	RPL(AMT) U-3	270	06/04/2023	18:18		Continued.	APH problem	10/04/2023
MSPGCL	Parli Unit 8	250	07/04/2023	10:01	07/04/2023	13:25	Electrical Protection Operated.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (702) OF 765/21KV GT-4 and 765/400KV ICT (HV Side) @ TIRORA	IntraState	06/04/2023	10:25	06/04/2023	18:05	PO	For bay(702) equipment maintenance and testing work.
400 KV TIEBAY Outages/Trippings							
TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	IntraState	06/04/2023	17:34	06/04/2023	19:54	T	WHILE WORKING ON BUS REACTOR . 415 AND 416 TRIPPED
400 KV MAINBAY Outages/Trippings							
MAIN BAY 416 OF 400KV 125MVAR BUS REACTOR	InterState	06/04/2023	17:34	06/04/2023	19:53	T	WHILE WORKING ON BUS REACTOR . 415 AND 416 TRIPPED
400 KV LR Outages/Trippings							
MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	IntraState	07/04/2023	14:12		Continued.	PO	Main circuit breaker(bay 407) mechanical overhauling work carried out by agency.
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 2	InterState	06/04/2023	08:41	06/04/2023	17:09	PO	PMM. Auto reclose of 400 kv SSP - Dhule - 2 wil remain out
CHANDRAPUR - BHADRAVATI CKT - 2	InterState	06/04/2023	10:21	06/04/2023	19:55	HT	Outage by PG
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
PADGHE - NAGOTHANE CKT - 1	IntraState	05/04/2023	12:37	07/04/2023	16:09	PO	for earth wire restringing work
PARLI-SOLAPUR (LAMBOTI)	IntraState	06/04/2023	11:03	06/04/2023	11:46	T	D/P OPTED: P END: Y PH, Z1, 182KM, ILY = 2.519KA S END: YPH, Z1,11.4KM, ILY =5.37KA
PARLI-SOLAPUR (LAMBOTI)	IntraState	06/04/2023	11:08	06/04/2023	11:46	T	Tripped from one end only, Parli
PADGHE - KALWA CKT - 1	IntraState	07/04/2023	00:13	07/04/2023	07:35	EO	Replacement of faulty disc of all three phase of tower location No.2B
LONIKAND - JEJURI CKT - 2	IntraState	07/04/2023	14:19	07/04/2023	18:54	HT	For load management
PADGHE - KALWA CKT - 1	IntraState	07/04/2023	22:22		Continued.	EO	(1) Replacement of faulty disc of Middle & bottom phase of tower location No.2B.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	05/04/2023	09:35	07/04/2023	20:52	PO	1) Erection of tertiary side IPS tube for RRS project work . 2) Routine Bay maintenance work.
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	06/04/2023	01:09	06/04/2023	01:33	HT	H/T due to sparking on Bus side Isolator.
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	06/04/2023	09:23	06/04/2023	16:39	PO	Replacement of B-ph CT , Due to Higher Tan-d Values.
400/220 KV 315MVA ICT - 2 @ KARAD	IntraState	06/04/2023	16:05	06/04/2023	23:35	PO	Tan delta & capacitance measurement of Bushing & winding. Testing of Vendre make NIFPS by M/s Vendre Ltd,Pune for healthiness of NIFPS
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	06/04/2023	18:16	06/04/2023	22:30	PO	For work of RRS
400/220/33 KV 500 MVA ICT - 1 @ JEJURI	IntraState	06/04/2023	23:50	07/04/2023	01:41	EO	Attending hotspot at 220kV side Y -ph CT isolator side

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	07/04/2023	09:28		Continued.	PO	For laying of power cable (02Days)
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AEML BORIVALI - TPC BORIVALI LINE	IntraState	20/03/2023	00:14			T	Tripped due to cable joint failure.
RANJANGAON - U TECH SUGAR CKT	IntraState	30/03/2023	13:30	06/04/2023	20:28	PO	1) Bunching of 220kV Lonikand-Kathapur at 321 opening the jump 2) Bunching of 220kV Utech-Ranjangaon at 303 opening the jump3) after opening jump at 321 & 303 line will be dead. after bunching circuit become 220kV Lonikand2-Ranjangaon & 220kV Kathapur-Utech 4) Tower erection work L.No-16 (inline tower) of 220kV Kathapur-Lonikad line (for making LILO of 220kV Lonikand2-Kathapur line at 220kV Khedcity SS)
PARGAON(KATHAPUR)-LONIKAND	IntraState	30/03/2023	13:43	06/04/2023	21:12	PO	1) Bunching of 220kV Lonikand-Kathapur at 321 opening the jump 2) Bunching of 220kV Utech-Ranjangaon at 303 opening the jump3) after opening jump at 321 & 303 line will be dead. after bunching circuit become 220kV Lonikand2-Ranjangaon & 220kV Kathapur-Utech 4) Tower erection work L.No-16 (inline tower) of 220kV Kathapur-Lonikad line (for making LILO of 220kV Lonikand2-Kathapur line at 220kV Khedcity SS)
APTA - KALWA	IntraState	03/04/2023	22:56	06/04/2023	01:52	PO	Erection of Cable Termination kit on newly erected 2 nos. of CTT Monopole with fixing of Cross arm in between loc no. 686 to 687 in r/o newly proposed 220KV GIS substation of M/s. Print House (India) Pvt. Ltd.
BORIVALI - TARAPUR	IntraState	05/04/2023	12:51	07/04/2023	15:40	PO	Replacement of Rusted Hardware work under scheme at Loc No.28 To 50, by M/s.BNC Power Project.
KANDALGAON - BHIRA	IntraState	06/04/2023	09:28	06/04/2023	18:11	EO	Y- ph line side isolator alignment work to be carried out at Bhira TR HPS end.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/04/2023	10:15	06/04/2023	19:40	HT	-
220 KV CHALISGAON - KHADKA CKT -1	IntraState	06/04/2023	13:02	06/04/2023	13:24	T	Y, B-PH, 6.23KA,5.63KA, A/R L/O.
CHIKHALI-JALNA I	IntraState	06/04/2023	15:56	06/04/2023	20:13	HT	H/T TO CONTROL OVERLOADING OF AKOLA ICT . PARAS U-4 IS OUT
CHIKHALI-JALNA II	IntraState	06/04/2023	15:56	06/04/2023	20:13	HT	H/T TO CONTROL OVERLOADING OF AKOLA ICT . PARAS U-4 IS OUT
220 KV CHALISGAON - KHADKA CKT -1	IntraState	06/04/2023	15:57	06/04/2023	16:34	T	Tripped on D/P
OSMANABAD - SOLAPUR (BALE)	IntraState	06/04/2023	20:29	06/04/2023	20:53	T	D/P, 40KM, B PH. CKT TRIPPED AT BALE END ONLY

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - KALWA	IntraState	07/04/2023	09:25	07/04/2023	10:52	EO	For attending hotspot at B-phase Bottom pad N/B in main CB by shifting the line on TBC.
AMBAZARI-KALMESHVAR	IntraState	07/04/2023	10:25	07/04/2023	16:58	PO	Fixing of Vibration Damper
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	07/04/2023	11:12	07/04/2023	18:39	PO	For OPGW stringing work of MTCIL from loc no 182 to 183.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	07/04/2023	11:12	07/04/2023	18:39	PO	OPGW work
OSMANABAD - SOLAPUR (BALE)	IntraState	07/04/2023	12:38	07/04/2023	14:08	HT	To remove Tarpaulin
220KV BADNERA -NER CKT	IntraState	07/04/2023	14:19	07/04/2023	14:48	T	Distance protection
220 KV BALAPUR - MALKAPUR LINE	IntraState	07/04/2023	20:15	07/04/2023	20:19	T	Distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
250 MVA ICT-5 @ TROMBAY	IntraState	05/04/2023	22:00	07/04/2023	22:16	EO	Heavy oil leak from 220KV Cph CT
220/132 KV 200 MVA ICT 2 @ BEED	IntraState	06/04/2023	09:15	06/04/2023	14:20	PO	REPLACEMENT OF CT (HAVING HIGH TANDELTA 132KV CT
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	06/04/2023	09:27	06/04/2023	22:59	PO	TF painting & general maintainance work
100 MVA 220/132 KV ICT - 2 @ BHUGAON	IntraState	06/04/2023	10:44	06/04/2023	15:47	PO	1) OIL LEAKAGE ATTENDING WORK. 2) ISOLATOR ALIGNMENT WORK BY AGENCY M/S HIGHTECH
220/132 KV 200MVA ICT 2 @ JALNA	IntraState	06/04/2023	12:33	06/04/2023	20:27	PO	HV SIDE Y PH CT REPLACEMENT WORK
220/132 KV 200 MVA ICT - 1 @ HARANGUL	IntraState	07/04/2023	10:07	07/04/2023	12:24	EO	To attend Oil Leakage
220/132KV 100MVA ICT 1@ PETH	IntraState	07/04/2023	10:22	07/04/2023	14:50	PO	For replacement of R-ph LV CT & quarterly maintenance work
220/100 KV 200 MVA ICT 3 @ KALWA	IntraState	07/04/2023	11:20	07/04/2023	14:03	EO	Fire Extinguisher FD relay checking work as alarm was heard.
220/132 KV 200 MVA ICT 1 @ BOISAR-II	IntraState	07/04/2023	11:22	07/04/2023	13:31	PO	Hot spot attending work at ICT-1 1. 220kVBph CT clamp jumper crimping, 1210C 2. 132kV Rph suspension jumper nut/bolts, 141.60C (132kV A-Bus outage required for safety) 3. 132kV Rph CB upper jumper palm joint nut/bolts,750C 4. 132kV A-Bus outage is required to attend the above mentioned hot spot
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	07/04/2023	11:38	07/04/2023	17:17	EO	FOR REPLACEMENT OF FAULTY OTI METER
132 KV LINE Outages/Trippings							
DEEPNAGAR - MUKTAINAGAR CKT	IntraState	06/04/2023	07:40	06/04/2023	16:53	PO	1.R& B PHASE CT REPLACEMENT WORK. 2.ROUTINE BAY MAINTENANCEWORK.
GANGAKHED - KANDHAR	IntraState	06/04/2023	12:10	06/04/2023	18:25	PO	OUTAGE REQUIRED FOR LINE PROTECTION RELAY TESTING AND UPGRADITIONWORK.
AUSA - UJANI	IntraState	06/04/2023	14:30	06/04/2023	15:14	EO	REMOVING OF SPRINKER PIPE ON CONDUCTOR

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAIJ - KALLAM	IntraState	06/04/2023	19:48	06/04/2023	23:36	EO	EMERGENCY HANDTRIPPED DUE TO WAVETRAPHANGING PROBLEM.
110 KV LINE Outages/Trippings							
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	04/04/2023	21:59			PO	FOR 400 KV KVPTL WORK
WAGHIVALI - MANKHURD	IntraState	04/04/2023	23:57			PO	FOR 400 KV KVPTL WORK
TATA BORIVLI MSETCL BORIVLI 1	IntraState	06/04/2023	09:08	06/04/2023	13:44	PO	Attending hot spot and tree trimming

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage