

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Apr/2025 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	164.432	966.782	1) Gujrat	2.877	1.992
2) Hydro	11.735	107.464	2) Madhya Pradesh	9.945	75.932
3) Gas	5.896	34.678	3) Chattisgarh	3.190	26.370
Total MSPGCL	182.063	1108.924	4) Maharashtra	220.655	1317.608
B) 1) APMIL	67.818	385.245	5) Goa (Amona)	-2.465	-15.836
2) JSWEL	26.442	153.872	Total	234.202	1406.066
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.556	249.402
4) RPL(AMT)	31.524	188.193	b) Mumbai Drawl	44.497	285.163
5) SWPGPL	12.507	74.741	c) MSEDCL Bilateral *	126.127	746.035
6) Other IPP	19.080	111.519	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.556	249.402
C) 1) TPCL Thermal	10.584	64.122	Include PX	0.000	0.000
2) TPCL Hydro	1.912	25.838	Standby	0.000	0.000
3) TPCL Gas	4.097	23.994	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.005	58.042	1) MSEDCL	552.676	3255.830
D) STATE			2) Mumbai Discoms	70.094	457.158
1) Thermal	341.392	2002.516	3) Other Discoms	12.933	79.894
(A1+C1+C4+(B1-B6))			TOTAL STATE	635.703	3792.882
2) Hydro	13.647	133.302			
(A2+C2)					
3) Gas	9.993	58.672			
(A3+B7+C3)					
4) Wind	9.411	62.183			
6) SOLAR	27.059	130.144			
TOTAL STATE	401.502	2386.817			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5914	6490	7187	7607
MSPGCL Hydro	247	463	654	525
MSPGCL Gas	254	252	258	267
MSPGCL Total Generation	6415	7205	8099	8399
Central Sector Receipt	9902	10118	10788	8353
WIND	314	284	283	388
CPP / IPP Thermal	5926	6139	7093	6962
CPP / IPP Gas	0	0	0	0
SOLAR	3301	1593	0	789
Exchange with Mumbai	-1931	-1927	-1996	-1467
MSEDCL DEMAND MET	23359	22839	23697	22880
Load Shedding	0	0	0	0
MSEDCL DEMAND	23359	22839	23697	22880
TPCL GENERATION	597	689	775	622
AEML GENERATION	335	476	286	389
MUMBAI DEMAND	2863	3092	3057	2478
OTHER DISCOM DEMAND	568	573	570	544
STATE DEMAND MET	26790	26504	27324	25902
STATE DEMAND	26790	26504	27324	25902
Frequency (Hz)	50.03	50.03	50.01	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.48 Hz at 13:02 Hrs	49.81 Hz at 20:35 Hrs	50.04	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Apr/2025

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.01	23.48	179	117
Unit 8	13.34	77.22	590	468
Unit 9	12.55	79.95	561	445
Unit 10	10.22	67.24	535	310
Total	40.12	247.88		
Bhusawal				
Unit 3	3.35	19.20	160	125
Unit 4	9.98	56.28	495	280
Unit 5	0.07	43.44	66	0
Unit 6	9.70	31.60	654	0
Total	23.10	150.52		
Parli				
Unit 6	4.76	25.71	239	139
Unit 7	4.57	15.78	230	137
Unit 8	4.46	25.00	217	146
Total	13.79	66.48		
Chandrapur				
Unit 3	4.01	23.65	193	127
Unit 4	3.42	19.68	155	120
Unit 5	8.91	51.03	415	275
Unit 6	9.72	56.04	460	280
Unit 7	9.29	53.81	446	285
Unit 8	8.17	55.23	485	0
Unit 9	0.00	0.00	0	0
Total	43.53	259.44		
Paras				
Unit 3	4.49	26.36	213	144
Unit 4	4.43	27.15	209	142
Total	8.92	53.51		
Khaparkheda				
Unit 1	3.80	22.32	180	115
Unit 2	4.06	22.90	193	122
Unit 3	4.20	24.84	190	131
Unit 4	3.97	17.43	179	128
Unit 5	10.69	44.29	470	410
Total	26.72	131.77		
Nasik				
Unit 3	1.32	16.09	134	0
Unit 4	3.53	21.23	172	124
Unit 5	3.39	19.86	172	112
Total	8.25	57.17		
Uran				
All Units	5.90	34.68	268	136
Total	5.90	34.68		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	0.50	37	0
Total	0.07	0.50		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.78	17.50	430	40
Stage 4	2.88	44.72	1000	0
Stage 3	1.83	14.05	320	0
Total	7.49	76.28		
Hydro				
KDPH	0.77	4.94	32	32
VTRNA	0.89	5.05	60	0
TILLARI	0.19	2.80	62	0
BHIRA T.R.	0.20	1.60	40	0
SMLHY_PTN	2.19	16.07	96	85
GHATGHAR	0.00	0.72	0	0
Total	4.24	31.18		
Wind				
Total	9.41	62.18	0	0
Total	9.41	62.18		
CPP				
APML(Mus)	67.82	385.24	0	0
JSWEL(Mus)	26.44	153.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.52	188.19	0	0
SWPGPL-Mus	12.51	74.74	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.14	36.31	270	200
Other(Mus)	6.70	39.75	0	0
JPL	6.24	35.46	275	244
Total	157.37	913.57		
SOLAR				
Total	27.06	130.14	0	0
Total	27.06	130.14		
Tata				
Trombay 5	6.96	42.57	380	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.57	14.96	111	105
Trombay 7B	1.52	9.03	65	63
TATA Hydro	1.91	25.84	272	22
Trombay 8	3.62	21.55	219	127
Total	16.59	113.95		
AEML				
DTPS U-1&2	9.00	58.04	499	286
Total	9.00	58.04		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	164.43	966.78	MSPGCL Total	182.06	1108.92
			MSPGCL Thml+Gas	170.33	1001.46	Koyna 1,2 & 4 Total	5.66	62.23
			MSPGCL Hydro	11.74	107.46	State Total	401.50	2386.82

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Apr/2025

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7518	1827	264	9609	298	7044	0	0	8807	8940	-1752	23634	0	0	23634	3165	505	27304	50.04
2	7409	1305	265	8979	371	6982	0	0	9416	9720	-1708	23860	0	0	23860	2975	484	27319	49.94
3	7587	720	264	8571	430	7043	0	0	9252	9235	-1492	23321	0	0	23321	2807	466	26594	49.92
4	7622	220	265	8107	498	7087	0	0	9411	9284	-1371	23142	0	0	23142	2672	463	26277	50.01
5	7654	161	267	8082	651	7067	0	0	9376	9402	-1482	23256	0	0	23256	2559	464	26279	50.01
6	7694	163	268	8125	554	7073	0	0	9790	9955	-1493	23715	0	3	23715	2535	499	26749	50.01
7	7709	454	268	8431	499	7065	0	111	9322	9498	-1375	23711	0	8	23711	2504	518	26733	50.02
8	7607	525	267	8399	388	6962	0	789	8521	8353	-1467	22880	0	6	22880	2478	544	25902	50.02
9	6634	456	264	7354	221	6347	0	1830	8529	8581	-1614	22159	0	4	22159	2588	560	25307	50.04
10	6445	327	260	7032	230	6126	0	2707	9199	9015	-1788	22746	0	0	22746	2721	576	26043	50.10
11	5914	247	254	6415	314	5926	0	3301	9901	9902	-1931	23359	0	0	23359	2863	568	26790	50.03
12	5697	231	251	6179	364	5515	0	3519	10223	10058	-2093	22997	0	0	22997	2982	545	26524	50.12
13	5044	230	249	5523	363	5306	0	3558	9907	10545	-2140	22601	0	0	22601	3065	554	26220	50.28
14	5247	227	247	5721	404	5341	0	3474	9918	10259	-2218	22440	0	0	22440	3103	541	26084	50.33
15	5461	255	249	5965	299	5485	0	3076	10495	10288	-2237	22313	0	13	22313	3140	563	26016	50.01
16	5679	500	252	6431	287	5552	0	2461	10524	10685	-2248	22557	0	91	22557	3178	611	26346	50.00
17	6490	463	252	7205	284	6139	0	1593	10026	10118	-1927	22839	0	0	22839	3092	573	26504	50.03
18	6815	364	254	7433	343	6948	0	622	9709	9587	-1906	22450	0	3	22450	2952	577	25979	49.98
19	7068	424	255	7747	356	6910	0	18	9931	9707	-1984	22189	0	0	22189	2911	565	25665	50.00
20	7187	654	258	8099	283	7093	0	0	10411	10788	-1996	23697	0	0	23697	3057	570	27324	50.01
21	7354	826	211	8391	374	7083	0	0	9684	9872	-2050	23091	0	0	23091	3091	579	26761	49.96
22	7452	674	136	8262	483	7076	0	0	9955	9989	-2127	23135	0	0	23135	3132	548	26815	50.00
23	7545	251	168	7964	535	7105	0	0	10249	10357	-2137	23288	0	0	23288	3208	536	27032	50.03
24	7600	231	208	8039	582	7096	0	0	10254	10064	-1961	23296	0	0	23296	3317	524	27137	50.03
MUs	164.43	11.74	5.90	182.06	9.41	157.37	0.00	27.06	232.81	234.20	-44.50	552.68	0.00	0.13	552.68	70.10	12.93	635.70	50.04

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR Carried out at 132kV MIDC A'Nagar S/S due to overloading of 132 kV Sonewadi to MIDC Line.

Maximum Demand scenario for the date 06/Apr/2025		
State Demand	MSEDC L Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
27324 MW	23860 MW	3317 MW
20 Hrs	2 Hrs	24 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Apr/2025

Position as on 6.30 Hrs of 07/Apr/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	20/04/2025
MSPGCL	Chandrapur Unit 9	500	11/01/2025	18:55		Continued.	Generator Protection operated	01/05/2025
MSPGCL	Uran Unit 7	108	04/03/2025	14:15		Continued.	Turbine bearing vibration high	20/04/2025
MSPGCL	Bhusawal Unit 5	500	06/04/2025	00:15		Continued.	Boiler Tube Leakage	08/04/2025
MSPGCL	Chandrapur Unit 8	500	06/04/2025	08:08	06/04/2025	12:01	DUE TO PA FAN B PROBLEM.	
MSPGCL	Nasik Unit 3	210	06/04/2025	10:31		Continued.	Due to BTL at Reheater/Penthouse	08/04/2025
MSPGCL	Bhusawal Unit 6	660	06/04/2025	12:05	06/04/2025	18:07	Flame Failure	
MSPGCL	Uran Unit A0	120	06/04/2025	20:39	07/04/2025	00:34	Boilet trip protection	
MSPGCL	Uran Unit 6	108	06/04/2025	20:39	06/04/2025	21:38	Boiler trip protection	
MSPGCL	Koradi Unit 9	660	07/04/2025	12:28		Continued.	Boiler Tube Leakage	
Total Capacity MSPGCL		3491						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/06/2025
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2025
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3811						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	04/04/2025	22:00	07/04/2025	03:15	Due to No Schedule by MSEDCL (open cycle)	
Total Capacity MSPGCL		108						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		108						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Apr/2025

Position as on 6.30 Hrs of 07/Apr/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity		988						
FORCED OUTAGE DUE TO NO PPA								

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
SOLAPUR (PG) - PUNE (GIS)	InterState	07/04/2025	11:53			PO	Restrining of loose conductor between loc 267-270
400 KV LR Outages/Trippings							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	04/12/2024	12:04			EO	400kV Dhule SSNNL-2 line CB as hydraulic operated CB mechanism oil pressure is 310bar & not building up so it is requested to give permission for shifting of 400KV Dhule SSNNL-2 line load shifting to 400KV TBC urgently & attending same.
Boisar (PG) - Aurangabad (PG) ckt -1	InterState	04/04/2025	11:09			PO	Repairing of a damaged sub-conductor that snapped on 12.03.2025. (Non-auto of Ckt#2 is also required.) A simultaneous outage of the 220 kV Tarapur-Boisar line is also necessary, as this line passes underneath the 400 kV Aurangabad-Boisar transmission line.
LONIKAND I - TALEGAON (PGCIL)	InterState	05/04/2025	17:15	06/04/2025	01:05	T	Tripped on distance protection
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/03/2025	00:53			HT	IN VIEW OF 400KV TALEGAON - CHAKAN LINE LOADING
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	26/03/2025	21:30	07/04/2025	11:49	HT	IN VIEW OF 400KV TALEGAON - CHAKAN LINE LOADING
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	06/04/2025	09:59	06/04/2025	16:32	EO	Attending hot Glow was observed near Bph clamp on IPS tube between 89A Isolator of 412 Bay & 89B Isolator of 411 Bay.
DEEPNAGAR - THAPTI TANDA	IntraState	07/04/2025	08:12			PO	Maintenance work like disc repalcement and nut-bolt tightening work
DABHOL - NEW KOYNA CKT - 1	IntraState	07/04/2025	12:27			PO	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
105 MVA SPARE ICT @ CHAKAN	IntraState	26/02/2025	10:59			PO	Long Duration outage required for Rapid restoration scheme work of ICT at 400kV Chakan s/sn
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	IntraState	31/03/2025	13:33			EO	For 1) Shifting of ICT3 LV bay to ICT4 LV side. 2) Building of incomplete firewall between ICT3 & ICT4.
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	07/04/2025	10:38			PO	1) Winding Resistance, IR Value testing work.2) Bay Maintenance work.
400 KV BR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS REACTOR (125MVar) @ WARORA	IntraState	07/04/2025	09:40			PO	Filtration of Oil of 400KV, 125MVAR BUS REACTOR OF MAIN TANK with DGA Testing with allied test by AGENCY
220 KV TIEBAY Outages/Trippings							
BUS COUPLER @ PHURSUNGI	IntraState	06/04/2025	20:45			HT	Hand Tripped.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
PRINT HOUSE - NAVI MUMBAI (PG)	InterState	05/12/2024	23:09			EO	1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Taloja s/stn. 2)For opening jumpers at TL no 678/1.
PANCHALI TSS - BOISAR (PG)	InterState	06/04/2025	06:44	07/04/2025	06:00	PO	1) For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor. 2) Bus Maintenance and Diagnostic Testing.
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
SAKI (AEML) - SAKI (TATA) CKT - 1	IntraState	21/01/2025	15:26			HT	fire caught near Marve bridge
SAKI (AEML) - SAKI (TATA) CKT - 2	IntraState	21/01/2025	15:26			HT	Fire Caught near Marve Bridge
PETH- MUDSHINGI 1 LINE	IntraState	28/03/2025	07:55			PO	For D/C suspension tower replacement at loc no. 167 & 168 by D/C tension towers (6 meter & 9 meter extension) for height raising at new NH-166 Ratnagiri-Nagpur highway crossing at Nagaon Village, Kolhapur.
SALSETTE BORIVLI - 2	IntraState	03/04/2025	09:18			EO	Work on Salsette Borivali-2 cable sealing end in vicinity of O/H line
BOISAR II - TARAPUR	IntraState	04/04/2025	11:11			PO	A simultaneous outage of the 220 kV Tarapur-Boisar line and 400KV -AURANGABAD-BOISAR-1 are required, as 220 kV Tarapur-Boisar line passes underneath the 400 kV Aurangabad-Boisar transmission line in the section where the damaged sub-conductor is to be repaired
HINJAWADI I- CHINCHWAD	IntraState	04/04/2025	22:50	06/04/2025	20:45	HT	Load management
BOISAR - VERSOVA	IntraState	05/04/2025	07:41			PO	Relocation / Modification of lines infringing NHAI route-Shifting of lines on permanent towers from ERS at SS 158 & SS 163
BUS SECTION-6 @ TROMBAY	IntraState	05/04/2025	23:42	06/04/2025	10:49	PO	MAIN BUS-6 CVT TESTING, BUS SECTION-4 CT TESTING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VERSOVA - GHODBUNDER	IntraState	06/04/2025	06:36	06/04/2025	14:40	PO	For safety purpose while dismantling of gantry under BESS Project
BOISAR II - BOISAR (PG) CKT - 2	IntraState	06/04/2025	06:47	07/04/2025	05:44	PO	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	06/04/2025	06:51	06/04/2025	20:26	HT	H/T for load management.
BHAVEGHAR - ROMA	IntraState	06/04/2025	09:27	06/04/2025	17:40	PO	Routine Maintenance Work.
BABLESHWAR -BHENDA	IntraState	06/04/2025	12:45	06/04/2025	13:19	T	Tripped at Bhenda end only
BABLESHWAR AHAMADNAGAR-II	IntraState	06/04/2025	14:52	06/04/2025	15:26	T	Tripped at bableshwar end only
MALHARPEETH SATARA MIDC	IntraState	06/04/2025	15:12	06/04/2025	16:25	T	Tripped on distance protection
HINJAWADI I- CHINCHWAD	IntraState	07/04/2025	04:58			HT	H/T for load management.
GHODBUNDER - GORAI	IntraState	07/04/2025	05:58			PO	For safety purpose while dismantling of gantry under BESS Project
KHAREPATAN -PAWAS LINE	IntraState	07/04/2025	08:22			PO	Bus Isolator maintenance and bus & Gantry insulators string washing. Also all bay equipments routine maintenance.
BUS SECTION - 1 @ KHAREPATAN	IntraState	07/04/2025	09:00			PO	Bus Isolator maintenance and bus & Gantry insulators string washing. Also, all bay equipment's routine maintenance.
KANDALGAON - PIRANGUT	IntraState	07/04/2025	11:20	07/04/2025	11:44	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132 KV 80 MVA ICT 1 @ HINGANGHAT	IntraState	19/02/2025	12:45			HT	H/T Due to end of expected life of paper insulation of ICT
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	07/04/2025	08:58			PO	Bus Isolator maintenance and bus & Gantry insulators string washing. Also, all bay equipment routine maintenance.
220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II	IntraState	07/04/2025	09:30			EO	1) Main tank & HV CT (R Phase) oil leakage attending work.
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	07/04/2025	10:18			PO	Quarterly Maintenance Work
220/110 kv 200 MVA ICT 3 @ MUDSHINGI	IntraState	07/04/2025	11:57			PO	Quarterly maint work & Diagnostic Testing Work.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	12/02/2025	19:12			HT	System Constraints H/T at Pench End.
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
132 KV PATHRI-MAJALGAON CKT	IntraState	06/01/2025	13:05			HT	After completion of outage on 132kv patri parbhani ckt
132 KV BADNAPUR - HYOSUNG (STERLIGHT) CKT	IntraState	14/02/2025	17:01			T	B - R PH, Z2, 2.56 KA, 26 KM. H - R PH, 3 KA, 700 MTR.
132 KV UJANI - BASSK	IntraState	18/03/2025	13:10			T	Distance protection.
132 KV ICT Outages/Trippings							
132/33 KV 50 MVA PTR 2 @ DONDAICHA	IntraState	15/11/2024	11:40			T	Tripped on Buchholz alarm
110 KV LINE Outages/Trippings							
TATA BORIVLI MSETCL BORIVLI 2	IntraState	24/03/2025	09:18			PO	Line to be shift on TBC for Overhauling of Pole and Mechanism of 145 kv Circuit Breaker.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Apr/2025

Statement-VII

Position as on 6.30 Hrs of 07/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	IntraState	07/04/2025	09:52			PO	Sealing End preparation & Work in vicinity of line

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage