

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Jun/2015 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	117.512	743.387	1) Gujrat	3.938	-7.509
2) Hydro	14.815	94.557	2) Madhya Pradesh	18.023	93.844
3) Gas	6.632	39.861	3) Chattisgarh	2.790	28.860
Total MSPGCL	138.959	877.805	4) Maharashtra Net	104.945	628.500
B) 1) APMIL	56.600	345.370	5) Goa	-7.122	-43.707
2) JSWEL	14.179	97.372	6) TAPS 1&2 Injection	0.844	3.774
3) VIPL	11.643	72.509	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	5.390	33.550	8) Pench (MS)	0.029	0.567
5) WPCL	6.581	30.112	9) Pench (Excess)	-0.029	-0.355
6) Other IPP	5.735	32.408	Total	123.389	703.407
C) 1) TPCL Thermal	17.378	99.669	a) Mumbai Schedule	27.385	177.577
2) TPCL Hydro	3.185	26.357	b) Mumbai Drawl	29.833	186.933
3) TPCL Gas	2.581	16.303	c) MSEDCL Bilateral *	31.419	174.744
4) R-INFRA Thermal	12.161	73.489	Include PX	-0.109	2.469
D) STATE			d) Mumbai Bilateral *	27.385	177.577
1) Thermal	247.179	1527.866	Include PX	2.125	12.112
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	18.000	120.914	H) ENERGY CATERED (MUs)		
3) Gas	9.213	56.164	1) MSEDCL	341.343	2106.699
4) Wind	7.920	94.279	2) Mumbai Discoms	65.136	402.744
6) SOLAR	0.780	6.465	TOTAL STATE	406.479	2509.443
TOTAL STATE	283.092	1805.688			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	5007	5089	5171	4471
MSPGCL Hydro	1106	1495	530	76
MSPGCL Gas	283	272	271	279
MSPGCL Total Generation	6396	6856	5972	4826
Central Sector Receipt	5213	5299	5376	4939
WIND	287	223	207	401
CPP / IPP	4456	4374	4380	3514
SOLAR	101	80	0	0
Exchange with Mumbai	-1448	-1442	-1341	-831
MSEDCL DEMAND MET	15005	15390	14594	12849
Load Shedding	42	38	38	42
MSEDCL DEMAND	15047	15428	14632	12891
TPCL GENERATION	1104	1207	1016	855
R-INFRA GENERATION	508	509	514	511
MUMBAI DEMAND	3060	3158	2871	2197
STATE DEMAND MET	18065	18548	17465	15046
STATE DEMAND	18107	18586	17503	15088
Frequency (Hz)	49.99	49.92	49.80	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.22 Hz at 10.00 Hrs	49.57 Hz at 20.20 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 06/Jun/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	11.60	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	5.06	0	0
Total	0.00	16.65		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	10.25	66.18	500	375
Unit 5	4.69	28.32	500	0
Total	14.94	94.50		
Parli				
Unit 3	3.79	21.90	163	152
Unit 4	0.00	0.00	0	0
Unit 5	3.59	21.42	152	143
Unit 6	4.73	30.07	229	178
Unit 7	4.88	32.06	249	190
Total	16.99	105.45		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.41	17.36	150	135
Unit 3	4.59	25.68	205	170
Unit 4	4.20	25.68	185	163
Unit 5	9.70	55.56	430	375
Unit 6	9.43	57.21	415	360
Unit 7	7.33	50.12	370	271
Total	38.66	231.61		
Paras				
Unit 3	5.58	32.43	250	202
Unit 4	5.35	32.96	250	197
Total	10.93	65.38		
Khaparkheda				
Unit 1	0.07	17.45	69	0
Unit 2	3.64	21.01	170	135
Unit 3	4.10	23.48	190	147
Unit 4	3.90	22.46	171	148
Unit 5	9.87	61.18	463	386
Total	21.59	145.58		
Nasik				
Unit 3	4.90	28.52	210	195
Unit 4	4.72	27.78	202	182
Unit 5	4.78	27.91	207	176
Total	14.41	84.20		
Uran				
All Units	6.63	39.86	285	260
Total	6.63	39.86		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.03	0.57	20	0
Total	0.03	0.57		
Koyna				
Stage 1-2	3.72	28.42	340	40
Stage 4	5.08	33.61	760	0
Stage 3	1.79	13.73	240	0
Total	10.59	75.76		
Hydro				
KDPH	0.00	1.57	0	0
VTRNA	0.82	5.00	61	0
TILLARI	0.31	1.68	64	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.20	1.40	80	0
RNGR+BHTSA	0.22	1.11	10	9
BHANDARDRA	0.00	0.63	0	0
ELDARY	0.22	0.44	10	8
SMLHY_PTN	0.13	1.26	13	2
GHATGHAR	2.33	5.72	250	0
Total	4.23	18.80		
Wind				
Total	7.92	94.28	0	0
Total	7.92	94.28		
CPP				
APML(Mus)	56.60	345.37	0	0
JSWEL(Mus)	14.18	97.37	0	0
VIPL(Mus)	11.64	72.51	0	0
RPLAMT(Mus)	5.39	33.55	0	0
WPCL(Mus)	6.58	30.11	0	0
Other(Mus)	5.74	32.41	0	0
Total	100.13	611.32		
SOLAR				
Total	0.78	6.46	0	0
Total	0.78	6.46		
Tata				
Trombay 5	11.46	57.77	496	427
Trombay 6	0.00	13.80	0	0
Trombay 7A	1.43	9.20	60	59
Trombay 7B	1.15	7.10	49	47
Trombay 8	5.91	28.10	251	212
TATA Hydro	3.18	26.36	379	6
Total	23.14	142.33		
R-INFRA				
1-2	12.16	73.49	514	440
Total	12.16	73.49		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	117.51	743.39
MSPGCL Thml+Gas	124.14	783.25

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	14.82	94.56
MSPGCL Total	138.96	877.80

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	8.80	62.03
State Total	283.09	1805.69

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Jun/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4745	91	278	5114	731	4206	0	5034	5588	-1431	14208	59	14267	2782	17049	49.94
2	4564	66	278	4908	765	4040	0	4845	5408	-1265	13856	42	13898	2579	16477	49.93
3	4524	62	279	4865	414	3998	0	4735	5318	-1018	13577	42	13619	2420	16039	49.98
4	4484	62	279	4825	529	3831	0	4658	4913	-860	13238	42	13280	2283	15563	49.97
5	4471	76	279	4826	401	3514	0	4489	4939	-831	12849	42	12891	2197	15088	49.91
6	4443	256	279	4978	338	3431	0	4497	5195	-833	13109	42	13151	2197	15348	49.96
7	4509	553	281	5343	252	3727	4	4620	4783	-779	13330	43	13373	2143	15516	50.03
8	4525	208	280	5013	152	4146	30	4742	5009	-780	13570	43	13613	2145	15758	49.99
9	4748	245	279	5272	131	4201	52	4877	5082	-903	13835	46	13881	2285	16166	49.96
10	4837	922	285	6044	194	4366	59	4900	4868	-1155	14376	46	14422	2626	17048	50.01
11	4888	1337	282	6507	179	4248	79	4964	4910	-1285	14638	44	14682	2894	17576	50.03
12	5007	1106	283	6396	287	4456	101	5230	5213	-1448	15005	42	15047	3060	18107	49.99
13	5137	874	272	6283	291	4354	97	5293	5373	-1507	14891	42	14933	3124	18057	49.96
14	5099	1027	272	6398	158	4352	87	5148	5391	-1462	14924	38	14962	3077	18039	49.97
15	5168	1320	272	6760	165	4341	92	5125	5274	-1436	15196	38	15234	3157	18391	49.92
16	5089	1495	272	6856	223	4374	80	5140	5299	-1442	15390	38	15428	3158	18586	49.92
17	5047	1499	272	6818	129	4374	61	4992	5102	-1486	14998	38	15036	3104	18140	49.99
18	5168	1229	272	6669	77	4299	33	4752	4679	-1437	14320	38	14358	2971	17329	49.97
19	5199	502	272	5973	216	4357	5	4421	4558	-1400	13709	38	13747	2816	16563	49.93
20	5171	530	271	5972	207	4380	0	4932	5376	-1341	14594	38	14632	2871	17503	49.80
21	5226	509	260	5995	262	4342	0	5037	5237	-1322	14514	38	14552	2878	17430	49.76
22	5255	148	275	5678	678	4346	0	5075	5261	-1389	14574	38	14612	2806	17418	49.93
23	5057	173	278	5508	673	4222	0	5073	5259	-1500	14162	38	14200	2714	16914	49.90
24	5151	525	282	5958	468	4223	0	5110	5354	-1523	14480	38	14518	2851	17369	49.93
MUs	117.51	14.82	6.63	138.96	7.92	100.13	0.78	117.69	123.39	-29.83	341.34	0.99	342.34	65.14	407.47	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jun/2015

Position as on 6.30 Hrs of 07/Jun/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling work	
MSPGCL	Parli Unit 4	210	13/04/2015	11.27		Continued.	Turbine vibration high. Continued to AOH w.e.f.01.05.2015	
IPP	Adani U-1	660	01/06/2015	01.48		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn	
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22		Continued.	BLR Tripped.	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
IPP	RPL(AMT) U-4	270	03/04/2015	11.42		Continued.	Boiler feed Pump problem.	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
IPP	RPL(AMT) U-3	270	05/04/2015	22.01		Continued.	Governor AVR Problem.	
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem	
MSPGCL	Bhusawal Unit 3	210	20/04/2015	00.00		Continued.	no buyer as per msdcl regirment	
IPP	JSW (J) U1	300	14/05/2015	19.16		Continued.	Turbine Bearing Problem	
IPP	WPCL U-2	135	31/05/2015	00.01		Continued.	ID Fan Problem	
CPP	WPCL U-1	135	01/06/2015	00.00	06/06/2015	05.29	ESP bag filter puring header heavy Leakage.	
IPP	RPL(AMT) U-2	270	01/06/2015	06.53		Continued.	Coal bunkering problem	
CENT.SECTOR	Tarapur 2	160	01/06/2015	22.42	06/06/2015	11.24	Primary system Leakage.	
MSPGCL	Koradi Unit 7	210	02/06/2015	11.05		Continued.	Leakage at Chimany base.	
MSPGCL	Bhusawal Unit 5	500	03/06/2015	08.01	06/06/2015	08.37	Boiler Tube Leakage	
MSPGCL	Koradi Unit 5	200	04/06/2015	10.30		Continued.	I D Fan Vaibration High.	
TPC-G	Trombay 6	500	05/06/2015	05.59		Continued.	Economic Shutdown.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jun/2015

Position as on 6.30 Hrs of 07/Jun/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 1	210	06/06/2015	01.03	07/06/2015	08.27	Air heater problem	
MSPGCL	Chandrapur Unit 7	500	07/06/2015	13.59		Continued.	Boiler Tube Leakage	
IPP	RPL(AMT) U-1	270	07/06/2015	22.12		Continued.	Bus Bar Operated.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2015

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Wardha PG -Aurangabad PG III	InterState	03/05/2015	07.24		Continued.	HT	To Control ICT Loading.
Wardha(PG)-Aurangabad(PG)- II	InterState	22/05/2015	16.44		Continued.	HT	To Control ICT Loading.
Koradi-III - Akola-II ckt-I	IntraState	06/06/2015	10.19	06/06/2015	17.16	PO	Emergency work
400 KV LINE Outages/Trippings							
Wardha (PG)-Warora II	InterState	20/05/2015	02.39		Continued.	T	Breaker Accumulator Oil Leakage
Kolhapur Mapusa I	InterState	04/06/2015	17.42	06/06/2015	07.34	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	05/06/2015	10.22	06/06/2015	07.31	PO	Corona ring replacement(RFC 18.00Hrs)
Dabhol Nagothane II	InterState	06/06/2015	02.56	06/06/2015	08.38	T	Over Voltage
Koradi Bhilai	InterState	06/06/2015	08.49		Continued.	PO	Annual Maintenance Work
Chandrapur Bhadravati IV	InterState	06/06/2015	11.34	06/06/2015	19.23	PO	Disc Insulator Replacement Work
Chandrapur Bhadravati III	InterState	06/06/2015	12.09	06/06/2015	19.27	PO	Annual Maintenance Work
Kolhapur Mapusa II	InterState	06/06/2015	16.39		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	06/06/2015	21.31	07/06/2015	07.04	HT	Over Voltage
Dabhol Nagothane I	InterState	07/06/2015	13.08		Continued.	T	Distance Protection R Ph Earth.
Dabhol Nagothane II	InterState	07/06/2015	13.20	07/06/2015	14.14	T	Distance Protection Y Ph Earth.
Kolhapur Solapur (PG) II	InterState	07/06/2015	16.54		Continued.	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	07/06/2015	17.14		Continued.	HT	Over Voltage
Akola II - RPL(Rattaniindia) Ckt I	IntraState	07/04/2015	00.27		Continued.	T	"R" Phase Metering CT Burst.
Akola II - Taptitanda	IntraState	20/05/2015	08.59		Continued.	HT	Ckt I and Ckt 2 new charged to control BBL SR ICT loading.
Bhusawal-Aurangabad	IntraState	04/06/2015	17.11	06/06/2015	07.18	HT	Over Voltage
karad -kolhapur-II	IntraState	05/06/2015	17.50	06/06/2015	08.23	HT	Over Voltage
Karad-Jaigad - I	IntraState	05/06/2015	19.47	06/06/2015	09.38	T	Distance protection(RFC 21.10Hrs)
Babhaleshwar-Taptitanda ckt-II	IntraState	06/06/2015	01.21		Continued.	HT	To control line loading
karad -kolhapur-I	IntraState	06/06/2015	17.39	07/06/2015	08.51	HT	Over Voltage
Babhaleshwar-Taptitanda ckt-I	IntraState	07/06/2015	04.39		Continued.	HT	To control line loading
Dhule - Bableswhar - li	IntraState	07/06/2015	06.55	07/06/2015	19.06	PO	AR Out for OPGW Work.
Dhule- Bableswhar - I	IntraState	07/06/2015	06.55	07/06/2015	19.06	PO	AR Out for OPGW Work.
Babhaleshwar - Padghe-I	IntraState	07/06/2015	07.31		Continued.	PO	Stringing of Insulator String.
Padghe - Talegaon (PG)	IntraState	07/06/2015	09.00	07/06/2015	14.20	PO	AR Out for OPGW Work.
karad -kolhapur-I	IntraState	07/06/2015	16.01		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	07/06/2015	16.34		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	07/06/2015	17.21		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	07/06/2015	17.42		Continued.	HT	Over Voltage
Akola II - RPL(Rattaniindia) Ckt-II	IntraState	07/06/2015	22.12		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	06/06/2015	07.43	06/06/2015	18.54	PO	Tan Delta Measurment of CTs
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	06/06/2015	21.38	07/06/2015	01.25	T	NDR Operated
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	07/06/2015	11.12	07/06/2015	16.21	PO	P.M.Work.
220 KV LINE Outages/Trippings							
Sahara-Urse	IntraState	03/03/2015	11.06		Continued.	PO	Tower erection work (90Days)
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 06/Jun/2015

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chikhli-Jalna-I	IntraState	03/06/2015	18.30		Continued.	HT	O/L of Akola ICT.
Chikhli-Jalna-II	IntraState	03/06/2015	18.30		Continued.	HT	O/L of Akola ICT.
Parvati - Hybrid Pass	IntraState	05/06/2015	12.13		Continued.	T	TO control chinchawad urse loading
Kharghar - Nerul	IntraState	06/06/2015	02.50	06/06/2015	07.08	PO	stringing of single conductor
Kharghar Trombay	IntraState	06/06/2015	03.05	06/06/2015	07.32	PO	safty to work for stringing of conductor on 220 kharghar-nerul line
Dahanu Versova	IntraState	06/06/2015	06.30	06/06/2015	11.41	PO	Replacement of vibration damper
Theur- Magar Patta City	IntraState	06/06/2015	09.02	06/06/2015	15.11	PO	Half yearly maintenance work
Nashik-Padgha	IntraState	06/06/2015	15.33	06/06/2015	17.43	T	Distance Protection
Pedhambe - Oni	IntraState	06/06/2015	19.55	06/06/2015	20.15	T	Distance Protection
Oni Kharepatan Line	IntraState	06/06/2015	19.55	07/06/2015	02.25	T	Line under B.D.
Kharghar Trombay	IntraState	07/06/2015	05.18	07/06/2015	23.07	PO	Destringing of Existing Kharghar-Trombay Connection,Stringing of Top Ckt.& Bottom Ckt for Pressing Sleeve for Attending Hot Spot.
Eklahara(Gcr)(Nasik)- Bableshtar-I	IntraState	07/06/2015	08.14	07/06/2015	16.51	PO	AR Out for OPGW Work.
Aarey Saki Line 1	IntraState	07/06/2015	09.08	07/06/2015	13.58	PO	Annual Maintenance Work.
Nanded - Parli Ext. Ckt II	IntraState	07/06/2015	14.24	07/06/2015	14.45	T	Distance Protection Operated Zone-I Y-E Phase.
Pedhambe - Oni	IntraState	07/06/2015	16.10		Continued.	T	Distance Protection
Lamboti-Vita	IntraState	07/06/2015	17.15	07/06/2015	18.05	T	Distance Protection
Lamboti - Pandharpur li	IntraState	07/06/2015	17.29	07/06/2015	18.05	T	Distance Protection
220 KV ICT Outages/Tripping							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Internal Fault
220/33kv 100 MVA Transformer 4 @Aarey R/S	IntraState	06/06/2015	09.15	06/06/2015	12.00	PO	Pre monsoon work
220/33kv 100MVA Transformer 1 @Versova R/S	IntraState	06/06/2015	09.42	06/06/2015	19.18	PO	Replacement of 33 kv bushing
220/100 Kv 200 Mva Vijai Ict 2 @Trombay	IntraState	06/06/2015	09.50	06/06/2015	21.28	PO	Attending Oil Leakage
220/132 Kv 200 MVA ICT-III @Phursungi	IntraState	06/06/2015	14.09	06/06/2015	18.39	PO	Replacement work
132 KV LINE Outages/Tripping							
Nanded - Kandhar	IntraState	07/06/2015	14.32	07/06/2015	15.00	T	Distance Protection Operated Zone-I.
Bhoom - Kharda	IntraState	07/06/2015	17.03	07/06/2015	17.35	T	Distance Protection Operated.
Dondaicha- Shahada	IntraState	07/06/2015	21.08		Continued.	T	L A Brust @ Shahada.
100 KV LINE Outages/Tripping							
Pal - Kalwa	IntraState	06/06/2015	06.52		Continued.	PO	replacement of dp structure

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage