

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Jun/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.477	850.836	1) Gujrat	-2.457	-18.032
2) Hydro	27.935	160.842	2) Madhya Pradesh	6.018	46.629
3) Gas	5.091	31.205	3) Chattisgarh	3.380	17.670
Total MSPGCL	176.503	1042.883	4) Maharashtra	215.862	1309.209
B) 1) APML	75.359	379.660	5) Goa (Amona)	-1.478	-8.788
2) JSWEL	25.984	147.978	Total	221.325	1346.688
3) VIPL	0.000	0.000	a) Mumbai Schedule	44.698	261.637
4) RPL(AMT)	30.602	184.088	b) Mumbai Drawl	49.804	290.693
5) SWPGPL	10.789	61.668	c) MSEDCL Bilateral *	104.357	660.619
6) Other IPP	2.269	14.865	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.689	261.628
C) 1) TPCL Thermal	12.702	75.364	Include PX	0.000	0.000
2) TPCL Hydro	6.018	31.966	Standby	0.009	0.009
3) TPCL Gas	2.216	12.938	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.852	46.429	1) MSEDCL	527.981	3074.357
D) STATE			2) Mumbai Discoms	79.592	457.390
1) Thermal	310.034	1760.888	3) Other Discoms	10.941	63.824
(A1+C1+C4+(B1-B6))			TOTAL STATE	618.514	3595.571
2) Hydro (A2+C2)	33.953	192.808			
3) Gas (A3+B7+C3)	7.307	44.143			
4) Wind	29.646	155.313			
6) SOLAR	16.249	95.731			
TOTAL STATE	397.189	2248.883			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5931	6294	6261	5629
MSPGCL Hydro	794	1322	1432	1630
MSPGCL Gas	201	194	207	226
MSPGCL Total Generation	6926	7810	7900	7486
Central Sector Receipt	10031	9912	8521	8095
WIND	528	492	1703	1724
CPP / IPP Thermal	5807	6221	6311	6060
CPP / IPP Gas	0	0	0	0
SOLAR	2224	1281	0	0
Exchange with Mumbai	-2534	-2377	-1830	-1819
MSEDCL DEMAND MET	22496	22850	22134	21189
Load Shedding	0	570	0	0
MSEDCL DEMAND	22496	23420	22134	21189
TPCL GENERATION	699	1050	1194	629
AEML GENERATION	499	501	310	287
MUMBAI DEMAND	3732	3928	3334	2735
OTHER DISCOM DEMAND	487	490	472	357
STATE DEMAND MET	26714	27268	25940	24280
STATE DEMAND	26714	27838	25940	24280
Frequency (Hz)	49.99	49.94	50.03	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.29 Hz at 18.04 Hrs	49.74 Hz at 12.36 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.83	28.22	205	200
Unit 8	5.93	5.93	546	0
Unit 9	0.00	0.00	0	0
Unit 10	13.04	77.92	582	513
Total	23.80	112.07		
Bhusawal				
Unit 3	0.00	15.51	0	0
Unit 4	10.24	59.50	460	385
Unit 5	11.15	63.16	490	430
Total	21.40	138.17		
Parli				
Unit 6	3.92	29.98	244	0
Unit 7	5.46	28.90	245	173
Unit 8	4.73	25.99	209	146
Total	14.11	84.87		
Chandrapur				
Unit 3	3.56	11.92	161	119
Unit 4	3.70	21.95	156	153
Unit 5	0.00	0.00	0	0
Unit 6	0.00	36.56	0	0
Unit 7	9.21	55.04	403	341
Unit 8	11.52	67.02	495	460
Unit 9	11.47	68.13	493	429
Total	39.47	260.63		
Paras				
Unit 3	4.99	30.02	220	171
Unit 4	4.96	31.36	225	172
Total	9.94	61.38		
Khaparkheda				
Unit 1	2.96	18.27	130	110
Unit 2	2.76	18.02	132	107
Unit 3	4.07	15.32	182	153
Unit 4	3.71	24.89	165	140
Unit 5	9.85	64.87	475	320
Total	23.36	141.38		
Nasik				
Unit 3	3.28	4.16	181	0
Unit 4	4.18	24.38	182	166
Unit 5	3.96	23.80	171	158
Total	11.42	52.34		
Uran				
All Units	5.09	31.20	229	194
Total	5.09	31.20		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	0.64	24	0
Total	0.06	0.64		
Koyna				
Stage 1-2	7.58	35.69	510	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	11.91	76.49	760	136
Stage 3	4.68	25.71	320	80
Total	24.18	137.90		
Hydro				
KDPH	0.42	2.71	18	18
VTRNA	1.04	6.72	61	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.38	2.13	80	0
SMLHY_PTN	1.66	9.51	74	63
GHATGHAR	0.19	0.19	125	0
Total	3.69	22.31		
Wind				
Total	29.65	155.31	0	0
Total	29.65	155.31		
CPP				
APML(Mus)	75.36	379.66	0	0
JSWEL(Mus)	25.98	147.98	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.60	184.09	0	0
SWPGPL-Mus	10.79	61.67	0	0
Dhariwal	0.00	0.00	0	0
IEPL	0.00	0.00	0	0
Other(Mus)	2.27	14.86	0	0
Total	145.00	788.26		
SOLAR				
Total	16.25	95.73	0	0
Total	16.25	95.73		
Tata				
Trombay 5	8.32	49.53	431	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.23	7.13	107	38
Trombay 7B	0.99	5.81	63	35
TATA Hydro	6.02	31.97	420	118
Trombay 8	4.38	25.84	230	129
Total	20.94	120.27		
AEML				
DTPS U-1&2	8.85	46.43	502	285
Total	8.85	46.43		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.48	850.84	MSPGCL Total	176.50	1042.88
			MSPGCL Thml+Gas	148.57	882.04	Koyna 1,2 & 4 Total	19.50	112.18
			MSPGCL Hydro	27.94	160.84	State Total	397.19	2248.88

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5675	1796	225	7696	1880	6193	0	0	7596	8009	-1797	21579	356	0	21935	3318	401	25654	50.03
2	5634	1754	226	7614	1855	6182	0	0	7946	8209	-1719	21757	87	0	21844	3081	383	25308	50.07
3	5683	1512	226	7420	1713	6158	0	0	8206	8316	-1818	21432	0	0	21432	2880	357	24670	49.95
4	5629	1630	226	7486	1724	6060	0	0	8174	8095	-1819	21189	0	0	21189	2735	357	24280	49.95
5	5612	1638	226	7476	1630	6173	0	0	7759	8323	-1734	21496	0	0	21496	2662	371	24530	50.01
6	5655	1634	228	7517	1483	5995	0	0	8899	9008	-1762	21828	0	0	21828	2661	413	24902	50.04
7	5714	863	229	6806	1357	5918	0	178	9295	9204	-1715	21299	0	0	21299	2621	449	24369	49.99
8	5699	1204	228	7130	1266	5930	0	608	8589	8896	-1822	21536	0	0	21536	2732	472	24740	50.06
9	5638	520	218	6376	1011	5832	0	1256	9208	9347	-2111	21213	0	14	21213	3043	498	24754	50.03
10	5628	530	210	6368	1029	5513	0	1722	9829	9825	-2331	21627	0	14	21627	3386	499	25512	49.99
11	5651	556	201	6408	747	5353	0	2015	10207	10320	-2431	21922	0	41	21922	3637	490	26050	50.03
12	5931	794	201	6926	528	5807	0	2224	10129	10031	-2534	22496	0	79	22496	3732	487	26714	49.99
13	6118	818	202	7138	435	5913	0	2108	10111	9903	-2547	22444	0	40	22444	3749	506	26698	49.89
14	6177	778	198	7154	502	5887	0	1953	10055	10227	-2482	22773	0	23	22773	3689	468	26930	50.04
15	6232	1164	197	7592	477	5905	0	1673	9900	10250	-2528	22886	347	256	23233	3851	484	27568	49.99
16	6294	1322	194	7810	492	6221	0	1281	9800	9912	-2377	22850	570	395	23420	3928	490	27838	49.94
17	6303	1212	197	7712	747	6227	0	769	9866	10178	-2305	22847	55	82	22902	3876	482	27260	50.01
18	6306	1426	198	7930	1013	6035	0	404	9761	9962	-2361	22476	0	15	22476	3697	507	26680	50.06
19	6349	983	200	7532	1230	6116	0	58	9472	9249	-2264	21417	0	17	21417	3446	504	25367	50.06
20	6303	1194	206	7702	1402	6303	0	0	9133	9097	-1973	22045	0	0	22045	3377	487	25908	50.04
21	6261	1432	207	7900	1703	6311	0	0	8231	8521	-1830	22134	0	0	22134	3334	472	25940	50.03
22	6337	902	215	7454	1835	6332	0	0	8636	8554	-1821	21888	0	0	21888	3319	466	25672	50.01
23	6329	1044	218	7590	1773	6301	0	0	8701	8962	-1877	22291	0	0	22291	3375	458	26124	50.03
24	6319	1232	215	7766	1814	6338	0	0	8685	8927	-1846	22556	0	0	22556	3463	443	26462	50.00
MUs	143.48	27.93	5.09	176.50	29.65	145.00	0.00	16.25	218.19	221.33	-49.80	527.98	1.41	0.98	529.40	79.59	10.94	619.93	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR done due to Low Voltage at Lonikand.2)DLS done due to failure of 220/22KV 50MVA TF-3 at 400KV Chakan S/s.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jun/2023

Position as on 6.30 Hrs of 07/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	07/06/2023
MSPGCL	Koradi Unit 8	660	29/05/2023	05:36	06/06/2023	09:11	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	30/05/2023	00:08		Continued.	Boiler Tube Leakage	07/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Nasik Unit 3	210	04/06/2023	02:10	06/06/2023	03:05	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	05/06/2023	01:55	07/06/2023	05:18	Boiler Tube Leakage	08/06/2023
MSPGCL	Bhusawal Unit 3	210	05/06/2023	15:40		Continued.	Boiler Tube Leakage	08/06/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	13/06/2023
MSPGCL	Parli Unit 6	250	06/06/2023	03:45	06/06/2023	07:26	Furnace Pressure High	
MSPGCL	Koyna STG-IV Unit-4	250	06/06/2023	14:20		Continued.	GOP Problem	08/06/2023
MSPGCL	Bhusawal Unit 4	500	07/06/2023	10:42		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
400KV TIE BAY 402 STN TF 1 AND AKOLA2 CKT 1 @ NANDGAONPETH	InterState	06/06/2023	06:18			HT	Hand tripped for breaker trials of STN TF-1
TIE BAY - 405 OF SOLAPUR PG @ ALKUD	IntraState	06/06/2023	11:19	06/06/2023	12:42	PO	Diagnostic testing & Maintenance work
400 KV MAINBAY Outages/Trippings							
400/6.9KV 63MVA STN T/F 1 @ NANDGAONPETH	InterState	01/06/2023	06:09	06/06/2023	18:11	PO	ST-1 transformer oil leakage arresting, maintenance , diagnostic testing, Metering CT and CVT testing and ST1 transformer protection relay testing work. ST-1transformer painting work
MAIN BAY 401 OF STN T/F 1 @ NANDGAONPETH	InterState	06/06/2023	06:18			HT	Hand tripped for breaker trials of STN TF-1
MAIN BAY (404) OF SOLAPUR PG @ ALKUD	IntraState	06/06/2023	12:49	06/06/2023	13:38	PO	Diagnostic testing & Maintenance work
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 1	InterState	06/06/2023	08:54	06/06/2023	22:56	PO	Under MTAMC Project work, Main -II Dist Protn relay replacement work
PADGHE (GIS) PG - KUDUS CKT - 2	InterState	06/06/2023	10:51	06/06/2023	20:06	PO	CVT replacement in 400 kV Padghe-Kudus ckt-2 at MSETCL Kudus.
DABHOL - NEW KOYNA CKT - 2	IntraState	22/05/2023	13:26	06/06/2023	22:18	PO	Dismantling of exising tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/06/2023	23:37			HT	HT for load management
KORADI - KHAPERKHEDA CKT - 2	IntraState	06/06/2023	14:33	06/06/2023	15:51	T	Tripped on Distance Protection.
KORADI - KHAPERKHEDA CKT - 1	IntraState	06/06/2023	14:33	06/06/2023	15:42	T	Tripped on Distance Protection.
LONIKAND I - KOYNA STAGE-IV	IntraState	06/06/2023	21:04			T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	05/06/2023	16:30	06/06/2023	21:49	EO	for attending hot-spot observed at Y ph,D isolator jaw & B-ph,A-bus isolator ,T-jump side jaw at 400 kV Talandge
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2023	09:32	06/06/2023	15:35	PO	HV ISOLATOR OVERHAULING WORK BY SHIFTING HV CB ON 400 KV TBC
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	IntraState	06/06/2023	11:59	06/06/2023	13:54	PO	Premonsoon Maintenance Work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	IntraState	06/06/2023	12:55	06/06/2023	16:09	EO	On dtd. 06.06.2023, general switchyard inspection was carried during inspection it was found that one of the twin conductor jumpers from 400/220/33KV Y-ph Line CT snapped and now the same snapped conductor is to be re-connected. Image of the same is attached in mail. For snapped jumper connection of 400/220/33KV ICT-1 Y-ph Line CT
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	07/06/2023	11:25			PO	Pre-Monsoon maintenaance
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV WANI - PANDHARKAWDA CKT II BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
220 KV CHANDRAPUR - 2-BALLARSHAH CKT	IntraState	06/06/2023	07:07	06/06/2023	11:56	PO	Routine Maintenance work
HINGANGHAT - BHUGAON	IntraState	06/06/2023	07:09	06/06/2023	09:30	PO	Testing work
MUMEWADI -HALKARNI 2 LINE	IntraState	06/06/2023	09:01	06/06/2023	17:41	PO	Insulator cleaning work
DAHANU - GHODBUNDER CKT - 1	IntraState	06/06/2023	10:00	06/06/2023	11:30	PO	Premonsoon maintenance of Circuit Breaker.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	06/06/2023	10:06	06/06/2023	20:09	PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
BHAVEGHAR - ROMA	IntraState	06/06/2023	10:12	06/06/2023	16:40	EO	EHV breaker OH work at 220KV Bhaveghar Sub Station by shifting the line on TBC.
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	06/06/2023	10:18	06/06/2023	20:16	PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
GHATODI-NANDED	IntraState	06/06/2023	10:32	06/06/2023	18:37	PO	Restrining of Loose OPGW Earth wire
PUSAD - HINGOLI	IntraState	06/06/2023	10:33	06/06/2023	17:51	PO	Restrining of Loose OPGW earthwire
DAHANU - GHODBUNDER CKT - 2	IntraState	06/06/2023	11:52	06/06/2023	14:27	PO	Premonsoon maintenance of Circuit Breaker
MIRAJ - ICHALKARANJI	IntraState	06/06/2023	12:21	06/06/2023	17:38	EO	Balance dismantling work of tower at loc No.29A
MALEGAON (ZODGA) - BALAPUR CKT 2	IntraState	06/06/2023	12:54	06/06/2023	16:36	PO	Repairing of 132KV CKT Breaker limit switch
ALKUD - VITA	IntraState	06/06/2023	18:08	06/06/2023	21:57	EO	Jump Replacement work at Loc No.61 Y ph
OSMANABAD - SOLAPUR (BALE)	IntraState	06/06/2023	21:21	06/06/2023	22:47	EO	Y phase LA Tilted
GHODBUNDER - MSETCL BOISAR	IntraState	06/06/2023	22:55			T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VERSOVA - GHODBUNDER	IntraState	06/06/2023	23:38	06/06/2023	06:17	PO	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
GHODBUNDER - GORAI	IntraState	06/06/2023	23:51	06/06/2023	06:26	PO	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	07/06/2023	07:22			PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	07/06/2023	07:28			PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
TALOJA II - OCIL 1	IntraState	07/06/2023	08:40			PO	220kv OCIL-01 Bay Maintenance OCIL end
OSMANABAD - BARSHI	IntraState	07/06/2023	09:28			PO	Outage is required for Quarterly Maintenance
TILLARI - AMONA LINE	IntraState	07/06/2023	09:52			PO	Maintenance work
COLOURCHEM - TEMGHAR	IntraState	07/06/2023	10:18	07/06/2023	11:14	HT	sparking on wave trap observed , so Handtripped at colourchem end
KALMESHVAR-PANDHURNA	IntraState	07/06/2023	10:43			PO	Routine Maint. Work
GHODBUNDER - GORAI	IntraState	07/06/2023	11:01	07/06/2023	12:44	PO	Premonsoon maintenance of Circuit Breaker
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	06/06/2023	08:23	06/06/2023	13:30	PO	Faulty jumper replacement work by agency & Hot spot attending work.
220/33KV 25MVA PTR 2 @ PAWAS	IntraState	06/06/2023	10:00	06/06/2023	16:27	PO	For Pre-monsoon Maintenance activities of 220/33kv 25MVA T/F II & 33kV Main Bus with 33kV Equipments; Replacement Bph HVCT.
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	06/06/2023	14:15	06/06/2023	16:45	PO	Faulty jumper replacement work by agency & Hot spot attending work.
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	IntraState	07/06/2023	08:34	07/06/2023	12:16	PO	Outage is required for Diagnostic testing and maintenance work
220 / 110 / 22kV 250MVA ICT 1 @ BORIVALI (TATA)	IntraState	07/06/2023	09:18	07/06/2023	11:57	PO	R/M & Testing
220/100 KV 200 MVA ICT 2 @ PAL- DOMBIVALI	IntraState	07/06/2023	10:15			PO	Plastic paper wrapping & RM Work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
KANHAN-PENCH	IntraState	07/06/2023	09:54			PO	Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	05/06/2023	21:26	06/06/2023	06:35	PO	Tower erection & conductor shifting at loc 165
KALWA KALYAN	IntraState	06/06/2023	21:05	07/06/2023	06:40	PO	Tower erection & conductor shifting at loc 165

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHOPOLI - DAVDI	IntraState	07/06/2023	06:55	07/06/2023	12:00	PO	Lightning spikes installation

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage