

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Jun/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.506	968.842	1) Gujrat	4.450	20.470
2) Hydro	6.250	74.349	2) Madhya Pradesh	3.745	27.302
3) Gas	7.484	45.091	3) Chattisgarh	2.940	17.310
Total MSPGCL	176.240	1088.282	4) Maharashtra	204.148	1247.347
B) 1) APLM	64.150	402.782	5) Goa (Amona)	-2.093	-13.623
2) JSWEL	26.914	165.448	Total	213.190	1298.806
3) VIPL	0.000	0.000	a) Mumbai Schedule	58.584	286.272
4) RPL(AMT)	31.728	167.296	b) Mumbai Drawl	56.031	294.990
5) SWPGPL	12.465	73.472	c) MSEDCL Bilateral *	84.956	584.570
6) Other IPP	13.563	90.946	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	58.572	286.219
C) 1) TPCL Thermal	13.658	80.575	Include PX	0.000	0.000
2) TPCL Hydro	6.205	37.973	Standby	0.013	0.053
3) TPCL Gas	4.127	24.768	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.469	54.779	1) MSEDCL	501.687	3129.946
D) STATE			2) Mumbai Discoms	85.490	493.085
1) Thermal	330.453	2004.140	3) Other Discoms	12.033	69.796
(A1+C1+C4+(B1-B6))			TOTAL STATE	599.210	3692.827
2) Hydro	12.455	112.322			
(A2+C2)					
3) Gas	11.611	69.859			
(A3+B7+C3)					
4) Wind	16.525	112.550			
6) SOLAR	14.976	95.150			
TOTAL STATE	386.020	2394.021			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	5996	6988	7264	6632
MSPGCL Hydro	231	660	500	126
MSPGCL Gas	363	363	280	290
MSPGCL Total Generation	6590	8011	8044	7048
Central Sector Receipt	9704	9476	7965	8753
WIND	364	675	931	783
CPP / IPP Thermal	5181	5700	6975	6097
CPP / IPP Gas	0	0	0	0
SOLAR	2302	888	0	0
Exchange with Mumbai	-2585	-2775	-2275	-1975
MSEDCL DEMAND MET	21018	21440	21101	20283
Load Shedding	0	0	0	0
MSEDCL DEMAND	21018	21440	21101	20283
TPCL GENERATION	1139	1224	1090	703
AEML GENERATION	250	249	228	189
MUMBAI DEMAND	3974	4248	3593	2867
OTHER DISCOM DEMAND	538	535	539	423
STATE DEMAND MET	25530	26223	25233	23573
STATE DEMAND	25530	26223	25233	23573
Frequency (Hz)	49.96	50.03	50.02	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 09.02 Hrs	49.77 Hz at 23.53 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.36	25.46	186	167
Unit 8	13.18	83.04	603	510
Unit 9	13.56	57.78	605	512
Unit 10	12.61	77.66	550	447
Total	43.71	243.95		
Bhusawal				
Unit 3	0.05	2.39	46	0
Unit 4	10.78	64.10	485	330
Unit 5	4.78	55.67	485	0
Total	15.61	122.16		
Parli				
Unit 6	4.21	27.42	237	141
Unit 7	4.05	18.98	223	140
Unit 8	4.15	27.00	236	146
Total	12.40	73.40		
Chandrapur				
Unit 3	3.72	22.48	165	129
Unit 4	3.80	22.80	170	130
Unit 5	6.79	47.07	300	275
Unit 6	5.12	37.64	235	200
Unit 7	8.92	54.69	409	288
Unit 8	10.18	61.86	450	300
Unit 9	10.95	34.30	500	354
Total	49.48	280.84		
Paras				
Unit 3	5.31	26.11	234	160
Unit 4	0.00	7.43	0	0
Total	5.31	33.54		
Khaparkheda				
Unit 1	3.52	21.87	165	135
Unit 2	4.46	26.91	205	168
Unit 3	2.64	13.76	139	103
Unit 4	4.37	26.16	191	155
Unit 5	11.34	66.45	490	450
Total	26.33	155.15		
Nasik				
Unit 3	3.53	20.31	165	126
Unit 4	2.64	19.19	148	0
Unit 5	3.50	20.29	166	118
Total	9.66	59.80		
Uran				
All Units	7.48	45.09	367	280
Total	7.48	45.09		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	0.03	20	0
Total	0.03	0.03		
Koyna				
Stage 1-2	2.28	21.92	415	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.14	24.95	140	0
Stage 3	0.68	10.61	138	0
Total	3.10	57.48		
Hydro				
KDPH	0.44	2.78	19	18
VTRNA	0.76	2.96	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.61	9.54	71	60
GHATGHAR	0.33	1.58	125	0
Total	3.15	16.86		
Wind				
Total	16.52	112.55	0	0
Total	16.52	112.55		
CPP				
APML(Mus)	64.15	402.78	0	0
JSWEL(Mus)	26.91	165.45	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.73	167.30	0	0
SWPGPL-Mus	12.46	73.47	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.06	33.85	270	0
Other(Mus)	3.82	28.87	0	0
JPL	4.68	28.23	269	127
Total	148.82	899.94		
SOLAR				
Total	14.98	95.15	0	0
Total	14.98	95.15		
Tata				
Trombay 5	8.93	54.12	445	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	15.55	108	108
Trombay 7B	1.54	9.22	64	63
TATA Hydro	6.20	37.97	444	53
Trombay 8	4.73	26.46	233	131
Total	23.99	143.32		
AEML				
DTPS U-1&2	5.47	54.78	251	151
Total	5.47	54.78		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.51	968.84	MSPGCL Total	176.24	1088.28
			MSPGCL Thml+Gas	169.99	1013.93	Koyna 1,2 & 4 Total	2.42	46.87
			MSPGCL Hydro	6.25	74.35	State Total	386.02	2394.02

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6702	446	287	7435	660	6765	0	0	9504	9084	-2241	21247	0	0	21247	3606	456	25309	50.01
2	6781	262	288	7331	652	6828	0	0	9168	8782	-2129	21030	0	0	21030	3355	434	24819	49.96
3	6757	265	289	7311	696	6875	0	0	8865	8440	-2081	20832	0	0	20832	3124	409	24365	50.02
4	6554	212	290	7056	788	6508	0	0	8879	8617	-2091	20477	0	0	20477	2976	401	23854	50.03
5	6632	126	290	7048	783	6097	0	0	9095	8753	-1975	20283	0	0	20283	2867	423	23573	50.03
6	6621	121	292	7034	785	6436	0	0	9577	9022	-1934	20886	0	0	20886	2848	457	24191	50.00
7	6652	125	291	7068	686	6403	0	131	9140	8782	-1907	20692	0	0	20692	2795	471	23958	49.99
8	6541	130	291	6962	562	6075	0	605	8746	8714	-2045	20353	0	0	20353	2929	520	23802	50.01
9	6416	128	291	6835	512	5459	0	1163	9412	9202	-2389	20237	0	0	20237	3261	545	24043	50.06
10	6149	133	295	6577	566	5189	0	1661	9594	9715	-2466	20691	0	0	20691	3600	551	24842	50.08
11	6000	133	367	6500	521	5169	0	2092	10026	9696	-2576	20876	0	0	20876	3850	526	25252	49.94
12	5996	231	363	6590	364	5181	0	2302	9898	9704	-2585	21018	0	0	21018	3974	538	25530	49.96
13	6662	137	362	7161	372	5561	0	2113	9350	9232	-2532	21381	0	0	21381	4008	526	25915	49.97
14	6782	127	363	7272	452	5599	0	1808	9554	9222	-2645	21180	0	0	21180	4016	528	25724	50.04
15	6807	257	364	7428	478	5631	0	1474	10200	9678	-2721	21424	0	19	21424	4185	544	26153	50.01
16	6988	660	363	8011	675	5700	0	888	10034	9476	-2775	21440	0	39	21440	4248	535	26223	50.03
17	7023	602	364	7989	650	5664	0	483	9732	9700	-2659	21280	0	131	21280	4147	547	25974	49.99
18	7085	390	328	7803	642	6054	0	229	9626	9460	-2604	21047	0	0	21047	3917	537	25501	50.00
19	7122	238	281	7641	816	6768	0	27	8668	8078	-2493	20290	0	0	20290	3659	547	24496	50.05
20	7264	500	280	8044	931	6975	0	0	8199	7965	-2275	21101	0	0	21101	3593	539	25233	50.02
21	7290	420	284	7994	1043	6940	0	0	7978	7601	-2172	20882	0	0	20882	3578	524	24984	50.01
22	7106	226	286	7618	952	6967	0	0	7977	8020	-2189	20854	0	0	20854	3593	514	24961	50.02
23	7237	189	288	7714	1078	6994	0	0	8124	7967	-2249	21019	0	0	21019	3649	485	25153	50.09
24	7339	192	287	7818	861	6982	0	0	8479	8280	-2298	21168	0	0	21168	3712	475	25355	49.96
MUs	162.51	6.25	7.48	176.24	16.53	148.82	0.00	14.98	219.82	213.19	-56.03	501.69	0.00	0.19	501.69	85.49	12.03	599.21	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

- 1.ELR carried out at 220KV GCR S/S due to BBLR-1 & 2 loading
- 2.Power cut due to transmission constraints in Thane(U) Vashi Palghar circl

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 06/Jun/2024

Position as on 6.30 Hrs of 07/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Bhusawal Unit 3	210	03/06/2024	00:30	06/06/2024	22:45	Boiler tube leakage (On tolling).	07/06/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	16/06/2024
MSPGCL	Bhusawal Unit 5	500	05/06/2024	22:05	06/06/2024	11:49	Air heater problem	08/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
Total Capacity MSPGCL		1415						
AEML								
AEML	AEML Unit 2	250	04/06/2024	16:58	07/06/2024	07:46	Boiler Tube Leakage	07/06/2024
Total Capacity AEML		250						
IPP								
IPP	IEPL Unit 1	270	05/06/2024	20:25	06/06/2024	22:37	ID Fan Problem	
IPP	IEPL Unit 1	270	05/06/2024	23:25	06/06/2024	01:20	Protection MS temperature malfunction	
Total Capacity IPP		540						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2525						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	05/06/2024	17:15	06/06/2024	09:50	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						
FORCED OUTAGE DUE TO NO PPA								
IPP								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jun/2024

Position as on 6.30 Hrs of 07/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV TIEBAY Outages/Trippings							
TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	06/06/2024	05:57	06/06/2024	14:51	PO	Diagnostic testing and Pre Monsoon Maintenance
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	06/06/2024	05:57	06/06/2024	14:51	PO	Diagnostic testing and Pre Monsoon Maintenance
400 KV LINE Outages/Trippings							
PUNE(GIS) - TALEGAON(PG) CKT - 4	InterState	05/06/2024	17:13	06/06/2024	00:15	T	Tripped on distance protection
KALWA - TALEGAON (PG)	InterState	06/06/2024	16:16	06/06/2024	16:42	HT	HT due to heavy sparking on 29 D isolator at Kalwa ss
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVA bus reactor by new 125 MVA bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
LONIKAND I - KOYNA STAGE-IV	IntraState	05/06/2024	12:53	06/06/2024	01:59	T	Tripped on distance protection
DABHOL - NEW KOYNA CKT - 1	IntraState	06/06/2024	05:24	06/06/2024	17:20	T	Tripped on distance protection
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	06/06/2024	06:32	06/06/2024	13:03	PO	DCRM of 410 CB and Routine maintenance & Relay Testing work.
220 KV CHANDRAPUR (400 KV) - TADALI CKT	IntraState	06/06/2024	07:00	06/06/2024	12:23	PO	DAIGONISTIC TESTING WORK AT BOTH END
220 KV DEEPNAGAR (400 KV) - BAMBHORI CKT	IntraState	06/06/2024	11:09	06/06/2024	17:00	PO	FOR REPLACEMENT OF OLD FAULTY INSULATORS OF LOC NO 05,06,11,12 & 13
JAIGAD - KARAD CKT - 2	IntraState	06/06/2024	18:46			T	Tripped on distance protection
LONIKAND 2 - KARJAT CKT - 1	IntraState	07/06/2024	04:00	07/06/2024	04:56	T	Tripped from Karjat end only
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	05/06/2024	16:35	06/06/2024	01:59	T	Tripped on differential protection
400/220KV 500MVA ICT - 1 @ KARJAT	IntraState	06/06/2024	09:34	06/06/2024	20:56	PO	All Isolator Alignment work (related to ICT-1 bay) to be done by Agency, Diagnostic Testing Pre Monsoon Maintenance and relay testing work.
400 KV BR Outages/Trippings							
50 MVAr BUS REACTOR - 1 @ JAIGAD	IntraState	04/06/2024	10:29			PO	CSD RELAY INTALLATION AND COMMISSIONING AT JAIGAD END
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25	06/06/2024	00:44	T	TOWER COLLAPSED AT LOC.414-419.
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25	06/06/2024	00:45	T	TOWER COLLAPSED AT LOC.414-419.
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
GIS BHANDUP - BORIVALI	IntraState	06/06/2024	00:42	06/06/2024	06:38	PO	For the installation of saver assembly sets at TL no. 23 & 26. (Total 12 sets are to be installed) Total Completed 2 24 sets out of 48 sets.
KHARGHAR - BORIVALI CKT - 2	IntraState	06/06/2024	00:44	06/06/2024	06:41	PO	For the installation of saver assembly sets at TL no. 23 & 26. (Total 12 sets are to be installed) Total Completed 2 24 sets out of 48 sets
WAGHIVALI - DHARAVI 8	IntraState	06/06/2024	01:19	06/06/2024	07:30	PO	METRO PROJECT WORK
TROMBAY - VIKHROLI (GIS) CKT - 3	IntraState	06/06/2024	01:35	06/06/2024	07:40	PO	Project Work for - Resagging of conductor in span 38-39 at S G Barve Metro - 2B crossing
PALGHAR - PANCHALI TSS	IntraState	06/06/2024	04:20	06/06/2024	08:59	PO	Replacement of Rusted Insulator strings at Loc No.06, 21 &18.
PALGHAR - NALASOPARA	IntraState	06/06/2024	04:44	06/06/2024	09:02	PO	Replacement of Insulator String Identified in PID.
TALOJA II - OCIL 1	IntraState	06/06/2024	08:08	06/06/2024	19:20	PO	Preventive Maintenance & Testing of switchgear at OCIL end
DAHANU - VIRAJ	IntraState	06/06/2024	09:02	06/06/2024	14:27	PO	Pre Monsoon Maintenance.
DAHANU - VIRAJ	IntraState	06/06/2024	09:02	06/06/2024	14:02	PO	Inspection & Preventive Maintenance of circuit breaker
ABHIJEET-WARDHA-1	IntraState	06/06/2024	12:32	06/06/2024	15:40	T	R PH, Z1, 18.8 KM, 5.82 KA. A - Z1, R PH, 29.77 KM.
THEUR - SERUM	IntraState	06/06/2024	13:26			PO	1) Attending hotspot by double jumpering work at L. N -1 (DC tower)- Y Phase-52.9 Degree L.N.-26(MC tower)-B Phase-65 Degree L.N.-30A(MC tower)-B Phase-58 degree
JEJURI (400KV) - BARAMATI CKT	IntraState	06/06/2024	15:26			PO	Retrofitting of Distance Protection Relay to be carried out by M/s GE.
220 KV AMRAVATI - KARANJA CKT	IntraState	06/06/2024	15:50	06/06/2024	20:14	T	R PH Y PH 3.3KA 17.8KM Z1
KHARGHAR - NET MAGIC GIS	IntraState	06/06/2024	22:26	07/06/2024	02:07	PO	For safety purpose during saver assembly installation work on 220 kV Kharghar-Sonkhar line
KHARGHAR - SONKHAR	IntraState	06/06/2024	22:37	07/06/2024	01:54	PO	For the installation of saver assembly sets at TL no. 679 (Total 3 sets out of 6 sets are to be installed)
TILLARI - AMONA LINE	IntraState	07/06/2024	02:55	07/06/2024	04:46	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 07/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 200 MVA ICT 3	IntraState	06/06/2024	08:24	06/06/2024	10:26	PO	FOR PREMONSOON MAINTENANCE AND RM WORK OF BAY
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	06/06/2024	09:13	06/06/2024	11:20	PO	Premonsoon Maintenance Work, Plastic paper wrapping to TF Auxiliaries
35 MVA 220/ 6.6 KV STN TF - II @ PARLI U-8	IntraState	06/06/2024	09:35	06/06/2024	11:30	PO	PREMANSOON MAINT WORK
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	06/06/2024	10:15	06/06/2024	12:35	PO	Pre monsoon Maintenance work
220/110kV 100MVA ICT-1@ NIWALI	IntraState	06/06/2024	10:51			PO	HV CB overhauling work
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	06/06/2024	11:26	06/06/2024	12:47	PO	Premonsoon Maintenance Work, Plastic paper wrapping to TF Auxiliaries.
220/132 KV 200MVA ICT 2 @ KURKUMBH	IntraState	06/06/2024	13:20	06/06/2024	14:30	PO	Pre monsoon Maintenance work
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage