

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 06/Jul/2018 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 109.415        | 665.351         | 1) Gujrat                      | -6.949         | -21.213         |
| 2) Hydro            | 4.782          | 23.878          | 2) Madhya Pradesh              | 11.828         | 85.880          |
| 3) Gas              | 8.666          | 53.113          | 3) Chattisgarh                 | 5.500          | 35.000          |
| <b>Total MSPGCL</b> | <b>122.863</b> | <b>742.342</b>  | 4) Maharashtra                 | 105.038        | 589.557         |
| B) 1) APMIL         | 55.817         | 352.272         | 5) Goa (Amona)                 | -0.352         | -2.486          |
| 2) JSWEL            | 17.275         | 99.842          | <b>Total</b>                   | <b>115.065</b> | <b>686.738</b>  |
| 3) VIPL             | 5.986          | 37.123          | a) Mumbai Schedule             | 26.549         | 135.729         |
| 4) RPL(AMT)         | 9.981          | 62.362          | b) Mumbai Drawl                | 35.829         | 181.516         |
| 5) SWPGPL           | 2.521          | 14.993          | c) MSEDCL Bilateral *          | 26.455         | 146.632         |
| 6) Other IPP        | 7.496          | 36.923          | Include PX                     | -3.611         | -15.789         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 26.549         | 135.729         |
| C) 1) TPCL Thermal  | 5.338          | 41.865          | Include PX                     | 9.528          | 44.166          |
| 2) TPCL Hydro       | 6.839          | 36.162          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.821          | 23.031          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.049          | 62.996          | 1) MSEDCL                      | 346.790        | 2139.038        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 60.876         | 345.569         |
| 1) Thermal          | 222.878        | 1373.727        | 3) Other Discoms               |                |                 |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>407.666</b> | <b>2484.607</b> |
| 2) Hydro (A2+C2)    | 11.621         | 60.040          |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 12.487         | 76.144          |                                |                |                 |
| 4) Wind             | 41.526         | 260.605         |                                |                |                 |
| 6) SOLAR            | 4.089          | 27.354          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>292.601</b> | <b>1797.870</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 4980                      | 4552                  | 4359                      | 4615                      |
| MSPGCL Hydro               | 218                       | 288                   | 349                       | 62                        |
| MSPGCL Gas                 | 375                       | 351                   | 360                       | 378                       |
| MSPGCL Total Generation    | 5573                      | 5191                  | 5068                      | 5055                      |
| Central Sector Receipt     | 5048                      | 5009                  | 4937                      | 4167                      |
| WIND                       | 1917                      | 1917                  | 1790                      | 1380                      |
| CPP / IPP Thermal          | 4296                      | 3817                  | 4364                      | 3846                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 424                       | 574                   | 0                         | 0                         |
| Exchange with Mumbai       | -1787                     | -1962                 | -1632                     | -1102                     |
| <b>MSEDCL DEMAND MET</b>   | <b>15471</b>              | <b>14546</b>          | <b>14527</b>              | <b>13346</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 15471                     | 14546                 | 14527                     | 13346                     |
| TPCL GENERATION            | 692                       | 771                   | 793                       | 364                       |
| AEML GENERATION            | 376                       | 375                   | 375                       | 377                       |
| <b>MUMBAI DEMAND</b>       | <b>2855</b>               | <b>3108</b>           | <b>2800</b>               | <b>1843</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>0</b>                  | <b>0</b>              | <b>0</b>                  | <b>0</b>                  |
| STATE DEMAND MET           | 18326                     | 17654                 | 17327                     | 15189                     |
| <b>STATE DEMAND</b>        | <b>18326</b>              | <b>17654</b>          | <b>17327</b>              | <b>15189</b>              |
| Frequency (Hz)             | 49.94                     | 50.00                 | 49.81                     | 49.93                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 13.04 Hrs | 49.67 Hz at 06.14 Hrs | 49.93         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 06/Jul/2018

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 9.92         | 54.36         | 504      | 330      |
| Unit 10            | 9.18         | 52.56         | 448      | 330      |
| <b>Total</b>       | <b>19.10</b> | <b>106.92</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.80         | 56.69         | 485      | 355      |
| Unit 5             | 9.76         | 56.12         | 485      | 350      |
| <b>Total</b>       | <b>19.56</b> | <b>112.81</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 4.90         | 25.96         | 232      | 182      |
| <b>Total</b>       | <b>4.90</b>  | <b>25.96</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 9.04         | 55.86         | 455      | 300      |
| Unit 6             | 8.92         | 59.26         | 441      | 302      |
| Unit 7             | 8.70         | 57.85         | 423      | 320      |
| Unit 8             | 10.53        | 62.54         | 495      | 360      |
| Unit 9             | 0.00         | 4.95          | 0        | 0        |
| <b>Total</b>       | <b>37.19</b> | <b>240.46</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.17         | 25.76         | 194      | 150      |
| Unit 4             | 4.27         | 23.65         | 200      | 155      |
| <b>Total</b>       | <b>8.43</b>  | <b>49.40</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.04         | 19.24         | 145      | 100      |
| Unit 2             | 3.16         | 21.04         | 150      | 85       |
| Unit 3             | 3.09         | 21.90         | 162      | 109      |
| Unit 4             | 3.28         | 21.65         | 150      | 124      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>12.58</b> | <b>83.83</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.86         | 23.05         | 173      | 156      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 3.82         | 22.92         | 163      | 154      |
| <b>Total</b>       | <b>7.67</b>  | <b>45.96</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 8.67         | 53.11         | 381      | 349      |
| <b>Total</b>       | <b>8.67</b>  | <b>53.11</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.10         | 0.45          | 24       | 0        |
| <b>Total</b>       | <b>0.10</b>  | <b>0.45</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.15         | 10.64         | 225      | 40       |
| Stage 4         | 0.10         | 0.18          | 102      | 0        |
| Stage 3         | 1.25         | 6.04          | 160      | 0        |
| <b>Total</b>    | <b>3.50</b>  | <b>16.86</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.00          | 0        | 0        |
| VTRNA           | 0.00         | 0.32          | 0        | 0        |
| TILLARI         | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.42         | 2.28          | 80       | 0        |
| SMLHY_PTN       | 0.16         | 0.58          | 15       | 4        |
| GHATGHAR        | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>0.58</b>  | <b>3.19</b>   |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 41.53        | 260.60        | 0        | 0        |
| <b>Total</b>    | <b>41.53</b> | <b>260.60</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 55.82        | 352.27        | 0        | 0        |
| JSWEL(Mus)      | 17.28        | 99.84         | 0        | 0        |
| VIPL(Mus)       | 5.99         | 37.12         | 0        | 0        |
| RPLAMT(Mus)     | 9.98         | 62.36         | 0        | 0        |
| WPCL(Mus)       | 2.52         | 14.99         | 0        | 0        |
| Other(Mus)      | 7.50         | 36.92         | 0        | 0        |
| <b>Total</b>    | <b>99.08</b> | <b>603.52</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 4.09         | 27.35         | 0        | 0        |
| <b>Total</b>    | <b>4.09</b>  | <b>27.35</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 0.00         | 9.51          | 0        | 0        |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.37         | 14.30         | 109      | 78       |
| Trombay 7B      | 1.45         | 8.73          | 64       | 53       |
| TATA Hydro      | 6.84         | 36.16         | 459      | 2        |
| Trombay 8       | 5.34         | 32.36         | 229      | 214      |
| <b>Total</b>    | <b>16.00</b> | <b>101.06</b> |          |          |
| <b>R-INFRA</b>  |              |               |          |          |
| DTPS U-1&2      | 9.05         | 63.00         | 383      | 374      |
| <b>Total</b>    | <b>9.05</b>  | <b>63.00</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 109.42      | 665.35        | MSPGCL Total        | 122.86      | 742.34        |
|                |             |         | MSPGCL Thml+Gas | 118.08      | 718.46        | Koyna 1,2 & 4 Total | 2.25        | 10.82         |
|                |             |         | MSPGCL Hydro    | 4.78        | 23.88         | State Total         | 292.60      | 1797.87       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 06/Jul/2018

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | LOAD<br>SHED<br>DING | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        |                      |                               |                      |                               |                 |               |
| 1                  | 4811        | 152  | 357  | 5320   | 1434  | 4166      | 0    | 0     | 4227        | 4094        | -1178                | 13836                  | 0                    | 13836                         | 2161                 |                               | 15997           | 49.85         |
| 2                  | 4784        | 91   | 358  | 5233   | 1376  | 3992      | 0    | 0     | 4326        | 4205        | -1074                | 13732                  | 0                    | 13732                         | 1978                 |                               | 15710           | 49.95         |
| 3                  | 4615        | 62   | 378  | 5055   | 1380  | 3846      | 0    | 0     | 4438        | 4167        | -1102                | 13346                  | 0                    | 13346                         | 1843                 |                               | 15189           | 49.93         |
| 4                  | 4574        | 56   | 357  | 4987   | 1369  | 3817      | 0    | 0     | 4529        | 4353        | -1026                | 13500                  | 0                    | 13500                         | 1758                 |                               | 15258           | 49.96         |
| 5                  | 4835        | 90   | 360  | 5285   | 1457  | 4032      | 0    | 0     | 4680        | 4228        | -1013                | 13989                  | 0                    | 13989                         | 1739                 |                               | 15728           | 49.97         |
| 6                  | 4949        | 160  | 381  | 5490   | 1520  | 4342      | 0    | 0     | 4668        | 4482        | -1106                | 14728                  | 0                    | 14728                         | 1830                 |                               | 16558           | 49.91         |
| 7                  | 5036        | 265  | 359  | 5660   | 1439  | 4571      | 0    | 42    | 5269        | 5384        | -1153                | 15943                  | 0                    | 15943                         | 1983                 |                               | 17926           | 49.86         |
| 8                  | 5026        | 216  | 374  | 5616   | 1460  | 4367      | 0    | 139   | 5692        | 5701        | -1263                | 16020                  | 0                    | 16020                         | 2185                 |                               | 18205           | 49.99         |
| 9                  | 4995        | 221  | 359  | 5575   | 1522  | 4291      | 0    | 291   | 5525        | 5500        | -1526                | 15653                  | 0                    | 15653                         | 2508                 |                               | 18161           | 50.00         |
| 10                 | 4980        | 218  | 375  | 5573   | 1917  | 4296      | 0    | 424   | 5707        | 5048        | -1787                | 15471                  | 0                    | 15471                         | 2855                 |                               | 18326           | 49.94         |
| 11                 | 4548        | 264  | 354  | 5166   | 1987  | 4050      | 0    | 513   | 5496        | 5195        | -1953                | 14958                  | 0                    | 14958                         | 3083                 |                               | 18041           | 49.94         |
| 12                 | 4429        | 484  | 349  | 5262   | 1968  | 3844      | 0    | 575   | 5173        | 5262        | -1980                | 14931                  | 0                    | 14931                         | 3158                 |                               | 18089           | 49.95         |
| 13                 | 4552        | 288  | 351  | 5191   | 1917  | 3817      | 0    | 574   | 5419        | 5009        | -1962                | 14546                  | 0                    | 14546                         | 3108                 |                               | 17654           | 50.00         |
| 14                 | 4380        | 109  | 371  | 4860   | 2112  | 3794      | 0    | 458   | 5326        | 5157        | -1810                | 14571                  | 0                    | 14571                         | 2943                 |                               | 17514           | 50.02         |
| 15                 | 4342        | 65   | 351  | 4758   | 2267  | 3787      | 0    | 477   | 5056        | 4878        | -1816                | 14351                  | 0                    | 14351                         | 2981                 |                               | 17332           | 49.93         |
| 16                 | 4278        | 55   | 350  | 4683   | 2583  | 3772      | 0    | 303   | 5085        | 4782        | -1821                | 14302                  | 0                    | 14302                         | 3000                 |                               | 17302           | 49.94         |
| 17                 | 4138        | 125  | 363  | 4626   | 2318  | 3572      | 0    | 195   | 4804        | 4615        | -1784                | 13542                  | 0                    | 13542                         | 2981                 |                               | 16523           | 49.93         |
| 18                 | 4185        | 317  | 370  | 4872   | 2092  | 3985      | 0    | 85    | 4597        | 4749        | -1726                | 14057                  | 0                    | 14057                         | 2926                 |                               | 16983           | 49.99         |
| 19                 | 4147        | 141  | 354  | 4642   | 2186  | 4189      | 0    | 13    | 4950        | 4829        | -1632                | 14227                  | 0                    | 14227                         | 2832                 |                               | 17059           | 49.95         |
| 20                 | 4359        | 349  | 360  | 5068   | 1790  | 4364      | 0    | 0     | 4736        | 4937        | -1632                | 14527                  | 0                    | 14527                         | 2800                 |                               | 17327           | 49.81         |
| 21                 | 4370        | 359  | 362  | 5091   | 1483  | 4453      | 0    | 0     | 4691        | 4799        | -1490                | 14336                  | 0                    | 14336                         | 2727                 |                               | 17063           | 49.82         |
| 22                 | 4363        | 341  | 354  | 5058   | 1402  | 4559      | 0    | 0     | 4658        | 4648        | -1359                | 14308                  | 0                    | 14308                         | 2594                 |                               | 16902           | 49.89         |
| 23                 | 4378        | 219  | 364  | 4961   | 1389  | 4605      | 0    | 0     | 4877        | 4732        | -1303                | 14384                  | 0                    | 14384                         | 2492                 |                               | 16876           | 49.88         |
| 24                 | 4341        | 135  | 355  | 4831   | 1158  | 4565      | 0    | 0     | 4916        | 4312        | -1333                | 13533                  | 0                    | 13533                         | 2411                 |                               | 15944           | 49.94         |
| MUs                | 109.41      | 4.78 | 8.67 | 122.86 | 41.53 | 99.08     | 0.00 | 4.09  | 118.85      | 115.07      | -35.83               | 346.79                 | 0.00                 | 346.79                        | 60.88                |                               | 407.67          | 49.93         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 06/Jul/2018**

**Position as on 6.30 Hrs of 07/Jul/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                            |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                             |               |
| MSPGCL                | Koyna STG-IV Unit-4     | 250      | 12/06/2018   | 09.40        |            | Continued. | Annual Overhaul                                                            |               |
| MSPGCL                | Khaparkhedha Unit 5     | 500      | 20/06/2018   | 05.14        |            | Continued. | Annual Overhaul                                                            |               |
| MSPGCL                | Parli Unit 6            | 250      | 24/06/2018   | 18.02        |            | Continued. | Zero Schedule(Converted for Capital overhaul from 00.00Hrs Dt. 23/07/2018) |               |
| MSPGCL                | Koradi Unit 8           | 660      | 29/06/2018   | 13.27        |            | Continued. | Converted to APH from 19/07/2018                                           |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 01/07/2018   | 11.35        |            | Continued. | Annual Overhaul                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                          |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                    | 25/06/2022    |
| IPP                   | SWPGPL U-2              | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                     |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                       |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                       |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 03/12/2017   | 01.35        |            | Continued. | Water Shortage                                                             |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 03/12/2017   | 14.17        |            | Continued. | Water Shortage                                                             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 14/04/2018   | 23.45        |            | Continued. | Stator Earth Fault                                                         |               |
| IPP                   | RPL(AMT) U-1            | 270      | 01/05/2018   | 00.00        |            | Continued. | Coal Shortage( Zero schedule on 30.06.2018)                                |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/05/2018   | 18.46        |            | Continued. | Coal Swapping IEPL                                                         |               |
| MSPGCL                | Nasik Unit 4            | 210      | 01/06/2018   | 00.53        |            | Continued. | Dhariwal Inter Change                                                      |               |
| MSPGCL                | Uran Unit 6             | 108      | 09/06/2018   | 11.50        |            | Continued. | GT winding short.                                                          |               |
| IPP                   | SWPGPL U-4              | 135      | 10/06/2018   | 00.01        |            | Continued. | Maintenance work                                                           |               |
| IPP                   | VIPL U-1                | 300      | 11/06/2018   | 00.30        |            | Continued. | Coal Shortage                                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 11/06/2018   | 22.10        |            | Continued. | Coal Shortage                                                              |               |
| MSPGCL                | Parli Unit 7            | 250      | 17/06/2018   | 08.32        |            | Continued. | ZERO SCHEDULE                                                              |               |
| IPP                   | RPL(AMT) U-4            | 270      | 22/06/2018   | 17.31        |            | Continued. | Bottom Ash Problem.                                                        |               |
| IPP                   | RPL(AMT) U-3            | 270      | 26/06/2018   | 00.01        |            | Continued. | Zero Schedule                                                              |               |
| IPP                   | IEPL Unit 1             | 270      | 26/06/2018   | 13.00        |            | Continued. | Poor Coal Receipt                                                          |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01.12        |            | Continued. | Stator Earth Fault                                                         |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01:12        |            | Continued. | Stator Earth Fault                                                         |               |
| TPC-G                 | Trombay 5               | 500      | 03/07/2018   | 00.31        | 07/07/2018 | 13.29      | to attend east side bunker gallery junction tower 5 cross bracing.         |               |
| IPP                   | Adani U-5               | 660      | 04/07/2018   | 14:52        |            | Continued. | Turbine side MS Drain leakage.                                             |               |
| IPP                   | JSW (J) U2              | 300      | 05/07/2018   | 06.44        |            | Continued. | Generator Elect. Fault                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 06/Jul/2018**

**Position as on 6.30 Hrs of 07/Jul/2018**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage    | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------|---------------|
| IPP                | RPL(AMT) U-5            | 270      | 06/07/2018   | 07.18        | 06/07/2018 | 09.10      | Auxiliary Problem   |               |
| MSPGCL             | Khaparkheda Unit 1      | 210      | 07/07/2018   | 00.38        | 07/07/2018 | 06.57      | Flame Failure       |               |
| MSPGCL             | Khaparkheda Unit 4      | 210      | 07/07/2018   | 10.15        |            | Continued. | Boiler Tube Leakage |               |

