

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Jul/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	135.366	867.396	1) Gujrat	0.669	-15.332
2) Hydro	5.632	38.251	2) Madhya Pradesh	3.420	29.532
3) Gas	0.000	0.000	3) Chattisgarh	3.290	13.100
Total MSPGCL	140.998	905.647	4) Maharashtra	158.989	988.676
B) 1) APLM	56.522	383.626	5) Goa (Amona)	-1.051	-6.754
2) JSWEL	21.274	115.788	Total	165.317	1009.222
3) VIPL	0.000	0.000	a) Mumbai Schedule	38.775	214.784
4) RPL(AMT)	24.675	150.055	b) Mumbai Drawl	42.126	236.823
5) SWPGPL	8.805	52.519	c) MSEDCL Bilateral *	83.747	505.710
6) Other IPP	6.269	40.020	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	38.775	213.985
C) 1) TPCL Thermal	3.618	25.875	Include PX	0.000	0.000
2) TPCL Hydro	5.447	35.574	Standby	0.000	0.798
3) TPCL Gas	4.128	23.631	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.675	52.674	1) MSEDCL	428.393	2637.758
D) STATE			2) Mumbai Discoms	62.994	374.577
1) Thermal	264.204	1687.953	3) Other Discoms	9.863	59.016
(A1+C1+C4+(B1-B6))			TOTAL STATE	501.250	3071.351
2) Hydro (A2+C2)	11.079	73.825			
3) Gas (A3+B7+C3)	4.128	23.631			
4) Wind	46.079	206.567			
6) SOLAR	10.443	70.153			
TOTAL STATE	335.933	2062.129			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5533	5046	6008	5990
MSPGCL Hydro	229	298	299	148
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5762	5344	6307	6138
Central Sector Receipt	8008	7485	6648	5851
WIND	2253	2598	2547	667
CPP / IPP Thermal	4427	4262	5769	5397
CPP / IPP Gas	0	0	0	0
SOLAR	965	792	0	0
Exchange with Mumbai	-2211	-2073	-1889	-1160
MSEDCL DEMAND MET	18767	17973	18935	16573
Load Shedding	0	0	0	0
MSEDCL DEMAND	18767	17973	18935	16573
TPCL GENERATION	511	564	632	560
AEML GENERATION	288	290	345	305
MUMBAI DEMAND	3010	2927	2866	2025
OTHER DISCOM DEMAND	437	435	447	320
STATE DEMAND MET	22214	21335	22248	18918
STATE DEMAND	22214	21335	22248	18918
Frequency (Hz)	49.98	50.00	50.05	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 10:17 Hrs	49.77 Hz at 14:18 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.85	23.82	180	130
Unit 8	12.86	76.26	615	372
Unit 9	11.93	73.61	558	371
Unit 10	10.98	71.12	500	382
Total	39.61	244.81		
Bhusawal				
Unit 3	3.05	19.20	140	110
Unit 4	9.56	59.92	450	285
Unit 5	9.62	62.38	460	280
Total	22.24	141.50		
Parli				
Unit 6	3.64	8.09	172	144
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	3.64	8.09		
Chandrapur				
Unit 3	3.34	20.72	160	119
Unit 4	3.30	20.62	155	120
Unit 5	0.00	0.00	0	0
Unit 6	7.76	50.84	381	285
Unit 7	7.79	50.85	391	279
Unit 8	9.45	62.30	454	283
Unit 9	9.09	64.43	456	288
Total	40.75	269.77		
Paras				
Unit 3	0.00	15.68	0	0
Unit 4	4.67	29.32	221	146
Total	4.67	45.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.87	15.22	132	104
Unit 3	3.37	24.09	183	0
Unit 4	2.52	18.15	109	100
Unit 5	8.97	60.39	435	310
Total	17.73	117.87		
Nasik				
Unit 3	3.58	8.04	179	119
Unit 4	3.14	19.99	143	119
Unit 5	0.00	12.33	0	0
Total	6.72	40.37		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	1.60	12.30	230	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	0.00	0	0
Stage 3	0.73	4.39	106	0
Total	2.34	16.69		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.36	0	0
TILLARI	0.16	1.16	40	0
BHIRA T.R.	0.47	2.69	80	0
SMLHY_PTN	2.66	15.15	139	108
GHATGHAR	0.00	2.06	0	0
Total	3.30	21.56		
Wind				
Total	46.08	206.57	0	0
Total	46.08	206.57		
CPP				
APML(Mus)	56.52	383.63	0	0
JSWEL(Mus)	21.27	115.79	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.68	150.06	0	0
SWPGPL-Mus	8.80	52.52	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.18	31.24	271	157
Other(Mus)	1.08	8.78	0	0
Total	117.54	742.01		
SOLAR				
Total	10.44	70.15	0	0
Total	10.44	70.15		
Tata				
Trombay 5	0.00	3.11	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	14.70	108	108
Trombay 7B	1.54	8.93	64	64
TATA Hydro	5.45	35.57	335	101
Trombay 8	3.62	22.77	206	129
Total	13.19	85.08		
AEML				
DTPS U-1&2	7.68	52.67	393	288
Total	7.68	52.67		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	135.37	867.40	MSPGCL Total	141.00	905.65
			MSPGCL Thml+Gas	135.37	867.40	Koyna 1,2 & 4 Total	1.60	12.30
			MSPGCL Hydro	5.63	38.25	State Total	335.93	2062.13

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5971	153	0	6124	775	5743	0	0	6190	5936	-1260	16940	0	0	16940	2324	378	19642	50.01
2	6023	148	0	6171	736	5447	0	0	6462	6087	-1274	16809	0	0	16809	2156	358	19323	49.98
3	5990	148	0	6138	667	5397	0	0	6330	5851	-1160	16573	0	0	16573	2025	320	18918	49.99
4	6035	148	0	6183	749	5435	0	0	6339	5895	-1174	16758	0	0	16758	1957	330	19045	50.01
5	6069	149	0	6218	947	5316	0	0	6810	6320	-1259	17195	0	0	17195	1971	347	19513	50.02
6	6042	149	0	6191	1033	5191	0	0	7782	7248	-1326	17967	0	0	17967	2063	370	20400	49.98
7	6082	149	0	6231	1365	5239	0	77	8412	8045	-1471	19084	0	0	19084	2213	402	21699	50.00
8	5910	231	0	6141	1911	4751	0	306	8416	8199	-1696	19186	0	0	19186	2408	426	22020	49.98
9	5582	260	0	5842	2242	4647	0	684	8133	7837	-2009	18799	0	0	18799	2735	444	21978	49.97
10	5533	229	0	5762	2253	4427	0	965	8141	8008	-2211	18767	0	0	18767	3010	437	22214	49.98
11	5404	234	0	5638	2151	4264	0	1247	8076	7989	-2317	18527	0	0	18527	3171	445	22143	50.08
12	5123	291	0	5414	2148	4278	0	1453	7976	7687	-2278	18263	0	0	18263	3188	439	21890	49.98
13	4609	277	0	4886	2187	3888	0	1543	7970	7505	-2173	17414	0	0	17414	3114	422	20950	49.98
14	4587	263	0	4850	2234	3885	0	1367	7736	7480	-2065	17343	0	0	17343	2990	408	20741	50.05
15	4699	385	0	5084	2483	4146	0	1129	7566	7250	-2034	17636	0	0	17636	2945	422	21003	49.97
16	5046	298	0	5344	2598	4262	0	792	7361	7485	-2073	17973	0	0	17973	2927	435	21335	50.00
17	5593	427	0	6020	2667	4313	0	606	6810	6547	-2078	17623	0	0	17623	2926	452	21001	49.99
18	5843	413	0	6256	2598	4627	0	244	6571	6295	-2063	17506	0	0	17506	2907	451	20864	49.97
19	5899	310	0	6209	2677	4926	0	30	7100	6836	-2030	18192	0	0	18192	2886	456	21534	50.03
20	6008	299	0	6307	2547	5769	0	0	7057	6648	-1889	18935	0	0	18935	2866	447	22248	50.05
21	5980	203	0	6183	2452	5588	0	0	6834	6494	-1735	18551	0	0	18551	2746	431	21728	49.99
22	5930	168	0	6098	2288	5585	0	0	6533	5956	-1601	17898	0	0	17898	2595	428	20921	50.02
23	5784	150	0	5934	2204	5231	0	0	6508	6185	-1538	17599	0	0	17599	2484	417	20500	50.06
24	5624	150	0	5774	2167	5190	0	0	6191	5534	-1412	16856	0	0	16856	2387	397	19640	50.07
MUs	135.37	5.63	0.00	141.00	46.08	117.54	0.00	10.44	173.30	165.32	-42.13	428.39	0.00	0.00	428.39	62.99	9.86	501.25	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jul/2023

Position as on 6.30 Hrs of 07/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	09/07/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyana STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	On boiler protection	
MSPGCL	Parli Unit 7	250	29/06/2023	14:31		Continued.	On Zero Schedule	
TPC-G	Trombay 5	500	01/07/2023	11:51		Continued.	Coal feeding problem	
IPP	SWPGPL U-1	135	02/07/2023	02:54		Continued.	PA Fan problem	10/07/2023
MSPGCL	Paras Unit 3	250	04/07/2023	09:39	07/07/2023	11:04	Boiler Tube Leakage	06/07/2023
MSPGCL	Nasik Unit 5	210	04/07/2023	18:00		Continued.	Generator Swapping : nashik Unit-3 sync 16:35 Hrs and tolling agreement with IEPL	
MSPGCL	Khaparkheda Unit 3	210	06/07/2023	07:46	06/07/2023	10:21	Furnace Pressure High	
MSPGCL	Koradi Unit-10	660	07/07/2023	12:30		Continued.	To attend Hot Spot at B Phase Jumper, connect to line CT at 400 KV Koradi II.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
TIE BAY (408) LINE - 2 OF KORADI-2 @ KORADI 3	IntraState	06/07/2023	09:51	06/07/2023	13:08	PO	DGA test of Current Transformer
TBC @ PADGHE	IntraState	06/07/2023	11:32	06/07/2023	17:33		1) A bus PG isolator clamp replacement 2) Bay maint work.
TBC 1 @ CHANDRAPUR GCR	IntraState	06/07/2023	13:20	06/07/2023	16:57	EO	To attend the closing problem of Yph of circuit breaker.
TIE BAY (411) LINE - 1 OF KORADI-2 @ KORADI 3	IntraState	07/07/2023	09:57	07/07/2023	13:09	PO	DGA test of Current Transformer
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synchronizing CVT.
MAIN BAY (403) OF CHANDRAPUR GCR CKT - 1 @ CHANDRAPUR - 2	IntraState	06/07/2023	10:45	06/07/2023	18:07	PO	Diagnostic testing and allied bay maintenance work
MAIN BAY (409) LINE - 2 OF KORADI-2 @ KORADI 3	IntraState	06/07/2023	14:21	06/07/2023	16:15	PO	DGA test of Current Transformer
MAIN BAY (412) LINE - 1 OF KORADI-2 @ KORADI 3	IntraState	07/07/2023	14:26			PO	DGA test of Current Transformer
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/07/2023	08:12			HT	HT for Load Management
DHULE- - BABLESHWAR CKT - 1	IntraState	06/07/2023	08:48	06/07/2023	19:23	PO	Routine Line maintenance and Insulator cleaning work
DABHOL - NAGOTHANE CKT - 1	IntraState	06/07/2023	10:07	06/07/2023	17:07	HT	Work at Dabhol end
JEJURI- KOYNA STAGE-IV	IntraState	06/07/2023	17:21	07/07/2023	06:26	PO	For Maintenance & Testing work
JAIGAD - KARAD CKT - 2	IntraState	07/07/2023	00:44	07/07/2023	06:51	HT	For voltage management
CHANDRAPUR - KHAPERKHEDA	IntraState	07/07/2023	07:16			PO	Replacement of 19 nos.of faulty string observed in PID testing.16 nos of tension strings and 3 nos., of suspension strings
DHULE- - BABLESHWAR CKT - 2	IntraState	07/07/2023	09:39			PO	Routine Line maintenance and Insulator cleaning work,CVT ,Tan delta & bay maintenance work
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	07/07/2023	11:42			PO	Diagnostic Testing and Maintenance Work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
220 KV TBC Outages/Trippings							
220 KV TBC	IntraState	06/07/2023	08:15	06/07/2023	10:00	HT	Diagnostic testing work.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
GOREGAON - AAREY CKT - 2	IntraState	17/06/2023	18:14			PO	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
URAN - KHARGHAR 1	IntraState	23/06/2023	17:36			PO	LILO and commissioning of 220kV Ulwe GIS
BAPGAON - KALWA	IntraState	29/06/2023	13:06			PO	Erection of cable termination kit and LA on newly erected CTT Monopole on 220 KV Kalwa Bapgaon line in between Loc No-398 to 399 for the Work of newly proposed 220KV GIS substation of M/s. Estela Enterprises Pvt. Ltd
GOREGAON - VERSOVA CKT - 1	IntraState	05/07/2023	11:08	06/07/2023	19:46	EO	Attending Hotspot and conductor damage at VAB 19 by replacing all phase connection between VAB 19 to VAB 19A. Removing PG Clamp arrangement by jumper cone connection
KARAD -MUDSHINGI CKT 2-TAK	IntraState	06/07/2023	09:15	06/07/2023	18:07	PO	Cold line washing of insulator strings
KANDALGAON - PIRANGUT	IntraState	06/07/2023	10:01	06/07/2023	17:42	PO	Work :-1) Attending hot spots at Loc no 100,101 2) Emergency Tree Cutting
PHURSUNGI-PARVATI	IntraState	06/07/2023	10:28	06/07/2023	12:11	PO	Bay is to be shifted on TBC for CRM and timing measurement work without affecting any load.
GHODBUNDER - MSETCL BOISAR	IntraState	06/07/2023	10:30	06/07/2023	18:22	EO	Replacement of Old hardware at critical locations.
KHADKI- CENTURY ENKA	IntraState	06/07/2023	10:53	06/07/2023	13:40	PO	Half Yearly Maintenance Work
URAN - APTA CKT - 1	IntraState	06/07/2023	11:05	06/07/2023	18:21	EO	Replacement of damaged jumper at Loc no. 64 (Top & Middle phase)
BABLESHWAR- ALEPHATA CKT - 1	IntraState	06/07/2023	14:21	06/07/2023	21:10	PO	220 Kv Babhaleshwar Alephata Ckt for attending the damage conductor at various cut point locations found in monkey patrolling of the line. 83 Y ph Alephata side, 82 B ph Alephata side, 74 R Y B ph BBLR side, 98 R ph alephata side . 124 R ph BBLR side , 131 R Y B PH ALEphata side . 172 R Y B ph BBLR SIDE ,
GHODBUNDER - MSETCL BOISAR	IntraState	07/07/2023	05:19	07/07/2023	09:52	PO	For the replacement of old hardwares at various critical locations.
BORIVALI - BOISAR II LINE	IntraState	07/07/2023	05:21	07/07/2023	09:59	PO	1) For the replacement of old hardwares at various critical locations. 2) For replacement of Wave Traps at 220KV Borivali S/stn
KARAD -MUDSHINGI CKT 2-TAK	IntraState	07/07/2023	08:47			PO	Cold line washing of insulator strings
KARAD -MUDSHINGI CKT 2-TAK	IntraState	07/07/2023	08:47			PO	For insulator strings cleaning by cold line method .
TALANDGE - BIDRI	IntraState	07/07/2023	10:06			PO	Replacement of Faulty PID string and Quarterly maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 07/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - WADA	IntraState	07/07/2023	11:35			PO	Routine maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132-110 KV 100 MVA ICT 2	IntraState	21/06/2023	11:00			EO	Replacement of HV CB
220/132KV 200MVA ICT 1 @ JEUR	IntraState	05/07/2023	14:44			PO	Outage is required for Quarterly Maintenance
220/33KV 50MVA PTR 2 @ KATHAPUR	IntraState	06/07/2023	09:13	06/07/2023	20:02	PO	OLTC Epoxy coupling rod replacement work and general premonsoon maintenance
220/33KV 50MVA PTR 1 @ KURKUMBH	IntraState	06/07/2023	09:30	06/07/2023	11:29	PO	Premonsoon Maintenance of PTR and 33kV equipments
220/33 KV 50 MVA PTR 1	IntraState	06/07/2023	10:15	06/07/2023	20:05	HT	R Y B HV CT replacement works under les and 9 number aux relay replacement work.
220/132-110/11KV 200MVA VID ICT 1 @ MIRAJ	IntraState	06/07/2023	11:22	06/07/2023	18:41	PO	HV CB Maintenance Work
220/33KV 50MVA PTR -2 @ KURKUMBH	IntraState	06/07/2023	12:40	06/07/2023	14:51	PO	Premonsoon Maintenance of PTR and 33kV equipments
220/22 KV 50 MVA PTR 1 @ LONIKAND	IntraState	07/07/2023	09:54	07/07/2023	11:31	PO	Premansoon maint. work
220/110 kV 200 MVA ICT 3 @ MUDSHINGI	IntraState	07/07/2023	10:36			PO	TAMS (Transformer Auxillary Monitoring System) wiring& testing work and Quarterly maint. work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
110 KV BR Outages/Trippings							
110KV GROUP BREAKER-2 @ TROMBAY	IntraState	07/07/2023	01:24	07/07/2023	02:13	PO	BUS OUTAGE FOR PHASING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage