

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Aug/2018 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	118.802	659.828	1) Gujrat	-0.805	-0.983
2) Hydro	4.211	34.627	2) Madhya Pradesh	8.761	60.308
3) Gas	5.847	34.863	3) Chattisgarh	5.000	29.670
Total MSPGCL	128.860	729.318	4) Maharashtra Net	103.108	616.859
B) 1) APML	52.327	335.855	5) Goa (Amona)	-0.660	-4.796
2) JSWEL	18.885	114.761	Total	115.404	701.058
3) VIPL	6.204	31.471	a) Mumbai Schedule	21.492	143.895
4) RPL(AMT)	24.908	156.657	b) Mumbai Drawl	28.994	172.411
5) WPCL	4.507	27.418	c) MSEDCL Bilateral *	19.452	121.037
6) PGPL	0.000	0.000	Include PX	-0.193	2.600
7) Other IPP	3.658	21.904	d) Mumbai Bilateral *	21.492	143.895
C) 1) TPCL Thermal	12.913	81.583	Include PX	6.463	51.720
2) TPCL Hydro	5.272	26.473	Include Standby	0.000	0.000
3) TPCL Gas	3.949	17.312	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	9.057	57.817	1) MSEDCL	385.800	2280.042
D) STATE			2) Mumbai Discoms	60.187	355.597
1) Thermal	251.261	1487.294	TOTAL STATE	445.987	2635.639
(A1+C1+C4+(B1-B6))					
2) Hydro	9.483	61.100			
(A2+C2)					
3) Gas	9.796	52.175			
(A3+B6+C3)					
4) Wind	55.797	307.951			
6) SOLAR	4.244	26.060			
TOTAL STATE	330.581	1934.580			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5089	5103	5394	4416
MSPGCL Hydro	278	274	209	86
MSPGCL Gas	239	257	248	239
MSPGCL Total Generation	5606	5634	5851	4741
Central Sector Receipt	5672	5383	4369	4103
WIND	2456	2641	2217	2111
CPP / IPP Thermal	4549	4517	4978	4405
CPP / IPP Gas	0	0	0	0
SOLAR	537	591	0	0
Exchange with Mumbai	-1607	-1595	-1211	-781
MSEDCL DEMAND MET	17213	17171	16204	14579
Load Shedding	0	0	0	0
MSEDCL DEMAND	17213	17171	16204	14579
TPCL GENERATION	1098	1055	1150	620
R-INFRA GENERATION	376	376	393	377
MUMBAI DEMAND	3081	3026	2754	1778
STATE DEMAND MET	20294	20197	18958	16357
STATE DEMAND	20294	20197	18958	16357
Frequency (Hz)	50.01	50.00	49.95	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.21 Hz at 13.06 Hrs	49.78 Hz at 06.12 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 06/Aug/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	3.92	0	0
Unit 8	9.00	51.10	409	305
Unit 9	9.48	53.64	465	310
Unit 10	0.00	0.00	0	0
Total	18.48	108.66		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.24	58.82	475	345
Unit 5	7.67	57.28	490	0
Total	16.91	116.10		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	4.87	29.86	248	173
Unit 8	5.19	31.74	241	187
Total	10.06	61.60		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	3.90	10.82	186	64
Unit 5	9.48	58.32	415	365
Unit 6	10.26	42.98	465	360
Unit 7	10.31	61.28	451	370
Unit 8	10.46	35.23	470	418
Unit 9	0.00	0.00	0	0
Total	44.40	208.63		
Paras				
Unit 3	4.75	30.62	229	171
Unit 4	4.74	29.68	235	172
Total	9.49	60.30		
Khaparkheda				
Unit 1	3.08	18.98	140	110
Unit 2	3.64	21.62	170	125
Unit 3	0.00	11.40	0	0
Unit 4	3.77	23.26	167	150
Unit 5	4.96	4.96	400	0
Total	15.45	80.23		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.00	24.31	187	156
Unit 5	0.00	0.00	0	0
Total	4.00	24.31		
Uran				
All Units	5.85	34.86	257	237
Total	5.85	34.86		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.52	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.52		
Koyna				
Stage 1-2	1.19	10.40	120	40
Stage 4	0.00	4.66	0	0
Stage 3	0.24	5.83	80	0
Total	1.43	20.90		
Hydro				
KDPH	0.67	1.25	36	18
VTRNA	0.33	0.56	61	0
TILLARI	0.72	3.90	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.32	2.35	40	0
RNGR+BHTSA	0.00	0.32	0	0
BHANDARDRA	0.34	2.01	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.40	3.34	24	14
GHATGHAR	0.00	0.00	0	0
Total	2.78	13.73		
Wind				
Total	55.80	307.95	0	0
Total	55.80	307.95		
CPP				
APML(Mus)	52.33	335.86	0	0
JSWEL(Mus)	18.88	114.76	0	0
VIPL(Mus)	6.20	31.47	0	0
RPLAMT(Mus)	24.91	156.66	0	0
WPCL(Mus)	4.51	27.42	0	0
Other(Mus)	3.66	21.90	0	0
Total	110.49	688.07		
SOLAR				
Total	4.24	26.06	0	0
Total	4.24	26.06		
Tata				
Trombay 5	7.70	50.15	404	294
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.44	11.03	114	61
Trombay 7B	1.51	6.28	67	50
Trombay 8	5.21	31.43	233	210
TATA Hydro	5.27	26.47	418	2
Total	22.13	125.37		
R-INFRA				
DTPS U-1&2	9.06	57.82	393	375
Total	9.06	57.82		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	118.80	659.83	MSPGCL Total	128.86	729.32
			MSPGCL Thml+Gas	124.65	694.69	Koyna 1,2 & 4 Total	1.19	15.06
			MSPGCL Hydro	4.21	34.63	State Total	330.58	1934.58

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Aug/2018

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4624	91	240	4955	2331	4499	0	0	3879	4080	-1053	14812	0	14812	2104	16916	49.96
2	4633	86	249	4968	2357	4490	0	0	3682	3773	-921	14667	0	14667	1947	16614	49.99
3	4610	91	249	4950	2155	4498	0	0	3741	3857	-842	14618	0	14618	1840	16458	49.99
4	4416	86	239	4741	2111	4405	0	0	3844	4103	-781	14579	0	14579	1778	16357	49.98
5	4580	86	250	4916	1938	4486	0	0	3994	4352	-781	14911	0	14911	1773	16684	49.98
6	5045	96	238	5379	1787	4865	0	0	4238	5029	-899	16161	0	16161	1894	18055	49.99
7	5292	91	250	5633	1847	4962	0	23	5300	5965	-968	17462	0	17462	2055	19517	49.92
8	5293	86	239	5618	2076	4965	0	102	5440	5947	-1051	17657	0	17657	2245	19902	50.00
9	5346	159	240	5745	2266	4960	0	238	5232	5339	-1229	17319	0	17319	2582	19901	50.04
10	5151	217	249	5617	2307	4712	0	395	5037	5704	-1473	17262	0	17262	2884	20146	49.98
11	5072	269	238	5579	2689	4608	0	460	5185	5374	-1593	17117	0	17117	3063	20180	50.00
12	5089	278	239	5606	2456	4549	0	537	5089	5672	-1607	17213	0	17213	3081	20294	50.01
13	5103	274	257	5634	2641	4517	0	591	5070	5383	-1595	17171	0	17171	3026	20197	50.00
14	5079	284	239	5602	2491	4513	0	589	4962	4066	-1506	15755	900	16655	2921	19576	50.06
15	4849	230	237	5316	2626	4312	0	482	4965	5000	-1522	16214	0	16214	2923	19137	49.97
16	4830	205	248	5283	2738	4257	0	407	4944	5635	-1493	16827	0	16827	2909	19736	49.96
17	4772	255	237	5264	2587	4234	0	263	4923	5718	-1461	16605	0	16605	2899	19504	49.93
18	4848	285	237	5370	2362	4282	0	131	4900	5098	-1424	15819	0	15819	2857	18676	49.95
19	5134	172	249	5555	2258	4539	0	26	4492	4961	-1340	15999	0	15999	2800	18799	49.96
20	5394	209	248	5851	2217	4978	0	0	4402	4369	-1211	16204	0	16204	2754	18958	49.95
21	5074	185	250	5509	2271	4924	0	0	4295	4227	-1131	15800	0	15800	2661	18461	49.97
22	4929	205	238	5372	2263	4731	0	0	3845	3869	-1003	15232	0	15232	2513	17745	49.92
23	4864	160	239	5263	2569	4603	0	0	3877	4009	-1058	15386	0	15386	2416	17802	49.96
24	4775	111	248	5134	2454	4599	0	0	3799	3873	-1052	15008	0	15008	2260	17268	49.96
MUs	118.80	4.21	5.85	128.86	55.80	110.49	0.00	4.24	109.14	115.40	-28.99	385.80	0.90	386.70	60.18	446.88	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Aug/2018

Position as on 6.30 Hrs of 07/Aug/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 5	500	20/06/2018	05.14	06/08/2018	06.10	Annual Overhaul	
MSPGCL	Chandrapur Unit 9	500	01/07/2018	11.35		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 6	250	23/07/2018	00:00		Continued.	Annual Overhaul	
MSPGCL	Koradi Unit 10	660	28/07/2018	01.09		Continued.	Annual Overhaul	
IPP	Adani U-1	660	04/08/2018	00:00		Continued.	Annual Overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown. (NO PPA FROM 01.04.2018)	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Chandrapur Unit 3	210	03/12/2017	01.35		Continued.	Water Shortage	
MSPGCL	Ghatghar Unit-1	125	14/04/2018	23.45		Continued.	Stator Earth Fault	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	IEPL Inter change	
MSPGCL	Uran Unit 6	108	09/06/2018	11.50		Continued.	Bucchholz relay operated.	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01.12		Continued.	Stator Earth Fault	
IPP	IEPL Unit 1	270	11/07/2018	13.00		Continued.	poor coal receipt.	
MSPGCL	Nasik Unit 5	210	12/07/2018	00.00		Continued.	ZERO SCHEDULE.	
IPP	Dhariwal	300	13/07/2018	23.59		Continued.	Critical coal stock	
MSPGCL	Koradi Unit 6	210	16/07/2018	09.18		Continued.	due to low pressure.	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	compressor search protection	
IPP	VIPL U-2	300	27/07/2018	00.48		Continued.	Boiler Validity Extention	
MSPGCL	Nasik Unit 3	210	28/07/2018	00:15	07/08/2018	12.50	Dhariwal Exchange	
MSPGCL	Khaparkheda Unit 3	210	04/08/2018	23.03		Continued.	Chemical parameter abnormal.	
MSPGCL	Bhusawal Unit 5	500	06/08/2018	20.17	07/08/2018	4.25	Attending Hot Spot At GT R -Phase Bushing.	
MSPGCL	Koyana STG-IV Unit-2	250	07/08/2018	09.00		Continued.	replacement of Valve.	
MSPGCL	Khaparkheda Unit 5	500	07/08/2018	09.33		Continued.	Due To Speed Sensor Supply Failed.	
MSPGCL	Nasik Unit 4	210	07/08/2018	15.35		Continued.	ID Fan Problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2018

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 1	IntraState	06/08/2018	20.20	07/08/2018	00.09	EO	Attending Water Leakage In Valve.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	03/08/2018	17.33	06/08/2018	08.20	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	06/08/2018	08.50		Continued.	PO	Line Maintenance work
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	06/08/2018	12.44	06/08/2018	16.39	HT	Isolator Sparking.
Chakan Talegaon(Pg)	InterState	07/08/2018	11.43	07/08/2018	12.08	T	Shifted On B-Bus
Dhule - Bableswhar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule- Bableswhar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Karad-Jaigad - I	IntraState	04/08/2018	17.18	06/08/2018	10.36	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	05/08/2018	18.51	06/08/2018	10.56	HT	Over Voltage
Main Bus-II @ Kolhapur	IntraState	06/08/2018	09.32	07/08/2018	16.42	PO	Replacement Of String, Alignment Bus Hangers.
New Koyna - Dabhol-I	IntraState	06/08/2018	09.38	06/08/2018	17.37	PO	String Replacement At LOC No.91 & Line Sign. Test.
Chandrapur-II - Nanded ckt II	IntraState	06/08/2018	11.05	06/08/2018	17.08	PO	Replacement Of Damaged Earth Wire Cross ARM.
karad -kolhapur-II	IntraState	06/08/2018	12.23	07/08/2018	09.29	T	DP, Decapping At LOC. No.18 YPH. RFC@18:55.
Lonikand 1 - Chakan	IntraState	06/08/2018	13.06	06/08/2018	18.12	T	During 400kv TBC Bay Isolator Opening At Chakan.
Karad - Lonikand 1	IntraState	06/08/2018	13.06	06/08/2018	14.08	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand2-Lonikand1 (Intrconector)	IntraState	06/08/2018	13.06	06/08/2018	14.23	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand 1 - Talegaon(Pgcil)	IntraState	06/08/2018	13.06	06/08/2018	15.08	T	During 400kv TBC Bay Isolator Opening At Chakan.
Girwali - Lonikand 1	IntraState	06/08/2018	13.06	06/08/2018	14.42	T	During 400kv TBC Bay Isolator Opening At Chakan.
Girwali- Lonikand 2	IntraState	06/08/2018	13.06	06/08/2018	13.57	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand 1 -Jejuri	IntraState	06/08/2018	13.06	06/08/2018	13.49	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand I - Koyna stage-IV	IntraState	06/08/2018	13.06	06/08/2018	15.06	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand 1 - Talegaon(Pgcil)	IntraState	06/08/2018	16.53	06/08/2018	19.45	PO	Sparking At B Phase Line Isolator At Talegaon Pg.
Chandrapur II - Chandrapur ckt I	IntraState	07/08/2018	09.22	07/08/2018	18.06	PO	RM & Dignostic Testing.
karad -kolhapur-I	IntraState	07/08/2018	10.01	07/08/2018	15.40	EO	Isolator alignment Work.
Karad - Jaigad - II	IntraState	07/08/2018	20.36		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	06/08/2018	13.06	06/08/2018	14.09	T	on 186,286 operated.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	06/08/2018	13.06	06/08/2018	14.15	T	on 186,286 operated.
400/220/33kv 315mva lct3 @Lonikand	IntraState	06/08/2018	13.06	06/08/2018	14.01	T	Tripped During 400kv TBC bay isolater opening
400/220 Kv 315 MVA ICT-II @Chakan	IntraState	06/08/2018	13.06	06/08/2018	14.27	T	Tripped on Overload
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	06/08/2018	13.06	06/08/2018	14.00	T	Tripped During 400kv TBC bay isolater opening
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	06/08/2018	13.06	06/08/2018	13.50	T	Tripped During 400kv TBC bay isolater opening
400/220 Kv 315 Mva lct 1 @Chakan	IntraState	06/08/2018	13.06	06/08/2018	13.25	T	Tripped on Overload
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	06/08/2018	1306	06/08/2018	14.09	T	on 186,286 operated.
400/220 Kv 315 Mva lct 1 @Chakan	IntraState	07/08/2018	12.35	07/08/2018	17.25	EO	B Ph PG Isolator Rotary Insulator To Be Changed By Hot Line

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2018

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Method.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Kalwa 52B Interconnector CB	IntraState	01/06/2018	01.35		Continued.	HT	To control load on ICT.
Vita - Miraj	IntraState	16/06/2018	14.15		Continued.	PO	Construction Work.
Vita - Mhaishal	IntraState	16/06/2018	15.10		Continued.	PO	Construction Work.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	T	To control line loading for availing outage on PG ckt 3.
Pophli Pedhmbe Line- 1	IntraState	05/08/2018	05.17		Continued.	T	Distance Protection
Talandge(400kv)- Ichalkaranji 1	IntraState	06/08/2018	09.49	06/08/2018	20.29	PO	String Replacement Work.
Butibori - VIPL Ckt II	IntraState	06/08/2018	10.03	06/08/2018	16.50	PO	Measurement Of CB Timing And CRM Alignment Work Of Isolator.
Lonand-Baramati	IntraState	06/08/2018	11.00	06/08/2018	20.00	PO	PA ROD Replacement, Jumpers Replacement, Puilot Addition & String Replacement.
Paras-Balapur I	IntraState	06/08/2018	11.05	06/08/2018	18.23	PO	Routine Maintenance Work
Aarey Saki Line 1	IntraState	06/08/2018	11.18	06/08/2018	14.08	PO	Positive & Zero Sequence Impedance Measurement Of Cable.
Taloja li - OCIL-II	IntraState	06/08/2018	11.28		Continued.	PO	Replacement Of Y & B PH CT.
Balapur-Malegaon	IntraState	06/08/2018	12.04	06/08/2018	17.50	PO	Fixing Of Cut Point Jumper To Pilot String.
Lonikand (400 Kv)-Theur I	IntraState	06/08/2018	13.06	06/08/2018	14.19	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand - Bhosari	IntraState	06/08/2018	13.06	06/08/2018	14.34	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand (400 Kv)-Theur li	IntraState	06/08/2018	13.06	06/08/2018	14.20	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand-VSNL	IntraState	06/08/2018	13.06	06/08/2018	14.36	T	During 400kv TBC Bay Isolator Opening At Chakan.
Lonikand-II- Kathapur	IntraState	06/08/2018	13.06	06/08/2018	14.38	T	During 400kv TBC Bay Isolator Opening At Chakan.
Ranjangaon-Lonikand	IntraState	06/08/2018	13.06	06/08/2018	14.25	T	During 400kv TBC Bay Isolator Opening At Chakan.
Urse-Chinchwad	IntraState	06/08/2018	13.12	06/08/2018	14.45	T	During 400kv TBC Bay Isolator Opening At Chakan.
Chakan-Chinchwad	IntraState	06/08/2018	13.22	06/08/2018	13.33	HT	During 400kv TBC Bay Isolator Opening At Chakan.
Chakan-Bhosari	IntraState	06/08/2018	13.22	06/08/2018	13.26	T	During 400kv TBC Bay Isolator Opening At Chakan.
Chakan I - Chakan II (tap to Volkswagen)	IntraState	06/08/2018	13.23	06/08/2018	13.28	HT	During 400kv TBC Bay Isolator Opening At Chakan.
Chakan-Mahindra Vehicle	IntraState	06/08/2018	13.30	06/08/2018	13.41	HT	During 400kv TBC Bay Isolator Opening At Chakan.
Bus section-I @ Tambati	IntraState	07/08/2018	08.30	07/08/2018	16.18	PO	Attending R ph CT Oil Leakage Of 220kv Sectionliser.
Bus Coupler @ Borivali	IntraState	07/08/2018	09.19	07/08/2018	14.13	PO	Annual Maint. Of GIS Bus.
Kalwa-TIFIL	IntraState	07/08/2018	10.10	07/08/2018	10.15	HT	Avail Outage But Charged Due To Tripping On Siemens Line.
Mahape - TIFIL	IntraState	07/08/2018	10.11	07/08/2018	10.24	T	Distance Protection
Kalwa - Colourchem	IntraState	07/08/2018	10.11	07/08/2018	10.37	T	Backup Protection
Kalwa - Siemens	IntraState	07/08/2018	10.11	07/08/2018	16.15	T	B-PH Jumper Opened At Siemens End.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2018

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BHUGAON WARORA CKT-I	IntraState	07/08/2018	11.31	07/08/2018	13.35	PO	Line Maintenance work
BHUGAON WARORA CKT-II	IntraState	07/08/2018	13.36	07/08/2018	15.37	PO	Line Maintenance work
Harangul-Parly	IntraState	07/08/2018	18.17	07/08/2018	21.34	EO	Attending Hot Spot
220 KV ICT Outages/Trippings							
220/132 Kv 100 Mva Bhel Ict 1 @Padegaon	IntraState	30/06/2018	15:03		Continued.	T	Buchholz.
220/22 Kv 50 Mva Ptr 3 @Chakan	IntraState	06/08/2018	13.23	06/08/2018	13.35	HT	Over Voltage
220/22 KV 50MVA T/F-I @ Chakan II	IntraState	06/08/2018	13.23	06/08/2018	13.37	HT	Over Voltage
220/22 Kv 50 Mva Ptr 1 @Chakan	IntraState	06/08/2018	13.23	06/08/2018	13.37	HT	H/T
220/22 Kv 50 Mva Ptr 2 @Chakan	IntraState	06/08/2018	13.24	06/08/2018	13.38	HT	Over Voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage