

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Aug/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	118.820	702.554	1) Gujrat	4.888	48.276
2) Hydro	11.393	91.932	2) Madhya Pradesh	0.678	36.419
3) Gas	3.832	30.201	3) Chattisgarh	2.510	15.350
Total MSPGCL	134.045	824.687	4) Maharashtra	163.135	1055.152
B) 1) APML	44.484	314.089	5) Goa (Amona)	-1.069	-5.610
2) JSWEL	14.858	86.377	Total	170.142	1149.587
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.834	209.624
4) RPL(AMT)	17.477	115.680	b) Mumbai Drawl	35.860	220.567
5) SWPGPL	7.438	33.643	c) MSEDCL Bilateral *	59.436	418.354
6) Other IPP	6.921	40.752	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.805	209.472
C) 1) TPCL Thermal	9.426	65.747	Include PX	0.000	0.000
2) TPCL Hydro	3.597	33.022	Standby	0.029	0.153
3) TPCL Gas	2.691	16.756	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.194	55.097	1) MSEDCL	395.203	2438.013
D) STATE			2) Mumbai Discoms	61.768	391.189
1) Thermal	229.618	1413.939	3) Other Discoms	8.613	53.854
(A1+C1+C4+(B1-B6))			TOTAL STATE	465.584	2883.056
2) Hydro (A2+C2)	14.990	124.954			
3) Gas (A3+B7+C3)	6.523	46.957			
4) Wind	35.736	95.028			
6) SOLAR	8.575	52.591			
TOTAL STATE	295.442	1733.469			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4510	5229	5381	4784
MSPGCL Hydro	617	381	672	268
MSPGCL Gas	136	136	136	130
MSPGCL Total Generation	5263	5746	6189	5182
Central Sector Receipt	8235	7287	7373	6237
WIND	1574	1914	1590	1522
CPP / IPP Thermal	3303	3916	4578	3492
CPP / IPP Gas	0	0	0	0
SOLAR	965	253	0	0
Exchange with Mumbai	-2040	-1860	-1450	-1029
MSEDCL DEMAND MET	16907	16856	17893	15113
Load Shedding	0	0	0	0
MSEDCL DEMAND	16907	16856	17893	15113
TPCL GENERATION	576	641	933	561
AEML GENERATION	390	357	432	466
MUMBAI DEMAND	3006	2858	2815	2056
OTHER DISCOM DEMAND	393	400	387	291
STATE DEMAND MET	20306	20114	21095	17460
STATE DEMAND	20306	20114	21095	17460
Frequency (Hz)	50.05	50.01	49.91	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 13.02 Hrs	49.73 Hz at 15.30 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.58	17.80	150	60
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	6.84	42.81	369	0
Unit 10	11.33	64.27	508	410
Total	20.75	124.88		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	7.42	48.94	360	275
Unit 5	7.68	44.02	375	280
Total	15.11	92.96		
Parli				
Unit 6	3.93	25.37	190	147
Unit 7	3.82	16.85	187	137
Unit 8	3.38	21.67	162	117
Total	11.12	63.88		
Chandrapur				
Unit 3	2.73	14.70	125	90
Unit 4	1.99	7.46	94	70
Unit 5	5.91	31.64	270	210
Unit 6	6.76	36.55	300	250
Unit 7	0.00	0.00	0	0
Unit 8	9.10	59.02	441	281
Unit 9	9.73	59.77	451	291
Total	36.22	209.14		
Paras				
Unit 3	3.94	24.53	215	121
Unit 4	3.99	24.51	192	131
Total	7.93	49.04		
Khaparkheda				
Unit 1	3.03	16.52	135	100
Unit 2	3.29	16.88	145	120
Unit 3	3.90	22.40	181	131
Unit 4	3.84	21.70	179	130
Unit 5	8.13	50.21	420	275
Total	22.18	127.70		
Nasik				
Unit 3	2.95	17.51	147	103
Unit 4	0.00	0.00	0	0
Unit 5	2.56	17.43	133	0
Total	5.50	34.94		
Uran				
All Units	3.83	30.20	264	120
Total	3.83	30.20		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.61	3.64	27	23
Total	0.61	3.64		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.90	21.08	340	30
Stage 4	0.24	21.64	94	0
Stage 3	1.20	11.02	240	0
Total	5.34	53.74		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.69	1.46	61	0
TILLARI	0.00	0.31	0	0
BHIRA T.R.	0.44	2.61	80	0
SMLHY_PTN	4.31	27.86	197	171
GHATGHAR	0.00	2.32	0	0
Total	5.44	34.55		
Wind				
Total	35.74	95.03	0	0
Total	35.74	95.03		
CPP				
APML(Mus)	44.48	314.09	0	0
JSWEL(Mus)	14.86	86.38	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	17.48	115.68	0	0
SWPGPL-Mus	7.44	33.64	0	0
Other(Mus)	6.92	40.75	0	0
Total	91.18	590.54		
SOLAR				
Total	8.58	52.59	0	0
Total	8.58	52.59		
Tata				
Trombay 5	5.88	43.66	275	221
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.56	9.77	113	45
Trombay 7B	1.13	6.99	66	38
TATA Hydro	3.60	33.02	376	38
Trombay 8	3.54	22.09	238	133
Total	15.71	115.52		
AEML				
DTPS U-1&2	10.19	55.10	490	315
Total	10.19	55.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	118.82	702.55	MSPGCL Total	134.04	824.69
			MSPGCL Thml+Gas	122.65	732.76	Koyna 1,2 & 4 Total	4.14	42.72
			MSPGCL Hydro	11.39	91.93	State Total	295.44	1733.47

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4845	569	120	5534	1580	3849	0	0	6235	6134	-1210	15559	0	15559	2350	328	18237	49.99
2	4812	304	129	5245	1700	3719	0	0	6293	6103	-1093	15370	0	15370	2166	304	17840	49.93
3	4784	268	130	5182	1522	3492	0	0	6102	6237	-1029	15113	0	15113	2056	291	17460	49.95
4	4888	473	139	5500	1268	3466	0	0	6009	6379	-967	15349	0	15349	1962	297	17608	49.98
5	5074	638	160	5872	1047	3598	0	0	6428	6591	-941	15851	0	15851	1948	316	18115	49.98
6	5229	351	201	5781	932	3912	0	0	7537	7633	-1007	16917	0	16917	2024	334	19275	49.99
7	5285	268	232	5785	957	4240	0	40	8357	7978	-1088	17566	0	17566	2093	346	20005	50.04
8	5090	269	264	5623	845	3928	0	292	8584	8211	-1203	17324	0	17324	2212	372	19908	50.06
9	5142	276	261	5679	987	3578	0	603	8047	7930	-1417	16959	0	16959	2474	401	19834	50.05
10	4789	425	227	5441	1298	3376	0	911	7977	8178	-1753	17054	0	17054	2788	397	20239	50.06
11	4510	617	136	5263	1574	3303	0	965	8201	8235	-2040	16907	0	16907	3006	393	20306	50.05
12	4488	592	138	5218	1882	3284	0	953	8011	7597	-2140	16423	0	16423	3073	371	19867	50.03
13	4523	610	137	5270	1778	3218	0	1072	7541	7288	-2147	16113	0	16113	3005	366	19484	49.99
14	4470	658	135	5263	1803	3140	0	1057	6861	6739	-1973	15666	0	15666	2891	363	18920	50.02
15	4529	598	133	5260	1837	3099	0	974	7199	7120	-2003	15926	0	15926	2910	361	19197	49.94
16	4492	626	131	5249	1811	3098	0	813	7378	7241	-2009	15824	0	15824	2938	379	19141	49.96
17	4889	398	136	5423	1976	3678	0	591	7396	7344	-1981	16643	0	16643	2907	388	19938	50.02
18	5229	381	136	5746	1914	3916	0	253	7241	7287	-1860	16856	0	16856	2858	400	20114	50.01
19	5311	455	136	5902	1774	4275	0	51	7217	6896	-1629	16878	0	16878	2788	391	20057	50.01
20	5381	672	136	6189	1590	4578	0	0	7574	7373	-1450	17893	0	17893	2815	387	21095	49.91
21	5437	475	139	6051	1504	4659	0	0	7094	7104	-1255	17690	0	17690	2731	373	20794	49.92
22	5279	370	136	5785	1506	4650	0	0	6489	6461	-1204	16831	0	16831	2700	367	19898	49.99
23	5203	535	164	5902	1275	4590	0	0	5774	6134	-1118	16441	0	16441	2542	342	19325	49.99
24	5141	565	176	5882	1376	4532	0	0	5818	5949	-1343	16052	0	16052	2531	344	18927	49.98
MUs	118.82	11.39	3.83	134.04	35.74	91.18	0.00	8.57	171.36	170.14	-35.86	395.20	0.00	395.20	61.77	8.61	465.58	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 06/Aug/2022

Position as on 6.30 Hrs of 07/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	17/08/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	10/08/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
MSPGCL	Bhusawal Unit 3	210	16/07/2022	06:30		Continued.	Critical coal stock	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	03/08/2022	03:00		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	03/08/2022	21:45		Continued.	Boiler Validity Renevoation	
MSPGCL	Koradi Unit 9	660	05/08/2022	03:35	06/08/2022	01:34	RAPH A JAM	
MSPGCL	Bhusawal Unit 5	500	05/08/2022	10:26		Continued.	ID Fan Problem	
MSPGCL	Uran Unit B0	120	05/08/2022	20:56	06/08/2022	06:33	Gas shortage	
MSPGCL	Uran Unit 8	108	05/08/2022	20:56	06/08/2022	03:54	Gas shortage	
MSPGCL	Uran Unit A0	120	06/08/2022	09:59	07/08/2022	01:58	Gas shortage	
MSPGCL	Uran Unit 6	108	06/08/2022	10:00	06/08/2022	22:03	Gas shortage	
MSPGCL	Nasik Unit 5	210	06/08/2022	21:58	07/08/2022	01:42	Flame Failure	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Aug/2022

Position as on 6.30 Hrs of 07/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage	09/08/2022
MSPGCL	Koyna Unit 5	80	07/08/2022	23:59		Continued.	Major Gov.Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV ICT-1 @ TIRORA	IntraState	06/08/2022	10:24	06/08/2022	18:26	HT	Attending Hotspot on main & Tie bay Isolator
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/08/2022	23:01	06/08/2022	01:17	EO	Attending hot spot at Pole 2 Non-Base Filter Z21-Z4 R & Y-ph
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	07/08/2022	11:34	07/08/2022	14:01	T	TC-2 High Flow Trip B-phase indication
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
CHANDRAPUR - BHADRAVATI CKT - 3	InterState	07/08/2022	12:29	07/08/2022	22:23	T	DT send from Chandrapur end to Bhadrawati ss.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	05/08/2022	00:06			HT	For load management
KARAD - TALANDGE CKT - 1	IntraState	05/08/2022	18:14			EO	Sparking observed at B -phase C Bus isolator own bay during shifting on TBC for CB overhauling work.
KARAD - LONIKAND I	IntraState	05/08/2022	22:29	06/08/2022	06:57	HT	H/t to control line loading on 400 KV Karad-Kolhapur ckt 2
KHADKA-AURANGABAD (WALUJ)	IntraState	05/08/2022	23:47	06/08/2022	09:30	HT	H/T DUE TO O/V
CHANDRAPUR-PARLI CKT-3	IntraState	06/08/2022	08:54	06/08/2022	20:49	PO	1) For replacement of old M-2 distance relays. 2) Circuit Breaker timing, CRM & DCRM. 3) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.
KARAD - LONIKAND I	IntraState	06/08/2022	10:31			HT	H/T TO CONTROL LINE LOADING
KHADKA-AURANGABAD (WALUJ)	IntraState	07/08/2022	00:52			HT	To control overvoltage
PADGHE - KALWA CKT - 1	IntraState	07/08/2022	10:25	07/08/2022	12:34	PO	1)Bay maint work 2) Diagnostic Testing work 3) Replacement of Gantry to Wave trap jumper of Rph 4)MTAMC work 5) Replacement of PG Isolator under LES schme
MAIN BUS - 1 @ KORADI - 2	IntraState	07/08/2022	10:26	07/08/2022	17:00	PO	Tan delta measurement of Bus CVT
PADGHE - KALWA CKT - 2	IntraState	07/08/2022	16:33		Continued.	T	TRIPPED ON DISTANCE PROTECTION
400 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ LONIKAND	IntraState	06/08/2022	12:24	06/08/2022	16:13	EO	Attending hot spot on 400kv Main Bus B R-ph Hanger assembly of 400kv Jejuri Bay (Temp > 160 ˚C) by hot Line unit Pune
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	06/08/2022	13:32	06/08/2022	15:42	EO	Replacement of Flashover string found at Loc no.29- B ph in r/o AR operated on Dt: 05.08.2022
SALSETTE BORIVLI - 1	IntraState	02/08/2022	08:37	06/08/2022	22:03	PO	MBS+6 Tower erection with conductor shifting at new tower no. 2A for customer funded project (third party)
EKLAHARE (OCR) - PADGHE	IntraState	03/08/2022	05:03			HT	H/T for Line Loading.
TOPWORTH - Vile - bhagad	IntraState	06/08/2022	00:06	06/08/2022	07:22	T	DP
POPHALI - KDPH	IntraState	06/08/2022	08:50	06/08/2022	11:35	PO	Breaker to CT conductor strands broken

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
APTA - KALWA	IntraState	06/08/2022	10:35	06/08/2022	12:18	EO	To attend hot-spots on own CB.
CENTURI ENKA- BHOSARI	IntraState	06/08/2022	10:37	06/08/2022	15:01	PO	CB Compressor tank air leakage attending work at Cenka s/s for Bhosari 1 bay CB 2) Testing work -relay shifting up side in panel at Bhosari-1 S/S
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	06/08/2022	10:45	06/08/2022	19:47	PO	PID faulty STRING REPLACEMENT WORK 1)STN LOC NO 1-Y BBLR Side, 3-RY BBLR Side, 12-B BBLR Side, 15-B BBLR Side, 60-R,B Both Side, 68-B BBLR side, 68- Y Both side, 2)SSN Loc no :-21-Y, 44-R, 46-B Pilot
CHALISGAON -KOPARGAON	IntraState	06/08/2022	11:12	06/08/2022	13:47	PO	For attending problem of spring charge motor of CB & Diagnostic testing work
PIRANGUT - HINJAWADI 2	IntraState	06/08/2022	11:30	06/08/2022	16:12	PO	DT work and 220kV CB Hot spot attending work
PHURSUNGI-PARVATI	IntraState	06/08/2022	12:16	06/08/2022	18:17	PO	1) L.N.-13-R Phase (1 to 21 M/C) Double Jumering 2) L.N.-13-Y Phase(1 to 21 M/C) STN String Replacement 3) L.N.-10 (1 to 21 M/C) ESN Replacement 4) L.N.-4 (1 to 21 M/C) - B Phase-DSN Clamp Replacement 5) L.N.-8 (1 to 21 M/C) Yoke Plate Nut bolt replacement 6) L.N.-1-R Phase,1A - Baphse(1 to 18) Double Jumping 7) L.N.-3 R & Y phase (1 to 18) DSN clamp Replacement 8) L.N.17(1 to 18), SSN Clamp Replacement-R & B Phase 9) L.N.-73A (73 to 106) ȳ Y Phase quarter D shackle Replacement work 10) L.N.-74 (73 to 106) ȳ Y SSN clamp Replacement work 11) Fixing of VD at L.N.-80,81,82,84,85,90,84,95,96,103 12) Fixing of CB at L.N.-85,90,86
MAHAPE - RELIANCE GIS	IntraState	06/08/2022	12:34	06/08/2022	15:19	EO	4 Nature of work to be carried out. Replacement of ȳ Dȳ shakle Quarter pin attached to insulator string.
CHAKAN-BHOSARI 1	IntraState	06/08/2022	15:41	06/08/2022	22:16	T	Distance Protection
TROMBAY - SALSETTE CKT - 1	IntraState	07/08/2022	06:27	07/08/2022	08:31	PO	FOR TREE TRIMMING
SALSETTE BORIVLI - 2	IntraState	07/08/2022	10:13			PO	THIRD PARTY WORK-FOR CONDUCTOR SHIFTING ON NEW TOWER AT LOC-2A
KANDALGAON - ONGC PANVEL	IntraState	07/08/2022	14:25	07/08/2022	15:29	T	TRIPPED ON DISTANCE PROTECTION
PIRANGUT - HINJAWADI 2	IntraState	07/08/2022	16:11	07/08/2022	18:27	EO	To remove flex at location no 20,21,12,13
INFOSYS - HINJAWADI 1	IntraState	07/08/2022	19:04	07/08/2022	19:45	EO	To remove flex at loc no 19,20
BOISAR II - TARAPUR	IntraState	07/08/2022	22:42			T	Tripped on Distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132kV 100MVA ICT - 2 @ KALWAN	IntraState	06/08/2022	10:20	06/08/2022	17:00	PO	For Diagnostic testing work & bay maintenance work
132 KV LINE Outages/Trippings							
SOLAPUR 2(BALE)-NALDURG	IntraState	07/08/2022	15:28	07/08/2022	15:45	T	TRIPPED ON DISTANCE PROTECTION
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
KALYAN KALWA SALSETTE 1	IntraState	06/08/2022	06:38	06/08/2022	11:20	PO	Projrct work- to facilitate construction of 220 KV Kalwa Salsette-5 line(work in vicinity)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage