

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Aug/2023 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	121.410	710.353	1) Gujrat	11.828	59.155
2) Hydro	9.855	63.675	2) Madhya Pradesh	7.514	38.575
3) Gas	0.000	0.000	3) Chattisgarh	2.280	17.400
Total MSPGCL	131.265	774.028	4) Maharashtra	146.904	903.000
B) 1) APLM	44.371	262.312	5) Goa (Amona)	-1.431	-9.516
2) JSWEL	14.392	86.324	Total	167.095	1008.614
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.995	206.515
4) RPL(AMT)	24.037	149.288	b) Mumbai Drawl	33.351	227.692
5) SWPGPL	6.696	39.827	c) MSEDCL Bilateral *	99.676	562.714
6) Other IPP	5.554	35.282	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.995	206.515
C) 1) TPCL Thermal	9.639	58.930	Include PX	0.000	0.000
2) TPCL Hydro	3.365	25.096	Standby	0.000	0.000
3) TPCL Gas	2.362	14.383	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.795	52.358	1) MSEDCL	416.454	2485.139
D) STATE			2) Mumbai Discoms	56.512	378.459
1) Thermal	233.894	1394.674	3) Other Discoms	9.520	59.277
(A1+C1+C4+(B1-B6))			TOTAL STATE	482.486	2922.875
2) Hydro	13.220	88.771			
3) Gas	2.362	14.383			
4) Wind	53.923	356.501			
6) SOLAR	11.992	59.932			
TOTAL STATE	315.391	1914.261			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5177	4538	5495	5154
MSPGCL Hydro	549	306	730	314
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5726	4844	6225	5468
Central Sector Receipt	7829	7032	7294	6159
WIND	2608	2805	2295	1654
CPP / IPP Thermal	3631	3496	4453	4248
CPP / IPP Gas	0	0	0	0
SOLAR	1239	1580	0	0
Exchange with Mumbai	-1581	-1705	-1420	-996
MSEDCL DEMAND MET	19037	17663	18420	16182
Load Shedding	0	0	0	0
MSEDCL DEMAND	19037	17663	18420	16182
TPCL GENERATION	534	548	773	677
AEML GENERATION	301	315	344	426
MUMBAI DEMAND	2416	2568	2537	2099
OTHER DISCOM DEMAND	415	389	427	351
STATE DEMAND MET	21868	20620	21384	18632
STATE DEMAND	21868	20620	21384	18632
Frequency (Hz)	50.02	50.01	49.99	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 17:03 Hrs	49.81 Hz at 19:07 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.19	18.26	165	110
Unit 8	12.75	73.59	603	375
Unit 9	11.64	70.78	570	385
Unit 10	0.00	0.00	0	0
Total	27.58	162.64		
Bhusawal				
Unit 3	2.77	16.92	130	90
Unit 4	8.34	49.49	450	235
Unit 5	8.79	47.05	460	285
Total	19.90	113.46		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.10	15.16	141	119
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.27	43.06	344	270
Unit 7	6.99	42.10	318	255
Unit 8	10.06	59.58	475	293
Unit 9	10.36	61.11	474	342
Total	37.80	221.01		
Paras				
Unit 3	4.56	26.15	216	137
Unit 4	4.32	24.87	205	142
Total	8.88	51.02		
Khaparkheda				
Unit 1	1.88	11.70	85	65
Unit 2	2.56	15.88	125	87
Unit 3	3.49	21.55	179	124
Unit 4	3.39	21.88	177	126
Unit 5	9.34	53.51	440	285
Total	20.66	124.50		
Nasik				
Unit 3	3.47	20.97	176	120
Unit 4	3.12	3.68	161	100
Unit 5	0.00	13.08	0	0
Total	6.58	37.73		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.22	5.78	52	50
Total	1.22	5.78		
Koyna				
Stage 1-2	1.88	12.18	370	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.14	2.73	140	0
Stage 3	0.88	6.40	80	0
Total	2.90	21.31		
Hydro				
KDPH	0.86	5.06	36	36
VTRNA	0.00	0.43	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.42	2.58	80	0
SMLHY_PTN	4.45	27.07	187	181
GHATGHAR	0.00	1.44	0	0
Total	5.74	36.58		
Wind				
Total	53.92	356.50	0	0
Total	53.92	356.50		
CPP				
APML(Mus)	44.37	262.31	0	0
JSWEL(Mus)	14.39	86.32	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.04	149.29	0	0
SWPGPL-Mus	6.70	39.83	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.71	29.36	231	165
Other(Mus)	0.85	5.92	0	0
Total	95.05	573.03		
SOLAR				
Total	11.99	59.93	0	0
Total	11.99	59.93		
Tata				
Trombay 5	6.47	39.41	285	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.34	8.17	108	39
Trombay 7B	1.02	6.21	64	36
TATA Hydro	3.36	25.10	270	45
Trombay 8	3.17	19.52	154	127
Total	15.37	98.41		
AEML				
DTPS U-1&2	7.80	52.36	426	284
Total	7.80	52.36		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	121.41	710.35	MSPGCL Total	131.26	774.03
			MSPGCL Thml+Gas	121.41	710.35	Koyna 1,2 & 4 Total	2.02	14.91
			MSPGCL Hydro	9.86	63.68	State Total	315.39	1914.26

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5280	453	0	5733	1709	3672	0	0	6630	6710	-1293	16141	0	0	16141	2355	390	18886	49.98
2	5224	643	0	5867	1641	3869	0	0	6388	6247	-1088	16168	0	0	16168	2211	368	18747	49.97
3	5154	314	0	5468	1654	4248	0	0	6367	6159	-996	16182	0	0	16182	2099	351	18632	49.98
4	5151	308	0	5459	1617	4160	0	0	6648	6474	-1050	16337	0	0	16337	2011	323	18671	49.99
5	5013	317	0	5330	1694	4502	0	0	6696	6584	-1030	16735	0	0	16735	1997	345	19077	49.97
6	5065	389	0	5454	1826	4712	0	1	7111	6926	-995	17555	0	0	17555	2056	369	19980	49.98
7	5102	389	0	5491	2026	4639	0	80	7925	7542	-1157	18233	0	0	18233	2084	388	20705	50.00
8	5248	464	0	5712	2006	4143	0	416	8209	7806	-1275	18403	0	0	18403	2162	405	20970	49.99
9	4850	543	0	5393	2315	3717	0	910	8150	8130	-1479	18572	0	0	18572	2288	414	21274	50.03
10	5177	549	0	5726	2608	3631	0	1239	7662	7829	-1581	19037	0	0	19037	2416	415	21868	50.02
11	4823	487	0	5310	2476	3546	0	1320	7969	7964	-1735	18478	0	0	18478	2558	403	21439	50.00
12	4994	372	0	5366	2563	3525	0	1532	7819	7613	-1767	18428	0	0	18428	2605	404	21437	50.06
13	4538	306	0	4844	2805	3496	0	1580	7569	7032	-1705	17663	0	0	17663	2568	389	20620	50.01
14	4162	312	0	4474	2735	3253	0	1469	7309	7389	-1645	17289	0	0	17289	2489	386	20164	50.09
15	4192	417	0	4609	2697	3370	0	1255	7157	7231	-1601	17175	0	0	17175	2448	386	20009	50.04
16	4689	348	0	5037	2555	3544	0	1080	7169	6668	-1585	16890	0	0	16890	2427	409	19726	49.99
17	4799	308	0	5107	2554	3571	0	671	7030	6835	-1536	16783	0	0	16783	2388	419	19590	49.99
18	4937	322	0	5259	2656	3724	0	364	7010	6822	-1472	16923	0	0	16923	2376	430	19729	50.02
19	5436	384	0	5820	2473	4034	0	75	7339	6802	-1331	17452	0	0	17452	2419	421	20292	50.02
20	5495	730	0	6225	2295	4453	0	0	7571	7294	-1420	18420	0	0	18420	2537	427	21384	49.99
21	5567	466	0	6033	2214	4796	0	0	6738	6488	-1390	17713	0	0	17713	2551	428	20692	49.94
22	5536	406	0	5942	2256	4403	0	0	6519	6369	-1420	17134	0	0	17134	2526	416	20076	49.98
23	5488	315	0	5803	2202	4009	0	0	6444	6448	-1413	16621	0	0	16621	2493	428	19542	50.00
24	5490	313	0	5803	2346	4033	0	0	6096	5733	-1387	16124	0	0	16124	2448	404	18976	50.03
MUs	121.41	9.86	0.00	131.26	53.92	95.05	0.00	11.99	171.52	167.10	-33.35	416.45	0.00	0.00	416.45	56.51	9.52	482.49	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 06/Aug/2023

Position as on 6.30 Hrs of 07/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
IPP	SWPGPL U-3	135	21/07/2023	01:54		Continued.	Non-availability of linkage coal stock and due to continuous rains.	07/08/2023
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	DUE TO HPT DIFFERENTIAL EXPANSION ON HIGHER SIDE	22/08/2023
MSPGCL	Uran Unit 6	108	27/07/2023	20:10		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	28/07/2023	15:30		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	28/07/2023	21:07		Continued.	Zero Schedule.	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	12/08/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Aug/2023

Position as on 6.30 Hrs of 07/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00		Continued.	ID Fan Problem.	07/08/2023
IPP	RPL(AMT) U-3	270	05/08/2023	19:07		Continued.	Due to TG shaft vibration high.	09/08/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	06/08/2023	09:13	06/08/2023	19:21	PO	Replacement of connecting jumper of capacitor bank at Pole-1 base filter due to aging effect
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	04/08/2023	09:22			PO	400 kV 125 MVar Bus Reactor to be kept OFF during Outage on 400 kV Bus-2 as it is connected to 400 kV Bus-2
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 4Y4 phase Protection CT Of NTPP I (RPL 1)
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03			PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
JAIGAD - KARAD CKT - 2	IntraState	06/08/2023	01:30	06/08/2023	08:17	HT	H/T FOR O/V
KHADKA-AURANGABAD (WALUJ)	IntraState	06/08/2023	01:48	06/08/2023	07:56	HT	H/T FOR O/V
KHADKA-AURANGABAD (WALUJ)	IntraState	06/08/2023	21:02	07/08/2023	07:28	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 1	IntraState	06/08/2023	21:04	07/08/2023	08:08	HT	H/T on overvoltage
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	07/08/2023	08:46			PO	Pending work related to work done by project division at Loc. No. 154
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44			PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	06/08/2023	09:44			PO	Cooling System Renovation, commissioning, HV CB timing/DCRM,SFRA,REF,NDR relay & bay Maintenance work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	07/08/2023	09:03	07/08/2023	15:01	PO	(1)ICT-1 B ph unit RPRR relay inspection/ repairing work by representative of M/s CTR,Pune. 2) 220kV side CT tan delta & CB diagnostice testing work.
400/220/33 KV 500 MVA ICT - 3 @ DHULE	IntraState	07/08/2023	12:20			PO	Pending work of RRS scheme for 501 MVA ICT-3
400/220KV 167 MVA SPARE ICT @ DHULE	IntraState	07/08/2023	12:40			PO	Pending work of RRS scheme for 501 MVA ICT-3
220 KV TIEBAY Outages/Trippings							
TBC @ PHURSUNGI	IntraState	07/08/2023	11:50	07/08/2023	13:12	PO	Half yearly Maint., CT tan Delta and C measurement.
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	07/08/2023	11:05			PO	AMP as per Maintenance schedule
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
BOMBAY DYEING - SAHARA	IntraState	03/08/2023	12:24			T	Tripped on distance protection
APTA - BOMBAY DYEING	IntraState	03/08/2023	12:24			T	Tripped on distance protection
TROMBAY - SALSETTE CKT - 1	IntraState	06/08/2023	00:16	06/08/2023	03:25	PO	For making T connection for charging 220KV cable & GIS at 400KV KVPTL Vikroli RSS
MAIN BUS - 1 @ BHIRA	IntraState	06/08/2023	10:36	06/08/2023	14:10	PO	Testing of Bus fault protection. All equipments will remain in service
KANDALGAON - BHIRA	IntraState	06/08/2023	12:00	06/08/2023	14:12	EO	Y-Ph, Line Isolator hotspot attending works to be carried out at Bhira end.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	06/08/2023	14:15	06/08/2023	17:03	HT	H/T for facitilate emergency outage on BBLR- Chalisgaon
CHALISGAON -BABHALESHWAR	IntraState	06/08/2023	14:30	06/08/2023	16:43	EO	Replacement of faulty string at cut point loc no 278 R Ph Csn side detected in monkey patrolling of the line done for AR successful.
132 KV JALNA (220 KV) - JALNA MIDC CKT	IntraState	06/08/2023	20:30	06/08/2023	20:45	T	Distance Protection Z1 B PH d=5KM.
URAN - APTA 2	IntraState	07/08/2023	08:59	07/08/2023	12:15	PO	Replacement of damaged Jumper at loc no 42. Replacement of flashover polymer insulator at Loc no. 60
URAN - KHARGHAR 1	IntraState	07/08/2023	13:57	07/08/2023	16:51	PO	Replacement of damaged Jumper at loc no 18 Top phase)
TROMBAY - SALSETTE CKT - 1	IntraState	07/08/2023	23:20	07/08/2023	08:18	PO	- Loop closing at loc. 48 for making "T" connection on 220 kV Trombay Salsette 1 Line for soak test of 220 kV cable and 220 kV GIS at 400 kV KVTL Vikhroli S/S
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
250 MVA ICT-5 @ TROMBAY	IntraState	06/08/2023	19:32	06/08/2023	20:11	PO	110 KV BUS OUTAGE AT TROMBAY FOR PHASING
220/110KV 100MVA ICT - 3 @ PETH	IntraState	07/08/2023	09:00	07/08/2023	14:43	PO	SFRA Testing Work
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	07/08/2023	09:12	07/08/2023	15:19	PO	"1) Attending OLTC Testing work. 2) Verification of Oil leakage from OLTC tank. 3) Attending QMW Maint Work. "

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 07/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	IntraState	07/08/2023	15:29			PO	1)Quarterly bay maintenance work 2) Attending OLTC Testing work.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
DHARANI - NEPANAGAR	InterState	06/08/2023	19:11	06/08/2023	19:51	T	Tripped on distane protection
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage