

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Sep/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	124.117	767.548	1) Gujrat	7.477	52.964
2) Hydro	17.036	84.278	2) Madhya Pradesh	1.828	21.687
3) Gas	3.076	23.800	3) Chattisgarh	3.050	19.880
Total MSPGCL	144.229	875.626	4) Maharashtra	163.178	1002.300
B) 1) APML	72.988	391.518	5) Goa (Amona)	-1.268	-5.619
2) JSWEL	20.355	119.577	Total	174.265	1091.212
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.450	201.397
4) RPL(AMT)	19.207	80.983	b) Mumbai Drawl	37.436	223.332
5) SWPGPL	5.330	32.317	c) MSEDCL Bilateral *	38.347	285.998
6) Other IPP	5.902	35.894	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.436	201.345
C) 1) TPCL Thermal	12.628	70.016	Include PX	0.000	0.000
2) TPCL Hydro	5.656	32.525	Standby	0.014	0.053
3) TPCL Gas	0.426	6.248	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.068	57.057	1) MSEDCL	409.159	2443.327
D) STATE			2) Mumbai Discoms	66.214	389.177
1) Thermal	270.595	1554.910	3) Other Discoms	9.073	54.365
(A1+C1+C4+(B1-B6))			TOTAL STATE	484.446	2886.869
2) Hydro (A2+C2)	22.692	116.803			
3) Gas (A3+B7+C3)	3.502	30.048			
4) Wind	4.230	37.649			
6) SOLAR	9.162	56.248			
TOTAL STATE	310.181	1795.658			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5030	5200	5225	5121
MSPGCL Hydro	658	532	2158	247
MSPGCL Gas	120	128	130	123
MSPGCL Total Generation	5808	5860	7513	5491
Central Sector Receipt	8432	8010	6968	6213
WIND	64	80	332	89
CPP / IPP Thermal	5016	4592	5370	5226
CPP / IPP Gas	0	0	0	0
SOLAR	1129	1181	0	0
Exchange with Mumbai	-2123	-2152	-1392	-1172
MSEDCL DEMAND MET	17900	17167	18373	15573
Load Shedding	0	0	0	0
MSEDCL DEMAND	17900	17167	18373	15573
TPCL GENERATION	696	714	1180	531
AEML GENERATION	386	356	454	391
MUMBAI DEMAND	3205	3222	3026	2094
OTHER DISCOM DEMAND	426	404	418	274
STATE DEMAND MET	21531	20793	21817	17941
STATE DEMAND	21531	20793	21817	17941
Frequency (Hz)	50.00	49.92	49.95	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 17:31 Hrs	49.76 Hz at 12:53 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.32	20.21	165	85
Unit 7	0.00	0.00	0	0
Unit 8	10.86	68.57	475	425
Unit 9	0.00	0.00	0	0
Unit 10	10.21	65.50	456	395
Total	24.38	154.28		
Bhusawal				
Unit 3	2.77	16.68	150	90
Unit 4	9.72	53.50	455	360
Unit 5	0.00	0.00	0	0
Total	12.50	70.19		
Parli				
Unit 6	4.86	27.34	221	187
Unit 7	3.91	25.57	198	122
Unit 8	4.52	25.19	203	175
Total	13.28	78.11		
Chandrapur				
Unit 3	3.65	21.19	163	116
Unit 4	3.52	20.73	156	115
Unit 5	6.68	10.29	295	265
Unit 6	7.76	45.89	395	275
Unit 7	7.75	46.60	368	252
Unit 8	0.19	49.00	186	0
Unit 9	10.31	60.09	449	399
Total	39.85	253.79		
Paras				
Unit 3	4.29	26.84	208	142
Unit 4	3.85	25.95	179	152
Total	8.14	52.78		
Khaparkheda				
Unit 1	2.61	15.86	120	100
Unit 2	2.30	14.82	115	75
Unit 3	2.66	19.87	133	84
Unit 4	3.24	21.46	156	100
Unit 5	8.79	51.40	400	273
Total	19.60	123.40		
Nasik				
Unit 3	3.30	18.48	157	120
Unit 4	0.00	0.00	0	0
Unit 5	3.08	16.51	160	107
Total	6.38	34.99		
Uran				
All Units	3.08	23.80	134	118
Total	3.08	23.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.57	3.42	27	13
Total	0.57	3.42		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.52	16.74	485	35
Stage 4	4.96	14.98	952	0
Stage 3	1.74	7.33	240	0
Total	9.22	39.05		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.71	4.43	60	0
TILLARI	0.52	3.02	58	0
BHIRA T.R.	0.41	2.46	70	0
SMLHY_PTN	4.67	29.66	212	167
GHATGHAR	0.94	2.25	125	0
Total	7.24	41.81		
Wind				
Total	4.23	37.65	0	0
Total	4.23	37.65		
CPP				
APML(Mus)	72.99	391.52	0	0
JSWEL(Mus)	20.36	119.58	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.21	80.98	0	0
SWPGPL-Mus	5.33	32.32	0	0
Other(Mus)	5.90	35.89	0	0
Total	123.78	660.29		
SOLAR				
Total	9.16	56.25	0	0
Total	9.16	56.25		
Tata				
Trombay 5	8.56	47.12	451	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.43	4.01	85	0
Trombay 7B	0.00	2.24	0	0
TATA Hydro	5.66	32.52	419	110
Trombay 8	4.07	22.89	232	130
Total	18.71	108.79		
AEMIL				
DTPS U-1&2	10.07	57.06	494	323
Total	10.07	57.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	124.12	767.55	MSPGCL Total	144.23	875.63
			MSPGCL Thml+Gas	127.19	791.35	Koyna 1,2 & 4 Total	7.48	31.72
			MSPGCL Hydro	17.04	84.28	State Total	310.18	1795.66

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5226	247	132	5605	143	5242	0	0	6149	6195	-1164	15672	0	15672	2535	349	18556	49.95
2	5075	259	122	5456	167	5225	0	0	6125	6109	-1107	15544	0	15544	2339	306	18189	49.97
3	5088	232	133	5453	87	5225	0	0	5936	6055	-1051	15476	0	15476	2190	293	17959	49.97
4	5121	247	123	5491	89	5226	0	0	6130	6213	-1172	15573	0	15573	2094	274	17941	50.00
5	5158	258	132	5548	130	5260	0	0	6455	6615	-1188	16064	0	16064	2064	301	18429	50.00
6	5216	296	132	5644	135	5307	0	0	6970	7214	-1237	16729	0	16729	2151	334	19214	49.97
7	5243	1444	131	6818	119	5348	0	42	6679	6733	-1118	17588	0	17588	2254	354	20196	49.89
8	5273	1529	132	6934	110	5347	0	223	7569	7609	-1396	18448	0	18448	2400	379	21227	49.96
9	5280	662	134	6076	90	5342	0	492	8248	8436	-1840	18199	0	18199	2687	397	21283	50.01
10	5344	548	131	6023	64	5339	0	873	8416	8271	-2141	18005	0	18005	2993	424	21422	50.02
11	5030	658	120	5808	64	5016	0	1129	9014	8432	-2123	17900	0	17900	3205	426	21531	50.00
12	5145	613	130	5888	81	4736	0	1211	8589	8298	-2128	17669	0	17669	3286	417	21372	49.91
13	5200	532	128	5860	80	4592	0	1181	8332	8010	-2152	17167	0	17167	3222	404	20793	49.92
14	5064	423	128	5615	93	4482	0	1210	8123	8029	-2009	17019	0	17019	3108	401	20528	50.03
15	5108	400	118	5626	138	4939	0	1060	8078	7800	-2014	17155	0	17155	3149	394	20698	49.97
16	5142	371	128	5641	158	5029	0	836	7998	7632	-1883	17009	0	17009	3194	404	20607	50.00
17	5017	376	128	5521	207	5139	0	634	7910	7909	-1931	17073	64	17137	3155	406	20698	50.01
18	5094	657	129	5880	335	5057	0	253	7930	7791	-1979	16930	56	16986	3065	407	20458	50.01
19	5152	1259	120	6531	327	5315	0	18	7561	7431	-1713	17494	19	17513	2988	415	20916	49.96
20	5225	2158	130	7513	332	5370	0	0	6908	6968	-1392	18373	0	18373	3026	418	21817	49.95
21	5232	1789	131	7152	308	5362	0	0	6727	6607	-1280	17725	0	17725	2916	424	21065	50.00
22	5230	1026	131	6387	377	5393	0	0	6654	6696	-1154	17299	0	17299	2790	400	20489	49.99
23	5196	677	121	5994	316	5375	0	0	6681	6713	-1091	16928	0	16928	2719	379	20026	49.99
24	5258	375	132	5765	280	5116	0	0	6766	6499	-1173	16123	0	16123	2684	364	19171	49.99
MUs	124.12	17.04	3.08	144.23	4.23	123.78	0.00	9.16	175.95	174.27	-37.44	409.16	0.14	409.30	66.21	9.07	484.58	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Sep/2022

Position as on 6.30 Hrs of 07/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	13/09/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03	07/09/2022	02:57	Turbine bearing Vabration high	07/09/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/09/2022	02:24		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	05/09/2022	09:20		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	05/09/2022	22:00	06/09/2022	18:00	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Sep/2022

Position as on 6.30 Hrs of 07/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7A	120	06/09/2022	23:30		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	07/09/2022	02:04		Continued.	Withdrawn	08/09/2022
IPP	SWPGPL U-2	135	07/09/2022	10:45	07/09/2022	13:24	Electrical Fault.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 07/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Trippings							
707 LR (TIRODA CKT - 2) REACTOR @ KORADI 3	IntraState	07/09/2022	07:24	07/09/2022	09:06	PO	For Reactor changeover Activity as per CEA safety regulations. Spare reactor taken into service in place of B ph
765 KV LINE Outages/Trippings							
Tirora-Koradi III ckt - 2	IntraState	07/09/2022	07:21	07/09/2022	09:06	PO	For Reactor changeover Activity as per CEA safety regulations. Spare reactor taken into service in place of B ph
400 KV TIEBAY Outages/Trippings							
TIE BAY 418 OF ICT-1 @ LONIKAND 2	IntraState	06/09/2022	09:37	06/09/2022	11:07	PO	Diagnostic testing and Maintenance
TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	07/09/2022	09:22	07/09/2022	11:00	PO	Diagnostic testing and Maintenance
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY- 410 OF KOLHAPUR CKT - 2 @ KOLHAPUR (PG)	InterState	07/09/2022	11:50			PO	Bay AMP
400 KV LINE Outages/Trippings							
WARORA - IEPL	IntraState	01/09/2022	07:36			PO	1. Dis-Connecting Horizontal Jumper and covert 400kv IEPL-PGCIL Deoli Ckt (Temporary Arrangemet for 10 Days) 400kv IEPL-Warora Ckt. 2. Connecting 400kv IEPL-Warora through new towers.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38			T	Y Phase Ground Fault
KHADKA-AURANGABAD (WALUJ)	IntraState	06/09/2022	00:26	06/09/2022	07:55	HT	For Voltage Control
CHANDRAPUR 2 - DHARIWAL CKT - 1	IntraState	06/09/2022	12:20	06/09/2022	17:01	PO	Diagnostic testing and allied bay maintenance work
LONIKAND I - CHAKAN	IntraState	07/09/2022	02:55	07/09/2022	08:17	HT	Emergency outage. Work at Lonikand end
PARLI-SOLAPUR (LAMBOTI)	IntraState	07/09/2022	11:14			PO	Hardware Tightening & Fitting Work
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 2 @ DHULE	IntraState	06/09/2022	10:28	06/09/2022	17:32	PO	Routine Maint & testing Work
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	06/09/2022	10:49	06/09/2022	19:43	PO	1) Routine Maintenance work 2) Diagnostic Testing Work
400 KV BR Outages/Trippings							
400KV 125 MVAR BUS REACTOR@400KV DHULE SS	InterState	07/09/2022	08:50	07/09/2022	15:01	PO	Routine Maint & testing work
220 KV TBC Outages/Trippings							
AUXILIARY BUS @ MALEGAON	IntraState	29/08/2022	16:50			PO	Shifting of TBC Bay new 50MVA 220/33kv PTR 3
220 KV LINE Outages/Trippings							
KANDALGAON - KOYNA (POPHALI)	IntraState	04/09/2022	04:15	06/09/2022	21:50	T	TRIPPED ON DISTANCE PROTECTION
EKLAHARE (OCR) - PADGHE	IntraState	05/09/2022	09:49			HT	HT for Load Management
BORIVALI - BOISAR (PG)	IntraState	05/09/2022	16:45	06/09/2022	07:29	T	LINE TRIPPED ON DISTANCE PROTECTION.
BORIVALI - TARAPUR	IntraState	06/09/2022	00:17	06/09/2022	05:49	HT	For safety purpose of 220kv Borivali-Boiser PG line
PHALTAN MIDC - WALCHANDNAGAR	IntraState	06/09/2022	09:45	06/09/2022	19:00	PO	Fixing of missing nut bolts at cut point loc no.4,5,7

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 07/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SONEWADI - BHOSE CKT - 2	IntraState	06/09/2022	09:45	07/09/2022	01:23	PO	Outage Proposal on 220kV A'Nagar (Sonewadi)- Belwandi (Bhose) Line Ckt II for Stringing work at LILO point of 220kV Ahmednagar Belwandi (Bhose) line at 400kV Karjat Substation.
VITA - MIRAJ	IntraState	06/09/2022	10:12	06/09/2022	12:21	PO	Diagnostic Testing Work
WARDHA - WARDHA (PG)	IntraState	06/09/2022	10:23	06/09/2022	17:12	PO	Routine line maintenance work
MIRAJ - MHAISHAL	IntraState	06/09/2022	12:30	06/09/2022	15:37	PO	Diagnostic testing work
NEW KOYNA - LOTEPARSHURAM	IntraState	06/09/2022	12:52	06/09/2022	13:07	T	TRIPPED ON DISTANCE PROTECTION. LBB OPERATED AT LOTE S/STN.LINE TRIPPED ONLY FROM LOTE END.
LOTEPARSHURAM- DASTURI LINE	IntraState	06/09/2022	12:52	06/09/2022	20:42	T	TRIPPED ON DISTANCE PROTECTION
WATHAR - MUDSHINGI 3 LINE	IntraState	06/09/2022	14:14	06/09/2022	17:36	HT	At 220kV Mudshingi substation for Auxillary isolator alingment work & to free auxillary bus.
TILLARI - AMONA LINE	IntraState	07/09/2022	03:33	07/09/2022	04:41	T	Tripped on Distance protection
EKLAHARE (GCR) - GHATGHAR	IntraState	07/09/2022	04:23	07/09/2022	05:04	T	Opened at Ghatghar end
TROMBAY - SALSETTE CKT - 1	IntraState	07/09/2022	06:49	07/09/2022	09:51	PO	OPGW SHIFTING WORK FOR MONOPOLE ERECTION AT LOC -60
OSMANABAD - BARSHI	IntraState	07/09/2022	09:28	07/09/2022	13:36	PO	Outage is required for Quarterly Maintenance
LAMBOTI - PANDHARPUR	IntraState	07/09/2022	10:28			PO	Replacement of R-Ph Wave Trap of 220kV LBT-Pandharpur Line due to HOT SPOT.
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	07/09/2022	12:39			PO	TRANSFER BREAKER RELATED WIRING AND TRIALS AT MSETCL END
TROMBAY - KALWA	IntraState	07/09/2022	17:01			T	Distance Protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 50MVA T/F - 2 @ MIRAJ	IntraState	06/09/2022	10:38	06/09/2022	13:52	EO	For attending oil leakage through radiator.
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	06/09/2022	10:40	06/09/2022	15:25	PO	1) DC leakage rectification work, which is identified in MOG (30K-TF Auxiliary Relay) 2) Bay R&M Work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
AMBERNATH - KALYAN CKT - 1	IntraState	07/09/2022	11:30			PO	REPAIR TO SLEEVE COMPRESSION OF OFA TAP-1

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 07/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV BR Outages/Trippings							
110KV GROUP BREAKER-2 @ TROMBAY	IntraState	07/09/2022	10:44			PO	R/M AND TESTING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage