

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Sep/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.170	857.840	1) Gujrat	-0.122	34.084
2) Hydro	13.437	123.277	2) Madhya Pradesh	-2.047	14.413
3) Gas	6.883	41.871	3) Chattisgarh	3.990	17.840
Total MSPGCL	156.490	1022.988	4) Maharashtra	211.776	1221.448
B) 1) APLM	66.292	366.995	5) Goa (Amona)	-1.747	-10.286
2) JSWEL	26.816	160.094	Total	211.850	1277.499
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.033	184.443
4) RPL(AMT)	25.614	152.220	b) Mumbai Drawl	39.641	211.020
5) SWPGPL	11.921	71.549	c) MSEDCL Bilateral *	121.991	574.164
6) Other IPP	6.925	41.674	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.019	184.393
C) 1) TPCL Thermal	12.970	86.046	Include PX	0.000	0.000
2) TPCL Hydro	4.115	28.155	Standby	0.014	0.049
3) TPCL Gas	2.375	13.080	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.955	59.832	1) MSEDCL	505.221	3024.250
D) STATE			2) Mumbai Discoms	69.057	398.134
1) Thermal	296.663	1796.250	3) Other Discoms	10.415	62.223
(A1+C1+C4+(B1-B6))			TOTAL STATE	584.693	3484.607
2) Hydro	17.552	151.432			
(A2+C2)					
3) Gas	9.258	54.951			
(A3+B7+C3)					
4) Wind	36.925	124.453			
6) SOLAR	12.444	80.021			
TOTAL STATE	372.842	2207.107			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5704	5611	5859	5768
MSPGCL Hydro	205	416	1047	252
MSPGCL Gas	285	275	281	293
MSPGCL Total Generation	6194	6302	7187	6313
Central Sector Receipt	10523	9628	7797	6831
WIND	1006	1400	1876	1602
CPP / IPP Thermal	5637	6084	6168	6110
CPP / IPP Gas	0	0	0	0
SOLAR	1788	1144	0	0
Exchange with Mumbai	-2194	-2069	-1451	-1324
MSEDCL DEMAND MET	22491	22029	21103	19091
Load Shedding	0	0	0	0
MSEDCL DEMAND	22491	22029	21103	19091
TPCL GENERATION	717	849	1217	956
AEML GENERATION	413	464	495	501
MUMBAI DEMAND	3324	3382	3163	2781
OTHER DISCOM DEMAND	463	460	474	441
STATE DEMAND MET	26278	25871	24740	22313
STATE DEMAND	26278	25871	24740	22313
Frequency (Hz)	50.02	49.99	50.02	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 18.04 Hrs	49.8 Hz at 17.23 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Sep/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.19	22.90	160	90
Unit 8	10.67	79.34	504	390
Unit 9	9.97	69.65	462	384
Unit 10	0.00	0.00	0	0
Total	23.83	171.88		
Bhusawal				
Unit 3	2.27	15.69	135	0
Unit 4	9.52	58.48	440	325
Unit 5	9.42	59.31	420	360
Total	21.21	133.48		
Parli				
Unit 6	4.42	28.38	246	0
Unit 7	4.64	28.10	212	169
Unit 8	4.60	26.98	200	173
Total	13.65	83.47		
Chandrapur				
Unit 3	3.69	21.55	165	128
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.02	30.38	345	172
Unit 7	5.70	39.35	257	219
Unit 8	9.00	58.55	419	337
Unit 9	9.65	61.86	419	372
Total	35.06	211.69		
Paras				
Unit 3	4.84	29.30	225	184
Unit 4	5.43	30.12	235	210
Total	10.27	59.42		
Khaparkheda				
Unit 1	3.01	17.14	135	110
Unit 2	1.69	12.98	87	41
Unit 3	3.37	21.83	162	129
Unit 4	3.16	21.90	151	118
Unit 5	10.82	63.75	455	440
Total	22.06	137.61		
Nasik				
Unit 3	3.10	18.35	142	114
Unit 4	3.44	21.40	151	132
Unit 5	3.54	20.54	162	130
Total	10.08	60.28		
Uran				
All Units	6.88	41.87	293	275
Total	6.88	41.87		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.36	4.60	51	0
Total	0.36	4.60		
Koyna				
Stage 1-2	2.78	24.00	330	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.01	48.77	676	0
Stage 3	1.48	16.05	240	0
Total	8.27	88.82		
Hydro				
KDPH	0.43	2.59	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.38	2.47	80	0
SMLHY_PTN	3.76	23.97	159	154
GHATGHAR	0.24	0.83	80	0
Total	4.81	29.86		
Wind				
Total	36.92	124.45	0	0
Total	36.92	124.45		
CPP				
APML(Mus)	66.29	367.00	0	0
JSWEL(Mus)	26.82	160.09	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.61	152.22	0	0
SWPGPL-Mus	11.92	71.55	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.11	36.67	259	232
Other(Mus)	0.82	5.00	0	0
Total	137.57	792.53		
SOLAR				
Total	12.44	80.02	0	0
Total	12.44	80.02		
Tata				
Trombay 5	8.49	56.61	431	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.34	7.27	108	39
Trombay 7B	1.03	5.81	64	35
TATA Hydro	4.12	28.16	398	31
Trombay 8	4.48	29.44	227	133
Total	19.46	127.28		
AEML				
DTPS U-1&2	9.96	59.83	501	311
Total	9.96	59.83		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.17	857.84	MSPGCL Total	156.49	1022.99
			MSPGCL Thml+Gas	143.05	899.71	Koyna 1,2 & 4 Total	6.79	72.77
			MSPGCL Hydro	13.44	123.28	State Total	372.84	2207.11

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Sep/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5547	1422	291	7260	1679	5453	0	0	7055	7007	-1213	19813	0	0	19813	2604	373	22790	50.02
2	5520	1148	292	6960	1634	5465	0	0	7494	7608	-1105	20199	0	0	20199	2400	363	22962	50.01
3	5548	574	292	6414	1555	5481	0	0	8112	8146	-1148	20106	0	0	20106	2244	342	22692	49.96
4	5551	451	292	6294	1650	5504	0	0	8350	8354	-1292	20173	0	0	20173	2135	337	22645	49.98
5	5535	490	293	6318	1630	5533	0	0	8677	8763	-1287	20599	0	0	20599	2118	358	23075	50.03
6	5539	365	293	6197	1612	5491	0	0	9531	9387	-1291	21012	0	0	21012	2210	384	23606	49.99
7	5636	1108	292	7036	1603	5547	0	64	9312	9434	-1214	22043	0	6	22043	2379	427	24849	49.96
8	5642	795	293	6730	1478	5549	0	337	10107	10025	-1466	22219	0	10	22219	2552	434	25205	49.98
9	5720	601	287	6608	1543	5564	0	826	10155	10110	-1954	22253	0	11	22253	2837	444	25534	49.98
10	5704	345	286	6335	1334	5642	0	1275	10393	10332	-2171	22288	0	22	22288	3110	459	25857	49.99
11	5597	233	286	6116	1222	5479	0	1591	11090	10698	-2173	22463	0	27	22463	3261	470	26194	50.02
12	5704	205	285	6194	1006	5637	0	1788	10880	10523	-2194	22491	0	29	22491	3324	463	26278	50.02
13	5797	207	283	6287	1022	5647	0	1641	10561	10131	-2175	22090	0	22	22090	3305	463	25858	49.99
14	5796	215	280	6291	1077	5646	0	1612	10197	10046	-2195	22028	0	19	22028	3263	449	25740	50.00
15	5748	452	278	6478	1251	5598	0	1270	10268	9981	-2215	21930	0	15	21930	3322	433	25685	49.98
16	5611	416	275	6302	1400	6084	0	1144	9900	9628	-2069	22029	0	11	22029	3382	460	25871	49.99
17	5534	205	280	6019	1727	5775	0	628	9927	9306	-2017	20976	0	3	20976	3366	462	24804	50.00
18	5573	653	283	6509	1848	5877	0	236	8875	8372	-1840	20513	0	0	20513	3279	489	24281	49.93
19	5720	1171	286	7177	1588	6148	0	32	8086	7824	-1584	20690	0	0	20690	3210	495	24395	50.01
20	5859	1047	281	7187	1876	6168	0	0	8081	7797	-1451	21103	0	0	21103	3163	474	24740	50.02
21	5899	389	285	6573	1921	6103	0	0	7880	7291	-1422	19988	0	0	19988	3045	478	23511	50.02
22	5862	366	287	6515	1904	5945	0	0	7202	7303	-1493	19708	0	0	19708	2912	466	23086	50.03
23	5760	327	290	6377	1763	6122	0	0	6904	6953	-1348	19414	0	0	19414	2854	453	22721	50.03
24	5768	252	293	6313	1602	6110	0	0	6957	6831	-1324	19091	0	0	19091	2781	441	22313	50.01
MUs	136.17	13.44	6.88	156.49	36.92	137.57	0.00	12.44	215.99	211.85	-39.64	505.22	0.00	0.18	505.22	69.06	10.41	584.69	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) 132 KV BBLR to Rahuri line overload- at 132 KV Rahuri ss./stn (520 Amp/105 MW)

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Sep/2023

Position as on 6.30 Hrs of 07/Sep/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	20/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	13/09/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	08/09/2023
IPP	Adani U-4	660	12/08/2023	23:44	06/09/2023	08:33	Annual Overhaul	06/09/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	10/09/2023
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
MSPGCL	Uran Unit 6	108	02/09/2023	07:16		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	05/09/2023	06:56	06/09/2023	05:03	Boiler Tube Leakage	06/09/2023
MSPGCL	Parli Unit 6	250	06/09/2023	15:07	06/09/2023	17:39	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 07/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV TBC Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	06/09/2023	22:55	07/09/2023	01:43	HT	Emergency outage availed for attending hotspot of temp.158 deg. Cel.
500 KV LR Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	07/09/2023	22:22		Continued.	T	Tripped on level 3, jumper found broken
400 KV TIEBAY Outages/Trippings							
Tie bay (405) of Deepnagar line @ Taptitanda	IntraState	04/09/2023	12:11	06/09/2023	17:48	PO	Circuit breaker mechanism overhauling work by M/s CGL
TIE BAY (405) OF ICT -2 AND STG-4 @ JEJURI	IntraState	07/09/2023	11:30	07/09/2023	13:44	PO	Replacement of pole discrepancy relay of 405 Tie bay
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
CHANDRAPUR - BHADRAVATI CKT - 4	InterState	06/09/2023	08:11	06/09/2023	19:15	PO	Attending CVT Oil leakage.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 405 phase Protection CT Of NTPP I (RPL 1)
GT-10 @ KORADI-2	IntraState	04/09/2023	12:11	06/09/2023	18:30		1) Nut bolt tightening work of jumpers, clamp & connector of CT, CB & other bay equipments.
DABHOL - NAGOTHANE CKT - 2	IntraState	06/09/2023	08:30	07/09/2023	20:47	PO	String insulators replacement
PARLI-SOLAPUR (LAMBOTI)	IntraState	07/09/2023	10:21	07/09/2023	19:27	PO	(1) Main-1 distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work
DHULE- - BABLESHWAR CKT - 2	IntraState	07/09/2023	11:30	07/09/2023	20:36	PO	Routine line maintenance and insulator cleaning work
KHADKA-AURANGABAD (WALUJ)	IntraState	07/09/2023	17:07			HT	H/T For Voltage management.
LONIKAND 2 - KARJAT CKT - 1	IntraState	07/09/2023	19:22	07/09/2023	22:11	PO	Line Reactor testing work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	05/09/2023	09:21			PO	1.Replacement of HV CB under LES Scheme.2.A & B Bus PG isolator Maintenance Work.3.ICT HV Side will be in service through TBC.
220 KV LINE Outages/Trippings							
JEUR - SOLAPUR PG	InterState	06/09/2023	10:12	06/09/2023	18:03	PO	Outage is required for Quarterly Maintenance
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
KARAD - KADEGAON	IntraState	06/09/2023	09:44	06/09/2023	17:51	PO	1.Cold line washing of insulator String 2.Replacement of flashover/damaged insulator strings at various locations 3.Rusted Nut bolt replacement work at loc No.38 C/P
HALKARNI-MAHALAXMI LINE	IntraState	06/09/2023	09:54	06/09/2023	10:48	T	Tripped on Backup protection.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 07/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LAMBOTI - SOLAPUR 2(BALE) CKT- 2	IntraState	06/09/2023	10:58	06/09/2023	12:59	PO	For Bay Maintenance & Diagnostic testing work.
HALKARNI-MAHALAXMI LINE	IntraState	06/09/2023	11:13	06/09/2023	13:12	PO	" For Diagnostic Testing of CB & Maintenance work of bay equipments"
Aux Bus @ SOUTH SOLAPUR (KUMBHARI)	IntraState	06/09/2023	11:30	06/09/2023	15:40	PO	Outage is required for Quarterly Maintenance
WARDHA - WARDHA (PG)	IntraState	06/09/2023	11:36	06/09/2023	19:24	PO	For Amp of Line Bay
MUDSHINGI - CHIKODI	IntraState	06/09/2023	11:49	06/09/2023	20:05	T	Tripped on Distance protection.
MUMEWADI -HALKARNI 1 LINE	IntraState	06/09/2023	14:10	06/09/2023	15:54	PO	" For Diagnostic Testing of CB & Maintenance work of bay equipments"
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	06/09/2023	14:13	06/09/2023	16:03	PO	For bay maintenance & diagnostic testing work.
BHIGWAN - WALCHAND NAGAR	IntraState	06/09/2023	14:45	06/09/2023	21:10	PO	Cold line cleaning and washing of R, Y & B phase porcelain disc insulator strings from T. L. 50 - 90
SAHARA-URSE	IntraState	06/09/2023	23:13	07/09/2023	00:57	HT	To control line loading and to avail emergency outage on 220 kv Talegaon Ambi - Urse ckt 1.
URSE - TALEGAON (AMBI) CKT 1	IntraState	06/09/2023	23:20	07/09/2023	00:52	HT	Emergency outage availed for Attending Hot-Spot on Y-ph CT of 220kV Talegaon-Urse Ckt-1 line.
BABLESHWAR- ALEPHATA CKT - 1	IntraState	07/09/2023	07:22	07/09/2023	19:16	PO	for attending the damage conductor at various cut point locations found in monkey patrolling of the line. 83 Y ph Alephata side, 82 B ph Alephata side, 74 R ph BBLR side, 98 R ph alephata side ..
MUMEWADI -HALKARNI 2 LINE	IntraState	07/09/2023	10:06	07/09/2023	11:52	PO	" For Diagnostic Testing of CB & Maintenance work of bay equipments"
HALKARNI - TILARI LINE	IntraState	07/09/2023	13:04	07/09/2023	16:25	PO	" For Diagnostic Testing of CB & Maintenance work of bay equipments"
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ LONIKAND	IntraState	04/09/2023	10:40	06/09/2023	17:51	PO	220kV HV CB mechanism overhauling work
220/22 KV 50 MVA PTR 3 @ LONIKAND	IntraState	04/09/2023	10:47	06/09/2023	17:51	PO	TF- 3 HVCB Mechanism O/H work by shifting its load on 220 kV TBC
220 / 110 / 33kV 250MVA ICT 9 @ DHARAVI	IntraState	06/09/2023	10:01	06/09/2023	17:08	PO	145kV GIS Project Work: CSD Commissioning
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	06/09/2023	10:10	06/09/2023	13:15	PO	Diagnostic testing work. And LV Bay Maintenance work
220/132 KV 100 MVA ICT 2 @ RANJANGAON	IntraState	06/09/2023	10:20	07/09/2023	15:36	PO	for 220kV Circuit breaker overhauling work.
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	07/09/2023	10:42	07/09/2023	17:18	PO	Hot spot attending work .Diagnostic testing work , Annual relay testing work Yearly maintenance .
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 07/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
MAIN BUS - 2 @ PHALTAN MIDC- 220 KV	IntraState	04/09/2023	10:44	06/09/2023	17:15	PO	220kV Bus PT Extension Work
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	06/09/2023	11:27	06/09/2023	19:22	PO	Routine Maintenance work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
100 KV LINE Outages/Trippings							
KALWA - SALSETTE CKT - 1	IntraState	05/09/2023	09:41			PO	CB pole Overhauling work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage