

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Nov/2019 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	104.820	525.435	1) Gujrat	1.855	20.554
2) Hydro	9.243	54.786	2) Madhya Pradesh	5.428	28.218
3) Gas	6.874	60.491	3) Chattisgarh	7.110	44.190
Total MSPGCL	120.937	640.712	4) Maharashtra	116.168	666.442
B) 1) APLM	74.121	435.581	5) Goa (Amona)	-0.374	-2.860
2) JSWEL	20.814	121.702	Total	130.187	756.544
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.541	153.516
4) RPL(AMT)	6.707	13.090	b) Mumbai Drawl	30.543	174.612
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	24.389	128.292
6) Other IPP	8.256	50.371	Include PX	-0.213	-7.264
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.541	153.516
C) 1) TPCL Thermal	13.626	80.360	Include PX	8.465	48.886
2) TPCL Hydro	4.862	23.817	Standby	0.000	0.000
3) TPCL Gas	4.347	25.548	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.891	58.399	1) MSEDCL	339.834	1915.501
D) STATE			2) Mumbai Discoms	63.264	362.731
1) Thermal	238.235	1284.938	TOTAL STATE	403.098	2278.232
(A1+C1+C4+(B1-B6))					
2) Hydro	14.105	78.603			
(A2+C2)					
3) Gas	11.221	86.039			
(A3+B7+C3)					
4) Wind	3.232	41.348			
6) SOLAR	6.123	30.765			
TOTAL STATE	272.916	1521.693			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4189	4104	4416	4082
MSPGCL Hydro	381	168	1654	122
MSPGCL Gas	277	273	287	267
MSPGCL Total Generation	4847	4545	6357	4471
Central Sector Receipt	6318	6464	5440	5032
WIND	137	142	181	45
CPP / IPP Thermal	4618	4276	5011	3909
CPP / IPP Gas	0	0	0	0
SOLAR	898	865	0	0
Exchange with Mumbai	-1767	-1812	-1290	-901
MSEDCL DEMAND MET	15051	14480	15699	12556
Load Shedding	0	0	0	0
MSEDCL DEMAND	15051	14480	15699	12556
TPCL GENERATION	967	918	1230	663
AEML GENERATION	375	373	500	373
MUMBAI DEMAND	3109	3103	3020	1937
STATE DEMAND MET	18160	17583	18719	14493
STATE DEMAND	18160	17583	18719	14493
Frequency (Hz)	50.01	50.00	50.06	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 17.47 Hrs	49.81 Hz at 06.14 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 06/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.75	63.62	518	302
Unit 9	11.64	68.04	520	460
Unit 10	8.85	58.63	400	320
Total	30.24	190.29		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.90	55.80	400	350
Unit 5	9.12	57.06	430	345
Total	18.01	112.86		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.10	9.62	188	155
Unit 4	0.00	0.00	0	0
Unit 5	8.97	22.71	395	355
Unit 6	9.57	26.74	455	356
Unit 7	0.00	0.00	0	0
Unit 8	10.20	59.07	500	360
Unit 9	9.44	49.96	469	338
Total	42.28	168.10		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	10.17	34.26	500	360
Total	10.17	34.26		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.12	15.01	191	157
Unit 5	0.00	4.91	0	0
Total	4.12	19.92		
Uran				
All Units	6.87	60.49	361	263
Total	6.87	60.49		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	3.36	44	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.13	3.36		
Koyna				
Stage 1-2	2.81	17.88	385	35
Stage 4	2.75	17.68	834	0
Stage 3	1.19	8.19	206	0
Total	6.75	43.75		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.39	1.54	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.32	1.82	80	0
RNGR+BHTSA	0.39	2.30	17	16
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.52	1.02	22	21
SMLHY_PTN	0.44	2.22	19	18
GHATGHAR	0.44	2.14	125	0
Total	2.50	11.04		
Wind				
Total	3.23	41.35	0	0
Total	3.23	41.35		
CPP				
APML(Mus)	74.12	435.58	0	0
JSWEL(Mus)	20.81	121.70	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	6.71	13.09	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.26	50.37	0	0
Total	109.90	620.74		
SOLAR				
Total	6.12	30.76	0	0
Total	6.12	30.76		
Tata				
Trombay 5	8.85	51.87	480	282
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	16.25	117	115
Trombay 7B	1.56	9.30	66	65
Trombay 8	4.77	28.49	201	198
TATA Hydro	4.86	23.82	394	0
Total	22.84	129.72		
AEML				
DTPS U-1&2	9.89	58.40	500	372
Total	9.89	58.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	104.82	525.44	MSPGCL Total	120.94	640.71
			MSPGCL Thml+Gas	111.69	585.93	Koyna 1,2 & 4 Total	5.56	35.56
			MSPGCL Hydro	9.24	54.79	State Total	272.92	1521.69

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4119	182	319	4620	55	4317	0	0	4994	4899	-1228	12663	0	12663	2349	15012	49.99
2	4081	197	340	4618	43	3867	0	0	4909	5168	-1103	12593	0	12593	2157	14750	49.98
3	4093	311	361	4765	40	3835	0	0	4858	4890	-999	12531	0	12531	2035	14566	50.01
4	4082	122	267	4471	45	3909	0	0	4848	5032	-901	12556	0	12556	1937	14493	49.99
5	4300	91	281	4672	38	4272	0	0	4854	5045	-878	13149	0	13149	1914	15063	50.01
6	4613	200	294	5107	39	4634	0	0	4869	4835	-841	13774	0	13774	1993	15767	50.00
7	4691	760	284	5735	46	4683	0	13	4913	5005	-734	14748	0	14748	2096	16844	49.93
8	4777	935	285	5997	60	4654	0	182	5102	5174	-805	15262	0	15262	2265	17527	50.04
9	4748	412	282	5442	84	4751	0	472	5374	5535	-931	15353	0	15353	2572	17925	50.02
10	4547	185	281	5013	132	4818	0	723	5564	5556	-1321	14921	0	14921	2898	17819	50.01
11	4189	381	277	4847	137	4618	0	898	6273	6318	-1767	15051	0	15051	3109	18160	50.01
12	4161	380	264	4805	138	4516	0	896	6515	6284	-1834	14805	0	14805	3171	17976	50.03
13	4104	168	273	4545	142	4276	0	865	6524	6464	-1812	14480	0	14480	3103	17583	50.00
14	4111	156	272	4539	192	3895	0	778	6417	6557	-1711	14250	0	14250	3013	17263	50.01
15	4126	337	263	4726	163	4158	0	628	6301	6356	-1742	14289	0	14289	3065	17354	49.99
16	4494	142	273	4909	145	4808	0	437	5833	5725	-1643	14381	0	14381	3087	17468	49.98
17	4575	92	275	4942	181	4957	0	196	5497	5425	-1459	14242	0	14242	3058	17300	50.02
18	4614	355	278	5247	223	4959	0	35	5267	5253	-1305	14412	0	14412	2998	17410	50.07
19	4416	1654	287	6357	181	5011	0	0	5182	5440	-1290	15699	0	15699	3020	18719	50.06
20	4508	1202	280	5990	345	5061	0	0	5156	5239	-1167	15468	0	15468	2907	18375	50.05
21	4496	341	280	5117	305	5115	0	0	5052	5124	-1039	14622	0	14622	2783	17405	50.03
22	4530	175	282	4987	222	4997	0	0	5044	5161	-1292	14075	0	14075	2654	16729	50.01
23	4308	260	292	4860	112	4917	0	0	4971	4848	-1384	13353	0	13353	2576	15929	49.99
24	4137	205	284	4626	164	4870	0	0	5146	4854	-1357	13157	0	13157	2509	15666	49.99
MUs	104.82	9.24	6.87	120.94	3.23	109.90	0.00	6.12	129.46	130.19	-30.54	339.83	0.00	339.83	63.27	403.10	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Nov/2019

Position as on 6.30 Hrs of 07/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
MSPGCL	Khaparkheda Unit 4	210	22/10/2019	23.52		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 6	250	23/10/2019	03.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Parli Unit 7	250	23/10/2019	17.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Nov/2019

Position as on 6.30 Hrs of 07/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	26/10/2019	08.00	06/11/2019	17.24	Zero Schedule	
MSPGCL	Chandrapur Unit 4	210	31/10/2019	08.16		Continued.	Excessive Consumption of Hydrogen Cylinder.	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	
MSPGCL	Uran Unit 7	108	05/11/2019	00.17		Continued.	Internal Inspection	
MSPGCL	Uran Unit B0	120	05/11/2019	09.50	06/11/2019	02.47	Bearing vibration high	
MSPGCL	Uran Unit 8	108	06/11/2019	03.05	06/11/2019	18.09	Bearing vibration high	
MSPGCL	Uran Unit B0	120	06/11/2019	03.05		Continued.	Bearing vibration high	
MSPGCL	Uran Unit 8	108	06/11/2019	19.23		Continued.	Turbine Vibration	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 07/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
400 KV Main Bus II @ Aurangabad (Ektuni)	IntraState	07/11/2019	10.32	07/11/2019	16.17	PO	Routine Maintenance Work
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT I @ Aurangabad (Ektuni)	IntraState	07/11/2019	14.32	07/11/2019	16.18	T	Ektuni-Taptitanda-1 Y-PH Pole Burst At Ektuni S/S
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	05/11/2019	21.03	06/11/2019	23.44	PO	To attend Low Oil Level in convertor T/F OLTC
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	02/11/2019	13.42	06/11/2019	06.48	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	05/11/2019	10.03	07/11/2019	09.36	PO	Maintenance work(RFC 17.20Hrs)
Dhule Sar'Sarovar II	InterState	07/11/2019	19.22		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	27/10/2019	14.07		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	04/11/2019	23.55	06/11/2019	09.40	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	05/11/2019	21.01	06/11/2019	10.13	HT	Over Voltage
Bus Coupler @ Padgha	IntraState	06/11/2019	09.47	06/11/2019	17.56	EO	Attending Hot Spot
Koradi-Khaperkheda II	IntraState	06/11/2019	10.13	06/11/2019	16.42	PO	Diagnostic Testing & Routine Maintenance Work.
Kala Kudus Ckt-I	IntraState	06/11/2019	10.24	06/11/2019	19.40	PO	Annual Maintenance Work
Pune(GIS)-A'bad(Waluj) Ckt 1	IntraState	06/11/2019	14.55	06/11/2019	17.43	PO	Jumper Tightening, CC Replacement Work.
Karad-Jaigad - I	IntraState	06/11/2019	21.58		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/11/2019	10.24		Continued.	PO	RFC 19.38 Diagnostic Testing Work.
Ektuni-Bableswhar ckt II	IntraState	07/11/2019	14.32	07/11/2019	20.11	T	Ektuni-Taptitanda-1 Y-PH Pole Burst At Ektuni S/S
Khadka-Aurangabad (Waluj)	IntraState	07/11/2019	17.13		Continued.	HT	Over Voltage
Kala Kudus Ckt-I	IntraState	07/11/2019	17.23		Continued.	EO	To Attend Insulator For Flashover Work.
Ektuni - Taptitanda Ckt I	IntraState	07/11/2019	20.35	07/11/2019	21.05	T	Y-Phase Pole CB Burst & Charged Through TIE BREAKER.
Jejuri- Koynastage-IV	IntraState	07/11/2019	22.08		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220KV 500MVA ICT-I @Nanded	IntraState	07/11/2019	10.33	07/11/2019	17.40	PO	For ICT TerTriary Insulation Coating Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	06/11/2019	15.12		Continued.	T	Distance Protection, R-N, 15.5KM, 2.79KA.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Ranjangaon-Lonikand	IntraState	31/10/2019	15.29		Continued.	PO	Tower jumps opened.
Trombay - Kalwa	IntraState	05/11/2019	20.06	06/11/2019	14.49	PO	Tower Pilling Work
Lonikand2-Lonikand1 (Interconector)	IntraState	06/11/2019	08.36	06/11/2019	20.26	PO	To Make Twin Conductor Arrangement.
Dhule - Dondaicha Ckt	IntraState	06/11/2019	08.45	06/11/2019	11.12	PO	Bay Maintenance Work.
Khaparkheda-Kalmeshwar	IntraState	06/11/2019	08.59	06/11/2019	12.33	PO	Coverion of SSN To DSN

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 07/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Location 43,44.
Abhijeet-Wardha-I	IntraState	06/11/2019	09.06	06/11/2019	19.22	PO	Ckt From ERS To Diverted/Height Raised Tower From LOC No 144 To 146.
Vita-Hiwarwadi	IntraState	06/11/2019	09.31	06/11/2019	12.39	PO	C & Tan Delta And Testing CT Bay.
Abhijeet-Wardha-II	IntraState	06/11/2019	09.32	06/11/2019	19.30	PO	For Shifting And Charging of 220KV Wardha-Abhijit-1 Ckt From ERS To Diverted/Height Raised Tower From LOC No 144 To 146.
Bus Coupler @ Butibori	IntraState	06/11/2019	11.29	06/11/2019	13.20	PO	Attend CB Drain Valve Problem.
Kamba - Kolshet	IntraState	06/11/2019	12.07	06/11/2019	15.04	PO	Diagnostic Testing & Routine Maintenance Work.
Khaparkheda-Ambazari-II	IntraState	06/11/2019	12.45	06/11/2019	15.22	PO	Conversion of SSN To DSN LOC No.43.44.
Osmanabad - Barshi	IntraState	06/11/2019	13.15	06/11/2019	17.41	PO	Relay Testing.
Vita-Wayphale	IntraState	06/11/2019	14.10	06/11/2019	16.15	PO	C & Tan Delta And Testing CT Bay.
220kv Halkarni- Tillary	IntraState	06/11/2019	15.12	06/11/2019	16.24	T	Backup Protection
Talandage - Sawantwadi I	IntraState	06/11/2019	16.47	06/11/2019	17.09	T	Distance Protection, R-N,127KM, 1.49KA.
Sawantwadi-Bidri	IntraState	06/11/2019	16.52	07/11/2019	11.42	T	Distance Protection, R-N, 75.43KM. 1.664KA.
220kv Halkarni- Tillary	IntraState	06/11/2019	18.06		Continued.	T	B PH PT Burst.
Trombay - Kalwa	IntraState	06/11/2019	20.13		Continued.	PO	Pilling Work At LOC NO 19.
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	07/11/2019	08.48	07/11/2019	15.38	PO	Hot Line Work, Online Transfer Only.
Lonikand2-Lonikand1 (Interconector)	IntraState	07/11/2019	09.06	07/11/2019	18.23	PO	To MAKE twin Conductor Arrangement.
KORADI 2 - KAULEWADA CKT - I	IntraState	07/11/2019	09.18	07/11/2019	17.56	PO	To DSN AT Various Location
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	07/11/2019	10.07	07/11/2019	19.47	PO	CT replacment Work.
Walchandnagar-Bhigwan	IntraState	07/11/2019	10.30	07/11/2019	14.36	PO	Replacement Of Flashover String 2 LOC.
Khadka-Bhadli-2	IntraState	07/11/2019	10.42	07/11/2019	14.00	PO	Attending Oil Leakage of R-Phase Metering CT & Routine Maintenance Work.
BOTHE - PHALTAN MIDC	IntraState	07/11/2019	11.30	07/11/2019	13.50	PO	Routine Maintenance Work
Khadka-Chalisgaon-1	IntraState	07/11/2019	12.03	07/11/2019	20.08	PO	SUBSTATION BY M/S. MTCIL. 2) FOR MAKING LILO ARRANGEMENT AT LOC NO:- 238 BY REMOVING THROUGH JUMPERS OF 220KV KHADAKACHALISGAON CKT II FOR 200/132/33KV KEKATNIMBHORA SUBSTATION.
Kandalgaon - Koyna (Pophali)	IntraState	07/11/2019	12.10	07/11/2019	13.00	T	R-PH Distence Protection.
Jejuri- Ismt- Lonand	IntraState	07/11/2019	14.10	07/11/2019	17.52	PO	Routine Maintenance Work
Kalwa1- Airoli Knowledge Park	IntraState	07/11/2019	15.24	07/11/2019	15.52	T	Distance Protection power Swing.
Eklahare (Gcr)(Nashik) - Airoli Know Park	IntraState	07/11/2019	15.24	07/11/2019	17.33	T	Distance Protection Y-B-PH Fault.
220 KV ICT Outages/Trippings							
220/132 kV 200 MVA ICT-III @ Nanded	IntraState	06/11/2019	00.23	06/11/2019	01.15	T	Oil Temp. Trip, Winding Temp Trip.
220/132 Kv 200 Mva Bbl Ict 1 @Beed	IntraState	06/11/2019	11.42	06/11/2019	12.59	PO	Quarterly Maintenance Work
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	07/11/2019	10.08	07/11/2019	18.35	PO	TAn delta Testing Work.
220/132 KV 100MVA ICT-I @ Bhokar	IntraState	07/11/2019	11.32	07/11/2019	14.10	PO	C & Tan Delta Testing Of LV CT & Quarterly maintenance Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 07/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100MVA ICT-II @ Bhokar	IntraState	07/11/2019	14.12	07/11/2019	16.40	PO	Quarterly Maintainance Work