

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 06/Nov/2020 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 131.995        | 802.016         | 1) Gujrat                      | 2.345          | 12.112          |
| 2) Hydro            | 4.159          | 30.145          | 2) Madhya Pradesh              | 5.382          | 42.239          |
| 3) Gas              | 6.646          | 39.822          | 3) Chattisgarh                 | 6.620          | 38.640          |
| <b>Total MSPGCL</b> | <b>142.800</b> | <b>871.983</b>  | 4) Maharashtra                 | 124.602        | 736.939         |
| B) 1) APLM          | 61.115         | 385.352         | 5) Goa (Amona)                 | -1.125         | -7.130          |
| 2) JSWEL            | 18.478         | 102.975         | <b>Total</b>                   | <b>137.824</b> | <b>822.800</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 24.256         | 150.665         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 22.656         | 151.256         |
| 5) WPCL             | 7.064          | 43.698          | c) MSEDCL Bilateral *          | 29.426         | 168.621         |
| 6) Other IPP        | 13.276         | 71.725          | Include PX                     | 0.505          | 2.172           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 24.256         | 150.665         |
| C) 1) TPCL Thermal  | 16.390         | 92.489          | Include PX                     | 15.926         | 98.099          |
| 2) TPCL Hydro       | 5.354          | 21.350          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.321          | 26.254          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 4.924          | 30.231          | 1) MSEDCL                      | 377.604        | 2249.890        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 53.645         | 321.580         |
| 1) Thermal          | 253.242        | 1528.486        | <b>TOTAL STATE</b>             | <b>431.249</b> | <b>2571.470</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 9.513          | 51.495          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 10.967         | 66.076          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 12.542         | 62.458          |                                |                |                 |
| 6) SOLAR            | 7.161          | 40.155          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>293.425</b> | <b>1748.670</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5679                      | 5425                  | 5972                      | 4697                      |
| MSPGCL Hydro             | 255                       | 220                   | 430                       | 69                        |
| MSPGCL Gas               | 268                       | 276                   | 269                       | 293                       |
| MSPGCL Total Generation  | 6202                      | 5921                  | 6671                      | 5059                      |
| Central Sector Receipt   | 6494                      | 6663                  | 5866                      | 4980                      |
| WIND                     | 712                       | 394                   | 286                       | 723                       |
| CPP / IPP Thermal        | 4154                      | 4029                  | 4518                      | 3662                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 940                       | 1010                  | 0                         | 0                         |
| Exchange with Mumbai     | -995                      | -1047                 | -1048                     | -703                      |
| <b>MSEDCL DEMAND MET</b> | <b>17507</b>              | <b>16970</b>          | <b>16293</b>              | <b>13721</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17507                     | 16970                 | 16293                     | 13721                     |
| TPCL GENERATION          | 1307                      | 1313                  | 1262                      | 868                       |
| AEML GENERATION          | 249                       | 250                   | 250                       | 144                       |
| <b>MUMBAI DEMAND</b>     | <b>2551</b>               | <b>2610</b>           | <b>2560</b>               | <b>1715</b>               |
| STATE DEMAND MET         | 20058                     | 19580                 | 18853                     | 15436                     |
| <b>STATE DEMAND</b>      | <b>20058</b>              | <b>19580</b>          | <b>18853</b>              | <b>15436</b>              |
| Frequency (Hz)           | 49.98                     | 50.00                 | 50.02                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.2 Hz at 13.01 Hrs | 49.86 Hz at 11.04 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 06/Nov/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.89        | 67.66         | 601      | 370      |
| Unit 9             | 10.88        | 32.54         | 560      | 370      |
| Unit 10            | 8.98         | 53.37         | 400      | 360      |
| <b>Total</b>       | <b>31.74</b> | <b>153.56</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 8.66         | 56.10         | 470      | 280      |
| Unit 5             | 4.44         | 36.44         | 365      | 0        |
| <b>Total</b>       | <b>13.11</b> | <b>92.54</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 8.84          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 5.06         | 22.65         | 250      | 170      |
| <b>Total</b>       | <b>5.06</b>  | <b>31.49</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.82         | 22.99         | 178      | 116      |
| Unit 4             | 3.61         | 21.78         | 161      | 116      |
| Unit 5             | 8.62         | 54.66         | 425      | 275      |
| Unit 6             | 9.10         | 55.75         | 420      | 280      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 4.90         | 61.07         | 475      | 0        |
| Unit 9             | 11.66        | 67.60         | 490      | 469      |
| <b>Total</b>       | <b>41.72</b> | <b>283.84</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.45         | 33.81         | 244      | 180      |
| Unit 4             | 5.51         | 33.48         | 250      | 175      |
| <b>Total</b>       | <b>10.96</b> | <b>67.28</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.62         | 21.56         | 170      | 135      |
| Unit 2             | 3.82         | 23.54         | 180      | 140      |
| Unit 3             | 3.82         | 23.63         | 180      | 140      |
| Unit 4             | 3.86         | 24.17         | 185      | 140      |
| Unit 5             | 10.45        | 60.27         | 485      | 320      |
| <b>Total</b>       | <b>25.58</b> | <b>153.17</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.82         | 20.12         | 187      | 123      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>3.82</b>  | <b>20.12</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.65         | 39.82         | 293      | 256      |
| <b>Total</b>       | <b>6.65</b>  | <b>39.82</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.18         | 0.98          | 40       | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.18</b>  | <b>0.98</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 1.89         | 15.73         | 295      | 40       |
| Stage 4         | 0.00         | 1.87          | 0        | 0        |
| Stage 3         | 0.35         | 4.29          | 80       | 0        |
| <b>Total</b>    | <b>2.24</b>  | <b>21.90</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.00          | 0        | 0        |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 0.00         | 0.11          | 0        | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.37         | 1.19          | 40       | 0        |
| RNGR+BHTSA      | 0.35         | 2.12          | 15       | 14       |
| BHANDARDRA      | 0.00         | 0.00          | 0        | 0        |
| ELDARY          | 0.00         | 0.93          | 0        | 0        |
| SMLHY_PTN       | 0.00         | 0.00          | 0        | 0        |
| GHATGHAR        | 1.20         | 3.90          | 190      | 0        |
| <b>Total</b>    | <b>1.92</b>  | <b>8.25</b>   |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 12.54        | 62.46         | 0        | 0        |
| <b>Total</b>    | <b>12.54</b> | <b>62.46</b>  |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 61.12        | 385.35        | 0        | 0        |
| JSWEL(Mus)      | 18.48        | 102.98        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 7.06         | 43.70         | 0        | 0        |
| Other(Mus)      | 13.28        | 71.72         | 0        | 0        |
| <b>Total</b>    | <b>99.93</b> | <b>603.75</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 7.16         | 40.16         | 0        | 0        |
| <b>Total</b>    | <b>7.16</b>  | <b>40.16</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 10.96        | 60.36         | 465      | 423      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.75         | 16.76         | 117      | 114      |
| Trombay 7B      | 1.57         | 9.49          | 67       | 65       |
| Trombay 8       | 5.43         | 32.13         | 229      | 223      |
| TATA Hydro      | 5.35         | 21.35         | 455      | 2        |
| <b>Total</b>    | <b>26.06</b> | <b>140.09</b> |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 4.92         | 30.23         | 251      | 144      |
| <b>Total</b>    | <b>4.92</b>  | <b>30.23</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 132.00      | 802.02        | MSPGCL Total        | 142.80      | 871.98        |
|                |             |         | MSPGCL Thml+Gas | 138.64      | 841.84        | Koyna 1,2 & 4 Total | 1.89        | 17.60         |
|                |             |         | MSPGCL Hydro    | 4.16        | 30.14         | State Total         | 293.42      | 1748.67       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 06/Nov/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4725        | 59   | 281  | 5065   | 593   | 3814      | 0    | 0     | 5280        | 5237        | -998                 | 13711                 | 0                    | 13711                     | 2038             | 15749           | 49.99         |
| 2                  | 4703        | 84   | 291  | 5078   | 638   | 3777      | 0    | 0     | 5189        | 5049        | -884                 | 13658                 | 0                    | 13658                     | 1903             | 15561           | 49.99         |
| 3                  | 4696        | 64   | 282  | 5042   | 677   | 3716      | 0    | 0     | 5094        | 4998        | -794                 | 13639                 | 0                    | 13639                     | 1799             | 15438           | 50.00         |
| 4                  | 4697        | 69   | 293  | 5059   | 723   | 3662      | 0    | 0     | 5006        | 4980        | -703                 | 13721                 | 0                    | 13721                     | 1715             | 15436           | 50.00         |
| 5                  | 5225        | 59   | 292  | 5576   | 813   | 3746      | 0    | 0     | 4995        | 5280        | -688                 | 14727                 | 0                    | 14727                     | 1699             | 16426           | 49.97         |
| 6                  | 5760        | 69   | 273  | 6102   | 910   | 3968      | 0    | 0     | 5243        | 5395        | -723                 | 15652                 | 0                    | 15652                     | 1734             | 17386           | 49.97         |
| 7                  | 6052        | 54   | 293  | 6399   | 858   | 4551      | 0    | 8     | 6034        | 5497        | -758                 | 16555                 | 0                    | 16555                     | 1763             | 18318           | 49.98         |
| 8                  | 6086        | 65   | 283  | 6434   | 696   | 4834      | 0    | 194   | 6177        | 5880        | -860                 | 17178                 | 0                    | 17178                     | 1878             | 19056           | 49.99         |
| 9                  | 6041        | 65   | 292  | 6398   | 546   | 4838      | 0    | 541   | 6132        | 6082        | -781                 | 17624                 | 0                    | 17624                     | 2114             | 19738           | 50.00         |
| 10                 | 6069        | 137  | 270  | 6476   | 586   | 4720      | 0    | 804   | 6257        | 5875        | -871                 | 17590                 | 0                    | 17590                     | 2363             | 19953           | 50.03         |
| 11                 | 5679        | 255  | 268  | 6202   | 712   | 4154      | 0    | 940   | 6645        | 6494        | -995                 | 17507                 | 0                    | 17507                     | 2551             | 20058           | 49.98         |
| 12                 | 5430        | 220  | 267  | 5917   | 601   | 3973      | 0    | 1031  | 6748        | 6830        | -1074                | 17278                 | 0                    | 17278                     | 2645             | 19923           | 49.98         |
| 13                 | 5425        | 220  | 276  | 5921   | 394   | 4029      | 0    | 1010  | 6754        | 6663        | -1047                | 16970                 | 0                    | 16970                     | 2610             | 19580           | 50.00         |
| 14                 | 5250        | 225  | 256  | 5731   | 292   | 4046      | 0    | 939   | 6592        | 6597        | -991                 | 16614                 | 0                    | 16614                     | 2550             | 19164           | 50.02         |
| 15                 | 5443        | 365  | 256  | 6064   | 194   | 4008      | 0    | 814   | 6466        | 6587        | -1018                | 16649                 | 0                    | 16649                     | 2578             | 19227           | 49.98         |
| 16                 | 5854        | 270  | 266  | 6390   | 170   | 4257      | 0    | 573   | 6271        | 6506        | -1020                | 16876                 | 0                    | 16876                     | 2582             | 19458           | 50.02         |
| 17                 | 5911        | 323  | 256  | 6490   | 134   | 4527      | 0    | 267   | 6034        | 6083        | -962                 | 16539                 | 0                    | 16539                     | 2519             | 19058           | 50.02         |
| 18                 | 5978        | 330  | 278  | 6586   | 173   | 4836      | 0    | 40    | 5906        | 5512        | -981                 | 16166                 | 0                    | 16166                     | 2538             | 18704           | 50.00         |
| 19                 | 5972        | 430  | 269  | 6671   | 286   | 4518      | 0    | 0     | 5953        | 5866        | -1048                | 16293                 | 0                    | 16293                     | 2560             | 18853           | 50.02         |
| 20                 | 5978        | 366  | 279  | 6623   | 304   | 4119      | 0    | 0     | 5854        | 5735        | -1067                | 15714                 | 0                    | 15714                     | 2497             | 18211           | 50.05         |
| 21                 | 5689        | 220  | 280  | 6189   | 387   | 4016      | 0    | 0     | 5683        | 5300        | -1034                | 14858                 | 0                    | 14858                     | 2407             | 17265           | 50.04         |
| 22                 | 5345        | 85   | 271  | 5701   | 456   | 3989      | 0    | 0     | 5569        | 5234        | -1112                | 14268                 | 0                    | 14268                     | 2277             | 16545           | 50.01         |
| 23                 | 5165        | 60   | 292  | 5517   | 631   | 3969      | 0    | 0     | 5422        | 5165        | -1153                | 14129                 | 0                    | 14129                     | 2192             | 16321           | 50.02         |
| 24                 | 4822        | 65   | 282  | 5169   | 768   | 3866      | 0    | 0     | 5291        | 4979        | -1094                | 13688                 | 0                    | 13688                     | 2133             | 15821           | 49.99         |
| MUs                | 131.99      | 4.16 | 6.65 | 142.80 | 12.54 | 99.93     | 0.00 | 7.16  | 140.59      | 137.82      | -22.66               | 377.60                | 0.00                 | 377.60                    | 53.64            | 431.25          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 06/Nov/2020**

**Position as on 6.30 Hrs of 07/Nov/2020**

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                            | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |            |            |                                                                                             |               |
| IPP                  | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                     |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                 |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                 |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                      |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                               |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                               |               |
| MSPGCL               | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |            | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL               | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |            | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL               | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                  | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                  | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |            | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |            | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL               | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |            | Continued. | Gas shortage                                                                                |               |
| IPP                  | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL               | Chandrapur Unit 7       | 500      | 29/09/2020   | 01.58        |            | Continued. | Tripped On Generator Protection.                                                            |               |
| MSPGCL               | Parli Unit 7            | 250      | 22/10/2020   | 20.00        |            | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| AEML                 | AEML Unit 2             | 250      | 31/10/2020   | 18.47        | 06/11/2020 | 23.35      | Milling system problems                                                                     |               |
| IPP                  | JSW (J) U2              | 300      | 01/11/2020   | 04.44        |            | Continued. | No Schedule                                                                                 |               |
| MSPGCL               | Parli Unit 6            | 250      | 02/11/2020   | 23.28        |            | Continued. | Excess DM water consumption.                                                                |               |
| MSPGCL               | Bhusawal Unit 5         | 500      | 04/11/2020   | 08.30        | 06/11/2020 | 08.54      | Boiler Tube Leakage                                                                         |               |
| MSPGCL               | Chandrapur Unit-8       | 500      | 06/11/2020   | 10.56        |            | Continued. | Boiler validity expired.                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 06/Nov/2020**

**Statement-VII**

Position as on 6.30 Hrs of 07/Nov/2020

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                 |
| Chandrapur - Padghe Hvdc Pole 2                   | IntraState                | 19/10/2020   | 23.01        |            | Continued. | PO          | Abnormal sound from main tank of smoothing reactor at Chandrapur end                                            |
| Chandrapur - Padghe Hvdc Pole 1                   | IntraState                | 05/11/2020   | 15.53        | 06/11/2020 | 20.47      | T           | D.C. Differential Z Block.                                                                                      |
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                 |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                        |
| Dhule Sar'Sarovar I                               | InterState                | 03/11/2020   | 19.31        | 06/11/2020 | 08.59      | HT          | Over Voltage                                                                                                    |
| Dhule Sar'Sarovar II                              | InterState                | 06/11/2020   | 09.52        |            | Continued. | PO          | Earth Wire replacement work(RFC 19.00Hrs)                                                                       |
| Lamboti - Solapur (PG)                            | InterState                | 06/11/2020   | 17.06        | 06/11/2020 | 21.48      | PO          | jumper Nut Bolts tightening work                                                                                |
| Karad - Jaigad - II                               | IntraState                | 16/09/2020   | 23.34        |            | Continued. | HT          | Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).                                            |
| Jaigad-Karad Ckt-I                                | IntraState                | 27/09/2020   | 18.59        |            | Continued. | T           | Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).                                      |
| Akola - Bhusawal                                  | IntraState                | 05/11/2020   | 18.56        | 06/11/2020 | 06.21      | T           | Distance Protection                                                                                             |
| Dhule - Bableshtar - II                           | IntraState                | 06/11/2020   | 01.16        | 06/11/2020 | 07.25      | HT          | Over Voltage                                                                                                    |
| Deepnagar - Aurangabad                            | IntraState                | 06/11/2020   | 07.35        | 06/11/2020 | 16.12      | PO          | Replacement of Insulator String                                                                                 |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 06/11/2020   | 21.13        |            | Continued. | HT          | Over Voltage                                                                                                    |
| Akola II - RPL(Rattanindia) Ckt I                 | IntraState                | 06/11/2020   | 22.04        |            | Continued. | HT          | Over Voltage                                                                                                    |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                 |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                                        |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/09/2020   | 09.58        |            | Continued. | PO          | Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.                                                           |
| 400/220/33 Kv 315 Mva Ict 2 @Dhule                | IntraState                | 23/09/2020   | 09.12        |            | Continued. | PO          | Augmentation work of 400/220 315MVA ICT-II to 501MVA                                                            |
| 400/220/33kv 315MVA ICT2 @Lonikand                | IntraState                | 01/11/2020   | 03.34        |            | Continued. | T           | Differential protection                                                                                         |
| 400/220KV 500MVA ICT-II@Taptitanda                | IntraState                | 06/11/2020   | 12.58        | 06/11/2020 | 18.51      | PO          | Filtration of R Phase Unit OLTC Oil                                                                             |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                 |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                     |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                          |
| Tillari Amona                                     | InterState                | 02/11/2020   | 14.30        |            | Continued. | PO          | 220 kv Amona Bay old CB Replacement (civil,Erection & Commissioning,testing)Work at 220 kv Tillari Switch yard. |
| Kharghar-Borivali ckt II                          | IntraState                | 11/08/2020   | 01.45        |            | Continued. | T           | Special Repair Cable work.                                                                                      |
| Theur-Phursungi                                   | IntraState                | 14/08/2020   | 09.46        |            | Continued. | HT          | Outage Arrangement HTLS Work.                                                                                   |
| Theur- Magar Patta City                           | IntraState                | 14/08/2020   | 10.27        |            | Continued. | HT          | Outage Arrangement HTLS Work.                                                                                   |
| Parli 3 (Old Gcr)-Girwali Ckt-3                   | IntraState                | 20/08/2020   | 13.05        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                       |
| Parli 3(Old Gcr)- Girwali Ckt 4                   | IntraState                | 20/08/2020   | 13.06        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                       |
| Lonikand1 (400 Kv)-Theur II                       | IntraState                | 06/10/2020   | 08.54        |            | Continued. | PO          | HTLS Stringing work                                                                                             |
| Virur - Gadchiroli                                | IntraState                | 06/11/2020   | 08.45        | 06/11/2020 | 16.44      | PO          | Diagnostic Testing                                                                                              |
| Balapur-Akola I                                   | IntraState                | 06/11/2020   | 09.05        | 06/11/2020 | 14.12      | PO          | Line Maintenance work                                                                                           |
| Dhamangaon New - Badnera                          | IntraState                | 06/11/2020   | 09.18        | 06/11/2020 | 17.50      | PO          | Diagnostic Testing                                                                                              |
| Osmanabad - Solapur (Bale)                        | IntraState                | 06/11/2020   | 09.30        | 06/11/2020 | 13.22      | PO          | Measurment of Tan Delta and SFRA of ICT                                                                         |
| Lamboti -Solapur li(Bale) Ckt- II                 | IntraState                | 06/11/2020   | 09.30        | 06/11/2020 | 13.30      | PO          | Quarterly Maintenance Work                                                                                      |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 06/Nov/2020**

**Statement-VII**

**Position as on 6.30 Hrs of 07/Nov/2020**

| Name of Line                                        | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                          |
|-----------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------|
| Oni Kharepatan Line                                 | IntraState                | 06/11/2020   | 09.42        | 06/11/2020 | 18.20      | PO          | Quarterly Maintenance Work                                                |
| Parly-Parly Extn-I                                  | IntraState                | 06/11/2020   | 10.10        | 06/11/2020 | 16.53      | PO          | Measurment of Tan Delta and SFRA of ICT                                   |
| Vita-Hiwarwadi                                      | IntraState                | 06/11/2020   | 10.18        | 06/11/2020 | 12.27      | PO          | Tan Delta Measurment of CTs                                               |
| Wardha - Wardharytss1                               | IntraState                | 06/11/2020   | 10.58        | 06/11/2020 | 15.35      | PO          | Tan Delta Measurment of CTs                                               |
| Parli(U-VIII) GCR CKT                               | IntraState                | 06/11/2020   | 11.52        | 06/11/2020 | 16.53      | PO          | Routine Maintenance Work                                                  |
| ANANDNAGAR - PALAVA                                 | IntraState                | 06/11/2020   | 12.05        | 06/11/2020 | 18.20      | PO          | safety purpose(Outage on Palava-Pal Line)                                 |
| PAL DOMBIVALI - PALAVA                              | IntraState                | 06/11/2020   | 12.07        | 06/11/2020 | 19.27      | PO          | Conductor Replacement                                                     |
| Khaparkheda-Ambazari-I                              | IntraState                | 06/11/2020   | 12.38        | 06/11/2020 | 15.32      | PO          | Testing of Distance Protection Relay and IR Value Measurment and R M Work |
| Aurangabad (waluj)-Taptitanda ckt-1                 | IntraState                | 06/11/2020   | 12.49        | 06/11/2020 | 19.00      | PO          | To facilitate Taptitanda ICT Outage                                       |
| Lonikand-VSNL                                       | IntraState                | 06/11/2020   | 13.27        | 06/11/2020 | 15.54      | PO          | Sugarcane fire                                                            |
| Vita-Wayphale                                       | IntraState                | 06/11/2020   | 14.36        | 06/11/2020 | 16.15      | PO          | Tan Delta Measurment of CTs                                               |
| Shivajinagar-Gangapur                               | IntraState                | 06/11/2020   | 14.56        | 06/11/2020 | 19.32      | PO          | Replacement of Jumpers                                                    |
| Wada - Bhavveghar                                   | IntraState                | 06/11/2020   | 15.08        | 06/11/2020 | 18.40      | PO          | Yearly Diagnostics testing                                                |
| Wardha - Wardha Rly Tss 2                           | IntraState                | 06/11/2020   | 15.45        | 06/11/2020 | 18.33      | PO          | Tan Delta Measurment of CTs                                               |
| Ghodbunder - Versova                                | IntraState                | 06/11/2020   | 16.37        | 06/11/2020 | 18.12      | T           | Distance Protection                                                       |
| Eklahare (Gcr)(Nashik) - Airoli Know Park           | IntraState                | 06/11/2020   | 17.10        | 06/11/2020 | 20.09      | HT          | Load Management for BBLSR-Nasik-II outage                                 |
| Eklahara(Gcr)(Nasik)- Bableshtar 2                  | IntraState                | 06/11/2020   | 17.42        | 06/11/2020 | 19.56      | EO          | To attend Hot Spot                                                        |
| Eklahare (Ocr)Nasik - Padghe 2                      | IntraState                | 06/11/2020   | 17.43        | 06/11/2020 | 20.07      | HT          | Load Management for BBLSR-Nasik-II outage                                 |
| <b>220 KV ICT Outages/Trippings</b>                 |                           |              |              |            |            |             |                                                                           |
| 220/100 Kv 200MVA ICT-I @Padghe                     | IntraState                | 03/11/2020   | 10.18        |            | Continued. | PO          | Testing Work,filtration Work Going On.                                    |
| 220/132-110/11kv 200MVA ICT 1 @Miraj                | IntraState                | 04/11/2020   | 09.25        | 06/11/2020 | 16.34      | PO          | OLTC overhauling work.                                                    |
| 220/132 kv 100MVA ICT @ Bhandara                    | IntraState                | 06/11/2020   | 08.27        | 06/11/2020 | 18.32      | PO          | Diagnostic Testing                                                        |
| 200/132KV 100MVA ICT-1@Butibori                     | IntraState                | 06/11/2020   | 09.03        | 06/11/2020 | 10.14      | PO          | Measurement of IR Values                                                  |
| 220/132 Kv 100 Mva Cgl Ict 2 @Pusad                 | IntraState                | 06/11/2020   | 09.30        | 06/11/2020 | 18.15      | PO          | Testing Work                                                              |
| 220/110 Kv 200 MVA ICT-III @Kolhapur-II (Mudshingi) | IntraState                | 06/11/2020   | 10.10        | 06/11/2020 | 16.30      | PO          | Earth Resistance Measurement work                                         |
| 220/100 Kv 200 MVA ICT-I @Borivali                  | IntraState                | 06/11/2020   | 10.39        | 06/11/2020 | 22.00      | PO          | Annual Diagnostic testing work                                            |
| 220/132 Kv 200 Mva Emco Ict 3 @Waghala Nanded       | IntraState                | 06/11/2020   | 10.47        | 06/11/2020 | 19.14      | PO          | Tan Delta Measurment of CTs                                               |
| 220/132 Kv 200 Mva Bb Ict 2 @Chikhali               | IntraState                | 06/11/2020   | 11.07        | 06/11/2020 | 16.50      | PO          | Routine Maintenance Work                                                  |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage