

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Nov/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.347	845.681	1) Gujrat	-9.094	-58.937
2) Hydro	5.103	46.553	2) Madhya Pradesh	-3.362	-8.341
3) Gas	0.769	9.936	3) Chattisgarh	5.910	35.090
Total MSPGCL	146.219	902.170	4) Maharashtra	164.562	971.126
B) 1) APLM	65.082	346.115	5) Goa (Amona)	-1.141	-9.006
2) JSWEL	12.683	76.309	Total	156.875	929.932
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.081	188.131
4) RPL(AMT)	25.521	153.044	b) Mumbai Drawl	33.991	211.932
5) SWPGPL	5.709	33.347	c) MSEDCL Bilateral *	66.440	390.403
6) Other IPP	30.647	161.405	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.081	188.131
C) 1) TPCL Thermal	9.611	62.236	Include PX	0.000	0.000
2) TPCL Hydro	2.097	22.119	Standby	0.000	0.000
3) TPCL Gas	0.000	6.990	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.424	49.821	1) MSEDCL	424.049	2491.725
D) STATE			2) Mumbai Discoms	53.123	353.098
1) Thermal	297.024	1727.958	3) Other Discoms	8.803	55.796
(A1+C1+C4+(B1-B6))			TOTAL STATE	485.975	2900.619
2) Hydro	7.200	68.672			
(A2+C2)					
3) Gas	0.769	16.926			
(A3+B7+C3)					
4) Wind	11.644	82.536			
6) SOLAR	12.463	74.595			
TOTAL STATE	329.100	1970.687			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5870	5476	6481	5535
MSPGCL Hydro	167	186	449	254
MSPGCL Gas	0	0	90	91
MSPGCL Total Generation	6037	5662	7020	5880
Central Sector Receipt	7988	7622	6274	5856
WIND	515	587	277	255
CPP / IPP Thermal	5558	5556	6494	5510
CPP / IPP Gas	0	0	0	0
SOLAR	1694	1803	0	0
Exchange with Mumbai	-1592	-1667	-1355	-1476
MSEDCL DEMAND MET	19819	19191	18307	15673
Load Shedding	0	0	0	0
MSEDCL DEMAND	19819	19191	18307	15673
TPCL GENERATION	413	407	657	477
AEML GENERATION	319	297	413	322
MUMBAI DEMAND	2324	2371	2425	2275
OTHER DISCOM DEMAND	381	372	403	352
STATE DEMAND MET	22524	21934	21135	18300
STATE DEMAND	22524	21934	21135	18300
Frequency (Hz)	50.02	49.93	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 14.04 Hrs	49.71 Hz at 12.58 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.54	26.85	205	110
Unit 7	0.00	0.00	0	0
Unit 8	11.92	70.50	512	480
Unit 9	12.27	72.39	557	500
Unit 10	9.49	54.68	400	395
Total	38.23	224.42		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	7.95	52.13	450	260
Unit 5	8.19	55.52	450	275
Total	16.14	107.66		
Parli				
Unit 6	3.86	20.20	220	149
Unit 7	3.83	18.95	198	140
Unit 8	1.41	13.43	166	0
Total	9.11	52.58		
Chandrapur				
Unit 3	3.26	19.48	164	120
Unit 4	2.66	17.50	123	82
Unit 5	6.81	41.06	305	270
Unit 6	7.13	36.15	380	275
Unit 7	6.51	41.82	288	253
Unit 8	9.63	55.30	454	283
Unit 9	9.42	53.69	435	302
Total	45.42	265.00		
Paras				
Unit 3	4.75	30.72	208	181
Unit 4	0.00	0.00	0	0
Total	4.75	30.72		
Khaparkheda				
Unit 1	2.52	16.08	115	90
Unit 2	2.24	15.66	100	80
Unit 3	3.28	19.99	159	127
Unit 4	3.13	18.74	150	124
Unit 5	9.75	57.74	450	282
Total	20.92	128.21		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	2.95	19.23	156	99
Unit 5	2.82	17.86	152	102
Total	5.77	37.10		
Uran				
All Units	0.77	9.94	92	0
Total	0.77	9.94		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.01	5.86	44	38
Total	1.01	5.86		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.72	14.64	230	40
Stage 4	0.00	8.68	0	0
Stage 3	0.38	5.26	80	0
Total	2.09	28.58		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.18	0.88	77	0
SMLHY_PTN	1.72	9.77	78	68
GHATGHAR	0.10	1.47	52	0
Total	2.00	12.11		
Wind				
Total	11.64	82.54	0	0
Total	11.64	82.54		
CPP				
APML(Mus)	65.08	346.12	0	0
JSWEL(Mus)	12.68	76.31	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.52	153.04	0	0
SWPGPL-Mus	5.71	33.35	0	0
Other(Mus)	30.65	161.40	0	0
Total	139.64	770.22		
SOLAR				
Total	12.46	74.60	0	0
Total	12.46	74.60		
Tata				
Trombay 5	6.47	42.28	284	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.91	0	0
Trombay 7B	0.00	3.08	0	0
TATA Hydro	2.10	22.12	283	5
Trombay 8	3.14	19.96	135	129
Total	11.71	91.34		
AEML				
DTPS U-1&2	7.42	49.82	413	282
Total	7.42	49.82		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.35	845.68	MSPGCL Total	146.22	902.17
			MSPGCL Thml+Gas	141.12	855.62	Koyna 1,2 & 4 Total	1.72	23.32
			MSPGCL Hydro	5.10	46.55	State Total	329.10	1970.69

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5797	171	0	5968	675	5424	0	0	5736	5820	-1500	16035	0	16035	2251	352	18638	50.01
2	5845	153	0	5998	702	5526	0	0	5685	5720	-1414	16201	0	16201	2119	331	18651	50.02
3	5834	154	0	5988	730	5491	0	0	5569	5690	-1293	16309	0	16309	1990	297	18596	50.01
4	5688	153	0	5841	738	5559	0	0	5582	5651	-1216	16266	0	16266	1914	307	18487	50.00
5	5738	153	0	5891	808	5985	0	0	5697	5845	-1183	17033	0	17033	1881	313	19227	50.00
6	5822	157	0	5979	844	6264	0	0	6183	6120	-1202	17679	0	17679	1911	326	19916	50.02
7	5729	152	0	5881	841	6190	0	30	6767	6797	-1171	18216	0	18216	1921	352	20489	50.04
8	5701	182	0	5883	677	6190	0	399	6478	6572	-1156	18194	0	18194	1957	371	20522	50.00
9	5648	342	0	5990	508	5796	0	953	6788	7013	-1315	18562	0	18562	2077	383	21022	49.92
10	5781	221	0	6002	574	5664	0	1372	7258	7259	-1455	19017	0	19017	2212	399	21628	49.93
11	5870	167	0	6037	515	5558	0	1694	7794	7988	-1592	19819	0	19819	2324	381	22524	50.02
12	5841	151	0	5992	599	5531	0	1747	7864	7861	-1664	19683	0	19683	2378	383	22444	50.00
13	5476	186	0	5662	587	5556	0	1803	7647	7622	-1667	19191	0	19191	2371	372	21934	49.93
14	5454	201	0	5655	423	5461	0	1674	7212	7500	-1628	18712	0	18712	2336	373	21421	50.01
15	5894	151	0	6045	334	5743	0	1363	6982	7498	-1568	19040	0	19040	2339	375	21754	50.01
16	6029	151	45	6225	244	6219	0	941	7147	7011	-1584	18670	0	18670	2354	386	21410	49.98
17	6013	153	88	6254	211	6199	0	430	6736	6577	-1417	17860	0	17860	2323	394	20577	49.97
18	6161	159	90	6410	171	6222	0	57	6423	6458	-1323	17608	0	17608	2300	387	20295	50.01
19	6481	449	90	7020	277	6494	0	0	6255	6274	-1355	18307	0	18307	2425	403	21135	50.03
20	6359	331	92	6782	284	6302	0	0	6354	6198	-1356	17813	0	17813	2416	397	20626	50.00
21	6050	327	91	6468	227	5731	0	0	5837	5763	-1428	16366	0	16366	2386	395	19147	49.93
22	5917	341	91	6349	214	5557	0	0	5791	5905	-1501	16133	0	16133	2353	391	18877	49.95
23	5684	244	91	6019	206	5470	0	0	5826	5877	-1527	15663	0	15663	2310	382	18355	49.97
24	5535	254	91	5880	255	5510	0	0	5757	5856	-1476	15673	0	15673	2275	352	18300	49.99
MUs	140.35	5.10	0.77	146.22	11.64	139.64	0.00	12.46	155.37	156.88	-33.99	424.05	0.00	424.05	53.12	8.80	485.98	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Nov/2022

Position as on 6.30 Hrs of 07/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	14/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	14/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-3	135	21/10/2022	01:33		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	22/10/2022	16:51		Continued.	Turbine Vibration	15/11/2022
IPP	SWPGPL U-1	135	23/10/2022	20:29		Continued.	PA Fan Vibration Problem	06/11/2022
MSPGCL	Uran Unit 5	108	02/11/2022	17:35		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/11/2022	10:50	06/11/2022	12:14	MOT level fluctuate and fire protection operate turbine tripped and boiler hand tripped.	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Nov/2022

Position as on 6.30 Hrs of 07/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	05/11/2022	08:29	06/11/2022	15:22	Gas shortage	
CENT.SECTOR	Tarapur 3	540	07/11/2022	02:00		Continued.	For maintenance on reactor side	
MSPGCL	Koyana Unit 6	80	07/11/2022	08:00		Continued.	INJECTOR REPLACEMENT	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 07/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/11/2022	12:21			PO	Annual Maintenance work AC & DC yard Equipment, Valve Hall,Diagnostic testing, Line Maintenance, etc.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AKOLA - WARDHA(PG) CKT - 2	InterState	07/11/2022	08:06	07/11/2022	14:11	PO	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV- WARDHA-AKOLA-1
AKOLA - WARDHA(PG) CKT - 1	InterState	07/11/2022	15:35	07/11/2022	19:51	PO	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV- WARDHA-AKOLA-2
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/10/2022	10:27		Continued.	HT	For Load management
TBC @ KOLHAPUR(TALANDGE)	IntraState	03/11/2022	16:15			PO	Overhauling of A bus, B Bus, C Bus PG isolators.
PADGHE - PADGHE HVDC CKT- 2	IntraState	05/11/2022	12:21			PO	1. Bay maint. work 2. Diagnostic testing work 3. Bhel CB Pole Overhauling work 4. A bus PG Isolator Replacement work under LES 5. If pole Overhauling work not completed due to any reason line will be charge on TBC. 6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator 7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change .
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	05/11/2022	22:02	06/11/2022	06:22	EO	89C B-Phase Hot spot on IPS tube nut bolt
NEW KOYNA - STAGE IV CKT - 1	IntraState	05/11/2022	22:21	06/11/2022	09:44	PO	400 KV Breaker Time Testing
JAIGAD - KARAD CKT - 1	IntraState	07/11/2022	00:33	07/11/2022	09:25	HT	H/T DUE TO O/V
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	07/11/2022	06:35	07/11/2022	18:28	PO	Replacement of faulty Disc Insulator strings by LRP strings
RPL(AMT) NANDGAON PETH - AKOLA II LINE II	IntraState	07/11/2022	14:56	07/11/2022	19:32	EO	To attend hotspot(Temperature-130°C) in Line Isolator(B Phase) at Akola-II SS
KARAD - TALANDGE CKT - 2	IntraState	07/11/2022	16:49	07/11/2022	21:32	EO	Hotspot at Y ph C bus Isolator
400 KV ICT Outages/Trippings							
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	07/11/2022	02:28	07/11/2022	02:55	T	TRIPPED ON PDR
500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2	IntraState	07/11/2022	10:06	07/11/2022	18:19	PO	Diagnostic testing & allied bay maintenance work
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	07/11/2022	10:17			PO	Overhauling of 400kv Circuit Breaker (CGL Make) of 400/220kv, 315 MVA ICT-2 @ Girwali. 400/220kv, 315 MVA ICT-2 @ Girwali will remain charged through TBC

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 07/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	IntraState	07/11/2022	12:47	07/11/2022	15:28	EO	For attending HOTSPOT on LV side R-ph CT
220 KV MAINBAY Outages/Trippings							
BUS SECTION 3 @ MUDSHINGI	IntraState	07/11/2022	09:33	07/11/2022	18:30	PO	Half yearly maint. 220 kV Bus section III isolators.
BUS SECTION 2 @ MUDSHINGI	IntraState	07/11/2022	14:34	07/11/2022	18:30	PO	Half yearly Maintenance of bus isolators .
220 KV LINE Outages/Trippings							
ACCIL - APTA	IntraState	02/11/2022	15:57		Continued.	EO	CB DC leakage attending work by testing divison panvel.
SADAWAGHAPUR KARAD CKT 2	IntraState	05/11/2022	15:02	06/11/2022	00:47	PO	Annual Relay Testing Work
KANDALGAON - PIRANGUT	IntraState	06/11/2022	08:30	06/11/2022	15:42	PO	Replacement of Flashover & deteriorated polymer insulator at Loc.No.33 & 32 and other line maintenance work.
CHALISGAON -BABHALESHWAR	IntraState	06/11/2022	08:43	06/11/2022	17:29	HT	For load management
BABHALESHWAR - UTECH SUGAR	IntraState	06/11/2022	09:00	06/11/2022	17:20	PO	220 Kv BBLR Utech Line For replacement of faulty DISC insulator string as per PID report under LMSD BBLR.
EKLAHARE (OCR) - PADGHE	IntraState	06/11/2022	09:20	06/11/2022	21:42	HT	HT for load management
KAMBA - VASAI	IntraState	06/11/2022	09:25	06/11/2022	11:11	EO	For Y- phase identified LA IR test.
GHODBUNDER - MSETCL BORIVALI	IntraState	06/11/2022	10:18	06/11/2022	13:43	PO	Annual Diagnostic testing.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/11/2022	15:31	06/11/2022	18:55	HT	Line loading control
TROMBAY - MULUND	IntraState	06/11/2022	16:32	06/11/2022	18:45	HT	Emergency outage to release stuck isolator
HALKARNI - TILARI LINE	IntraState	07/11/2022	00:08	07/11/2022	14:43	T	TRIPPED ON DIST. PROTECTION
EKLAHARE (OCR) - PADGHE	IntraState	07/11/2022	07:42			HT	For Overloading of 220kV Nashik-BBLR Line
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/11/2022	08:24			HT	For Load Management
URAN - KHARGHAR 1	IntraState	07/11/2022	08:28		Continued.	EO	Humming noise observed from B ph CB pole hence checking & overhauling ,Testing of CB
MUDSHINGI - CHIKODI	IntraState	07/11/2022	08:44	07/11/2022	18:26	PO	For insulator strings cleaning at T.L no 282 to 295 in MIDC area.
KANDALGAON - KOYNA (POPHALI)	IntraState	07/11/2022	11:52	07/11/2022	15:45	T	Tripped on Dist Protection
JEJURI (400 KV)-JEJURI- II	IntraState	07/11/2022	17:07	07/11/2022	19:32	EO	To attend Hotspot on Wavetrap by replacement of Palm.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II	IntraState	07/11/2022	09:27	07/11/2022	15:20	PO	1)Quarterly bay maintenance work of TF and 33 kV Bus section II and its outgoing feeders 2) Diagnostic testing work of TF and bay equipment 3) Hot spot attending 4) Attending LV-1 CB Overhauling work and CB pole replacemnet work.
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	07/11/2022	11:12	07/11/2022	17:48	EO	For attending hot-spots for-Line iso Rph jaw CT side. Line iso Bph jaw CT side.
220/132KV 100MVA ICT 2 @ KATHAPUR	IntraState	07/11/2022	12:01	07/11/2022	17:35	PO	Diagnostic testing work and Half yearly maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 07/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33-33KV 100MVA TF NO. - 1 @ ICHALKARANJI - II	IntraState	07/11/2022	15:42	07/11/2022	18:31	PO	1)Quarterly bay maintenance work 2) T/F HV Bay insulator string replacement work 3) Relay testing work
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ TOPWORTH	IntraState	06/11/2022	08:15	06/11/2022	18:35		Post-monsoon Maintenance, red-hotspot attending work and Diagnostic Tesing Work of metering CT, PT.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
KALYAN KALWA SALSETTE 2	IntraState	07/11/2022	10:02	07/11/2022	19:31	PO	Opening, coil back and safe guarding of loops at loc. 43 (Towards Salsette) for project work of 220KV Kalwa-Salsette-5 line.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage