

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Dec/2021 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	134.442	778.148	1) Gujrat	-6.034	-41.550
2) Hydro	7.579	45.069	2) Madhya Pradesh	5.195	31.753
3) Gas	3.490	23.963	3) Chattisgarh	5.830	32.940
Total MSPGCL	145.511	847.180	4) Maharashtra	130.385	754.394
B) 1) APLM	52.800	312.282	5) Goa (Amona)	-1.716	-10.237
2) JSWEL	14.185	85.535	Total	133.660	767.300
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.909	139.480
4) RPL(AMT)	25.880	139.821	b) Mumbai Drawl	28.468	147.184
5) SWPGPL	7.737	41.858	c) MSEDCL Bilateral *	36.171	194.979
6) Other IPP	34.960	194.458	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.909	139.480
C) 1) TPCL Thermal	8.230	64.251	Include PX	0.000	1.590
2) TPCL Hydro	4.450	23.711	Standby	0.000	0.000
3) TPCL Gas	3.347	16.603	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.116	57.651	1) MSEDCL	385.989	2258.618
D) STATE			2) Mumbai Discoms	53.611	309.397
1) Thermal	287.350	1674.004	3) Other Discoms	9.844	58.136
(A1+C1+C4+(B1-B6))			TOTAL STATE	449.444	2626.151
2) Hydro	12.029	68.780			
(A2+C2)					
3) Gas	6.837	40.566			
(A3+B7+C3)					
4) Wind	3.481	47.448			
6) SOLAR	6.087	28.056			
TOTAL STATE	315.784	1858.854			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6101	5552	6146	4634
MSPGCL Hydro	358	292	947	208
MSPGCL Gas	145	151	143	147
MSPGCL Total Generation	6604	5995	7236	4989
Central Sector Receipt	6574	6482	5869	4552
WIND	63	52	136	153
CPP / IPP Thermal	6115	5189	6499	5049
CPP / IPP Gas	0	0	0	0
SOLAR	648	952	2	0
Exchange with Mumbai	-1458	-1346	-1196	-738
MSEDCL DEMAND MET	6180	4550	5938	5652
Load Shedding	0	0	0	0
MSEDCL DEMAND	6180	4550	5938	5652
TPCL GENERATION	724	825	986	467
AEML GENERATION	370	500	454	383
MUMBAI DEMAND	2552	2671	2636	1588
OTHER DISCOM DEMAND	375	387	382	253
STATE DEMAND MET	21098	19995	21182	15593
STATE DEMAND	21098	19995	21182	15593
Frequency (Hz)	50.00	49.99	49.97	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 17.01 Hrs	49.78 Hz at 06.12 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.54	20.88	185	120
Unit 7	0.00	0.00	0	0
Unit 8	13.98	82.43	660	400
Unit 9	14.10	20.00	635	418
Unit 10	13.17	79.85	620	374
Total	44.78	203.16		
Bhusawal				
Unit 3	0.00	6.30	0	0
Unit 4	8.68	51.98	460	280
Unit 5	8.74	51.82	490	275
Total	17.42	110.10		
Parli				
Unit 6	0.00	3.90	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	4.43	0	0
Total	0.00	8.32		
Chandrapur				
Unit 3	0.60	0.60	125	0
Unit 4	3.48	12.09	162	115
Unit 5	5.08	32.58	310	0
Unit 6	0.00	34.32	0	0
Unit 7	8.21	48.34	375	293
Unit 8	9.24	55.90	403	367
Unit 9	8.85	56.72	418	323
Total	35.46	240.55		
Paras				
Unit 3	3.94	24.20	218	132
Unit 4	4.18	24.41	230	139
Total	8.12	48.61		
Khaparkheda				
Unit 1	3.18	19.13	155	120
Unit 2	3.08	18.98	165	115
Unit 3	3.75	20.58	184	129
Unit 4	2.66	14.50	154	0
Unit 5	9.84	57.14	500	275
Total	22.50	130.32		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.04	18.13	145	116
Unit 5	3.12	18.95	184	116
Total	6.16	37.09		
Uran				
All Units	3.49	23.96	157	139
Total	3.49	23.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.02	0.34	13	0
Total	0.02	0.34		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.12	12.95	360	40
Stage 4	0.45	4.13	303	0
Stage 3	0.97	4.36	80	0
Total	3.53	21.44		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.16	1.44	72	0
SMLHY_PTN	3.89	22.20	165	154
GHATGHAR	0.00	0.00	0	0
Total	4.05	23.63		
Wind				
Total	3.48	47.45	0	0
Total	3.48	47.45		
CPP				
APML(Mus)	52.80	312.28	0	0
JSWEL(Mus)	14.18	85.54	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.88	139.82	0	0
SWPGPL-Mus	7.74	41.86	0	0
Other(Mus)	34.96	194.46	0	0
Total	135.56	773.95		
SOLAR				
Total	6.09	28.06	0	0
Total	6.09	28.06		
Tata				
Trombay 5	8.23	42.45	472	279
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.02	10.15	115	49
Trombay 7B	1.33	6.45	66	41
Trombay 8	0.00	21.80	3	0
TATA Hydro	4.45	23.71	429	0
Total	16.03	104.56		
AEMIL				
DTPS U-1&2	9.12	57.65	500	303
Total	9.12	57.65		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	134.44	778.15	MSPGCL Total	145.51	847.18
			MSPGCL Thml+Gas	137.93	802.11	Koyna 1,2 & 4 Total	2.56	17.08
			MSPGCL Hydro	7.58	45.07	State Total	315.78	1858.85

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 06/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4794	210	156	5160	104	4977	0	0	4908	4576	-981	13543	0	13543	1819	293	15655	50.04
2	4394	205	147	4746	120	5029	0	0	4871	4879	-872	13610	0	13610	1716	292	15618	49.97
3	4448	214	146	4808	135	5047	0	0	4822	4784	-799	13722	0	13722	1640	253	15615	50.01
4	4634	208	147	4989	153	5049	0	0	4765	4552	-738	13752	0	13752	1588	253	15593	50.01
5	5081	199	145	5425	169	5246	0	0	4750	4585	-739	14410	0	14410	1587	276	16273	50.02
6	5712	208	146	6066	237	5639	0	0	5058	4917	-835	15697	0	15697	1662	327	17686	49.97
7	6023	267	157	6447	274	5831	0	3	5225	5105	-913	16404	0	16404	1780	343	18527	49.92
8	6224	483	146	6853	212	6278	0	120	5508	5683	-991	17794	0	17794	1980	361	20135	49.98
9	6388	283	146	6817	132	6361	0	396	5969	5861	-1259	17937	0	17937	2269	371	20577	50.01
10	6101	358	145	6604	63	6115	0	648	6455	6574	-1458	18171	0	18171	2552	375	21098	50.00
11	6167	359	143	6669	58	5988	0	886	6797	6188	-1507	17897	0	17897	2712	385	20994	50.01
12	5832	293	141	6266	54	5576	0	984	6676	6534	-1344	17700	0	17700	2719	370	20789	50.03
13	5552	292	151	5995	52	5189	0	952	6753	6482	-1346	16937	0	16937	2671	387	19995	49.99
14	5317	342	139	5798	50	5022	0	866	6604	6890	-1523	16722	0	16722	2549	381	19652	49.99
15	5492	543	139	6174	44	5187	0	623	6455	6678	-1581	16758	0	16758	2571	367	19696	50.02
16	5995	294	139	6428	55	5614	0	406	6080	6083	-1459	16767	0	16767	2576	360	19703	49.96
17	6144	334	141	6619	46	5863	0	177	5860	5830	-1330	16839	0	16839	2567	366	19772	49.97
18	6117	301	140	6558	62	6337	0	24	5503	5352	-1148	16797	0	16797	2567	388	19752	49.98
19	6146	947	143	7236	136	6499	0	2	5654	5869	-1196	18164	0	18164	2636	382	21182	49.97
20	6129	430	144	6703	185	6485	0	0	5690	5434	-1297	17132	0	17132	2583	378	20093	50.02
21	5973	198	143	6314	213	6228	0	0	5354	5047	-1302	16132	0	16132	2433	368	18933	50.01
22	5700	208	155	6063	283	5529	0	0	5612	5327	-1459	15388	0	15388	2264	355	18007	50.00
23	5288	199	145	5632	307	5235	0	0	5507	5233	-1291	14765	0	14765	2145	351	17261	50.01
24	4791	204	146	5141	337	5238	0	0	5389	5197	-1100	14481	0	14481	2025	332	16838	50.02
MUs	134.44	7.58	3.49	145.51	3.48	135.56	0.00	6.09	136.27	133.66	-28.47	387.52	0.00	387.52	53.61	8.31	449.44	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Dec/2021

Position as on 6.30 Hrs of 07/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-4	660	10/11/2021	23.58		Continued.	Capital Overhauling	10/12/2021
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09.55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Uran Unit 5	108	07/11/2021	23.28		Continued.	Turbine problem.	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 3	210	23/11/2021	12:02	06/12/2021	15:49	ID Fan Problem	
MSPGCL	Parli Unit 7	250	28/11/2021	23.57		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	02/12/2021	00:00		Continued.	ZERO SCHEDULE	
MSPGCL	Parli Unit 8	250	02/12/2021	04:00	07/12/2021	04:01	ZERO SCHEDULE	07/12/2021
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	02/12/2021	23:25		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 5	500	04/12/2021	12:41	06/12/2021	04:57	fd47 heavy gland leakage	
MSPGCL	Chandrapur Unit 6	500	05/12/2021	10:08	07/12/2021	16:35	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	05/12/2021	20:46	06/12/2021	04:18	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 07/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT-1 @ KORADI 3	IntraState	07/12/2021	09:36	07/12/2021	19:37	PO	Annual Maintenance of 765/400KV ICT-1
400 KV LR Outages/Trippings							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	07/12/2021	10:37	07/12/2021	18:37	PO	To attend hot spot (71 o C) at 29D line isolator centre contact
400 KV LINE Outages/Trippings							
LONIKAND I - TALEGAON (PGCIL)	InterState	06/12/2021	10:19	06/12/2021	16:16	PO	For AMP and Relay testing
JAIGAD - KARAD CKT - 1	IntraState	02/12/2021	22:21	07/12/2021	10:08	HT	HT FOR OVERVOLTAGE
KARAD - TALANDGE CKT - 2	IntraState	04/12/2021	22:05	06/12/2021	09:04	HT	h/t for o/v
PADGHE - NAGOTHANE CKT - 2	IntraState	05/12/2021	23:40	06/12/2021	08:28	HT	H/T for O/V
LONIKAND I - KOYNA STAGE-IV	IntraState	06/12/2021	00:07	06/12/2021	08:57	HT	O/V
BUS - 2 @ AKOLA 2	IntraState	06/12/2021	10:55	06/12/2021	19:25	PO	Annual Maintenance of Bus Equipment
EKTUNI - BABLESHWAR CKT - 1	IntraState	06/12/2021	20:02	07/12/2021	00:59	EO	Attending red hot spots of Ektuni Babhaleshwar ckt 1
KARAD - TALANDGE CKT - 1	IntraState	06/12/2021	22:50		Continued.	HT	Handtripped for Over Voltage
LONIKAND I - KOYNA STAGE-IV	IntraState	06/12/2021	22:54	07/12/2021	09:48	HT	Handtripped for Over Voltage
EKTUNI - TAPTITANDA CKT - 2	IntraState	07/12/2021	11:41	07/12/2021	17:35	PO	Relay testing, CT CAP , Tan delta measurement
PADGHE - NAGOTHANE CKT - 2	IntraState	07/12/2021	13:07	07/12/2021	19:22	PO	earth wire Replacement and jumper tightening work
TBC @ BABHALESHWAR	IntraState	07/12/2021	14:04	07/12/2021	17:50	PO	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work
JAIGAD - KARAD CKT - 2	IntraState	07/12/2021	22:13		Continued.	HT	HT for Overvoltage
KARAD - TALANDGE CKT - 2	IntraState	07/12/2021	23:27		Continued.	HT	HT for OVERVOLTAGE
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	06/12/2021	09:11	06/12/2021	14:56	PO	1. Annual diagnostic Testing Work 2. QM Work
400/11.5KV STATION TRANSFORMER - 3 @ TIRORA	IntraState	06/12/2021	10:37	06/12/2021	19:33		Outage proposal of 400KV/11.5KV TIRODA-ST-3 for metering CT accuracy test by NABL accredited Testing agency in presence of MSEDCL and MSETCL testing team.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	06/12/2021	13:18	06/12/2021	20:56	T	220KV BUS FAULT
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	06/12/2021	13:18	06/12/2021	20:56	T	220kv side bus-B insulator flashover
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	07/12/2021	10:26	07/12/2021	16:14	PO	Outage for 400 kV side CB timing,CRM & DCRM
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	IntraState	07/12/2021	13:43		Continued.	EO	Retrofitting of Numerical REF relay & Trip relay under MTAMC project work.
220 KV LINE Outages/Trippings							
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
BIDRI - SAWANTWADI	IntraState	05/12/2021	22:06	06/12/2021	10:02	HT	over voltage
GOREGAON - VERSOVA CKT - 2	IntraState	05/12/2021	23:11	06/12/2021	11:19	EO	To attend HOTSPOT ON YPh CB Pad. Hotspot Temperature - 127 deg C
MAIN BUS @ ONI	IntraState	06/12/2021	09:35	06/12/2021	18:50	PO	220KV Main bus Section -I isolator bearing replacement, all bus isolator maintenance, 220KV PT maintenance and C & Tan delta test of 220KV Pedhambe Oni Line CT.
VITA - MIRAJ	IntraState	06/12/2021	09:49	06/12/2021	18:04	PO	Q.M work & CT tan delta measurement

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 06/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 07/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KARAD - WATHAR	IntraState	06/12/2021	10:26	06/12/2021	13:43	PO	Quarterly maintenance work.
URAN - HOC 1	IntraState	06/12/2021	10:57	06/12/2021	17:17	PO	Providing missing earthwire from loc 44 to 46. Replacement of pilot disc insulator at loc 25
NAGOTHANE - POSCO	IntraState	06/12/2021	11:08	06/12/2021	13:43		for Diagnostic testing work at Nagothane s/s.
TALANDGE - ICHALKARANJI 2	IntraState	06/12/2021	13:18	06/12/2021	14:00	T	220KV BUS FAULT
TALANDAGE - FIVE STAR MIDC 2	IntraState	06/12/2021	13:18	06/12/2021	13:58	T	220KV BUS FAULT
TALANDGE - HAMIDWADA	IntraState	06/12/2021	13:18	06/12/2021	13:48	T	220KV BUS FAULT
TALANDGE - BIDRI	IntraState	06/12/2021	13:18	06/12/2021	13:42	T	BUS Fault at Kolhapur
BORIVALI - BOISAR (PG)	IntraState	06/12/2021	13:34	06/12/2021	19:25		For AMP works. Line outage is required.
BIDRI - SAWANTWADI	IntraState	06/12/2021	22:15	07/12/2021	09:45	HT	Over Voltage of 238 kV at Bidri
LOTEPARSHURAM- DASTURI LINE	IntraState	07/12/2021	10:06	07/12/2021	17:33	PO	1) New Earth wire stringing work over 220KV Bus section-II. 2) 220KV Lote-Dasturi line isolator alignment work
NAGOTHANE - SPCL	IntraState	07/12/2021	10:19	07/12/2021	18:04	PO	for Diagnostic testing work at Nagothane s/s
KHARGHAR - BORIVALI CKT - 2	IntraState	07/12/2021	13:33	07/12/2021	18:27	PO	For carrying out the bunching work at Loc. No 48 to LILO LOc. No 01 of Tifil S/St it will form 220 KV Kharghar Tifil Borivali TAP Line for the period of outage.
220 KV ICT Outages/Trippings							
220 / 110 / 22KV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	IntraState	06/12/2021	09:20	06/12/2021	12:11	PO	1)110 KV CT Oil leakage attending work
220/132-110 KV 100MVA ICT No-01 @ OGLEWADI	IntraState	06/12/2021	10:03	06/12/2021	16:56	PO	1. Q.M work 2. Diagnostic testing work
220/33KV 50MVA PTR 1 @ MUMEWADI	IntraState	06/12/2021	10:20	06/12/2021	13:38	PO	T/F winding ,bushing & HV CT Tand Delta testing and quarterly maint.work
220/33KV 50MVA PTR 2 @ MUMEWADI	IntraState	06/12/2021	14:17	06/12/2021	16:16	PO	T/F winding ,bushing & HV CT Tand Delta testing and quarterly maint.work
220/22 KV 50 MVA PTR 1 @ MULUND	IntraState	06/12/2021	16:41	06/12/2021	17:40	EO	For attending Hot spot on B Phase LV Bushing
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	07/12/2021	09:18	07/12/2021	17:34	PO	Diagnostic Testing work & oil leakage attending work.
220/33 KV 50 MVA PTR 2	IntraState	07/12/2021	10:02	07/12/2021	16:10	PO	1) New Earth wire stringing work over 220KV Bus section-II. 2) 220/33 KV 50 MVA CGL TF no 2 quarterly maintenance work
220/132-110 KV 200MVA ICT @ OGLEWADI	IntraState	07/12/2021	10:02	07/12/2021	16:09	PO	1. Q.M work 2. Diagnostic testing work
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	07/12/2021	11:03		Continued.	PO	CB pole overhauling work by agency.
220/22 KV 50 MVA PTR 1 @ MULUND	IntraState	07/12/2021	11:37	07/12/2021	14:57	EO	For Replacement of B Phase LV Bushing dropper jumper.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage