

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 07/Mar/2018 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	133.742	986.010	1) Gujrat	1.206	9.591
2) Hydro	18.031	87.672	2) Madhya Pradesh	21.305	148.455
3) Gas	6.251	43.987	3) Chattisgarh	5.990	43.300
Total MSPGCL	158.024	1117.669	4) Maharashtra Net	117.413	803.890
B) 1) APML	45.786	295.369	5) Goa (Amona)	-0.660	-3.916
2) JSWEL	18.372	123.281	Total	145.254	1001.320
3) VIPL	7.484	47.538	a) Mumbai Schedule	21.553	146.943
4) RPL(AMT)	19.873	132.437	b) Mumbai Drawl	23.930	161.856
5) WPCL	4.448	24.966	c) MSEDCL Bilateral *	39.434	252.692
6) PGPL	0.000	0.000	Include PX	10.777	70.027
7) Other IPP	11.353	76.383	d) Mumbai Bilateral *	21.553	146.943
C) 1) TPCL Thermal	17.152	107.059	Include PX	8.137	49.869
2) TPCL Hydro	5.456	27.116	Include Standby	0.000	0.000
3) TPCL Gas	2.630	26.307	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	12.049	77.245	1) MSEDCL	397.342	2715.693
D) STATE			2) Mumbai Discoms	61.217	399.580
1) Thermal	270.259	1870.288	TOTAL STATE	458.559	3115.273
(A1+C1+C4+(B1-B6))					
2) Hydro	23.487	114.788			
(A2+C2)					
3) Gas	8.881	70.294			
(A3+B6+C3)					
4) Wind	7.526	34.579			
6) SOLAR	3.152	24.007			
TOTAL STATE	313.305	2113.956			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5575	5681	5773	5401
MSPGCL Hydro	783	576	717	197
MSPGCL Gas	272	256	276	278
MSPGCL Total Generation	6630	6513	6766	5876
Central Sector Receipt	7371	7353	5627	5229
WIND	556	436	325	320
CPP / IPP Thermal	4459	4437	4586	4332
CPP / IPP Gas	0	0	0	0
SOLAR	479	495	0	0
Exchange with Mumbai	-1359	-1376	-1124	-568
MSEDCL DEMAND MET	18136	17858	16180	15189
Load Shedding	0	0	0	0
MSEDCL DEMAND	18136	17858	16180	15189
TPCL GENERATION	1262	1211	1198	784
R-INFRA GENERATION	502	498	502	503
MUMBAI DEMAND	3123	3085	2824	1855
STATE DEMAND MET	21259	20943	19004	17044
STATE DEMAND	21259	20943	19004	17044
Frequency (Hz)	49.98	50.00	50.00	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 13.02 Hrs	49.79 Hz at 15.43 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 07/Mar/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	68.92	0	0
Unit 9	11.75	52.01	557	428
Unit 10	11.86	95.28	587	445
Total	23.61	216.20		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.80	78.78	500	470
Unit 5	11.84	79.75	500	480
Total	23.64	158.52		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.86	39.86	250	210
Unit 7	5.49	39.03	249	176
Unit 8	5.82	38.19	253	230
Total	17.17	117.08		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	11.02	77.73	465	449
Unit 6	0.00	0.00	0	0
Unit 7	10.46	18.62	447	404
Unit 8	0.00	69.72	0	0
Unit 9	11.56	78.38	497	469
Total	33.04	244.45		
Paras				
Unit 3	6.05	41.62	256	250
Unit 4	5.96	41.82	253	212
Total	12.00	83.43		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	1.92	13.53	182	0
Unit 4	2.27	18.19	201	0
Unit 5	11.24	80.34	500	440
Total	15.44	112.07		
Nasik				
Unit 3	0.00	3.83	0	0
Unit 4	4.23	28.75	180	171
Unit 5	4.60	21.67	198	169
Total	8.83	54.25		
Uran				
All Units	6.25	43.99	279	214
Total	6.25	43.99		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.05	0.24	25	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.05	0.24		
Koyna				
Stage 1-2	5.19	24.44	460	40
Stage 4	6.05	27.20	1005	0
Stage 3	2.43	10.80	240	0
Total	13.67	62.44		
Hydro				
KDPH	0.86	5.19	36	36
VTRNA	1.03	7.96	61	0
TILLARI	0.10	0.10	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.26	1.41	80	0
RNGR+BHTSA	0.34	2.07	15	14
BHANDARDRA	0.46	1.64	29	13
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.78	4.73	33	32
GHATGHAR	0.52	2.14	125	0
Total	4.36	25.23		
Wind				
Total	7.53	34.58	0	0
Total	7.53	34.58		
CPP				
APML(Mus)	45.79	295.37	0	0
JSWEL(Mus)	18.37	123.28	0	0
VIPL(Mus)	7.48	47.54	0	0
RPLAMT(Mus)	19.87	132.44	0	0
WPCL(Mus)	4.45	24.97	0	0
Other(Mus)	11.35	76.38	0	0
Total	107.32	699.97		
SOLAR				
Total	3.15	24.01	0	0
Total	3.15	24.01		
Tata				
Trombay 5	11.30	69.13	488	395
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.49	16.16	84	45
Trombay 7B	1.14	10.14	57	38
Trombay 8	5.85	37.92	248	202
TATA Hydro	5.46	27.12	450	47
Total	25.24	160.48		
R-INFRA				
DTPS U-1&2	12.05	77.24	505	498
Total	12.05	77.24		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	133.74	986.01	MSPGCL Total	158.02	1117.67
			MSPGCL Thml+Gas	139.99	1030.00	Koyna 1,2 & 4 Total	11.24	51.64
			MSPGCL Hydro	18.03	87.67	State Total	313.30	2113.96

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Mar/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5407	580	275	6262	281	4458	0	0	5429	5315	-786	15530	0	15530	2216	17746	49.89
2	5377	496	277	6150	262	4452	0	0	5353	5480	-617	15727	0	15727	2038	17765	49.91
3	5426	206	268	5900	311	4330	0	0	5318	5517	-629	15429	0	15429	1926	17355	49.95
4	5401	197	278	5876	320	4332	0	0	5283	5229	-568	15189	0	15189	1855	17044	49.96
5	5324	196	276	5796	280	4407	0	0	5293	5275	-503	15255	0	15255	1826	17081	49.94
6	5278	981	278	6537	247	4470	0	0	5532	5583	-485	16352	0	16352	1863	18215	49.92
7	5215	1567	279	7061	190	4499	0	3	6408	6512	-671	17594	0	17594	2088	19682	49.96
8	5264	1921	267	7452	189	4555	0	38	6031	6275	-670	17839	0	17839	2233	20072	49.97
9	5338	1826	277	7441	136	4572	0	135	5608	5596	-898	16982	0	16982	2525	19507	49.96
10	5424	1516	276	7216	223	4546	0	266	5834	6220	-1129	17342	0	17342	2833	20175	49.92
11	5545	1091	264	6900	453	4479	0	403	6475	6718	-1369	17584	0	17584	3038	20622	50.01
12	5575	783	272	6630	556	4459	0	479	7228	7371	-1359	18136	0	18136	3123	21259	49.98
13	5681	576	256	6513	436	4437	0	495	7127	7353	-1376	17858	0	17858	3085	20943	50.00
14	5759	568	214	6541	359	4314	0	458	6767	7191	-1365	17498	0	17498	2966	20464	50.00
15	5763	602	223	6588	390	4445	0	383	7096	7110	-1343	17573	0	17573	3001	20574	49.94
16	5804	877	214	6895	315	4427	0	278	7190	6978	-1292	17601	0	17601	2992	20593	49.90
17	5804	942	224	6970	249	4438	0	169	6652	6645	-1211	17260	0	17260	2962	20222	49.94
18	5761	742	215	6718	249	4515	0	45	5847	5668	-1121	16074	0	16074	2889	18963	49.95
19	5724	525	246	6495	290	4536	0	0	5507	5644	-1085	15880	0	15880	2831	18711	49.95
20	5773	717	276	6766	325	4586	0	0	5522	5627	-1124	16180	0	16180	2824	19004	50.00
21	5756	230	276	6262	476	4568	0	0	5423	5547	-1102	15751	0	15751	2694	18445	49.96
22	5792	234	276	6302	414	4484	0	0	5427	5351	-1130	15421	0	15421	2546	17967	49.93
23	5750	384	276	6410	271	4545	0	0	5456	5469	-1089	15606	0	15606	2467	18073	49.90
24	5801	274	268	6343	304	4462	0	0	5611	5580	-1008	15681	0	15681	2396	18077	49.94
MUs	133.74	18.03	6.25	158.02	7.53	107.32	0.00	3.15	143.42	145.25	-23.93	397.34	0.00	397.34	61.22	458.56	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Mar/2018

Position as on 6.30 Hrs of 08/Mar/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
CENT.SECTOR	Tarapur 2	160	26/12/2017	10.51		Continued.	AOH	
MSPGCL	Chandrapur Unit 6	500	04/01/2018	13.30		Continued.	Water Shortage, converted to AOH w.e.f 01.02.2018, 00:00Hrs	
MSPGCL	Koyna Unit 4	70	20/01/2018	08.50		Continued.	Thrust Bearing Temperature Problem, converted to COH w.e.f 25.01.2018	
MSPGCL	Uran Unit 6	108	11/02/2018	23.43		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	De-commissioned on dt. 01.04.2017	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	De-commissioned on dt.02.03.2017	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
IPP	Dhariwal	300	27/10/2017	17.31		Continued.	Drum level Not Maintained	
MSPGCL	Chandrapur Unit 3	210	03/12/2017	01.35		Continued.	Water Shortage	
MSPGCL	Chandrapur Unit 4	210	03/12/2017	14.17		Continued.	Water Shortage	
CPP	IEPL Unit 1	270	30/12/2017	23.58		Continued.	No Schedule	
IPP	Adani U-2	660	02/01/2018	15.26		Continued.	HPBP Bonnet leakage	
MSPGCL	Koradi Unit 7	210	07/01/2018	17.00		Continued.	Poor Coal Receipt.	
IPP	VIPL U-1	300	30/01/2018	22.55		Continued.	Coal Shortage	
IPP	RPL(AMT) U-4	270	10/02/2018	16.36		Continued.	Generator Exciter Bearing oil Leakage (Out due to coal shortage w.e.f 15.02.2018)	
IPP	Adani U-4	660	12/02/2018	07.24		Continued.	Governing valve abnormal sound(Out due to coal shortage w.e.f 20.02.2018, 18:00hrs)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Mar/2018

Position as on 6.30 Hrs of 08/Mar/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 3	210	14/02/2018	02.45		Continued.	Poor Coal Receipt.	
IPP	JSW (J) U1	300	20/02/2018	12.06		Continued.	Turbine Vibration high.	
MSPGCL	Khaparkheda Unit 2	210	21/02/2018	17.27		Continued.	Boiler Tube Leakage(Converted to coal shortage w.e.f 23.02.2018	
MSPGCL	Uran Unit 5	108	25/02/2018	11.11		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	25/02/2018	11.11		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	27/02/2018	00.01		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 1	210	27/02/2018	18.00		Continued.	Poor Coal Receipt	
MSPGCL	Nasik Unit 3	210	01/03/2018	20.40		Continued.	suspected btl.	
MSPGCL	Khaparkheda Unit 3	210	03/03/2018	13.20	07/03/2018	10.15	Coal Shortage	
MSPGCL	Khaparkheda Unit 4	210	04/03/2018	09.21	07/03/2018	09.16	Poor coal receipt	
MSPGCL	Koradi Unit-8	660	06/03/2018	16.07		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit-8	500	06/03/2018	23.05		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 8	108	08/03/2018	06.03	08/03/2018	11.23	Gas Pressure Low.	
MSPGCL	Uran Unit 8	108	08/03/2018	13.11		Continued.	Natural Gas Valve Tripped.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2018

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	08/03/2018	01.51	08/03/2018	12.03	T	High Angle Supervision Order.(Restricted Upto 900MW)
Chandrapur - Padghe Hvdc Pole 1	IntraState	08/03/2018	01.51		Continued.	T	High Angle Supervision Order.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	06/03/2018	17.30		Continued.	HT	Over Voltage
Padgha - Boisar (PG)	InterState	06/03/2018	19.51	07/03/2018	00.46	EO	Attending Hot Spot
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	07/03/2018	06.05	07/03/2018	07.43	T	Distance Protection
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	08/03/2018	06.35	08/03/2018	10.50	T	Over Voltage
Chandrapur II - Dhariwal -I	InterState	08/03/2018	09.34	08/03/2018	19.51	PO	Line Maint Work. Line Taken In Service Through TBC.
Dhule Sar'Sarovar I	InterState	08/03/2018	10.35	08/03/2018	14.55	OO	String Replacement
karad -kolhapur-I	IntraState	06/03/2018	11.33	07/03/2018	09.37	PO	Relay Testing And Quarterly Maintenance Work.
Khadka-Aurangabad (Waluj)	IntraState	06/03/2018	18.33	07/03/2018	07.52	HT	Over Voltage
Padghe(HVDC)- Padghe(HVAC)-I	IntraState	06/03/2018	23.04	07/03/2018	00.59	EO	Inspection Of Pole 1 DC Voltage Divider Terminal Wiring.
Padghe - Nagothane - I	IntraState	07/03/2018	09.16	07/03/2018	19.09	PO	Testing Work
Khadka-Aurangabad (Waluj)	IntraState	07/03/2018	17.54	08/03/2018	06.28	HT	Over Voltage
Padghe - Nagothane - II	IntraState	08/03/2018	09.48	08/03/2018	18.20	PO	Routine Maintenance Work
Koradi-Khaperkheda I	IntraState	08/03/2018	12.12	08/03/2018	17.19	PO	Tan Delta Measurement.
Pune(GIS)-Talegaon(PG) Ckt 2	IntraState	08/03/2018	16.52	08/03/2018	19.12	PO	Line Maintenance work
Khadka-Aurangabad (Waluj)	IntraState	08/03/2018	20.20		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	06/03/2018	05.38	07/03/2018	01.29	T	NDR Operated
400/220 kv 500MVA ICT-I @ Alkud	IntraState	07/03/2018	10.41	07/03/2018	19.07	PO	Testing Work
400/220kv, 500 MVA ICT-II @Deepnagar	IntraState	08/03/2018	09.09	08/03/2018	14.02	PO	Diagnostic Testing.
400/220 Kv 500 MVA ICT II @Lamboti	IntraState	08/03/2018	10.47	08/03/2018	16.38	PO	Isolator Overhauling.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Maisal-Jath I	InterState	07/03/2018	14.16	07/03/2018	15.55	PO	jumper replacement.
Talandage - Chikodi	InterState	08/03/2018	06.14	08/03/2018	16.40	T	Distance Protection
Mudshingi Chikodi	InterState	08/03/2018	06.26	08/03/2018	12.06	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Kharghar-Borivali ckt II	IntraState	07/06/2017	12:23		Continued.	T	Distance Protection
Pedambe-Nerle	IntraState	23/09/2017	00.50		Continued.	T	'B'Phase CT Burst
Mumewadi -Halkarni II	IntraState	17/11/2017	10.00		Continued.	PO	Tower erection work (temporarily line would be Mumewadi-Tillari)
Halkarni - Tillari II	IntraState	17/11/2017	12.25		Continued.	PO	Tower erection work. (temporarily line would be Mumewadi-Tillari)
Nerle - Dasgaon	IntraState	06/03/2018	13.05	08/03/2018	17.19	PO	To Change Copper Terminal Connectors To Aluminium.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2018

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Talandage(400kv) - Five Star Midc	IntraState	07/03/2018	06.05	07/03/2018	12.07	T	Distance Protection
Chakan (400kv)-Bridgestone	IntraState	07/03/2018	08.02	07/03/2018	17.38	PO	Line Maintenance work
Ambazari-Amravati	IntraState	07/03/2018	08.13	07/03/2018	12.40	PO	Maint. Of Suspension Clamp At LOC. No. 247 & Replacement Of Damaged Disc Insulator At LOC. No. 219.
Kalwa - Taloja	IntraState	07/03/2018	09.16	07/03/2018	17.17	PO	Routine Maintenance Work
Khadka-Chalisgaon-2	IntraState	07/03/2018	10.22	07/03/2018	17.15	PO	Jumper Tightening Work At Various LOC.
Kadegaon-Miraj	IntraState	07/03/2018	10.43	07/03/2018	13.44	PO	cold washing of insulator.
Uran - Kharghar I	IntraState	07/03/2018	10.52	07/03/2018	18.22	PO	replacement faulty disc insulator.
Mulund - GIS Bhandup	IntraState	07/03/2018	11.48	07/03/2018	15.25	EO	due to sparking on breaker.
Osmanabad - Barshi	IntraState	07/03/2018	11.50	07/03/2018	19.00	PO	Quarterly Maintainance Work
Patoda-Manjarsumba	IntraState	07/03/2018	13.00	07/03/2018	18.36	PO	Quarterly Maintainance Work
Valve-Jamde	IntraState	07/03/2018	17.42	07/03/2018	19.19	PO	Diagnostic Testing Work.
Bableshwar- Bableshwar-II	IntraState	07/03/2018	18.01	07/03/2018	19.28	EO	Attending Hot Spot
Mudshingi-Belewadi	IntraState	08/03/2018	04.14	08/03/2018	17.52	T	Distance Protection
Talandage(400kv) - Five Star Midc	IntraState	08/03/2018	06.35	08/03/2018	12.08	T	Distance Protection
Sawantwadi-Bidri	IntraState	08/03/2018	06.47	08/03/2018	08.10	T	Distance Protection
Nanded- Bhokar I	IntraState	08/03/2018	07.41	08/03/2018	13.31	PO	Carrying Out Signature Test.
Talandge-Hamidwada	IntraState	08/03/2018	07.46	08/03/2018	12.46	T	Distance Protection
Gangapur-Valve	IntraState	08/03/2018	08.42	08/03/2018	10.26	PO	Routine Maintenance Work
Mulund - GIS Bhandup	IntraState	08/03/2018	09.01	08/03/2018	22.28	PO	Main Bus Replacement.
Amalner - Bambhori	IntraState	08/03/2018	10.02	08/03/2018	16.40	PO	Jumper Tightening Work At Various LOC.
Kharepatan -Pawas Line	IntraState	08/03/2018	10.18	08/03/2018	12.46	PO	Insulator String Washing.
Badnera - Amravati	IntraState	08/03/2018	10.23	08/03/2018	17.40	PO	Replacement Of Aux. Iso. Under LE Scheme.
Kandalgaon - Pirangut	IntraState	08/03/2018	10.25	08/03/2018	18.31	PO	Line Maintenance work
Nanded-Parbhani	IntraState	08/03/2018	14.08	08/03/2018	17.29	PO	Replacement Of Flashover Disc Insulator String At LOC. No. 45 R-PH.
Niwali - Pawas Line	IntraState	08/03/2018	14.43	08/03/2018	16.45	PO	Isolator String Washing.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(repaired and ready for commissioning)
220/100 Kv 200 MVA ICT-IV@Kalwa	IntraState	24/11/2017	01.58		Continued.	T	Buchholz PRV Operated(Failed on Internal Fault)
220/66 Kv 150 Mva Ngef Ict 1 @Gadchandur	IntraState	04/03/2018	02.55		Continued.	T	Differential protection
220/132KV 100MVA ICT-I @ Satara	IntraState	07/03/2018	14.45	07/03/2018	16.27	PO	Quarterly Maintainance Work
220/22 Kv 50 Mva Ptr 2 @Lonikand	IntraState	08/03/2018	09.17	08/03/2018	19.30	PO	Routine Maintenance Work
220/132 Kv 200 Mva Vijai Ict 1 @Babhleshwar	IntraState	08/03/2018	10.40	08/03/2018	14.05	PO	Diagnostic Testing.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage