

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Mar/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	130.911	1177.343	1) Gujrat	1.502	25.129
2) Hydro	6.919	66.257	2) Madhya Pradesh	4.247	24.744
3) Gas	4.694	30.517	3) Chattisgarh	3.450	25.380
Total MSPGCL	142.524	1274.117	4) Maharashtra	116.942	1120.897
B) 1) APML	57.240	451.814	5) Goa (Amona)	-1.687	-8.518
2) JSWEL	24.073	179.888	Total	124.454	1187.632
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.554	199.314
4) RPL(AMT)	19.699	206.147	b) Mumbai Drawl	30.384	253.039
5) SWPGPL	9.248	69.864	c) MSEDCL Bilateral *	82.954	609.855
6) Other IPP	38.641	308.107	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.554	199.314
C) 1) TPCL Thermal	9.628	78.556	Include PX	0.000	0.000
2) TPCL Hydro	1.275	19.124	Standby	0.000	0.000
3) TPCL Gas	1.719	16.824	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.625	78.274	1) MSEDCL	411.323	3542.224
D) STATE			2) Mumbai Discoms	52.631	445.817
1) Thermal	299.065	2549.993	3) Other Discoms	9.661	70.027
(A1+C1+C4+(B1-B6))			TOTAL STATE	473.615	4058.068
2) Hydro (A2+C2)	8.194	85.381			
3) Gas (A3+B7+C3)	6.413	47.341			
4) Wind	25.214	97.524			
6) SOLAR	10.275	90.197			
TOTAL STATE	349.161	2870.436			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5401	5484	5441	5470
MSPGCL Hydro	228	511	329	152
MSPGCL Gas	206	196	129	163
MSPGCL Total Generation	5835	6191	5899	5785
Central Sector Receipt	5364	5420	6206	4444
WIND	1036	525	566	1564
CPP / IPP Thermal	6492	6915	6628	5638
CPP / IPP Gas	0	0	0	0
SOLAR	1471	992	31	0
Exchange with Mumbai	-1300	-1244	-1187	-1170
MSEDCL DEMAND MET	18476	18361	17691	15939
Load Shedding	0	0	0	0
MSEDCL DEMAND	18476	18361	17691	15939
TPCL GENERATION	499	510	630	478
AEML GENERATION	304	467	497	353
MUMBAI DEMAND	2103	2221	2314	2001
OTHER DISCOM DEMAND	422	438	452	322
STATE DEMAND MET	21001	21020	20457	18262
STATE DEMAND	21001	21020	20457	18262
Frequency (Hz)	49.91	49.79	50.08	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 06:01 Hrs	49.56 Hz at 15:16 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.37	32.28	170	130
Unit 8	8.94	92.53	396	368
Unit 9	9.08	92.08	405	372
Unit 10	9.18	86.62	394	380
Total	30.57	303.51		
Bhusawal				
Unit 3	2.90	23.63	135	115
Unit 4	6.89	67.94	345	275
Unit 5	6.90	73.38	350	275
Total	16.69	164.96		
Parli				
Unit 6	3.61	32.49	156	142
Unit 7	3.56	32.57	151	144
Unit 8	2.97	23.56	138	107
Total	10.13	88.63		
Chandrapur				
Unit 3	3.02	25.77	128	120
Unit 4	2.92	22.85	125	120
Unit 5	6.96	11.34	310	280
Unit 6	6.92	61.34	295	280
Unit 7	7.08	58.06	303	281
Unit 8	6.62	76.63	281	270
Unit 9	8.11	77.18	375	302
Total	41.64	333.16		
Paras				
Unit 3	3.60	33.48	182	140
Unit 4	3.82	36.43	203	141
Total	7.42	69.91		
Khaparkheda				
Unit 1	2.72	19.95	125	100
Unit 2	2.89	22.04	125	110
Unit 3	3.22	27.59	144	128
Unit 4	3.11	27.02	139	126
Unit 5	6.81	71.17	295	275
Total	18.76	167.77		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	2.95	24.95	131	119
Unit 5	2.75	24.45	120	111
Total	5.70	49.39		
Uran				
All Units	4.69	30.52	241	129
Total	4.69	30.52		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	1.08	40	0
Total	0.12	1.08		
Koyna				
Stage 1-2	2.21	17.42	345	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.10	13.09	104	0
Stage 3	0.57	6.48	80	0
Total	2.88	36.99		
Hydro				
KDPH	0.86	5.60	36	36
VTRNA	1.00	6.88	61	0
TILLARI	0.00	0.29	0	0
BHIRA T.R.	0.14	1.04	40	0
SMLHY_PTN	1.92	14.38	88	72
GHATGHAR	0.00	0.00	0	0
Total	3.91	28.18		
Wind				
Total	25.21	97.52	0	0
Total	25.21	97.52		
CPP				
APML(Mus)	57.24	451.81	0	0
JSWEL(Mus)	24.07	179.89	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.70	206.15	0	0
SWPGPL-Mus	9.25	69.86	0	0
Dhariwal	4.97	42.44	234	181
IEPL	3.64	37.91	178	149
Other(Mus)	30.03	227.75	0	0
Total	148.90	1215.82		
SOLAR				
Total	10.28	90.20	0	0
Total	10.28	90.20		
Tata				
Trombay 5	6.46	51.62	270	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.89	9.98	38	35
Trombay 7B	0.83	6.84	36	33
TATA Hydro	1.28	19.12	171	4
Trombay 8	3.16	26.94	134	130
Total	12.62	114.50		
AEML				
DTPS U-1&2	9.62	78.27	497	297
Total	9.62	78.27		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	130.91	1177.34	MSPGCL Total	142.52	1274.12
			MSPGCL Thml+Gas	135.60	1207.86	Koyna 1,2 & 4 Total	2.31	30.51
			MSPGCL Hydro	6.92	66.26	State Total	349.16	2870.44

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 07/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5502	176	160	5838	1376	6409	0	0	6101	5101	-1487	16859	0	16859	2345	378	19582	50.00
2	5474	162	184	5820	1614	5617	0	0	5931	4927	-1360	16258	0	16258	2218	360	18836	49.97
3	5450	154	173	5777	1585	5540	0	0	5433	4638	-1245	15959	0	15959	2092	336	18387	49.99
4	5470	152	163	5785	1564	5638	0	0	4693	4444	-1170	15939	0	15939	2001	322	18262	50.01
5	5470	150	196	5816	1608	6233	0	0	4544	3911	-1129	16107	0	16107	1968	332	18407	50.03
6	5491	153	241	5885	1774	5982	0	1	5372	3795	-1120	15954	0	15954	2010	363	18327	50.03
7	5514	152	238	5904	1790	5690	0	2	4824	4134	-1075	16063	0	16063	2017	382	18462	50.07
8	5514	396	237	6147	1505	5676	0	153	4259	4628	-981	16733	0	16733	2010	395	19138	50.01
9	5489	585	241	6315	1358	5646	0	409	4743	5189	-1051	17446	0	17446	2049	420	19915	50.03
10	5435	300	227	5962	1254	5635	0	923	6525	5634	-1219	17773	0	17773	2073	416	20262	50.06
11	5415	218	226	5859	1153	5822	0	1357	6483	5925	-1320	18377	0	18377	2093	419	20889	50.02
12	5401	228	206	5835	1036	6492	0	1471	5445	5364	-1300	18476	0	18476	2103	422	21001	49.91
13	5389	531	198	6118	868	5929	0	1410	5370	5506	-1353	18064	0	18064	2201	414	20679	49.87
14	5535	568	200	6303	702	6386	0	1317	4926	5308	-1380	18232	0	18232	2254	404	20890	49.93
15	5407	259	199	5865	598	5997	0	1285	6076	5948	-1274	18005	0	18005	2219	414	20638	49.79
16	5484	511	196	6191	525	6915	0	992	5228	5420	-1244	18361	0	18361	2221	438	21020	49.79
17	5382	305	200	5887	516	6631	0	662	5840	5625	-1204	17680	0	17680	2224	437	20341	49.97
18	5349	301	187	5837	607	6752	0	262	5838	5519	-1192	17338	0	17338	2243	447	20028	50.02
19	5441	329	129	5899	566	6628	0	31	5548	6206	-1187	17691	0	17691	2314	452	20457	50.08
20	5433	352	135	5920	616	6922	0	0	5899	5701	-1260	17466	0	17466	2392	433	20291	50.06
21	5465	254	161	5880	681	6493	0	0	5918	5726	-1379	16979	0	16979	2394	422	19795	50.00
22	5419	231	178	5828	665	6115	0	0	6003	5861	-1481	16562	0	16562	2394	426	19382	50.00
23	5445	221	201	5867	610	6847	0	0	5579	5338	-1489	16749	0	16749	2402	424	19575	50.05
24	5537	231	218	5986	643	6906	0	0	5239	4606	-1484	16252	0	16252	2394	405	19051	50.01
MUs	130.91	6.92	4.69	142.52	25.21	148.90	0.00	10.27	131.82	124.45	-30.38	411.32	0.00	411.32	52.63	9.66	473.62	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Mar/2023

Position as on 6.30 Hrs of 08/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 6	108	08/03/2023	13:13		Continued.	zero schedule by msedcl	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	boiler tube leakage (under tooling from dtd-27.2.2023 @ 16:00 hrs	
MSPGCL	Uran Unit B0	120	04/03/2023	23:58	07/03/2023	04:15	Maintenance work	06/03/2023
MSPGCL	Uran Unit B0	120	07/03/2023	17:37	07/03/2023	21:31	NDE Bearing Vibrations High.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV TBC Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	08/03/2023	16:15			EO	To attend 1 nos Hotspot
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	07/03/2023	18:32	08/03/2023	07:11	EO	For Replacement of 3 nos fan in Pole-2 R-ph and 1 nos fan in Pole-2 B-ph and 4 nos MCB replacement work.
400 KV LR Outages/Trippings							
400KV AKOLA-BHUSAWAL (Bhusawal end)	IntraState	06/03/2023	19:28	08/03/2023	15:17	T	Tripped from Akola end only. AR success at Khadka end
400 KV LINE Outages/Trippings							
CHAKAN - TALEGAON(PG)	InterState	06/03/2023	22:35	07/03/2023	06:27	EO	Since 09.02.2022 no maintenance carried out on 400 kV Chakan-Talegaon(PGCIL) line due to non receipt of approval from LD Kalwa. It is very critical and important source line to feed power to Chakan MIDC and Pune ring main. To have reliable service of line following very important maintenance activities need to be carried. 1. Chemical washing of insulator strings from loc. no. 1A, 1-53. 2. PID detected insulator strings replacement at loc. no. 12 B phase Cut point, Loc. no. 21 Y phase SSN, loc. no. 24 Y phase SSN. 3. Spacers installation. 4. Diagnostic testing by testing unit Chakan, 5. Bay maintenance activities by maintenance unit Chakan.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
KHADKA-AURANGABAD (WALUJ)	IntraState	06/03/2023	19:23	08/03/2023	07:17	HT	For Overvoltage control
KARAD - TALANDGE CKT - 1	IntraState	07/03/2023	06:44	07/03/2023	10:31	EO	attending hot spot at R ph 29C PG Isolator IPS clamp towards CT side Temp-444 degree
KHADKA-AURANGABAD (WALUJ)	IntraState	08/03/2023	20:56		Continued.	HT	Over Voltage.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	IntraState	06/03/2023	17:49	07/03/2023	00:26	PO	1. C & tan delta testing of 33kV bushings 2. Annual Maintenance Work 3. PID faulty strings replacement work at 220kv side
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	06/03/2023	21:39	07/03/2023	00:32	T	OLTC Bucholz Protection
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	07/03/2023	08:53	07/03/2023	19:58	PO	1. The erection work 220kv D-type tower. 2. Ten delta of LV CT & routine maintenance work
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	IntraState	08/03/2023	10:52			PO	for replacement of 36 kV HV Neutral bushing (Tertiary) of 400/220kV ICT-2 from external agency as detected oil leakage
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS - 1 @ NEW KOYNA	IntraState	08/03/2023	11:15			PO	A) Bus isolator Routine maint. Works following bay will be transfer on A Bus by TBC Shifting 1) 220KV side ICT-II 2)220KV Pophali 3)220KV Lote 4) 220KV side 25 MVA T/F-I B) Jumper works for ICT-3 New Bay
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	07/03/2023	06:54	07/03/2023	11:29	EO	Replacement of Broken Disc Insulator String at Loc No.140 B-Ph Nalasopara side.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	06/03/2023	09:34	07/03/2023	15:54	HT	For load management
MAIN BUS - 2 @ TALANDGE	IntraState	06/03/2023	16:30	07/03/2023	00:54	PO	1. PID faulty string replacement work of 220 kV ICT 1 critical gantry. 2. PID faulty string replacement work of various bays. 3. Annual maintenace of Bus and Bus isolator
PARGAON(KATHAPUR)-LONIKAND	IntraState	06/03/2023	19:57	07/03/2023	01:24	T	Tripped on Distance Protection.
GHATGHAR - BAPGAON	IntraState	06/03/2023	22:48	07/03/2023	04:05	T	Tripped on Distance Protection.
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	06/03/2023	22:57	07/03/2023	06:57	T	Distance Protection
GHATODI-NANDED	IntraState	07/03/2023	01:10	07/03/2023	16:15	T	Distance Protection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	07/03/2023	06:15	07/03/2023	08:05	EO	Emergency outage is required on 220 kV AKP-Nashik line to replace burst pilot insulator string of bottom ph at loc no. 401.
EKLAHARE (GCR) - GHATGHAR	IntraState	07/03/2023	09:50	07/03/2023	18:53	PO	For flashover insulator replacement and cold washing work.
PETH- MUDSHINGI 1 LINE	IntraState	07/03/2023	10:09	07/03/2023	14:41	PO	Rph CT replacement work and Quarterly maint work
PETH- MUDSHINGI 1 LINE	IntraState	07/03/2023	10:09	07/03/2023	14:41	PO	Quarterly maintenance work & R Ph CT Oil leakage attending work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GHATGHAR - BAPGAON	IntraState	07/03/2023	10:25	07/03/2023	19:45	PO	For flashover insulator replacement and cold washing work.
SADAWAGHAPUR KARAD CKT 1	IntraState	07/03/2023	10:39	07/03/2023	18:45	PO	Cold washing of insulator
BORIVALI - CTRLS CKT	IntraState	07/03/2023	12:43	07/03/2023	13:37	T	Y-ph trip
CTRLS - NET MAGIC GIS	IntraState	07/03/2023	12:43			T	Distance Protection.
CHIKHALI-JALNA I	IntraState	07/03/2023	16:03	07/03/2023	20:19	HT	In view of Akola ICT 2 outage
CHIKHALI-JALNA II	IntraState	07/03/2023	16:03	07/03/2023	20:19	HT	In view of Akola ICT 2 outage
PARGAON(KATHAPUR)-LONIKAND	IntraState	07/03/2023	23:52	08/03/2023	19:07	T	Line tripped on R-ph-Earth, Kathapur end, 3.9 k Amp, String Flash over at Loc no-3
GHATGHAR - BAPGAON	IntraState	08/03/2023	03:57	08/03/2023	04:32	T	Tripped on Y-Ph -Earth, from Ghatghar end only 4.96 kAmp
EKLAHARE (GCR) - GHATGHAR	IntraState	08/03/2023	05:47	08/03/2023	06:02	T	Tripped at Ghatghar end only
WASHALA - GHATGHAR	IntraState	08/03/2023	09:35	08/03/2023	18:55	PO	For flashover insulator replacement & cold washing work.
KALMESHWAR-PANDHURNA	IntraState	08/03/2023	09:45	08/03/2023	18:08	PO	FOR RESAGGING WORK OF CONDUCTOR TO MAINTAIN PROPER CLEARANCE & LINE MAINTENANCE WORK
KALMESHWAR-PANDHURNA	IntraState	08/03/2023	09:45	08/03/2023	18:08	PO	Routine Maint. Work
GHATGHAR - JINDAL	IntraState	08/03/2023	09:53	08/03/2023	19:05	PO	For flashover insulator replacement and cold washing.
HINJAWADI I- CHINCHWAD	IntraState	08/03/2023	11:21	08/03/2023	15:46	PO	Conversion Of SSN To DSN of strings
BABHALESHWAR - DEOGAON RANGARI	IntraState	08/03/2023	11:29	08/03/2023	13:20	EO	Flashover string replacement loc 64 R ph
BABHALESHWAR - DEOGAON RANGARI	IntraState	08/03/2023	11:29	08/03/2023	13:20	PO	To replaced flash over string.
EKLAHARE (GCR) - GHATGHAR	IntraState	08/03/2023	16:18	08/03/2023	16:05	T	Tripped at Ghatghar end only
MIRAJ - ICHALKARANJI	IntraState	08/03/2023	16:56	08/03/2023	20:11	PO	for making bunching arrangement between ckt-I & II of 220KV Miraj-Tilwani line at Loc No. 24 & 28 for erection of Loc no. 26A (D3), 27A(MAN+9) & 28A (SPND+3) for Jaysingpur Kurunwad link
AURANGABAD (WALUJ)-BHENDA	IntraState	08/03/2023	17:49	08/03/2023	19:30	PO	For Annual Diagnostic Testing work.
BABLESHWAR -BHENDA	IntraState	08/03/2023	19:30	08/03/2023	20:40	PO	For Annual Diagnostic Testing work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
PT - 2 @ PARVATI	IntraState	08/03/2023	10:55	08/03/2023	13:20	PO	Half Yearly Maintenance and PT Tan Delta
PT - 1 @ PARVATI	IntraState	08/03/2023	13:55	08/03/2023	15:06		Half Yearly maintenance and PT tan Delta
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
WAGHIVALI - MANKHURD	IntraState	08/03/2023	22:30		Continued.	PO	PROJECT WORK-MOVEMENT OF JACK UP BARGE IN VICINITY
100 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHAHAPUR - BHATSA	IntraState	05/03/2023	14:24			PO	1. Restoration of the line from ERS system to newly erected tower between Pillar No.10-1 1.of 100KV Bhatsa-Shahapur @Ch.No.667 +197 2) Shifting of the line to ERS system on 100KV Bhatsa - Salambe (Phutali) between Pillar No. 19-20.LILO line @ Ch.No 667+298.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage