

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Mar/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.057	1110.489	1) Gujrat	3.304	31.921
2) Hydro	9.144	50.463	2) Madhya Pradesh	13.401	86.484
3) Gas	7.031	46.482	3) Chattisgarh	4.970	30.600
Total MSPGCL	175.232	1207.434	4) Maharashtra	172.149	1201.455
B) 1) APLM	59.758	384.463	5) Goa (Amona)	-1.907	-13.875
2) JSWEL	26.430	175.884	Total	191.917	1336.585
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.776	206.049
4) RPL(AMT)	31.395	217.001	b) Mumbai Drawl	31.064	231.396
5) SWPGPL	9.225	80.629	c) MSEDCL Bilateral *	76.309	689.926
6) Other IPP	46.739	328.055	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.776	206.049
C) 1) TPCL Thermal	11.125	75.203	Include PX	0.000	0.000
2) TPCL Hydro	4.538	23.722	Standby	0.000	0.000
3) TPCL Gas	3.797	24.867	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.690	58.199	1) MSEDCL	526.195	3636.259
D) STATE			2) Mumbai Discoms	59.214	413.383
1) Thermal	352.419	2429.923	3) Other Discoms	10.932	75.372
(A1+C1+C4+(B1-B6))			TOTAL STATE	596.341	4125.014
2) Hydro	13.682	74.185			
(A2+C2)					
3) Gas	10.828	71.349			
(A3+B7+C3)					
4) Wind	8.893	93.286			
6) SOLAR	18.602	119.690			
TOTAL STATE	404.424	2788.433			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6067	6116	7466	6313
MSPGCL Hydro	397	335	692	447
MSPGCL Gas	286	279	286	304
MSPGCL Total Generation	6750	6730	8444	7064
Central Sector Receipt	9633	9178	7748	6584
WIND	267	139	285	547
CPP / IPP Thermal	7063	6801	7962	7099
CPP / IPP Gas	0	0	0	0
SOLAR	2231	2498	0	0
Exchange with Mumbai	-1793	-1880	-1157	-1015
MSEDCL DEMAND MET	23667	22976	22779	19871
Load Shedding	0	0	0	0
MSEDCL DEMAND	23667	22976	22779	19871
TPCL GENERATION	798	780	1169	655
AEML GENERATION	355	310	482	320
MUMBAI DEMAND	2946	2970	2808	1990
OTHER DISCOM DEMAND	484	490	503	408
STATE DEMAND MET	27097	26436	26090	22269
STATE DEMAND	27097	26436	26090	22269
Frequency (Hz)	49.97	50.02	50.00	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18.02 Hrs	49.81 Hz at 15.18 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.41	29.62	190	180
Unit 8	13.47	97.79	626	485
Unit 9	11.80	86.09	516	450
Unit 10	11.38	85.11	482	470
Total	41.06	298.61		
Bhusawal				
Unit 3	3.36	21.28	180	120
Unit 4	10.28	61.92	500	290
Unit 5	10.42	61.66	500	290
Total	24.06	144.86		
Parli				
Unit 6	3.93	25.55	240	140
Unit 7	3.76	25.20	227	137
Unit 8	0.43	21.87	142	0
Total	8.12	72.62		
Chandrapur				
Unit 3	2.95	21.19	150	100
Unit 4	3.24	21.94	150	120
Unit 5	8.28	52.07	435	275
Unit 6	8.15	51.67	430	280
Unit 7	8.46	53.34	451	274
Unit 8	9.41	60.46	420	285
Unit 9	10.11	54.67	482	276
Total	50.60	315.33		
Paras				
Unit 3	5.76	37.90	252	231
Unit 4	5.76	39.03	251	227
Total	11.53	76.93		
Khaparkheda				
Unit 1	3.42	24.28	170	125
Unit 2	3.58	26.14	171	130
Unit 3	3.56	25.46	168	130
Unit 4	3.62	27.04	173	139
Unit 5	5.57	59.61	450	0
Total	19.75	162.53		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.68	23.66	168	126
Unit 5	0.26	15.94	129	0
Total	3.94	39.60		
Uran				
All Units	7.03	46.48	309	277
Total	7.03	46.48		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	0.53	53	0
Total	0.14	0.53		
Koyna				
Stage 1-2	1.22	9.80	100	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.34	4.32	256	0
Stage 3	0.62	3.31	214	0
Total	3.18	17.42		
Hydro				
KDPH	0.86	6.05	36	36
VTRNA	0.65	4.49	60	0
TILLARI	0.50	3.23	64	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.78	16.78	122	109
GHATGHAR	1.02	1.96	220	0
Total	5.82	32.51		
Wind				
Total	8.89	93.29	0	0
Total	8.89	93.29		
CPP				
APML(Mus)	59.76	384.46	0	0
JSWEL(Mus)	26.43	175.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.40	217.00	0	0
SWPGPL-Mus	9.22	80.63	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.01	40.57	263	245
Other(Mus)	36.54	258.66	0	0
JPL	4.19	28.83	203	160
Total	173.55	1186.03		
SOLAR				
Total	18.60	119.69	0	0
Total	18.60	119.69		
Tata				
Trombay 5	7.40	50.18	425	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.34	15.14	108	38
Trombay 7B	1.46	9.73	65	36
TATA Hydro	4.54	23.72	422	34
Trombay 8	3.73	25.02	220	130
Total	19.46	123.79		
AEML				
DTPS U-1&2	8.69	58.20	497	291
Total	8.69	58.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.06	1110.49	MSPGCL Total	175.23	1207.43
			MSPGCL Thml+Gas	166.09	1156.97	Koyna 1,2 & 4 Total	2.56	14.11
			MSPGCL Hydro	9.14	50.46	State Total	404.42	2788.43

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6313	447	304	7064	547	7099	0	0	7179	6584	-1015	19871	0	0	19871	1990	408	22269	49.97
2	6029	446	303	6778	617	7053	0	0	7260	7177	-900	20353	0	0	20353	1856	372	22581	49.97
3	6227	440	305	6972	586	7066	0	0	7053	6801	-838	20234	0	0	20234	1771	353	22358	50.00
4	6540	457	307	7304	577	7161	0	0	6958	6675	-743	20625	0	0	20625	1718	349	22692	50.00
5	6711	440	308	7459	527	7178	0	0	7301	6947	-815	20931	0	0	20931	1730	365	23026	50.01
6	6793	353	308	7454	514	7400	0	0	7723	7952	-898	22031	0	0	22031	1829	391	24251	49.98
7	6942	594	309	7845	458	7966	0	12	7946	7633	-911	22573	0	0	22573	2012	430	25015	49.96
8	6926	618	307	7851	504	8080	0	365	7895	7758	-978	23124	0	0	23124	2233	456	25813	49.97
9	6557	393	306	7256	443	7641	0	1131	8435	8193	-1009	23156	0	0	23156	2561	499	26216	50.04
10	6039	410	293	6742	374	7105	0	1773	9018	8757	-1376	22895	0	30	22895	2791	480	26166	50.00
11	6067	397	286	6750	267	7063	0	2231	9702	9633	-1793	23667	0	23	23667	2946	484	27097	49.97
12	6420	380	285	7085	160	7103	0	2435	9320	9142	-1876	23575	0	26	23575	2986	474	27035	50.01
13	6116	335	279	6730	139	6801	0	2498	9149	9178	-1880	22976	0	15	22976	2970	490	26436	50.02
14	6074	264	281	6619	188	6568	0	2435	9075	9070	-1884	22505	0	15	22505	2860	491	25856	50.01
15	6027	253	279	6559	227	6401	0	2206	9333	9424	-1820	22506	0	16	22506	2915	491	25912	49.95
16	6493	253	277	7023	279	6796	0	1840	9153	9041	-1781	22693	0	17	22693	2970	505	26168	49.95
17	6826	244	277	7347	251	7135	0	1181	8945	8534	-1619	22330	0	16	22330	2935	499	25764	49.99
18	7032	322	284	7638	196	7135	0	474	8679	8564	-1461	22036	0	11	22036	2883	510	25429	50.03
19	7268	415	285	7968	184	7490	0	21	8005	7824	-1362	21628	0	0	21628	2813	497	24938	49.99
20	7466	692	286	8444	285	7962	0	0	7604	7748	-1157	22779	0	0	22779	2808	503	26090	50.00
21	7143	375	285	7803	319	7730	0	0	7802	7284	-1274	21369	0	0	21369	2647	493	24509	49.97
22	7126	207	290	7623	388	7220	0	0	7478	7375	-1277	20853	0	0	20853	2473	476	23802	49.95
23	7121	197	292	7610	395	7208	0	0	7462	7100	-1238	20602	0	0	20602	2324	473	23399	49.99
24	6801	213	295	7309	468	7186	0	0	7373	7522	-1159	20885	0	0	20885	2193	441	23519	50.01
MUs	159.06	9.14	7.03	175.23	8.89	173.55	0.00	18.60	195.85	191.92	-31.06	526.19	0.00	0.17	526.19	59.21	10.93	596.34	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to overloading of 220kV Nashik-BBLR lines, Due to overloading of 132kV BBLR to Rahuri line, Due to TF overloading at 220kV Kopargaon S/stn.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Mar/2024

Position as on 6.30 Hrs of 08/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Khaparkheda Unit 5	500	05/03/2024	18:04	07/03/2024	08:54	Boiler Tube Leakage	08/03/2024
MSPGCL	Nasik Unit 5	210	05/03/2024	23:45	07/03/2024	21:00	For attending boiler feed pump common discharge header line leakage.	08/03/2024
MSPGCL	Parli Unit 8	250	07/03/2024	03:06		Continued.	Air heater problem	10/03/2024
Total Capacity MSPGCL		1188						
IPP								
IPP	SWPGPL U-1	135	06/03/2024	14:40		Continued.	Boiler Tube Leakage	08/03/2024
IPP	Adani U-5	660	08/03/2024	06:27		Continued.	Mill inlet bellow leakage	11/03/2024
Total Capacity IPP		795						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2303						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Mar/2024

Position as on 6.30 Hrs of 08/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TBC @ PADGHE	IntraState	06/03/2024	12:01			PO	1. Replacement of CT with New ratio of 3000/1 Amp. 2. Diagnostic Testing work. 3. Bay Maintenance Work.
400 KV LR Outages/Trippings							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	07/03/2024	14:24	07/03/2024	19:53	EO	Replacement of flashover insulator string at location no.83(BPH)
400 KV LINE Outages/Trippings							
CHAKAN - TALEGAON(PG)	InterState	07/03/2024	00:17	07/03/2024	05:15	PO	Cold line washing, replacement of PID detected strings
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar-Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
DABHOL - NEW KOYNA CKT - 1	IntraState	07/03/2024	06:03	07/03/2024	07:08	T	Distance Protection
DABHOL - NEW KOYNA CKT - 2	IntraState	07/03/2024	06:03	07/03/2024	07:33	T	Tripped on Overvoltage
NAGOTHANE - DABHOL CKT - 1	IntraState	07/03/2024	09:03	07/03/2024	20:47	PO	for cold washing work
220 KV TAPTITANDA WALUJ	IntraState	07/03/2024	09:07	07/03/2024	11:13	PO	Trip Ckt. Supervision relay replacement work and bay maintenance work.
JEJURI- KOYNA STAGE-IV	IntraState	07/03/2024	11:15	08/03/2024	08:40	PO	Autoreclose implementation at stage IV end
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	IntraState	06/03/2024	07:32	07/03/2024	21:04	PO	Diagnostic testing & allied bay maintenance work
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	07/03/2024	09:05	07/03/2024	16:15	PO	Capacitance and Tan delta testing of bushing, Winding and Nifps system preventive maintenance works.
400220kV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	07/03/2024	10:19	07/03/2024	11:09	PO	For attending alarm appearing due to low pressure in CTR
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	07/03/2024	10:36	07/03/2024	19:50	PO	For Maintenance & Testing work
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	07/03/2024	11:07	07/03/2024	17:04	PO	Bay Maintenance ,Relay Testing Works

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	08/03/2024	02:09	08/03/2024	05:36	HT	Emergency outage for attending hotspot at Padghe S/S
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV TBC Outages/Trippings							
TBC @ BHOSARI 2	IntraState	07/03/2024	10:20	07/03/2024	14:42	PO	Half Yearly Maintenance
220 KV MAINBAY Outages/Trippings							
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	08/03/2024	09:15			PO	Annual Maintenance of Bay Equipments
220 KV LINE Outages/Trippings							
MAIN BUS - 2 @ TALEGAON (PG)	InterState	07/03/2024	13:26	08/03/2024	04:00	PO	for AMP work
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
SADAWAGHAPUR KARAD CKT 1	IntraState	05/03/2024	07:03			PO	For replacement work of Main Distance Relay.
MAHALAXMI - AMONA	IntraState	06/03/2024	17:14			T	Tripped on distance protection.
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	07/03/2024	01:45	07/03/2024	04:36	PO	METRO-4 PROJECT WORK IN VICINITY
WAGHIVALI - DHARAVI 7	IntraState	07/03/2024	01:45	07/03/2024	04:36	PO	METRO-4 PROJECT WORK IN VICINITY
POPHLI PEDHMBE LINE- 1	IntraState	07/03/2024	08:13	07/03/2024	17:20	PO	For Bay P/M work
BABLESHWAR -BHENDA	IntraState	07/03/2024	08:14	07/03/2024	19:48	PO	Replacement of the disc insulator with porcelain long rod under scheme
CHANDRAPUR GCR - CPUR RLY TSS 2	IntraState	07/03/2024	09:06	07/03/2024	13:44	PO	CT Tan delta work, Routine bay maintenance work.
CHINCHWAD 2-CHINCHWAD (INTERCONNECTOR)	IntraState	07/03/2024	10:09	07/03/2024	15:04	PO	Half Yearly Maintenance Work & diagnostic testing work.
220 KV JALNA - THAPTITANDA CKT - I	IntraState	07/03/2024	13:57	07/03/2024	19:23	PO	Replacement of faulty strings found in Pid diagnostic work.
PADGHE - WADA	IntraState	07/03/2024	15:19	07/03/2024	17:48	T	Tripped on distance protection
BAPGAON - KALWA	IntraState	08/03/2024	07:38			PO	For making LILO at 220 KV NTT S/Stn.
BABLESHWAR -BHENDA	IntraState	08/03/2024	09:16			PO	Replacement of the disc insulator with porcelain long rod under scheme
220 KV ICT Outages/Trippings							
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	05/03/2024	07:40			PO	ICI 1 overhauling ,Testing ,CRP replacement of CPLR 1-2 ,ICT 1
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	07/03/2024	10:20	08/03/2024	00:53	PO	Preventive Maintenance work by M/s. CTR on NIFPS.
220/33KV 50MVA PTR 1 @ KURKUMBH	IntraState	07/03/2024	10:25	07/03/2024	17:18	PO	To attend oil leakage and LV CB Mechanism Overhauling.
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	07/03/2024	10:27	07/03/2024	20:47	PO	For 1) Differential relay & HVLV Back up relay replacement work 2) RM work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 08/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 3 @ RANJANGAON	IntraState	07/03/2024	10:50	07/03/2024	14:05	PO	For Diagnostic Testing (HV CT's, Bushing and winding tan delta test) and half yearly maintenance work.
220/132 KV 200 MVA ICT 3	IntraState	07/03/2024	10:57	07/03/2024	20:54	PO	Diagnostic testing and bay maintenance work.
220 KV BUSBAR Outages/Trippings							
BUS-1@GIS BHANDUP	IntraState	06/03/2024	11:22			PO	F9 and F10 Bay Connection to Main Bus
BUS PT-1 @KAMBA-220 KV	IntraState	07/03/2024	11:30	07/03/2024	18:55	PO	For repairing of Base (Foundation) angles of 220kV R-Phase PT and for Diagnostic testing & maintenance work.
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	07/03/2024	09:56	07/03/2024	16:20	PO	For earthwire replacement & other Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage