

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 07/Apr/2021 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 152.069        | 1063.948        | 1) Gujrat                      | 1.605          | 11.787          |
| 2) Hydro            | 41.040         | 203.521         | 2) Madhya Pradesh              | 14.526         | 110.549         |
| 3) Gas              | 6.878          | 34.461          | 3) Chattisgarh                 | 3.940          | 27.120          |
| <b>Total MSPGCL</b> | <b>199.987</b> | <b>1301.930</b> | 4) Maharashtra                 | 150.921        | 1061.267        |
| B) 1) APLM          | 60.197         | 420.772         | 5) Goa (Amona)                 | -1.049         | -9.100          |
| 2) JSWEL            | 9.296          | 79.355          | <b>Total</b>                   | <b>169.943</b> | <b>1201.623</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 22.613         | 173.569         |
| 4) RPL(AMT)         | 31.370         | 219.523         | b) Mumbai Drawl                | 21.315         | 160.209         |
| 5) SWPGPL           | 8.727          | 63.072          | c) MSEDCL Bilateral *          | 41.329         | 312.735         |
| 6) Other IPP        | 23.573         | 165.805         | Include PX                     | 19.222         | 105.763         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 22.613         | 173.569         |
| C) 1) TPCL Thermal  | 17.177         | 116.494         | Include PX                     | 5.551          | 51.945          |
| 2) TPCL Hydro       | 4.657          | 18.565          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.280          | 21.696          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 12.025         | 83.517          | 1) MSEDCL                      | 501.182        | 3461.817        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 58.454         | 400.483         |
| 1) Thermal          | 314.434        | 2212.486        | <b>TOTAL STATE</b>             | <b>559.636</b> | <b>3862.300</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro (A2+C2)    | 45.697         | 222.086         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 10.158         | 56.157          |                                |                |                 |
| 4) Wind             | 11.793         | 109.203         |                                |                |                 |
| 6) SOLAR            | 7.611          | 60.743          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>389.693</b> | <b>2660.675</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 22 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6364                      | 6440                  | 6269                      | 6207                      |
| MSPGCL Hydro             | 1491                      | 2094                  | 1762                      | 764                       |
| MSPGCL Gas               | 273                       | 345                   | 276                       | 287                       |
| MSPGCL Total Generation  | 8128                      | 8879                  | 8307                      | 7258                      |
| Central Sector Receipt   | 8886                      | 7973                  | 5790                      | 6586                      |
| WIND                     | 169                       | 247                   | 769                       | 920                       |
| CPP / IPP Thermal        | 5485                      | 5533                  | 5605                      | 5578                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 1066                      | 674                   | 0                         | 0                         |
| Exchange with Mumbai     | -1049                     | -1002                 | -856                      | -650                      |
| <b>MSEDCL DEMAND MET</b> | <b>22685</b>              | <b>22304</b>          | <b>19615</b>              | <b>19692</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 22685                     | 22304                 | 19615                     | 19692                     |
| TPCL GENERATION          | 1272                      | 1321                  | 1018                      | 836                       |
| AEML GENERATION          | 500                       | 501                   | 501                       | 501                       |
| <b>MUMBAI DEMAND</b>     | <b>2821</b>               | <b>2824</b>           | <b>2375</b>               | <b>1987</b>               |
| STATE DEMAND MET         | 25506                     | 25128                 | 21990                     | 21679                     |
| <b>STATE DEMAND</b>      | <b>25506</b>              | <b>25128</b>          | <b>21990</b>              | <b>21679</b>              |
| Frequency (Hz)           | 50.02                     | 50.01                 | 49.92                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.14 Hz at 07.59 Hrs | 49.72 Hz at 14.50 Hrs | 49.97         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 07/Apr/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 5.42          | 0        | 0        |
| Unit 7             | 0.00         | 16.52         | 0        | 0        |
| Unit 8             | 12.66        | 81.10         | 621      | 406      |
| Unit 9             | 9.36         | 63.39         | 422      | 320      |
| Unit 10            | 8.01         | 10.74         | 357      | 305      |
| <b>Total</b>       | <b>30.02</b> | <b>177.17</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 4.22         | 16.88         | 190      | 125      |
| Unit 4             | 10.74        | 79.98         | 450      | 445      |
| Unit 5             | 11.83        | 82.06         | 500      | 475      |
| <b>Total</b>       | <b>26.80</b> | <b>178.92</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 5.75         | 39.45         | 250      | 216      |
| Unit 7             | 5.70         | 40.43         | 250      | 165      |
| Unit 8             | 5.05         | 34.85         | 236      | 194      |
| <b>Total</b>       | <b>16.51</b> | <b>114.73</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 8.95          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 10.22        | 63.72         | 432      | 415      |
| Unit 6             | 8.74         | 65.12         | 400      | 315      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.83        | 81.92         | 497      | 490      |
| Unit 9             | 10.62        | 77.41         | 471      | 411      |
| <b>Total</b>       | <b>41.41</b> | <b>297.12</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.71         | 39.82         | 252      | 215      |
| Unit 4             | 6.00         | 40.70         | 257      | 240      |
| <b>Total</b>       | <b>11.71</b> | <b>80.52</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.54         | 19.89         | 120      | 90       |
| Unit 2             | 2.72         | 20.78         | 130      | 100      |
| Unit 3             | 3.48         | 26.16         | 160      | 130      |
| Unit 4             | 3.07         | 24.90         | 155      | 105      |
| Unit 5             | 9.25         | 64.61         | 419      | 345      |
| <b>Total</b>       | <b>21.07</b> | <b>156.34</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 26.65         | 0        | 0        |
| Unit 5             | 4.55         | 32.49         | 202      | 154      |
| <b>Total</b>       | <b>4.55</b>  | <b>59.14</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.88         | 34.46         | 345      | 271      |
| <b>Total</b>       | <b>6.88</b>  | <b>34.46</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.08         | 0.38          | 66       | 0        |
| <b>Total</b>       | <b>0.08</b>  | <b>0.38</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 7.60          | 44.60         | 535      | 40       |
| Stage 4         | 20.53         | 80.61         | 1017     | 0        |
| Stage 3         | 5.71          | 26.47         | 240      | 214      |
| <b>Total</b>    | <b>33.84</b>  | <b>151.68</b> |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.86          | 6.05          | 36       | 36       |
| VTRNA           | 1.14          | 5.88          | 60       | 0        |
| TILLARI         | 0.00          | 2.20          | 0        | 0        |
| BHIRA T.R.      | 0.08          | 0.76          | 43       | 0        |
| SMLHY_PTN       | 5.11          | 34.30         | 220      | 201      |
| GHATGHAR        | 0.00          | 2.65          | 0        | 0        |
| <b>Total</b>    | <b>7.20</b>   | <b>51.84</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 11.79         | 109.20        | 0        | 0        |
| <b>Total</b>    | <b>11.79</b>  | <b>109.20</b> |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 60.20         | 420.77        | 0        | 0        |
| JSWEL(Mus)      | 9.30          | 79.36         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 31.37         | 219.52        | 0        | 0        |
| SWPGPL-Mus      | 8.73          | 63.07         | 0        | 0        |
| Other(Mus)      | 23.57         | 165.80        | 0        | 0        |
| <b>Total</b>    | <b>133.16</b> | <b>948.53</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 7.61          | 60.74         | 0        | 0        |
| <b>Total</b>    | <b>7.61</b>   | <b>60.74</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 11.58         | 78.37         | 486      | 469      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 1.96          | 12.92         | 115      | 63       |
| Trombay 7B      | 1.32          | 8.78          | 65       | 49       |
| Trombay 8       | 5.59          | 38.12         | 237      | 226      |
| TATA Hydro      | 4.66          | 18.56         | 459      | 0        |
| <b>Total</b>    | <b>25.11</b>  | <b>156.76</b> |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 12.02         | 83.52         | 502      | 500      |
| <b>Total</b>    | <b>12.02</b>  | <b>83.52</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 152.07      | 1063.95       | MSPGCL Total        | 199.99      | 1301.93       |
|                |             |         | MSPGCL Thml+Gas | 158.95      | 1098.41       | Koyna 1,2 & 4 Total | 28.14       | 125.22        |
|                |             |         | MSPGCL Hydro    | 41.04       | 203.52        | State Total         | 389.69      | 2660.68       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 07/Apr/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6180        | 2036  | 277  | 8493   | 879   | 5557      | 0    | 0     | 6026        | 6451        | -988                 | 20392                 | 0                    | 20392                     | 2399             | 22791           | 50.00         |
| 2                  | 6162        | 2020  | 277  | 8459   | 804   | 5582      | 0    | 0     | 6046        | 6238        | -876                 | 20207                 | 0                    | 20207                     | 2231             | 22438           | 50.03         |
| 3                  | 6146        | 1514  | 277  | 7937   | 867   | 5575      | 0    | 0     | 6483        | 6720        | -754                 | 20345                 | 0                    | 20345                     | 2094             | 22439           | 50.00         |
| 4                  | 6207        | 764   | 287  | 7258   | 920   | 5578      | 0    | 0     | 6853        | 6586        | -650                 | 19692                 | 0                    | 19692                     | 1987             | 21679           | 50.01         |
| 5                  | 6344        | 644   | 298  | 7286   | 727   | 5548      | 0    | 0     | 7031        | 7066        | -618                 | 20009                 | 0                    | 20009                     | 1940             | 21949           | 49.94         |
| 6                  | 6413        | 1378  | 289  | 8080   | 560   | 5549      | 0    | 0     | 7179        | 7175        | -647                 | 20717                 | 0                    | 20717                     | 1975             | 22692           | 49.91         |
| 7                  | 6465        | 2034  | 288  | 8787   | 422   | 5497      | 0    | 24    | 7325        | 7096        | -653                 | 21173                 | 0                    | 21173                     | 1985             | 23158           | 49.94         |
| 8                  | 6418        | 1891  | 298  | 8607   | 301   | 5537      | 0    | 184   | 7532        | 7827        | -724                 | 21732                 | 0                    | 21732                     | 2075             | 23807           | 50.01         |
| 9                  | 6467        | 1628  | 297  | 8392   | 234   | 5517      | 0    | 482   | 7563        | 7570        | -918                 | 21277                 | 0                    | 21277                     | 2309             | 23586           | 50.02         |
| 10                 | 6469        | 2030  | 285  | 8784   | 190   | 5547      | 0    | 742   | 7312        | 7775        | -1052                | 21986                 | 0                    | 21986                     | 2577             | 24563           | 49.99         |
| 11                 | 6502        | 1992  | 273  | 8767   | 158   | 5530      | 0    | 939   | 7924        | 7997        | -1154                | 22237                 | 0                    | 22237                     | 2748             | 24985           | 50.03         |
| 12                 | 6364        | 1491  | 273  | 8128   | 169   | 5485      | 0    | 1066  | 9076        | 8886        | -1049                | 22685                 | 0                    | 22685                     | 2821             | 25506           | 50.02         |
| 13                 | 6344        | 1446  | 271  | 8061   | 127   | 5382      | 0    | 1067  | 8811        | 8561        | -1041                | 22157                 | 0                    | 22157                     | 2827             | 24984           | 49.96         |
| 14                 | 6436        | 1658  | 281  | 8375   | 118   | 5344      | 0    | 1012  | 8515        | 8187        | -976                 | 22060                 | 0                    | 22060                     | 2772             | 24832           | 49.94         |
| 15                 | 6430        | 1993  | 286  | 8709   | 213   | 5381      | 0    | 886   | 8338        | 7990        | -970                 | 22209                 | 0                    | 22209                     | 2828             | 25037           | 49.90         |
| 16                 | 6440        | 2094  | 345  | 8879   | 247   | 5533      | 0    | 674   | 8049        | 7973        | -1002                | 22304                 | 0                    | 22304                     | 2824             | 25128           | 50.01         |
| 17                 | 6341        | 1909  | 292  | 8542   | 417   | 5569      | 0    | 384   | 7416        | 7196        | -930                 | 21178                 | 0                    | 21178                     | 2738             | 23916           | 49.95         |
| 18                 | 6286        | 1909  | 272  | 8467   | 475   | 5576      | 0    | 147   | 6289        | 6302        | -836                 | 20131                 | 0                    | 20131                     | 2624             | 22755           | 49.97         |
| 19                 | 6262        | 1519  | 284  | 8065   | 565   | 5567      | 0    | 4     | 6023        | 5983        | -864                 | 19320                 | 0                    | 19320                     | 2490             | 21810           | 49.97         |
| 20                 | 6231        | 1829  | 284  | 8344   | 596   | 5591      | 0    | 0     | 5945        | 5829        | -868                 | 19492                 | 0                    | 19492                     | 2488             | 21980           | 49.92         |
| 21                 | 6273        | 1448  | 285  | 8006   | 658   | 5642      | 0    | 0     | 5869        | 5824        | -796                 | 19334                 | 0                    | 19334                     | 2408             | 21742           | 49.99         |
| 22                 | 6269        | 1762  | 276  | 8307   | 769   | 5605      | 0    | 0     | 5892        | 5790        | -856                 | 19615                 | 0                    | 19615                     | 2375             | 21990           | 49.92         |
| 23                 | 6287        | 2047  | 297  | 8631   | 702   | 5713      | 0    | 0     | 5882        | 6354        | -998                 | 20402                 | 0                    | 20402                     | 2433             | 22835           | 49.97         |
| 24                 | 6333        | 2004  | 286  | 8623   | 675   | 5758      | 0    | 0     | 5916        | 6567        | -1095                | 20528                 | 0                    | 20528                     | 2506             | 23034           | 49.85         |
| MUs                | 152.07      | 41.04 | 6.88 | 199.99 | 11.79 | 133.16    | 0.00 | 7.61  | 169.29      | 169.94      | -21.31               | 501.18                | 0.00                 | 501.18                    | 58.45            | 559.64          | 49.97         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 07/Apr/2021**

**Position as on 6.30 Hrs of 08/Apr/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                       | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                        |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 16/03/2021   | 08.08        |            | Continued. | Boiler Tube Leakage(converted to Capital overhaul)                     |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                        |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                   |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                   |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                 |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                  |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).    |               |
| MSPGCL                | Koyana Unit 11          | 80       | 19/01/2021   | 10.05        |            | Continued. | Tripped on stator earth fault (will not be available till dt.18.04.21) |               |
| IPP                   | JSW (J) U1              | 300      | 01/02/2021   | 18.00        |            | Continued. | Due to turbine vibration high                                          |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 20/02/2021   | 23.43        |            | Continued. | Generator Earth Fault.                                                 |               |
| IPP                   | Adani U-2               | 660      | 04/03/2021   | 00.10        |            | Continued. | Increase Hydrogen Consumption                                          |               |
| IPP                   | JSW (J) U2              | 300      | 26/03/2021   | 01.13        | 07/04/2021 | 20.53      | No Schedule                                                            |               |
| MSPGCL                | Koradi Unit 6           | 210      | 02/04/2021   | 12.19        |            | Continued. | Fire in boiler electric board.                                         |               |
| MSPGCL                | Uran Unit 5             | 108      | 02/04/2021   | 23.19        |            | Continued. | Gas shortage                                                           |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 05/04/2021   | 10.43        |            | Continued. | ID Fan Bearing Temperature High.                                       |               |
| MSPGCL                | Koradi Unit 7           | 210      | 06/04/2021   | 10.57        | 08/04/2021 | 02.04      | Boiler Tube Leakage                                                    |               |
| MSPGCL                | Nasik Unit 4            | 210      | 06/04/2021   | 16.41        |            | Continued. | Line Heavy Leakage                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Apr/2021**

**Statement-VII**

Position as on 6.30 Hrs of 08/Apr/2021

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                        |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                         |
| Ektuni - Akola II Ckt I                           | IntraState                | 06/04/2021   | 06.46        |            | Continued. | PO          | Nagpur-Mumbai Express Highway Work.                                                     |
| <b>500 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                         |
| Chandrapur - Padghe Hvdc Pole 2                   | IntraState                | 06/04/2021   | 17.34        | 07/04/2021 | 02.00      | EO          | Attending Oil Leakage                                                                   |
| Chandrapur - Padghe Hvdc Pole 2                   | IntraState                | 07/04/2021   | 13.27        |            | Continued. | EO          | H/T at Padghe end                                                                       |
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                         |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                |
| Dhule Sar'Sarovar I                               | InterState                | 06/04/2021   | 18.35        | 07/04/2021 | 05.55      | HT          | Over Voltage                                                                            |
| BABHALESHWAR - RPL(NASHIK) CKT - 1                | IntraState                | 18/03/2021   | 15.48        |            | Continued. | EO          | Attending Hot Spot                                                                      |
| Chandrapur - Khaperkheda                          | IntraState                | 07/04/2021   | 10.25        | 07/04/2021 | 18.32      | PO          | DCRM of main Breaker and Tie Breaker                                                    |
| Kharghar-Talegaon(PG)                             | IntraState                | 07/04/2021   | 10.35        | 07/04/2021 | 14.44      | T           | Distance Protection                                                                     |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                         |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                   |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                         |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                             |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                  |
| Parli 3 (Old Gcr)-Girwali Ckt 2                   | IntraState                | 25/03/2021   | 10.28        |            | Continued. | PO          | Railway crossing tower erection work                                                    |
| Versova Gorai Line                                | IntraState                | 05/04/2021   | 09.47        | 07/04/2021 | 16.13      | PO          | 220KV Circuit Breaker (352) Operating Mechanism Overhauling Work At Versova-Gorai Line. |
| Bhugaon-WardhaPG (Deoli)                          | IntraState                | 06/04/2021   | 23.30        | 07/04/2021 | 03.12      | HT          | H/T By WRLDC to control Overdrawal                                                      |
| Lamboti - Solapur li(Bale) Ckt- I                 | IntraState                | 07/04/2021   | 09.14        | 07/04/2021 | 11.25      | PO          | Testing Work                                                                            |
| Kalmeshwar-Pandhurna                              | IntraState                | 07/04/2021   | 09.46        | 07/04/2021 | 17.12      | PO          | Routine Maintenance Work                                                                |
| Ghodbunder - Versova                              | IntraState                | 07/04/2021   | 09.57        | 07/04/2021 | 13.11      | PO          | Replacement of doors of CB mechanism and marshalling Box                                |
| Kalmeshwar-Kalmeshwar Rly Tss 2                   | IntraState                | 07/04/2021   | 09.58        | 07/04/2021 | 17.56      | PO          | Bus Section outage at Kalmeshwar                                                        |
| Ambazari-Kalmeshwar                               | IntraState                | 07/04/2021   | 10.06        | 07/04/2021 | 17.08      | PO          | Stringing work                                                                          |
| Harangul-Parly                                    | IntraState                | 07/04/2021   | 10.33        | 07/04/2021 | 18.20      | PO          | Work at Parly PG end                                                                    |
| OSMANABAD BARSHI                                  | IntraState                | 07/04/2021   | 12.21        | 07/04/2021 | 21.51      | PO          | Replacement of Existing copper palm of RYB phase                                        |
| Lamboti -Solapur li(Bale) Ckt- II                 | IntraState                | 07/04/2021   | 12.28        | 07/04/2021 | 13.50      | PO          | Quarterly Maintenance Work                                                              |
| Jejuri- Ismt- Lonand                              | IntraState                | 07/04/2021   | 14.15        | 07/04/2021 | 14.40      | T           | Distance Protection                                                                     |
| Bhugaon-WardhaPG (Deoli)                          | IntraState                | 07/04/2021   | 23.28        | 08/04/2021 | 01.45      | HT          | H/T By WRLDC to control Overdrawal                                                      |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage