

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Apr/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	163.699	1158.461	1) Gujrat	-5.540	-32.779
2) Hydro	46.779	243.076	2) Madhya Pradesh	8.783	74.193
3) Gas	6.667	43.152	3) Chattisgarh	4.550	35.350
Total MSPGCL	217.145	1444.689	4) Maharashtra	156.519	1160.213
B) 1) APML	76.321	525.953	5) Goa (Amona)	-1.724	-12.276
2) JSWEL	19.773	121.562	Total	162.588	1224.701
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.275	206.969
4) RPL(AMT)	31.880	208.191	b) Mumbai Drawl	32.932	227.601
5) SWPGPL	9.486	61.757	c) MSEDCL Bilateral *	66.526	473.033
6) Other IPP	34.847	246.252	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.268	206.962
C) 1) TPCL Thermal	16.610	107.467	Include PX	0.000	0.000
2) TPCL Hydro	5.116	20.930	Standby	0.006	0.006
3) TPCL Gas	3.453	19.852	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.736	80.301	1) MSEDCL	532.868	3700.292
D) STATE			2) Mumbai Discoms	69.847	456.154
1) Thermal	364.352	2509.944	3) Other Discoms	8.568	62.056
(A1+C1+C4+(B1-B6))			TOTAL STATE	611.283	4218.502
2) Hydro	51.895	264.006			
(A2+C2)					
3) Gas	10.120	63.004			
(A3+B7+C3)					
4) Wind	12.923	92.488			
6) SOLAR	9.405	64.356			
TOTAL STATE	448.695	2993.798			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6706	7055	6830	6851
MSPGCL Hydro	1974	2152	2117	1787
MSPGCL Gas	278	267	289	292
MSPGCL Total Generation	8958	9474	9236	8930
Central Sector Receipt	9209	8772	5554	5606
WIND	435	335	518	513
CPP / IPP Thermal	6865	7016	7096	7159
CPP / IPP Gas	0	0	0	0
SOLAR	1308	813	0	0
Exchange with Mumbai	-1988	-1769	-1331	-805
MSEDCL DEMAND MET	24549	24396	20814	21260
Load Shedding	0	261	886	0
MSEDCL DEMAND	24549	24657	21700	21260
TPCL GENERATION	952	1169	1252	921
AEML GENERATION	448	487	502	475
MUMBAI DEMAND	3388	3425	3085	2201
OTHER DISCOM DEMAND	369	377	391	277
STATE DEMAND MET	28306	28198	24290	23738
STATE DEMAND	28306	28459	25176	23738
Frequency (Hz)	49.89	49.77	49.73	49.81

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.11 Hz at 07.58 Hrs	49.5 Hz at 18.56 Hrs	49.83	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.74	20.86	210	190
Unit 7	0.00	0.00	0	0
Unit 8	12.23	93.96	602	424
Unit 9	13.97	94.18	593	564
Unit 10	3.08	60.94	415	0
Total	34.02	269.94		
Bhusawal				
Unit 3	1.92	1.92	150	0
Unit 4	8.77	69.87	440	345
Unit 5	8.72	68.22	420	350
Total	19.41	140.01		
Parli				
Unit 6	2.82	24.57	192	0
Unit 7	4.05	26.00	176	165
Unit 8	3.38	24.23	150	129
Total	10.24	74.81		
Chandrapur				
Unit 3	4.58	31.63	194	186
Unit 4	4.16	28.57	175	172
Unit 5	8.84	61.87	385	330
Unit 6	9.54	40.35	410	382
Unit 7	8.42	60.10	390	305
Unit 8	10.72	71.73	460	428
Unit 9	10.42	70.65	446	424
Total	56.68	364.89		
Paras				
Unit 3	5.12	38.48	218	207
Unit 4	5.05	36.22	219	198
Total	10.17	74.70		
Khaparkheda				
Unit 1	3.10	23.22	150	95
Unit 2	3.46	24.11	155	120
Unit 3	4.19	28.72	192	133
Unit 4	3.72	28.21	181	130
Unit 5	10.30	75.97	450	360
Total	24.78	180.23		
Nasik				
Unit 3	4.28	25.41	193	135
Unit 4	4.12	28.47	196	127
Unit 5	0.00	0.00	0	0
Total	8.40	53.88		
Uran				
All Units	6.67	43.15	294	267
Total	6.67	43.15		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	0.85	20	0
Total	0.12	0.85		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	9.34	49.08	540	140
Stage 4	22.83	105.44	1005	500
Stage 3	6.79	33.08	320	210
Total	38.97	187.60		
Hydro				
KDPH	0.86	6.05	36	36
VTRNA	0.78	4.83	60	0
TILLARI	0.52	3.65	58	0
BHIRA T.R.	0.16	0.88	60	0
SMLHY_PTN	5.37	39.21	232	214
GHATGHAR	0.00	0.00	0	0
Total	7.69	54.62		
Wind				
Total	12.92	92.49	0	0
Total	12.92	92.49		
CPP				
APML(Mus)	76.32	525.95	0	0
JSWEL(Mus)	19.77	121.56	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.88	208.19	0	0
SWPGPL-Mus	9.49	61.76	0	0
Other(Mus)	34.85	246.25	0	0
Total	172.31	1163.72		
SOLAR				
Total	9.40	64.36	0	0
Total	9.40	64.36		
Tata				
Trombay 5	10.95	72.93	483	430
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.10	11.51	115	48
Trombay 7B	1.35	8.34	66	40
TATA Hydro	5.12	20.93	398	26
Trombay 8	5.66	34.54	243	204
Total	25.18	148.25		
AEMIL				
DTPS U-1&2	11.74	80.30	503	448
Total	11.74	80.30		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	163.70	1158.46	MSPGCL Total	217.14	1444.69
			MSPGCL Thml+Gas	170.37	1201.61	Koyna 1,2 & 4 Total	32.17	154.52
			MSPGCL Hydro	46.78	243.08	State Total	448.70	2993.80

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 07/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6859	1494	291	8644	963	7268	0	0	5915	5965	-1193	21326	104	21430	2760	321	24511	49.73
2	6843	1898	282	9023	841	7285	0	0	5897	5767	-1096	21530	41	21571	2551	290	24412	49.83
3	6824	2108	281	9213	712	7309	0	0	5567	5664	-949	21684	60	21744	2368	265	24377	49.89
4	6855	2005	282	9142	587	7259	0	0	5579	5517	-842	21394	0	21394	2252	269	23915	49.93
5	6851	1787	292	8930	513	7293	0	0	5687	5606	-805	21260	0	21260	2201	277	23738	49.81
6	6846	1869	272	8987	415	7252	0	0	5855	5755	-852	21250	0	21250	2274	307	23831	49.66
7	6898	1844	292	9034	447	7234	0	28	5918	5650	-983	21068	0	21068	2351	342	23761	49.91
8	6777	1879	294	8950	474	7276	0	229	5700	5895	-1067	21385	0	21385	2452	372	24209	50.00
9	6561	2060	281	8902	387	7090	0	579	6434	6636	-1245	21952	0	21952	2743	397	25092	49.97
10	6632	2043	280	8955	479	7054	0	939	7296	7530	-1538	23018	0	23018	3077	401	26496	49.89
11	6608	2219	269	9096	528	7095	0	1156	8145	8296	-1796	23998	0	23998	3319	377	27694	49.97
12	6706	1974	278	8958	435	6996	0	1308	8987	9209	-1988	24549	0	24549	3388	369	28306	49.89
13	6891	1275	267	8433	345	6930	0	1321	9708	9642	-1993	24307	0	24307	3390	371	28068	49.93
14	6890	1893	267	9050	263	6865	0	1241	8897	8800	-1919	23926	0	23926	3322	374	27622	49.93
15	7007	2113	267	9387	277	6930	0	1077	9006	9099	-1913	24482	0	24482	3388	375	28245	49.82
16	7055	2152	267	9474	335	7148	0	813	8628	8772	-1769	24396	261	24657	3425	377	28459	49.77
17	6914	2046	267	9227	329	7188	0	503	7723	7606	-1712	22741	716	23457	3350	400	27207	49.74
18	6931	2026	268	9225	324	7193	0	196	6382	6326	-1548	21332	895	22227	3219	384	25830	49.72
19	6914	1822	269	9005	343	7217	0	15	5813	5919	-1312	20772	627	21399	3072	415	24886	49.77
20	6830	2117	289	9236	518	7228	0	0	5769	5554	-1331	20814	886	21700	3085	391	25176	49.73
21	6757	1973	270	9000	669	7268	0	0	5724	5568	-1286	20819	540	21359	3028	400	24787	49.87
22	6731	1994	281	9006	983	7309	0	0	5654	5883	-1252	21561	203	21764	2951	368	25083	49.79
23	6759	2096	280	9135	897	7297	0	0	5783	6205	-1262	21899	362	22261	2934	373	25568	49.67
24	6760	2091	281	9132	859	7323	0	0	5932	5725	-1281	21404	489	21893	2947	354	25194	49.78
MUs	163.70	46.78	6.67	217.14	12.92	172.31	0.00	9.40	162.00	162.59	-32.93	532.87	5.18	538.05	69.85	8.57	616.47	49.83

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Apr/2022

Position as on 6.30 Hrs of 08/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25		Continued.	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	12/04/2022
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Bhusawal Unit 3	210	20/03/2022	07:00	07/04/2022	05:57	Coal Shortage	
MSPGCL	Nasik Unit 5	210	22/03/2022	23:40		Continued.	Withdrawn	
MSPGCL	Uran Unit B0	120	01/04/2022	19:02		Continued.	Filter Replacement work(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Uran Unit 8	108	01/04/2022	19:21		Continued.	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Parli Unit 6	250	05/04/2022	05:29	07/04/2022	06:35	Drum level low	
MSPGCL	Bhusawal Unit 3	210	07/04/2022	06:34	07/04/2022	08:09	Drum Level High	
MSPGCL	Koradi Unit-10	660	07/04/2022	08:08		Continued.	Condenser Cleaning work.	
MSPGCL	Paras Unit 4	250	08/04/2022	06:32	08/04/2022	10:22	Furnace Pressure High	08/04/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 08/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	29/03/2022	13:28			T	HT FOR LOAD MANAGEMENT
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	02/04/2022	12:00		Continued.	T	TRIPPED ON DIST. PROTN
NEW KOYNA - DABHOL CKT - 2	IntraState	07/04/2022	00:20	07/04/2022	00:56	T	Tripped at Dabhol end
PADGHE - NAGOTHANE CKT - 1	IntraState	07/04/2022	08:53	07/04/2022	20:43	PO	for jumper tightening and string replacement work
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	07/04/2022	11:18	07/04/2022	17:53	PO	PG Isolator overhauling work) Line maintenance work & replacement of PID faulty String
TBC @ KOLHAPUR(TALANDGE)	IntraState	07/04/2022	12:15	07/04/2022	14:45	PO	QM Work
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	07/04/2022	16:21	07/04/2022	22:11	T	Distance Protection
CHANDRAPUR-PARLI CKT-3	IntraState	07/04/2022	16:21	08/04/2022	00:38	T	Distance Protection
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	07/04/2022	17:48		Continued.	EO	The Rectification/ replacing work of jointing plate of cross arm of twin monopole for Samruddhi Mahamarg Crossing work.
400 KV ICT Outages/Trippings							
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	23/03/2022	10:14			EO	Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in ICT-I R ph unit
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	08/04/2022	16:02	08/04/2022	21:02	PO	Inspection & Maintenance work of OLTC Diverter switch
220 KV TBC Outages/Trippings							
TBC @ BIDRI	IntraState	07/04/2022	12:30	07/04/2022	14:27	PO	For PID testing Work
TBC @ AAREY	IntraState	07/04/2022	12:50	07/04/2022	17:21		For Annual maintenance of 189C side isolator during opportunity outage of Bay-1 i.e 220kV aarey Goregaon Line-1
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GOREGAON - AAREY CKT - 1	IntraState	31/03/2022	10:50		Continued.	PO	Under MMRC Line Diversion scheme for Metro-3 project, 220kV Outdoor termination at 220kV AEML Aarey and
EKLAHARE (GCR) - GHATGHAR	IntraState	02/04/2022	12:29		Continued.	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	02/04/2022	12:51		Continued.	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
IPCL - SPCL	IntraState	06/04/2022	09:40	07/04/2022	18:23	PO	CT TAN DELTA AND BAY MAINTENANCE
MUMEWADI -HALKARNI 1 LINE	IntraState	06/04/2022	13:03	07/04/2022	16:42	PO	245kv CGL make CB overhauling work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 08/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GOREGAON - AAREY CKT - 2	IntraState	06/04/2022	22:51	07/04/2022	02:17	EO	Hot spot observed on B phase on Gantry near Pylon termination yard(Temp is above 100 degree.)
HINJEWADI 2 - PEGASUS	IntraState	06/04/2022	23:10	07/04/2022	03:51	EO	Pegasus substations ¿ Cable OET, LA & BPI connections to bus ¿ Releasing overhead line connections& Re-energising the cable on load.
TROMBAY - KALWA	IntraState	07/04/2022	09:00	08/04/2022	19:59	PO	Stringing of HTLS conductor from Loc no.76 to 220KV Trombay ss Gantry.
JEJURI-PHURSUNGI 2	IntraState	07/04/2022	11:25	07/04/2022	17:55	PO	1) Replacement of Disc insulators at L.N. 11 (R ph) due to flashover (SP). 2)Replacement of Disc insulators at L.N. 05 (Jejuri Side, R Ph) due to Disc Broken (CP).
LONAND-BARAMATI	IntraState	07/04/2022	11:27	07/04/2022	15:55	PO	REPL. OF FLASHOVER STRING AT LOC 71 B-PH
KARAD - VITA CKT- 1	IntraState	07/04/2022	14:56	07/04/2022	18:18	T	Distance Protection
PETH- MUDSHINGI 1 LINE	IntraState	07/04/2022	16:04	07/04/2022	20:14	EO	For repairing of damaged R & B ph conductor due to stone mine blasting at Loc no-164 to 165
CHINCHWAD-2 - TELCO	IntraState	07/04/2022	16:08	07/04/2022	23:39	PO	245kv CT replacement due to higher tab delta value and CT tan delta testing work.
URAN - APTA 4	IntraState	08/04/2022	09:04	08/04/2022	18:18	PO	For Taking Auto reclosed scheme in service & Diagnostic testing work at uran end
ONI KHAREPATAN LINE	IntraState	08/04/2022	09:05	08/04/2022	21:39	PO	For bay maintenance work, hotspot attending & CRM test of CB.
HALKARNI - TILARI LINE	IntraState	08/04/2022	10:32		Continued.	PO	245kv CGL make CB overhauling work
CHAKAN-BHOSARI 1	IntraState	08/04/2022	11:11	08/04/2022	15:22	T	LTS operated on 400KV Chakan Talegaon PG
VITA - GHATNANDRE	IntraState	08/04/2022	11:56	08/04/2022	16:00	PO	String replacement at Loc No.22 Y Ph pilot string by HLU
BHOSARI 2 - TELCO	IntraState	08/04/2022	13:32	08/04/2022	15:41	HT	HT for Load Management
BABLESHWAR AHAMADNAGAR-II	IntraState	08/04/2022	14:24	08/04/2022	14:45	T	tripped on dist prot
PADGHE - WADA	IntraState	08/04/2022	14:32	08/04/2022	19:03	PO	1) Replacement of Faulty insulator strings at loc. No. 91(B-PH). 2) Cold line washing of insulator strings at loc. No. 87, 88, 89, 90, 91, 92, 93
KURKUMBH - RELIANCE RETAIL LIMITED (RIL)	IntraState	08/04/2022	15:25	08/04/2022	21:05	PO	Reconnection of jumpers of 29A isolator of ICT 1 at 220kv Kurkumbh ss.
MUMEWADI -HALKARNI 2 LINE	IntraState	08/04/2022	17:22	08/04/2022	18:07	T	Distance Protection
LAMBOTI - TULJAPUR CKT - 1	IntraState	08/04/2022	21:04	08/04/2022	21:53	T	Distance Protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Differential protection and Declare faulty

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 07/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 08/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	25/03/2022	11:32		Continued.	PO	1.Retrofitting of 86M Relay, BO/BI LVCT/PT connection to BCU under MTAMC work. 2.Arresting oil leakage from Top cover of Body by replacing all gaskets at site by opening /dismantling of accessories & installation of DM of 50MVA BHEL make Tf. 3.After complete work oil filtration & vacuum cycle will be done by pursing/injecting N2 gas .
220 / 110 / 33kv 315 MVA ICT 6 @ CARNAC	IntraState	03/04/2022	11:00			PO	FOR SHIFTING ON NEW 110 KV GIS
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	04/04/2022	15:35	07/04/2022	17:35	PO	REPLACEMENT OF 29(A) BUS ISOLATOR
220/100 KV 100 MVA ICT 1 @ TALOJA	IntraState	06/04/2022	11:39	07/04/2022	18:43	PO	EMCO ICT Painting work
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	07/04/2022	09:10	07/04/2022	18:43	PO	1. Diagnostic Testing of ICT, HV & LV bays. 2. Routine Maintenance activities.
220/22 KV 50 MVA PTR 2 @ CHAKAN	IntraState	07/04/2022	11:02	07/04/2022	17:33	EO	For attending oil Leakage from Y phase CT of 220/22 KV 50 MVA Power transformer no. 2
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	07/04/2022	11:06	07/04/2022	17:30	PO	For replacement of faulty relays and alignment of 29D , 132kv Isolator
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	07/04/2022	11:50	07/04/2022	17:35	PO	LOW OIL LEVEL.AIR CELL COMMISSIONING WORK.
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	08/04/2022	09:26	08/04/2022	15:33	PO	Quarterly Maintenance Work.
220/22 KV 50 MVA PTR 5 @ TEMGHAR	IntraState	08/04/2022	09:54	08/04/2022	19:02	PO	OLTC Overhauling work & oil leakage attending work.
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	08/04/2022	10:40	08/04/2022	15:11	PO	1. Annual relay testing work 2. Quarterly maintenance work
110 KV LINE Outages/Tripping							
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	07/04/2022	09:10	07/04/2022	17:44	PO	FOR BMC END WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage