

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Jun/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.339	1155.215	1) Gujrat	-1.700	-10.189
2) Hydro	4.155	29.565	2) Madhya Pradesh	6.818	56.164
3) Gas	6.646	47.022	3) Chattisgarh	4.490	24.950
Total MSPGCL	173.140	1231.802	4) Maharashtra	111.251	783.019
B) 1) APML	72.378	502.349	5) Goa (Amona)	-0.440	-2.684
2) JSWEL	25.279	169.451	Total	120.419	851.260
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.515	218.668
4) RPL(AMT)	25.051	172.448	b) Mumbai Drawl	40.756	273.307
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	6.874	75.407
6) Other IPP	7.355	50.757	Include PX	-8.147	-24.999
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.515	218.668
C) 1) TPCL Thermal	13.284	93.756	Include PX	14.183	97.902
2) TPCL Hydro	4.462	20.436	Standby	0.000	0.000
3) TPCL Gas	4.368	30.273	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.463	66.171	1) MSEDCL	413.407	2974.753
D) STATE			2) Mumbai Discoms	72.333	483.944
1) Thermal	315.149	2210.147	TOTAL STATE	485.740	3458.697
(A1+C1+C4+(B1-B6))					
2) Hydro	8.617	50.001			
(A2+C2)					
3) Gas	11.014	77.295			
(A3+B7+C3)					
4) Wind	25.182	226.594			
6) SOLAR	5.359	43.399			
TOTAL STATE	365.321	2607.436			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6796	6571	6765	6838
MSPGCL Hydro	163	476	316	70
MSPGCL Gas	278	268	281	272
MSPGCL Total Generation	7237	7315	7362	7180
Central Sector Receipt	5763	5868	4216	4748
WIND	756	721	1169	1028
CPP / IPP Thermal	5639	5906	4719	5184
CPP / IPP Gas	0	0	0	0
SOLAR	691	468	0	0
Exchange with Mumbai	-2209	-1783	-1525	-1755
MSEDCL DEMAND MET	17877	18495	15941	16385
Load Shedding	0	0	0	0
MSEDCL DEMAND	17877	18495	15941	16385
TPCL GENERATION	884	1329	1169	915
AEML GENERATION	373	499	383	376
MUMBAI DEMAND	3466	3611	3077	3046
STATE DEMAND MET	21343	22106	19018	19431
STATE DEMAND	21343	22106	19018	19431
Frequency (Hz)	49.92	49.94	49.96	49.89

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 19.02 Hrs	49.72 Hz at 22.18 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 07/Jun/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.60	27.82	195	115
Unit 7	3.02	18.71	164	85
Unit 8	9.89	60.22	482	355
Unit 9	10.16	73.89	510	302
Unit 10	10.96	74.06	537	348
Total	37.64	254.70		
Bhusawal				
Unit 3	0.00	12.44	0	0
Unit 4	11.08	70.26	500	350
Unit 5	2.52	61.55	500	0
Total	13.60	144.25		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	11.77	0	0
Total	0.00	11.77		
Chandrapur				
Unit 3	4.54	29.96	193	175
Unit 4	4.01	27.33	170	165
Unit 5	9.82	66.87	420	390
Unit 6	10.50	70.72	465	395
Unit 7	10.23	67.95	441	395
Unit 8	11.43	76.66	490	465
Unit 9	11.15	72.76	480	412
Total	61.68	412.25		
Paras				
Unit 3	6.09	40.75	259	250
Unit 4	5.87	39.86	250	228
Total	11.96	80.61		
Khaparkheda				
Unit 1	3.09	22.41	145	100
Unit 2	3.24	21.36	140	115
Unit 3	3.31	23.42	150	128
Unit 4	3.37	23.38	145	135
Unit 5	11.49	76.65	495	440
Total	24.49	167.22		
Nasik				
Unit 3	4.31	28.89	197	157
Unit 4	4.43	26.79	206	160
Unit 5	4.22	28.74	192	160
Total	12.96	84.42		
Uran				
All Units	6.65	47.02	288	247
Total	6.65	47.02		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.01	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.01		
Koyna				
Stage 1-2	1.46	8.97	260	35
Stage 4	0.00	0.00	0	0
Stage 3	0.38	2.09	80	0
Total	1.84	11.06		
Hydro				
KDPH	0.42	3.04	18	17
VTRNA	0.79	6.68	66	0
TILLARI	0.10	0.97	49	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.14	1.00	40	0
RNGR+BHTSA	0.21	1.52	9	8
BHANDARDRA	0.00	1.07	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.13	1.36	6	5
GHATGHAR	0.52	2.88	125	0
Total	2.31	18.50		
Wind				
Total	25.18	226.59	0	0
Total	25.18	226.59		
CPP				
APML(Mus)	72.38	502.35	0	0
JSWEL(Mus)	25.28	169.45	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	25.05	172.45	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	7.36	50.76	0	0
Total	130.06	895.00		
SOLAR				
Total	5.36	43.40	0	0
Total	5.36	43.40		
Tata				
Trombay 5	8.36	59.14	474	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	19.34	116	115
Trombay 7B	1.59	10.93	67	65
Trombay 8	4.92	34.62	230	198
TATA Hydro	4.46	20.44	444	0
Total	22.11	144.46		
AEML				
DTPS U-1&2	9.46	66.17	499	373
Total	9.46	66.17		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.34	1155.22	MSPGCL Total	173.14	1231.80
			MSPGCL Thml+Gas	168.98	1202.24	Koyna 1,2 & 4 Total	1.46	8.97
			MSPGCL Hydro	4.16	29.56	State Total	365.32	2607.44

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Jun/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	7200	73	284	7557	1357	5677	0	0	4970	4720	-1706	17605	0	17605	2964	20569	49.95
2	7269	73	285	7627	1233	5550	0	0	4821	4772	-1641	17541	0	17541	2741	20282	49.99
3	6862	78	275	7215	1103	5377	0	0	5034	5010	-1494	17211	0	17211	2581	19792	49.98
4	6762	78	286	7126	1079	5150	0	0	4845	5068	-1386	17037	0	17037	2457	19494	50.00
5	6907	73	286	7266	1040	5438	0	0	4835	4742	-1307	17179	0	17179	2379	19558	50.05
6	6970	104	287	7361	1287	5493	0	0	5072	4808	-1303	17646	0	17646	2373	20019	49.97
7	6770	144	288	7202	1173	5526	0	62	5178	5044	-1272	17735	0	17735	2344	20079	49.99
8	6633	134	276	7043	1221	5500	0	154	5063	5245	-1400	17763	0	17763	2473	20236	49.91
9	6443	129	285	6857	1032	5508	0	323	5195	5355	-1667	17408	0	17408	2741	20149	50.00
10	6486	131	283	6900	813	5492	0	511	5569	5895	-1959	17652	0	17652	3097	20749	49.97
11	6812	133	271	7216	897	5533	0	660	5870	5251	-2159	17398	0	17398	3353	20751	50.00
12	6796	163	278	7237	756	5639	0	691	5897	5763	-2209	17877	0	17877	3466	21343	49.92
13	6787	205	268	7260	794	5582	0	739	6015	5807	-2170	18012	0	18012	3466	21478	49.92
14	6668	193	277	7138	777	5583	0	714	5922	5828	-2095	17945	0	17945	3394	21339	49.95
15	6619	439	267	7325	822	5838	0	641	5934	5692	-2021	18297	0	18297	3529	21826	49.95
16	6571	476	268	7315	721	5906	0	468	5916	5868	-1783	18495	0	18495	3611	22106	49.94
17	6534	245	278	7057	1022	5861	0	281	5687	5239	-1771	17689	0	17689	3531	21220	49.96
18	6477	217	268	6962	1211	5062	0	124	5046	5066	-1740	16685	0	16685	3371	20056	49.94
19	6539	348	282	7169	1067	4751	0	18	4444	3602	-1452	15155	0	15155	3180	18335	50.02
20	6765	316	281	7362	1169	4719	0	0	4271	4216	-1525	15941	0	15941	3077	19018	49.96
21	6941	163	272	7376	1243	4891	0	0	4323	3829	-1583	15756	0	15756	3034	18790	49.95
22	6722	80	282	7084	1433	5065	0	0	4249	3976	-1576	15982	0	15982	2988	18970	49.95
23	6838	70	272	7180	1028	5184	0	0	4423	4748	-1755	16385	0	16385	3046	19431	49.89
24	6968	90	247	7305	904	5738	0	0	4895	4875	-1782	17040	0	17040	3137	20177	49.94
MUs	162.34	4.15	6.65	173.14	25.18	130.06	0.00	5.39	123.47	120.42	-40.76	413.43	0.00	413.43	72.33	485.77	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Jun/2019

Position as on 6.30 Hrs of 08/Jun/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	20/05/2019	16.01		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 3	210	04/06/2019	20.15		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 5	500	07/06/2019	06.17		Continued.	Ash Feed Gate replacement work	
MSPGCL	Koyana STG-IV Unit-3	250	07/06/2019	10.00		Continued.	Stepup T/F Oil Leakage and Shaft Seal replacement	
IPP	Adani U-2	660	07/06/2019	17.07	07/06/2019	20.58	Tripped Due To SPS Scheme Operated.	
MSPGCL	Uran Unit 5	108	07/06/2019	23.45		Continued.	Air Filter Replacement & Allied Work.	
MSPGCL	Paras Unit 4	250	08/06/2019	02.36	08/06/2019	07.30	Auxiliary supply failure	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 07/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 08/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi III - Akola II- ckt-II	IntraState	08/06/2019	16.16	08/06/2019	16.31	T	Distance Protection, Tripped From Koradi3 end.
Koradi-III - Akola-II ckt-I	IntraState	08/06/2019	16.16	08/06/2019	16.58	T	Distance Protection:3.8 KAMP 156 KM:Z-1:B-PH 56.1.5.3 KAMP.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	08/06/2019	15.42	08/06/2019	21.48	PO	Insulator Chemical Washing.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	04/06/2019	18.55		Continued.	HT	Over Voltage
Chandrapur Bhadravati IV	InterState	07/06/2019	18.34	08/06/2019	21.39	T	DT Sent, Over Voltage Trip. CVT Suspected.
Koradi Bhilai	InterState	08/06/2019	17.12	08/06/2019	18.03	T	Distance Protection: Y-Phase Z-1,IF15.8KA.
Khadka-Aurangabad (Waluj)	IntraState	06/06/2019	17.47	07/06/2019	08.32	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt-II	IntraState	06/06/2019	19.19	07/06/2019	00.59	T	Distance Protection, Akola End:- R, Y Ph, Z1, 5.4KA, 5.6KA, 54.28KM. RPL End:-R, Y Ph, Z1, 6.9KA, 37.3KM.
Chandrapur II - Chandrapur ckt I	IntraState	07/06/2019	07.10	07/06/2019	17.59	PO	Replacement of Y PH LA.
Khadka - Bableswhar	IntraState	07/06/2019	08.51	07/06/2019	21.09	PO	Stringing of Earth Wire.
Lonikand I - Koyna stage-IV	IntraState	07/06/2019	09.16	07/06/2019	21.23	PO	Replacement of Insulator String, Tripped While Charging Y-Ph CVT Jump Break (Tripped 21.23Hrs.)
New Koyna - Dabhol - II	IntraState	07/06/2019	10.24	07/06/2019	15.29	PO	Cold Washing & Routine Maintenance.
Warora-Adani (Tiroda) 2	IntraState	07/06/2019	17.07	07/06/2019	20.13	T	Distance Protection, Z1, R-Ph, 9.3KA, 25KMS.
Warora-Adani(Tiroda)1	IntraState	07/06/2019	17.07	07/06/2019	19.00	T	Distance Protection, Z1, R-Ph, 8 KA, 23.88KMS.
Khadka-Aurangabad (Waluj)	IntraState	07/06/2019	21.13		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	07/06/2019	21.23	08/06/2019	02.18	T	Y-Ph CVT Jump Break (Tripped 21.23HRS)
Lonikand I - Koyna stage-IV	IntraState	08/06/2019	03.32	08/06/2019	04.15	T	Distance Protection, Y Ph, E/F.
Lonikand I - Koyna stage-IV	IntraState	08/06/2019	11.14	08/06/2019	14.40	EO	Decapping attending work.
N.Koyna-Karad -Ckt II	IntraState	08/06/2019	14.56	08/06/2019	21.19	EO	Flashover String Replacement.
Koradi III(Adani)-Korad II Ckt-I	IntraState	08/06/2019	16.16	08/06/2019	17.56	T	DT REceived: Trip Protection Operated ON High Lightning
Akola II - RPL(Rattanindia) Ckt-II	IntraState	08/06/2019	16.16	08/06/2019	19.12	T	Distance Protection:B-PH:IF2.7 KAMP.
Koradi-RattanIndia	IntraState	08/06/2019	17.07	08/06/2019	17.31	T	Distance Protection:B-PH:IF2.7 KAMP.
Koradi III(Adani)-Koradi II ckt 2	IntraState	08/06/2019	17.09	08/06/2019	17.40	T	Distance Protection:B-PH:IF2.7 KAMP.
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	07/06/2019	11.26	07/06/2019	19.00	PO	Line Maintenance work
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 08/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Padgha - Temghar I	IntraState	07/06/2019	05.10	07/06/2019	10.55	EO	Attending Hot Spot
Padgha-Temghar-II	IntraState	07/06/2019	05.10	07/06/2019	10.55	HT	Avoid Tripping On Overload.
Niwali - Pawas Line	IntraState	07/06/2019	05.27	07/06/2019	15.43	T	Distance Protection, Z1, Y-E, 33.77KM, 18.86KA (Y Ph Decapping At LOC.No.26)
Chandrapur GCR - Warora - I	IntraState	07/06/2019	09.20	07/06/2019	21.25	PO	RPH CC Replacement Work.
Hingoli- Girawali	IntraState	07/06/2019	09.44	07/06/2019	14.04	PO	Shackle Nut Fixing At LOC 447 And 365 And 367.
Colourchem - Temghar	IntraState	07/06/2019	09.52	07/06/2019	13.38	T	Supervision Relay Problem At Temghar.
Nalasopara-Boisar	IntraState	07/06/2019	10.50	07/06/2019	19.03	PO	Bay Maintenance Work.
Chinchwad-Hinjewadi I	IntraState	07/06/2019	11.05	07/06/2019	18.15	HT	Load Management.
Nanded-Ghatodi	IntraState	07/06/2019	13.37	07/06/2019	15.30	PO	Y & B PH LA Work.
Koradi-Ambazari-Ii	IntraState	07/06/2019	15.12	07/06/2019	17.55	T	A= B-Ph, 22.1KM(TL=21.7), 5.0KA, K= B-Ph, Z1, 5KM.
KORADI 2 - KAULEWADA CKT - I	IntraState	07/06/2019	15.12	07/06/2019	16.31	T	K2= B-Ph, Z1, 7.8KA, 12.7KM. Kwada= B-Ph, Z2, 119.1KM, 831A.
KORADI 2 - KAULEWADA CKT - II	IntraState	07/06/2019	15.12	07/06/2019	17.16	T	K2= B-Ph, 12KA, 4.6KM, Z1. Kwada= B-Ph, Z2, 690A, 117.7KM.
Wardha-Dhamangaon	IntraState	07/06/2019	15.26	07/06/2019	15.59	T	Wardha= R-Ph, Z1, 9.14KM, 7KA. D= R-Ph, Z1, 1.7KA, 32KMS, A/R OPTD.
Warora - Hinganghat	IntraState	07/06/2019	17.16		Continued.	T	Tower Collapsed At Location No.327, RYB 3.94KA, 4.41KA, 4.11KA.
Warora - Wardha	IntraState	07/06/2019	17.16		Continued.	T	Wrora-Y PH Pick, B PH Pick Up,Z1.Wardha-Y PH B PH, Z1-B 91.8 KM.3.31KAMP.3.24KAMP.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	08/06/2019	03.09	08/06/2019	03.47	T	Trip From Navasari End Only.
Sadawaghapur Karad Ckt 2	IntraState	08/06/2019	04.49	08/06/2019	14.32	T	Distance Protection,Z-1,RYB Trip,R-4.23AMP,Y-1.75,B-680,D-31KM,B-phase 29A-29B T Section To Stub Bus Insulator Flashover.
Karad - Sadawagpur I	IntraState	08/06/2019	04.49	08/06/2019	14.30	T	Distance Protection,Z-1,RYB Trip,R-4.23AMP,Y-1.75,B-680,D-31KM,B-phase 29A-29B T Section To Stub Bus Insulator Flashover.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	08/06/2019	05.39	08/06/2019	14.00	T	Distance Protection,Z-1 R-G,D-66.91KM.IA-2437 AMP.
Kalwa-TIFIL	IntraState	08/06/2019	07.04	08/06/2019	12.17	PO	Replacement of rusted bolted tension clamp by dead end.
Pophali - Nerale	IntraState	08/06/2019	07.10	08/06/2019	19.50	PO	Bus section outage.
Pophali - New Koyna	IntraState	08/06/2019	08.00	08/06/2019	19.30	PO	Bus section outage.
Tata Borivli MSETCL Borivli 4	IntraState	08/06/2019	08.16	08/06/2019	13.02	PO	Tree trimming.
Bus Section II @ Pophali	IntraState	08/06/2019	08.45	08/06/2019	20.20	PO	Pre-monsoon maintenance work.
Kharghar-Panvel TSS	IntraState	08/06/2019	08.49	08/06/2019	16.34	PO	Replacement work
Vasai Kamba	IntraState	08/06/2019	09.20	08/06/2019	16.11	PO	Insulator Replacement Work
Malegaon-Satana	IntraState	08/06/2019	09.42	08/06/2019	18.33	PO	Insulator Replacement Work
Pophali - Pedambe II	IntraState	08/06/2019	10.45	08/06/2019	18.40	PO	Bus section outage.
Pegasus - Infosys	IntraState	08/06/2019	10.46	08/06/2019	15.01	PO	Premonsoon Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 08/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Nerle - Dasgaon	IntraState	08/06/2019	11.30	08/06/2019	13.51	PO	String Replacment.
Ekalahara(Ocr)(Nashik)-Navasari II	IntraState	08/06/2019	11.34	08/06/2019	14.00	T	Loc No.204 RPH Decapping.
Ekalahara(Ocr)(Nashik)-Navasari II	IntraState	08/06/2019	14.20	08/06/2019	16.27	EO	Replacement Of Flashover String.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Buccholz Trip.
220/100 Kv 100 MVA ICT II @Kandalgaon	IntraState	01/06/2019	11.30		Continued.	PO	Oil Filtration Work.(Charged On Humming).
220/33 Kv 100 Mva Ptr 1 @Sadawaghapur	IntraState	08/06/2019	00.41	08/06/2019	14.51	T	Y-PH C.B. To Stub Bus Insulator Flashover.
220/33 Kv 100 Mva Ptr 2 @Sadawaghapur	IntraState	08/06/2019	00.41	08/06/2019	14.31	T	B-PH C.B. To Stub Bus Insulator Flashover.
220/33 Kv 50 Mva Imp Ptr 1 @Sonkar	IntraState	08/06/2019	08.35	08/06/2019	12.35	PO	Premonsoon Maintenace.
220kv 200MVA ICT IV @ OCR Nashik	IntraState	08/06/2019	08.47	08/06/2019	10.26	PO	Premonsoon Maintenace.
220/132 KV ICT-2 @Nagar	IntraState	08/06/2019	10.17	08/06/2019	15.53	PO	Oil leakage attending work.
220/132 kv 200MVA ICT-V @ Nashik	IntraState	08/06/2019	10.31	08/06/2019	11.57	PO	Premonsoon Maintenace.
220/132 KV ICT III @ Nasik OCR	IntraState	08/06/2019	11.58	08/06/2019	13.04	PO	Premonsoon Maintenace.
220/100 Kv 100 Mva Cgl Ict 1 @Taloja	IntraState	08/06/2019	12.00	08/06/2019	12.58	PO	Premonsoon Maintenace.
220/33kv 100 Mva Transformer 3 @Ghodbunder R/S	IntraState	08/06/2019	15.25	08/06/2019	16.58	PO	Removal OF Birdnet.
132 KV LINE Outages/Trippings							
Ambazari-Amravati	IntraState	07/06/2019	15.20	07/06/2019	18.08	T	Ambz= B-Ph, Z1, 114.3KM(120KM), 0.95KA. Amv=B-Ph, Z1, 17.61KM, 5.07KA.
Kalmeshwar-Saoner 1	IntraState	07/06/2019	20.47	07/06/2019	21.04	T	KLMSR= B-Ph, 40.4KM, 2.11KM, SNR= Distance Protection, B-Ph, Z1, 8.42KM, 1.7KA.
Himayatnagar - Tamsa	IntraState	07/06/2019	22.11	07/06/2019	22.30	T	Tamsa= Distance Protection, Z1, R-E, 1.5KA, LL= 49KM, 37.16KM Rainfall Reported At Tamsa End. Load Affected Approx 17MW of Himayatnagar And Kinwat Area.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage