

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Jun/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.602	1013.438	1) Gujrat	-3.653	-21.685
2) Hydro	13.842	174.684	2) Madhya Pradesh	4.921	51.550
3) Gas	5.066	36.271	3) Chattisgarh	3.820	21.490
Total MSPGCL	181.510	1224.393	4) Maharashtra	217.642	1526.851
B) 1) APLM	73.302	452.962	5) Goa (Amona)	-1.541	-10.329
2) JSWEL	27.124	175.102	Total	221.189	1567.877
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.539	305.176
4) RPL(AMT)	31.304	215.392	b) Mumbai Drawl	47.441	338.134
5) SWPGPL	10.789	72.457	c) MSEDCL Bilateral *	109.243	769.863
6) Other IPP	2.236	17.101	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.539	305.167
C) 1) TPCL Thermal	12.602	87.966	Include PX	0.000	0.000
2) TPCL Hydro	5.932	37.898	Standby	0.000	0.009
3) TPCL Gas	2.262	15.200	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.719	57.148	1) MSEDCL	536.810	3611.166
D) STATE			2) Mumbai Discoms	78.956	536.346
1) Thermal	330.678	2091.566	3) Other Discoms	10.930	74.755
(A1+C1+C4+(B1-B6))			TOTAL STATE	626.696	4222.267
2) Hydro	19.774	212.582			
(A2+C2)					
3) Gas	7.328	51.471			
(A3+B7+C3)					
4) Wind	31.311	186.624			
6) SOLAR	16.416	112.147			
TOTAL STATE	405.507	2654.390			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6242	7173	7246	6780
MSPGCL Hydro	801	671	435	473
MSPGCL Gas	200	198	201	223
MSPGCL Total Generation	7243	8042	7882	7476
Central Sector Receipt	9916	10093	8561	9015
WIND	596	768	1614	1119
CPP / IPP Thermal	5760	6157	6265	6043
CPP / IPP Gas	0	0	0	0
SOLAR	2272	1231	0	609
Exchange with Mumbai	-2421	-2301	-1873	-1835
MSEDCL DEMAND MET	22880	23500	21966	21955
Load Shedding	0	0	0	0
MSEDCL DEMAND	22880	23500	21966	21955
TPCL GENERATION	809	1078	1020	599
AEML GENERATION	494	501	455	313
MUMBAI DEMAND	3724	3880	3348	2747
OTHER DISCOM DEMAND	486	490	483	472
STATE DEMAND MET	27090	27870	25797	25174
STATE DEMAND	27090	27870	25797	25174
Frequency (Hz)	49.98	50.02	50.11	50.05

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.35 Hz at 18:03 Hrs	49.82 Hz at 12:47 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.85	33.07	205	190
Unit 8	13.80	19.73	605	527
Unit 9	5.19	5.19	545	0
Unit 10	13.72	91.63	606	511
Total	37.56	149.63		
Bhusawal				
Unit 3	0.00	15.51	0	0
Unit 4	8.58	68.08	440	0
Unit 5	11.22	74.38	485	415
Total	19.81	157.98		
Parli				
Unit 6	4.96	34.94	240	149
Unit 7	5.20	34.10	248	144
Unit 8	4.55	30.54	206	147
Total	14.71	99.57		
Chandrapur				
Unit 3	3.70	15.62	165	130
Unit 4	3.72	25.68	158	142
Unit 5	0.00	0.00	0	0
Unit 6	6.32	42.88	401	0
Unit 7	9.82	64.87	425	380
Unit 8	11.53	78.56	497	435
Unit 9	11.15	79.28	500	382
Total	46.25	306.88		
Paras				
Unit 3	4.63	34.65	212	168
Unit 4	4.78	36.14	221	181
Total	9.41	70.79		
Khaparkheda				
Unit 1	2.68	20.96	125	95
Unit 2	2.70	20.73	125	94
Unit 3	3.40	18.73	160	129
Unit 4	3.41	28.31	160	129
Unit 5	10.43	75.31	455	355
Total	22.64	164.02		
Nasik				
Unit 3	4.06	8.22	182	143
Unit 4	4.15	28.54	181	142
Unit 5	4.01	27.81	173	139
Total	12.22	64.57		
Uran				
All Units	5.07	36.27	226	196
Total	5.07	36.27		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	0.70	20	0
Total	0.07	0.70		
Koyna				
Stage 1-2	3.38	39.08	435	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.72	81.22	513	0
Stage 3	1.95	27.67	204	0
Total	10.06	147.96		
Hydro				
KDPH	0.42	3.13	18	17
VTRNA	1.16	7.89	60	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.43	2.56	80	0
SMLHY_PTN	1.70	11.21	78	65
GHATGHAR	0.00	0.19	0	0
Total	3.71	26.02		
Wind				
Total	31.31	186.62	0	0
Total	31.31	186.62		
CPP				
APML(Mus)	73.30	452.96	0	0
JSWEL(Mus)	27.12	175.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.30	215.39	0	0
SWPGPL-Mus	10.79	72.46	0	0
Dhariwal	0.00	0.00	0	0
IEPL	0.00	0.00	0	0
Other(Mus)	2.24	17.10	0	0
Total	144.76	933.01		
SOLAR				
Total	16.42	112.15	0	0
Total	16.42	112.15		
Tata				
Trombay 5	8.17	57.70	409	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.26	8.39	107	37
Trombay 7B	1.00	6.81	63	34
TATA Hydro	5.93	37.90	411	77
Trombay 8	4.43	30.27	227	132
Total	20.80	141.06		
AEML				
DTPS U-1&2	10.72	57.15	501	310
Total	10.72	57.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.60	1013.44	MSPGCL Total	181.51	1224.39
			MSPGCL Thml+Gas	167.67	1049.71	Koyna 1,2 & 4 Total	8.11	120.29
			MSPGCL Hydro	13.84	174.68	State Total	405.51	2654.39

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6419	827	223	7469	1911	6322	0	0	9103	8862	-1794	22368	0	0	22368	3329	402	26099	50.00
2	6425	1090	224	7739	1873	6308	0	0	8867	8617	-1740	22413	0	0	22413	3083	385	25880	49.97
3	6406	933	223	7562	1819	6292	0	0	8811	8723	-1658	22382	0	0	22382	2880	357	25618	49.98
4	6431	696	226	7353	1809	6223	0	0	9075	9157	-1560	22623	0	0	22623	2725	359	25707	49.99
5	6463	504	224	7191	1552	6206	0	0	9263	9332	-1576	22334	0	0	22334	2657	371	25362	49.97
6	6463	769	226	7458	1283	6201	0	2	9417	9584	-1664	22450	0	0	22450	2647	414	25511	49.98
7	6628	925	222	7775	1042	6100	0	180	9252	9362	-1670	22340	0	0	22340	2620	450	25409	50.02
8	6780	473	223	7476	1119	6043	0	609	9047	9015	-1835	21955	0	0	21955	2747	472	25174	50.05
9	6682	395	220	7297	875	5619	0	1209	9321	9258	-2111	21649	0	1	21649	3035	498	25182	50.05
10	6709	509	208	7426	739	5419	0	1649	9458	9699	-2260	22175	0	0	22175	3365	497	26037	50.01
11	6557	608	203	7368	577	5430	0	2070	9897	9479	-2423	22012	0	40	22012	3620	489	26121	49.99
12	6242	801	200	7243	596	5760	0	2272	10229	9916	-2421	22880	0	7	22880	3724	486	27090	49.98
13	6362	498	201	7061	482	5767	0	2132	10345	10229	-2450	22717	0	14	22717	3722	504	26943	49.98
14	6631	643	197	7471	513	5705	0	2052	10109	9966	-2357	22880	0	5	22880	3667	470	27017	50.01
15	6971	757	197	7925	618	6074	0	1683	10199	10055	-2361	23513	0	47	23513	3796	481	27790	49.99
16	7173	671	198	8042	768	6157	0	1231	9969	10093	-2301	23500	0	2	23500	3880	490	27870	50.02
17	7224	408	196	7828	1166	6140	0	849	10224	9857	-2184	23174	0	40	23174	3722	482	27378	50.03
18	7047	233	201	7481	1662	6006	0	417	10171	9492	-2309	22247	0	69	22247	3653	502	26402	50.06
19	6495	534	201	7230	1842	5485	0	61	9278	9312	-2129	21299	0	12	21299	3427	502	25228	50.15
20	7246	435	201	7882	1614	6265	0	0	8215	8561	-1873	21966	0	0	21966	3348	483	25797	50.11
21	7269	416	208	7893	1740	6296	0	0	8190	7998	-1701	21755	0	0	21755	3305	471	25531	50.05
22	7287	296	212	7795	1890	6312	0	0	7761	7884	-1631	21783	0	0	21783	3274	466	25524	50.01
23	7324	238	214	7776	1835	6322	0	0	8175	8306	-1647	22136	0	0	22136	3318	456	25910	49.97
24	7368	183	218	7769	1986	6300	0	0	8262	8432	-1786	22258	0	0	22258	3412	443	26113	49.98
MUs	162.60	13.84	5.07	181.51	31.31	144.75	0.00	16.42	222.64	221.19	-47.44	536.81	0.00	0.24	536.81	78.96	10.93	626.70	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)Due to 132Kv BBLR-rahuri line overload.2)Due to overloading 220Kv jejuri Lonand line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Jun/2023

Position as on 6.30 Hrs of 08/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	07/06/2023
MSPGCL	Koradi Unit 9	660	30/05/2023	00:08	07/06/2023	11:03	Boiler Tube Leakage	
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Chandrapur Unit 6	500	05/06/2023	01:55	07/06/2023	05:18	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 3	210	05/06/2023	15:40		Continued.	Boiler Tube Leakage	08/06/2023
MSPGCL	Koyana STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	13/06/2023
MSPGCL	Koyana STG-IV Unit-4	250	06/06/2023	14:20		Continued.	GOP Problem	08/06/2023
MSPGCL	Bhusawal Unit 4	500	07/06/2023	10:42	07/06/2023	13:14	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 08/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/06/2023	23:37			HT	HT for load management
LONIKAND I - KOYNA STAGE-IV	IntraState	06/06/2023	21:04			T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	07/06/2023	11:25	07/06/2023	15:19	PO	Pre-Monsoon maintenaance
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	08/06/2023	05:31	08/06/2023	06:54	PO	For pre-mansoon maintenance work (e.g-for polythin paper wrapping work)
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220KV WARORA(400KV)-WARORA CKT 2	IntraState	07/06/2023	07:59	07/06/2023	11:11	EO	Attending hot spot on Y ph line isolator towards line side.
220 KV BUS COUPLER	IntraState	07/06/2023	13:35	07/06/2023	16:48	PO	Replacing overcurrent earth fault relay.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
GHODBUNDER - MSETCL BOISAR	IntraState	06/06/2023	22:55	07/06/2023	17:53	T	Tripped on distance protection
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	07/06/2023	07:22			PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	07/06/2023	07:28			PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
TALOJA II - OCIL 1	IntraState	07/06/2023	08:40	07/06/2023	18:20	PO	220kv OCIL-01 Bay Maintenance OCIL end
OSMANABAD - BARSHI	IntraState	07/06/2023	09:28	07/06/2023	14:34	PO	Outage is required for Quarterly Maintenance
TILLARI - AMONA LINE	IntraState	07/06/2023	09:52	07/06/2023	19:15	PO	Maintenance work
COLOURCHEM - TEMGHAR	IntraState	07/06/2023	10:18	07/06/2023	11:14	HT	sparking on wave trap observed , so Handtripped at colourchem end
KALMESHWAR-PANDHURNA	IntraState	07/06/2023	10:43	07/06/2023	16:49	PO	Routine Maint. Work
GHODBUNDER - GORAI	IntraState	07/06/2023	11:01	07/06/2023	12:44	PO	Premonsoon maintenance of Circuit Breaker

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 08/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
COLOURCHEM - TEMGHAR	IntraState	07/06/2023	12:55	07/06/2023	13:10	EO	For 220KV Temghar line CB hot spot attending work. And Bus T palm hot spot attending work on R-phase with help of Hot Line Team.
MAHALAXMI - AMONA	IntraState	07/06/2023	14:09	07/06/2023	15:14	EO	Outage required to M/s. Gadre Marine Export Pvt Ltd to transport the Turbine under 220KV D/C line ie 220KV Tilari-Amona & 220KV Mahalaxmi-Amona at location No. 342-343
NEW KOYNA - LOTEPARSHURAM	IntraState	07/06/2023	15:38	07/06/2023	17:28	T	Tripped on Distance Protection.
NEW KOYNA - PEDAMBE	IntraState	07/06/2023	16:03	07/06/2023	16:25	T	Tripped due to overloading at New Koyana end only.
VITA - MIRAJ	IntraState	07/06/2023	17:27	07/06/2023	19:46	PO	Jump Replacement work at Loc No.84 B Ph
KALWA SALSETTE - 4	IntraState	07/06/2023	22:33	08/06/2023	01:38	PO	For 2A2 phase LA replacement at Salsette
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	08/06/2023	02:01	08/06/2023	08:46	PO	1. Attending of low clearance in between loc.no.62 to 63 & 63-64. 2. Conversion of single jump into twin jump of tension tower at various locations. (as per current loading, frequent Red-Hot comes frequently).
TALOJA II - OCIL 2	IntraState	08/06/2023	07:55			PO	220KV OCIL-2 Bay Maintenance OCIL end
KURKUMBH - SHIRSHUPHAL CKT	IntraState	08/06/2023	09:10			PO	Premonsoon Maintenance, attending HOT spot on R CT.
HALKARNI - TILARI LINE	IntraState	08/06/2023	09:30			PO	Erection of Bph and Yph Pedestrial Wave Traps at 220KV Halkarni bay @ Tillari SS, cleaning of EHV equipments and line side tension, suspension insulator strings
IPCL - SPCL	IntraState	08/06/2023	10:22			PO	ABB MAKE CB OVERHAULUING WORK AT IPCL END CB
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	IntraState	07/06/2023	08:34	07/06/2023	12:16	PO	Outage is required for Diagnostic testing and maintenance work
220/132 KV 200 MVA ICT 3	IntraState	07/06/2023	08:37	07/06/2023	12:42	PO	Pre-moon maintenance work.
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	07/06/2023	09:06	07/06/2023	13:13	PO	Pre-moon maintenance work.
220 / 110 / 22kv 250MVA ICT 1 @ BORIVALI (TATA)	IntraState	07/06/2023	09:18	07/06/2023	11:57	PO	R/M & Testing
220/100 KV 200 MVA ICT 2 @ PALDOMBIVALI	IntraState	07/06/2023	10:15	07/06/2023	16:05	PO	Plastic paper wrapping & RM Work
220/132 KV 200 MVA ICT 1	IntraState	07/06/2023	12:47	07/06/2023	18:49	PO	Pre-moon maintenance work.
200 MVA 220/132 KV ICT 3 @ GIRWALI	IntraState	07/06/2023	14:03	07/06/2023	16:07	PO	Pre-moon maintenance work.
220/132 KV 200 MVA ICT 2 @ AMALNER	IntraState	07/06/2023	18:10	07/06/2023	20:30	PO	Diagnostic testing work carried by mobile testing unit nashik and pre-moon maintenance work.
220/132 KV 150 MVA ICT-2 @BHENDA	IntraState	07/06/2023	18:17	07/06/2023	19:40	EO	For attending hotspot of LV Y PH Bushing
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	08/06/2023	07:36			PO	For 1) Premonsoon maintenance work & 2) RM work.
220/132KV 100 MVA ICT 2@ PETH	IntraState	08/06/2023	10:01			PO	Structure Painting Work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 08/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 1 @ PAL- DOMBIVALI	IntraState	08/06/2023	10:15			PO	Plastic paper wrapping & RM Work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
KANHAN-PENCH	IntraState	07/06/2023	09:54	07/06/2023	20:10	PO	Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	06/06/2023	21:05	07/06/2023	06:40	PO	Tower erection & conductor shifting at loc 165
KHOPOLI - DAVDI	IntraState	07/06/2023	06:55	07/06/2023	12:00	PO	Lightning spikes installation
KALWA KALYAN	IntraState	07/06/2023	21:00	08/06/2023	04:55	PO	Tower erection & conductor shifting at loc 165
BHIRA (T) - KHOPOLI 2	IntraState	08/06/2023	07:25			PO	Replacement of Porcelain LA on cable section on Tower

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage