

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Jul/2018 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	103.578	768.929	1) Gujrat	-6.438	-27.651
2) Hydro	5.222	29.100	2) Madhya Pradesh	9.357	95.237
3) Gas	8.850	61.963	3) Chattisgarh	5.180	40.180
Total MSPGCL	117.650	859.992	4) Maharashtra	102.681	692.238
B) 1) APLM	60.440	412.712	5) Goa (Amona)	-0.330	-2.816
2) JSWEL	18.554	118.396	Total	110.450	797.188
3) VIPL	7.505	44.628	a) Mumbai Schedule	26.055	161.785
4) RPL(AMT)	12.199	74.561	b) Mumbai Drawl	29.959	211.475
5) SWPGPL	2.488	17.481	c) MSEDCL Bilateral *	22.918	169.550
6) Other IPP	7.620	44.543	Include PX		

Daily and Progressive Generation,Maximum,Minimum for 07/Jul/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	8.60	62.96	390	330
Unit 10	7.56	60.11	331	270
Total	16.15	123.08		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.56	67.24	480	350
Unit 5	10.48	66.60	485	350
Total	21.04	133.84		
Parli				
Unit 6	0.00	0.00		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	103.58	768.93	MSPGCL Total	117.65	859.99
			MSPGCL Thml+Gas	112.43	830.89	Koyna 1,2 & 4 Total	1.70	12.53
			MSPGCL Hydro	5.22	29.10	State Total	292.75	2090.62

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 07/Jul/2018

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4398	308	375	5081	1264	4573	0	0	3857	3954	-1088	13784	0	13784	2276		16060	49.92
2	4331	188	357	4876	1359	4576	0	0	3795	3742	-1097	13456	0</					

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Jul/2018

Position as on 6.30 Hrs of 08/Jul/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
MSPGCL	Koyna STG-IV Unit-4	250	12/06/2018	09.40		Continued.	Annual Overhaul	
MSPGCL	Khaparkhedha Unit 5	500	20/06/2018	05.14		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 6	250	24/06/2018	18.02		Continued.	Zero Schedule(Converted for Capital overhaul from 00.00Hrs Dt. 23/07/2018)	
MSPGCL	Koradi Unit 8	660	29/06/2018	13.27		Continued.	Converted to APH from 19/07/2018	
MSPGCL	Chandrapur Unit 9	500	01/07/2018	11.35				

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Jul/2018

Position as on 6.30 Hrs of 08/Jul/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 1	210	07/07/2018	00.38	07/07/2018	06.57	Flame Failure	
MSPGCL	Khaparkheda Unit 4	210	07/07/2018	10.15		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 8	500	08/07/2018	02.25	08/07/2018	05.09	Tripping Of PA Fans.	

