

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Aug/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	127.929	838.282	1) Gujrat	12.852	72.007
2) Hydro	16.211	79.886	2) Madhya Pradesh	8.731	47.306
3) Gas	0.000	0.000	3) Chattisgarh	1.780	19.180
Total MSPGCL	144.140	918.168	4) Maharashtra	151.154	1053.284
B) 1) APLM	49.145	311.457	5) Goa (Amona)	-1.680	-11.196
2) JSWEL	13.856	100.180	Total	172.837	1180.581
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.380	241.895
4) RPL(AMT)	25.601	174.889	b) Mumbai Drawl	39.168	266.860
5) SWPGPL	6.790	46.617	c) MSEDCL Bilateral *	103.406	666.120
6) Other IPP	6.303	41.585	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.380	241.895
C) 1) TPCL Thermal	11.017	69.947	Include PX	0.000	0.000
2) TPCL Hydro	4.910	30.006	Standby	0.000	0.000
3) TPCL Gas	2.491	16.874	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.526	60.884	1) MSEDCL	434.364	2918.633
D) STATE			2) Mumbai Discoms	66.112	444.571
1) Thermal (A1+C1+C4+(B1-B6))	249.167	1643.841	3) Other Discoms	10.264	69.541
2) Hydro (A2+C2)	21.121	109.892	TOTAL STATE	510.740	3432.745
3) Gas (A3+B7+C3)	2.491	16.874			
4) Wind	54.573	411.074			
6) SOLAR	10.551	70.483			
TOTAL STATE	337.903	2252.164			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5481	5355	5267	5264
MSPGCL Hydro	358	456	1571	309
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5839	5811	6838	5573
Central Sector Receipt	9112	7935	7520	5835
WIND	2355	2538	1880	2410
CPP / IPP Thermal	4169	4028	4833	3582
CPP / IPP Gas	0	0	0	0
SOLAR	933	1192	10	0
Exchange with Mumbai	-2201	-2261	-1348	-1217
MSEDCL DEMAND MET	19749	18794	19263	15821
Load Shedding	0	0	572	0
MSEDCL DEMAND	19749	18794	19835	15821
TPCL GENERATION	637	624	1172	657
AEML GENERATION	301	428	475	298
MUMBAI DEMAND	3139	3313	2995	2172
OTHER DISCOM DEMAND	458	449	470	362
STATE DEMAND MET	23346	22556	22728	18355
STATE DEMAND	23346	22556	23300	18355
Frequency (Hz)	50.01	49.96	49.96	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 08.40 Hrs	49.77 Hz at 06.15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.96	21.22	150	90
Unit 8	13.44	87.04	605	507
Unit 9	12.06	82.85	553	410
Unit 10	0.00	0.00	0	0
Total	28.47	191.11		
Bhusawal				
Unit 3	3.04	19.96	135	110
Unit 4	9.92	59.42	450	335
Unit 5	10.12	57.18	455	370
Total	23.10	136.55		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.10	0.10	48	0
Total	0.10	0.10		
Chandrapur				
Unit 3	3.33	18.49	147	127
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.44	50.50	353	255
Unit 7	7.14	49.23	319	265
Unit 8	10.00	69.58	465	389
Unit 9	10.06	71.17	464	372
Total	37.97	258.97		
Paras				
Unit 3	5.21	31.36	227	205
Unit 4	4.81	29.68	211	190
Total	10.02	61.04		
Khaparkheda				
Unit 1	2.00	13.70	100	75
Unit 2	2.39	18.27	125	88
Unit 3	3.52	25.06	162	126
Unit 4	3.46	25.34	163	115
Unit 5	9.80	63.31	420	385
Total	21.17	145.67		
Nasik				
Unit 3	3.70	24.67	177	128
Unit 4	3.40	7.08	176	45
Unit 5	0.00	13.08	0	0
Total	7.10	44.83		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.24	7.02	52	51
Total	1.24	7.02		
Koyna				
Stage 1-2	2.92	15.10	420	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.16	6.90	674	0
Stage 3	1.70	8.10	240	0
Total	8.78	30.09		
Hydro				
KDPH	0.86	5.92	36	36
VTRNA	0.00	0.43	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.42	3.00	80	0
SMLHY_PTN	4.32	31.39	187	165
GHATGHAR	0.59	2.03	125	0
Total	6.19	42.77		
Wind				
Total	54.57	411.07	0	0
Total	54.57	411.07		
CPP				
APML(Mus)	49.14	311.46	0	0
JSWEL(Mus)	13.86	100.18	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.60	174.89	0	0
SWPGPL-Mus	6.79	46.62	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.23	34.59	259	153
Other(Mus)	1.08	6.99	0	0
Total	101.70	674.73		
SOLAR				
Total	10.55	70.48	0	0
Total	10.55	70.48		
Tata				
Trombay 5	7.38	46.79	454	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.43	9.60	108	37
Trombay 7B	1.06	7.27	64	34
TATA Hydro	4.91	30.01	383	118
Trombay 8	3.64	23.15	217	127
Total	18.42	116.83		
AEML				
DTPS U-1&2	8.53	60.88	483	295
Total	8.53	60.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	127.93	838.28	MSPGCL Total	144.14	918.17
			MSPGCL Thml+Gas	127.93	838.28	Koyna 1,2 & 4 Total	7.08	21.99
			MSPGCL Hydro	16.21	79.89	State Total	337.90	2252.16

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5357	308	0	5665	2569	3657	0	0	6054	5754	-1294	15960	0	0	15960	2336	391	18687	49.98
2	5264	309	0	5573	2410	3582	0	0	5914	5835	-1217	15821	0	0	15821	2172	362	18355	50.01
3	5187	393	0	5580	2472	3593	0	0	5855	5828	-1135	16005	0	0	16005	2055	333	18393	49.99
4	5389	387	0	5776	2543	3741	0	0	5880	5603	-1082	16245	0	0	16245	1984	336	18565	50.01
5	5314	322	0	5636	2428	3590	0	0	6447	6334	-1099	16530	0	0	16530	1989	359	18878	49.96
6	5360	360	0	5720	2333	4185	0	0	6990	7020	-1232	17637	0	0	17637	2120	389	20146	49.94
7	5407	558	0	5965	2255	4756	0	46	7792	7674	-1368	18917	0	0	18917	2285	411	21613	49.91
8	5473	532	0	6005	2192	4503	0	257	8585	8378	-1582	19310	0	0	19310	2517	443	22270	49.97
9	5534	393	0	5927	2350	4629	0	597	8673	8582	-1768	19857	0	0	19857	2855	460	23172	50.04
10	5481	358	0	5839	2355	4169	0	933	9151	9112	-2201	19749	0	0	19749	3139	458	23346	50.01
11	5312	386	0	5698	2567	3716	0	1288	9065	9011	-2398	19421	0	0	19421	3328	461	23210	49.96
12	5377	586	0	5963	2602	3685	0	1293	8633	8582	-2419	19233	0	0	19233	3386	473	23092	49.97
13	5355	456	0	5811	2538	4028	0	1192	8092	7935	-2261	18794	0	0	18794	3313	449	22556	49.96
14	5200	334	0	5534	2542	3800	0	1363	8031	7722	-2256	18265	0	0	18265	3174	440	21879	49.99
15	5382	388	0	5770	2626	4009	0	1153	7884	8070	-2270	18931	0	0	18931	3181	427	22539	49.97
16	5233	331	0	5564	2557	4272	0	1057	8201	7623	-2197	18444	0	0	18444	3149	432	22025	49.96
17	5176	625	0	5801	2325	4318	0	748	7863	7503	-2020	18214	0	0	18214	3121	461	21796	49.98
18	5150	1053	0	6203	2092	4582	0	447	7485	7255	-1816	18307	0	0	18307	3093	456	21856	49.97
19	5142	1407	0	6549	1818	4755	0	167	7769	7627	-1744	18704	0	0	18704	3007	468	22179	50.00
20	5267	1571	0	6838	1880	4833	0	10	7162	7520	-1348	19263	572	0	19835	2995	470	23300	49.96
21	5333	1657	0	6990	1711	4830	0	0	6644	6528	-1203	18411	686	0	19097	2881	445	22423	50.05
22	5412	1325	0	6737	1750	4831	0	0	6372	6196	-1146	17919	33	0	17952	2766	449	21167	50.03
23	5434	1230	0	6664	1858	4816	0	0	5986	5698	-1101	17500	0	0	17500	2676	435	20611	50.04
24	5390	942	0	6332	1800	4815	0	0	5669	5447	-1011	16927	0	0	16927	2590	456	19973	50.03
MUs	127.93	16.21	0.00	144.14	54.57	101.69	0.00	10.55	176.20	172.84	-39.17	434.36	1.29	0.00	435.65	66.11	10.26	512.03	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 07/Aug/2023

Position as on 6.30 Hrs of 08/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00	08/08/2023	10:24	Annual Overhaul	08/08/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
IPP	SWPGPL U-3	135	21/07/2023	01:54		Continued.	Non-availability of linkage coal stock and due to continuous rains.	07/08/2023
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	DUE TO HPT DIFFERENTIAL EXPANSION ON HIGHER SIDE	22/08/2023
MSPGCL	Uran Unit 6	108	27/07/2023	20:10		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	28/07/2023	15:30	07/08/2023	20:57	Zero Schedule.	
MSPGCL	Parli Unit 8	250	28/07/2023	21:07	07/08/2023	20:57	Zero Schedule.	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	12/08/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Aug/2023

Position as on 6.30 Hrs of 08/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00		Continued.	ID Fan Problem.	09/08/2023
IPP	RPL(AMT) U-3	270	05/08/2023	19:07		Continued.	Due to TG shaft vibration high.	09/08/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 08/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20	08/08/2023	10:24	PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
765/400kV 1500 MVA ICT-1 @ EKTUNI	IntraState	08/08/2023	16:05			PO	Diagnostic testing
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	04/08/2023	09:22			PO	400 kV 125 MVar Bus Reactor to be kept OFF during Outage on 400 kV Bus-2 as it is connected to 400 kV Bus-2
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - KHANDWA CKT - 1	InterState	07/08/2023	10:35	07/08/2023	11:51	PO	TO REMOVE LINE REACTOR AT KHANDWA END.
DHULE - KHANDWA CKT - 1	InterState	07/08/2023	21:33	07/08/2023	23:26	HT	For retrofitting work of Line reactor at Khandwa end
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ȳȳ phase Protection CT Of NTPP I (RPL 1)
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03			PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	06/08/2023	21:02	07/08/2023	07:28	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 1	IntraState	06/08/2023	21:04	07/08/2023	08:08	HT	H/T on overvoltage
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	07/08/2023	08:46	07/08/2023	18:29	PO	Pending work related to work done by project division at Loc. No. 154
KHADKA-AURANGABAD (WALUJ)	IntraState	07/08/2023	20:24	08/08/2023	06:36	HT	H/T on overvoltage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44			PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	06/08/2023	09:44			PO	Cooling System Renovation, commissioning, HV CB timing/DCRM,SFRA,REF,NDR relay & bay Maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 08/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	07/08/2023	09:03	07/08/2023	15:01	PO	(1)ICT-1 B ph unit RPRR relay inspection/ repairing work by representative of M/s CTR,Pune. 2) 220kV side CT tan delta & CB diagnostic testing work.
400/220/33 KV 500 MVA ICT - 3 @ DHULE	IntraState	07/08/2023	12:20	07/08/2023	18:23	PO	Pending work of RRS scheme for 501 MVA ICT-3
400/220KV 167 MVA SPARE ICT @ DHULE	IntraState	07/08/2023	12:40	07/08/2023	18:37	PO	Pending work of RRS scheme for 501 MVA ICT-3
400/220 KV 500 MVA ICT @ ALKUD	IntraState	08/08/2023	10:35			PO	For routine maintenance & diagnostic testing work
220 KV TIEBAY Outages/Trippings							
TBC @ PHURSUNGI	IntraState	07/08/2023	11:50	07/08/2023	13:12	PO	Half yearly Maint., CT tan Delta and C measurement.
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	07/08/2023	11:05	07/08/2023	20:18	PO	AMP WORK AT PGCIL END.
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	07/08/2023	11:05	07/08/2023	20:18	PO	AMP as per Maintenance schedule
PANCHALI TSS - BOISAR (PG)	InterState	07/08/2023	14:26	07/08/2023	20:11	PO	AMP WORKS
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
BOMBAY DYEING - SAHARA	IntraState	03/08/2023	12:24			T	Tripped on distance protection
APTA - BOMBAY DYEING	IntraState	03/08/2023	12:24			T	Tripped on distance protection
URAN - APTA 2	IntraState	07/08/2023	08:59	07/08/2023	12:15	PO	Replacement of damaged Jumper at loc no 42. Replacement of flashover polymer insulator at Loc no. 60
220 KV GIRWALI (400 KV) -PARLI U -8 CKT	IntraState	07/08/2023	10:42	07/08/2023	20:46	PO	FOR REPLACEMENT OF Y AND B PH.
VIRUR - VIRUR RLY TSS 2	IntraState	07/08/2023	10:55	07/08/2023	13:05	PO	YEARLY MAINTENANCE BY RAILWAY AUTHORITY AT THEIR END.
132 KV PADEGAON (220 KV) - GARWARE CKT	IntraState	07/08/2023	12:02	07/08/2023	16:37	PO	FOR REPLACEMENT OF DAMAGED Y PH OUTGOING T CONNECTOR CAUSING HOT SPOT
URAN - KHARGHAR 1	IntraState	07/08/2023	13:57	07/08/2023	16:51	PO	Replacement of damaged Jumper at loc no 18 Top phase)
132 KV PADEGAON (220 KV) - PAITHAN CKT	IntraState	07/08/2023	14:37	07/08/2023	15:17	PO	TO REMOVE THE BIRD NEST FROM THE 132KV PAITHAN LINE O/G GANTRY.
VIRUR - VIRUR RLY TSS 1	IntraState	07/08/2023	15:00	07/08/2023	16:55	PO	WORK AT TSS END.
132 KV JAFRABAD - BHOKARDAN CKT	IntraState	07/08/2023	16:32	07/08/2023	17:35	PO	WORK FOR MANGO TREE CUTTING BETWEEN LOC. NO. 66-67 WHICH IS IN INDUCTION ZONE OF LINE.
TROMBAY - SALSETTE CKT - 1	IntraState	07/08/2023	23:20	08/08/2023	08:18	PO	- Loop closing at loc. 48 for making "T" connection on 220 kV Trombay Salsette 1 Line for soak test of 220 kV cable and 220 kV GIS at 400 kV KVTL Vikhroli S/S
KHAREPATAN -PAWAS LINE	IntraState	08/08/2023	10:13	08/08/2023	17:02	PO	Auto-Reclose Relay configuration and Relay testing for 220kV Pawas-Kharepatan Line at 220kV Kharepatan S/s.
LONAND-PHALTAN MIDC	IntraState	08/08/2023	11:37	08/08/2023	14:40	PO	TBC Wiring & Testing Work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 08/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/110kV 100MVA ICT - 3 @ PETH	IntraState	07/08/2023	09:00	07/08/2023	14:43	PO	SFRA Testing Work
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	07/08/2023	09:12	07/08/2023	15:19	PO	"1) Attending OLTC Testing work. 2) Verification of Oil leakage from OLTC tank. 3) Attending QMW Maint Work. "
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	IntraState	07/08/2023	15:29	07/08/2023	18:06	PO	1)Quarterly bay maintenance work 2) Attending OLTC Testing work.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage