

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 07/Aug/2024 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 120.113        | 840.440         | 1) Gujrat                      | 7.375          | 40.127          |
| 2) Hydro            | 19.708         | 80.540          | 2) Madhya Pradesh              | 6.056          | 17.838          |
| 3) Gas              | 6.716          | 40.994          | 3) Chattisgarh                 | 2.720          | 21.870          |
| <b>Total MSPGCL</b> | <b>146.537</b> | <b>961.974</b>  | 4) Maharashtra                 | 165.071        | 1086.622        |
| B) 1) APML          | 50.212         | 310.951         | 5) Goa (Amona)                 | -1.906         | -13.230         |
| 2) JSWEL            | 20.424         | 137.434         | <b>Total</b>                   | <b>179.316</b> | <b>1153.227</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 36.000         | 275.615         |
| 4) RPL(AMT)         | 16.265         | 111.960         | b) Mumbai Drawl                | 40.620         | 303.801         |
| 5) SWPGPL           | 9.215          | 60.511          | c) MSEDCL Bilateral *          | 78.371         | 633.021         |
| 6) Other IPP        | 11.541         | 75.498          | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 36.000         | 275.573         |
| C) 1) TPCL Thermal  | 11.440         | 49.889          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 6.226          | 40.179          | Standby                        | 0.000          | 0.042           |
| 3) TPCL Gas         | 3.365          | 21.754          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 7.193          | 49.943          | 1) MSEDCL                      | 426.299        | 2862.494        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 68.844         | 465.566         |
| 1) Thermal          | 246.403        | 1636.626        | 3) Other Discoms               | 11.155         | 77.777          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>506.298</b> | <b>3405.837</b> |
| 2) Hydro            | 25.934         | 120.719         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 10.081         | 62.748          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 32.998         | 346.414         |                                |                |                 |
| 6) SOLAR            | 11.566         | 86.103          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>326.982</b> | <b>2252.610</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 10 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5285                      | 4796                  | 4791                      | 5323                      |
| MSPGCL Hydro               | 1161                      | 334                   | 2125                      | 249                       |
| MSPGCL Gas                 | 277                       | 276                   | 366                       | 213                       |
| MSPGCL Total Generation    | 6723                      | 5406                  | 7282                      | 5785                      |
| Central Sector Receipt     | 8355                      | 8357                  | 8103                      | 5751                      |
| WIND                       | 1112                      | 1753                  | 1623                      | 1342                      |
| CPP / IPP Thermal          | 4635                      | 4547                  | 4758                      | 4421                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1148                      | 383                   | 0                         | 0                         |
| Exchange with Mumbai       | -2045                     | -2089                 | -1679                     | -1101                     |
| <b>MSEDCL DEMAND MET</b>   | <b>19428</b>              | <b>17846</b>          | <b>19585</b>              | <b>15816</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 19428                     | 17846                 | 19585                     | 15816                     |
| TPCL GENERATION            | 886                       | 858                   | 1163                      | 748                       |
| AEML GENERATION            | 308                       | 295                   | 312                       | 286                       |
| <b>MUMBAI DEMAND</b>       | <b>3239</b>               | <b>3242</b>           | <b>3154</b>               | <b>2135</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>500</b>                | <b>511</b>            | <b>502</b>                | <b>382</b>                |
| STATE DEMAND MET           | 23167                     | 21599                 | 23241                     | 18333                     |
| <b>STATE DEMAND</b>        | <b>23167</b>              | <b>21599</b>          | <b>23241</b>              | <b>18333</b>              |
| Frequency (Hz)             | 50.01                     | 49.93                 | 50.01                     | 49.91                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.22 Hz at 12.05 Hrs | 49.8 Hz at 02.16 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 07/Aug/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 2.04         | 12.81         | 146      | 0        |
| Unit 8             | 10.14        | 73.58         | 580      | 300      |
| Unit 9             | 10.36        | 72.35         | 510      | 365      |
| Unit 10            | 10.79        | 74.95         | 530      | 368      |
| <b>Total</b>       | <b>33.33</b> | <b>233.69</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 1.57         | 14.91         | 90       | 25       |
| Unit 4             | 7.20         | 51.33         | 375      | 275      |
| Unit 5             | 7.06         | 51.30         | 370      | 275      |
| <b>Total</b>       | <b>15.83</b> | <b>117.54</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 10.63         | 0        | 0        |
| Unit 7             | 3.72         | 25.26         | 191      | 126      |
| Unit 8             | 3.78         | 24.52         | 208      | 141      |
| <b>Total</b>       | <b>7.50</b>  | <b>60.42</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.44         | 17.74         | 120      | 78       |
| Unit 4             | 2.78         | 18.24         | 142      | 66       |
| Unit 5             | 6.82         | 42.98         | 325      | 250      |
| Unit 6             | 6.19         | 39.61         | 290      | 180      |
| Unit 7             | 6.96         | 43.65         | 322      | 244      |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 8.75         | 57.54         | 426      | 289      |
| <b>Total</b>       | <b>33.94</b> | <b>219.76</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.60         | 28.61         | 219      | 151      |
| <b>Total</b>       | <b>4.60</b>  | <b>28.61</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.62         | 18.32         | 130      | 80       |
| Unit 2             | 3.18         | 20.97         | 168      | 112      |
| Unit 3             | 3.23         | 22.06         | 148      | 122      |
| Unit 4             | 3.45         | 24.15         | 177      | 126      |
| Unit 5             | 7.84         | 58.56         | 440      | 280      |
| <b>Total</b>       | <b>20.33</b> | <b>144.06</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 2.39         | 20.12         | 116      | 79       |
| Unit 5             | 2.19         | 16.25         | 111      | 71       |
| <b>Total</b>       | <b>4.58</b>  | <b>36.37</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.72         | 40.99         | 373      | 137      |
| <b>Total</b>       | <b>6.72</b>  | <b>40.99</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.18         | 7.84          | 51       | 47       |
| <b>Total</b>       | <b>1.18</b>  | <b>7.84</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 3.84         | 15.60         | 450      | 40       |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 4         | 7.53          | 14.43         | 1022     | 0        |
| Stage 3         | 2.64          | 9.92          | 320      | 0        |
| <b>Total</b>    | <b>14.01</b>  | <b>39.95</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.86          | 6.05          | 36       | 36       |
| VTRNA           | 0.00          | 1.28          | 0        | 0        |
| TILLARI         | 0.20          | 5.80          | 55       | 0        |
| BHIRA T.R.      | 0.36          | 2.50          | 60       | 0        |
| SMLHY_PTN       | 3.61          | 22.42         | 154      | 146      |
| GHATGHAR        | 0.67          | 2.54          | 125      | 0        |
| <b>Total</b>    | <b>5.70</b>   | <b>40.59</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 33.00         | 346.41        | 0        | 0        |
| <b>Total</b>    | <b>33.00</b>  | <b>346.41</b> |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 50.21         | 310.95        | 0        | 0        |
| JSWEL(Mus)      | 20.42         | 137.43        | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 16.26         | 111.96        | 0        | 0        |
| SWPGPL-Mus      | 9.22          | 60.51         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00          | 0        | 0        |
| IEPL            | 5.80          | 35.30         | 268      | 167      |
| Other(Mus)      | 1.23          | 8.68          | 0        | 0        |
| JPL             | 4.51          | 31.52         | 253      | 160      |
| <b>Total</b>    | <b>107.66</b> | <b>696.35</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 11.57         | 86.10         | 0        | 0        |
| <b>Total</b>    | <b>11.57</b>  | <b>86.10</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 7.60          | 21.67         | 416      | 246      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 2.00          | 12.75         | 108      | 57       |
| Trombay 7B      | 1.36          | 9.01          | 64       | 48       |
| TATA Hydro      | 6.23          | 40.18         | 391      | 132      |
| Trombay 8       | 3.84          | 28.22         | 231      | 132      |
| <b>Total</b>    | <b>21.03</b>  | <b>111.82</b> |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 7.19          | 49.94         | 312      | 282      |
| <b>Total</b>    | <b>7.19</b>   | <b>49.94</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 120.11      | 840.44        | MSPGCL Total        | 146.54      | 961.97        |
|                |             |         | MSPGCL Thml+Gas | 126.83      | 881.43        | Koyna 1,2 & 4 Total | 11.36       | 30.03         |
|                |             |         | MSPGCL Hydro    | 19.71       | 80.54         | State Total         | 326.98      | 2252.61       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 07/Aug/2024

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |       | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 5201        | 225   | 137  | 5563   | 1623  | 4405      | 0    | 0     | 6459     | 6164     | -1283          | 16037            | 0             | 0                        | 16037                | 2466          | 435                 | 18938        | 49.95      |
| 2            | 5230        | 298   | 167  | 5695   | 1471  | 4406      | 0    | 0     | 6203     | 6109     | -1188          | 16074            | 0             | 0                        | 16074                | 2269          | 419                 | 18762        | 49.95      |
| 3            | 5323        | 249   | 213  | 5785   | 1342  | 4421      | 0    | 0     | 6136     | 5751     | -1101          | 15816            | 0             | 0                        | 15816                | 2135          | 382                 | 18333        | 49.91      |
| 4            | 5239        | 233   | 275  | 5747   | 1253  | 4407      | 0    | 0     | 6119     | 6048     | -1029          | 16066            | 0             | 0                        | 16066                | 2056          | 360                 | 18482        | 49.94      |
| 5            | 5326        | 264   | 277  | 5867   | 1268  | 4624      | 0    | 0     | 6267     | 6366     | -1066          | 16685            | 0             | 0                        | 16685                | 2046          | 374                 | 19105        | 50.01      |
| 6            | 5257        | 857   | 280  | 6394   | 1277  | 4714      | 0    | 0     | 6725     | 6935     | -1145          | 17770            | 0             | 0                        | 17770                | 2166          | 405                 | 20341        | 50.01      |
| 7            | 5124        | 1783  | 344  | 7251   | 1254  | 4650      | 0    | 60    | 7315     | 7545     | -1274          | 19027            | 0             | 0                        | 19027                | 2354          | 459                 | 21840        | 49.99      |
| 8            | 5157        | 2047  | 308  | 7512   | 1007  | 4660      | 0    | 303   | 7737     | 8017     | -1545          | 19483            | 444           | 0                        | 19927                | 2582          | 471                 | 22980        | 50.01      |
| 9            | 5210        | 2012  | 281  | 7503   | 1072  | 4625      | 0    | 666   | 7895     | 7900     | -1788          | 19471            | 21            | 0                        | 19492                | 2931          | 507                 | 22930        | 50.01      |
| 10           | 5285        | 1161  | 277  | 6723   | 1112  | 4635      | 0    | 1148  | 8444     | 8355     | -2045          | 19428            | 0             | 0                        | 19428                | 3239          | 500                 | 23167        | 50.01      |
| 11           | 5009        | 416   | 279  | 5704   | 1263  | 4488      | 0    | 1478  | 8919     | 8630     | -2303          | 18752            | 0             | 0                        | 18752                | 3443          | 508                 | 22703        | 50.04      |
| 12           | 4913        | 282   | 277  | 5472   | 1259  | 4300      | 0    | 1436  | 8478     | 8585     | -2319          | 18234            | 0             | 0                        | 18234                | 3475          | 499                 | 22208        | 50.05      |
| 13           | 4737        | 323   | 273  | 5333   | 1159  | 4038      | 0    | 1375  | 8208     | 8214     | -2247          | 17387            | 0             | 0                        | 17387                | 3419          | 485                 | 21291        | 50.04      |
| 14           | 4605        | 300   | 274  | 5179   | 1170  | 3716      | 0    | 1342  | 8403     | 8492     | -2232          | 17201            | 0             | 0                        | 17201                | 3311          | 466                 | 20978        | 50.04      |
| 15           | 4615        | 299   | 275  | 5189   | 1530  | 3939      | 0    | 1421  | 8460     | 7952     | -2244          | 17324            | 0             | 0                        | 17324                | 3341          | 463                 | 21128        | 50.05      |
| 16           | 4631        | 336   | 276  | 5243   | 1637  | 4025      | 0    | 1096  | 8343     | 8040     | -2265          | 17281            | 0             | 0                        | 17281                | 3360          | 496                 | 21136        | 50.03      |
| 17           | 4851        | 244   | 275  | 5370   | 1834  | 4506      | 0    | 786   | 8293     | 7914     | -2192          | 17721            | 0             | 0                        | 17721                | 3301          | 497                 | 21519        | 49.95      |
| 18           | 4796        | 334   | 276  | 5406   | 1753  | 4547      | 0    | 383   | 8658     | 8357     | -2089          | 17846            | 0             | 0                        | 17846                | 3242          | 511                 | 21599        | 49.93      |
| 19           | 4831        | 1449  | 278  | 6558   | 1695  | 4697      | 0    | 72    | 8384     | 7968     | -1762          | 18709            | 0             | 0                        | 18709                | 3200          | 519                 | 22428        | 50.00      |
| 20           | 4791        | 2125  | 366  | 7282   | 1623  | 4758      | 0    | 0     | 7957     | 8103     | -1679          | 19585            | 0             | 0                        | 19585                | 3154          | 502                 | 23241        | 50.01      |
| 21           | 4899        | 2049  | 373  | 7321   | 1420  | 4790      | 0    | 0     | 7155     | 7204     | -1502          | 18729            | 0             | 0                        | 18729                | 3018          | 504                 | 22251        | 50.05      |
| 22           | 5010        | 1572  | 363  | 6945   | 1334  | 4790      | 0    | 0     | 6895     | 6688     | -1414          | 17849            | 0             | 0                        | 17849                | 2880          | 494                 | 21223        | 49.98      |
| 23           | 5068        | 615   | 290  | 5973   | 1321  | 4751      | 0    | 0     | 7031     | 7078     | -1446          | 17223            | 0             | 0                        | 17223                | 2766          | 454                 | 20443        | 50.03      |
| 24           | 5005        | 235   | 282  | 5522   | 1321  | 4765      | 0    | 0     | 6946     | 6901     | -1462          | 16601            | 0             | 0                        | 16601                | 2690          | 446                 | 19737        | 50.05      |
| MUs          | 120.11      | 19.71 | 6.72 | 146.54 | 33.00 | 107.66    | 0.00 | 11.57 | 181.43   | 179.32   | -40.62         | 426.30           | 0.47          | 0.00                     | 426.76               | 68.84         | 11.16               | 506.76       | 50.00      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 07/Aug/2024**

Position as on 6.30 Hrs of 08/Aug/2024

| Generating Company             | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|--------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Paras Unit 3            | 250      | 30/06/2024   | 22:35        |            | Continued. | Annual Overhaul                                                                                                                                         | 14/08/2024    |
| MSPGCL                         | Koyna Unit 5            | 80       | 02/07/2024   | 11:00        |            | Continued. | PLC upgradation work                                                                                                                                    | 09/08/2024    |
| MSPGCL                         | Chandrapur Unit 8       | 500      | 19/07/2024   | 11:42        |            | Continued. | Annual Overhaul                                                                                                                                         | 10/08/2024    |
| MSPGCL                         | Parli Unit 6            | 250      | 04/08/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 25/08/2024    |
| Total Capacity MSPGCL          |                         | 1080     |              |              |            |            |                                                                                                                                                         |               |
| IPP                            |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                            | RPL(AMT) U-1            | 270      | 01/07/2024   | 07:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 09/08/2024    |
| IPP                            | Adani U-2               | 660      | 15/07/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 09/08/2024    |
| IPP                            | SWPGPL U-2              | 135      | 01/08/2024   | 01:50        |            | Continued. | Annual Overhaul                                                                                                                                         | 25/08/2024    |
| Total Capacity IPP             |                         | 1065     |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE  |                         | 2145     |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/08/2024    |
| MSPGCL                         | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/08/2024    |
| MSPGCL                         | Koradi Unit 6           | 210      | 05/08/2024   | 08:47        | 07/08/2024 | 06:05      | Boiler Tube Leakage                                                                                                                                     | 08/08/2024    |
| MSPGCL                         | Uran Unit 8             | 108      | 06/08/2024   | 20:21        | 07/08/2024 | 01:19      | NG (Gas) controller system protection                                                                                                                   | 07/08/2024    |
| Total Capacity MSPGCL          |                         | 563      |              |              |            |            |                                                                                                                                                         |               |
| IPP                            |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                            | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 15/08/2024    |
| Total Capacity IPP             |                         | 270      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                    |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                    | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                    | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/11/2024    |
| Total Capacity CENT.SECTOR     |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE   |                         | 1153     |              |              |            |            |                                                                                                                                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Uran Unit 5             | 108      | 31/07/2024   | 17:38        |            | Continued. | Zero Schedule given by MSEDCL                                                                                                                           |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 07/Aug/2024**

**Position as on 6.30 Hrs of 08/Aug/2024**

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                            | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------------------------------|---------------|
| MSPGCL                                        | Uran Unit 6             | 108      | 06/08/2024   | 20:32        | 07/08/2024 | 06:13      | Zero Schedule given by MSEDCL                               |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 07/08/2024   | 07:29        | 07/08/2024 | 18:57      | Zero Schedule given by MSEDCL                               |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 07/08/2024   | 22:05        | 08/08/2024 | 05:53      | ZERO SCHEDULE BY MSEDCL                                     |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 08/08/2024   | 08:00        |            | Continued. | Zero Schedule Given By MSEDCL.                              |               |
| Total Capacity MSPGCL                         |                         | 540      |              |              |            |            |                                                             |               |
| IPP                                           |                         |          |              |              |            |            |                                                             |               |
| IPP                                           | JSW (J) U2              | 300      | 01/07/2024   | 01:12        |            | Continued. | Non availability of load schedule                           |               |
| Total Capacity IPP                            |                         | 300      |              |              |            |            |                                                             |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 840      |              |              |            |            |                                                             |               |
| UNIT OUT ON TOLLING *                         |                         |          |              |              |            |            |                                                             |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                             |               |
| MSPGCL                                        | Nasik Unit 3            | 210      | 20/07/2024   | 21:18        |            | Continued. | ID Fan Motor Problem. (Tolling from 11:50 hrs dtd 21.07.24) |               |
| Total Capacity MSPGCL                         |                         | 210      |              |              |            |            |                                                             |               |
| Total Capacity UNIT OUT ON TOLLING *          |                         | 210      |              |              |            |            |                                                             |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                                             |               |
| IPP                                           |                         |          |              |              |            |            |                                                             |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                        |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                        |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                     |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                      |               |
| Total Capacity IPP                            |                         | 988      |              |              |            |            |                                                             |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |            |            |                                                             |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 08/Aug/2024

| Name of Line                                                     | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                 |
|------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV MAINBAY Outages/Trippings</b>                          |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2                       | IntraState                | 07/08/2024   | 11:21        | 07/08/2024 | 15:13      | PO          | SF6 analysis of BAY 707                                                                                                                                                                                                                                                          |
| <b>400 KV LINE Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| BUS REACTOR (50MVAR) @ PARLI                                     | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.                                                                                                                                                                                                              |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                              | IntraState                | 27/07/2024   | 11:42        | 07/08/2024 | 18:46      | HT          | For load management .                                                                                                                                                                                                                                                            |
| KHADKA-AURANGABAD (WALUJ)                                        | IntraState                | 05/08/2024   | 20:03        |            |            | HT          | HT for Overvoltage Control                                                                                                                                                                                                                                                       |
| JAIGAD - KARAD CKT - 1                                           | IntraState                | 07/08/2024   | 01:52        | 07/08/2024 | 08:16      | HT          | HT for Overvoltage Control                                                                                                                                                                                                                                                       |
| DABHOL - NEW KOYNA CKT - 1                                       | IntraState                | 07/08/2024   | 09:05        | 07/08/2024 | 16:29      | PO          | PLCC Panel Replacement work                                                                                                                                                                                                                                                      |
| JAIGAD - KARAD CKT - 2                                           | IntraState                | 07/08/2024   | 21:26        | 08/08/2024 | 07:26      | HT          | H/T on overvoltage                                                                                                                                                                                                                                                               |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                              | IntraState                | 08/08/2024   | 07:23        |            |            | HT          | H/T for load Management.                                                                                                                                                                                                                                                         |
| LONIKAND - JEJURI CKT - 1                                        | IntraState                | 08/08/2024   | 11:18        |            |            | PO          | DT, Bay and Line Maintenance activities @ Lonikand I & Relay Retrofitting work by G.E @ Jejuri                                                                                                                                                                                   |
| <b>400 KV ICT Outages/Trippings</b>                              |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| STATION TF No 3 @ CHANDRAPUR GCR                                 | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                   |
| 400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS                         | IntraState                | 10/02/2024   | 17:40        |            |            | HT          | H/T For LV only.                                                                                                                                                                                                                                                                 |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                              | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                                                          |
| 400KV/21KV GT-2 @ TIRODA                                         | IntraState                | 15/07/2024   | 09:02        |            |            | PO          | GT-2 Maintenance, testing and painting work. Main bay and Tie bay equipment maintenance work                                                                                                                                                                                     |
| 400/220/33 KV 315 MVA ICT - 1 @ LONIKAND                         | IntraState                | 07/08/2024   | 19:30        | 07/08/2024 | 23:16      | EO          | For inspection/ checking of Fire detector trip cable of 400/220/33 kV 3*105 MVA ICT-1 - Y ph Unit                                                                                                                                                                                |
| <b>400 KV BUSBAR Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| PUNE-GIS - 400KV - BUS 2                                         | InterState                | 05/08/2024   | 11:59        | 07/08/2024 | 18:09      | PO          | Subject to limit the Main bay connected to 400kV BUS_1 current would not more than 1550A due to twin moose thermal limit                                                                                                                                                         |
| 400KV BUS BAR PROTECTION SCHEME @ WARORA                         | InterState                | 07/08/2024   | 11:41        | 07/08/2024 | 18:06      | PO          | For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works                                                                                                                                                                                                                |
| <b>220 KV MAINBAY Outages/Trippings</b>                          |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| MAIN BAY(201) OF 220KV-SOLAPUR-NARANGWADI-1 @SOLAPUR (PG)-220 KV | InterState                | 29/07/2024   | 09:04        |            |            | PO          | Bay AMP Works<br>Note : 220kV Narangwadi-1 line shall be in service via TBC.                                                                                                                                                                                                     |
| 220KV BUS SECTION BAY @ PEDAMBE                                  | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                     |
| <b>220 KV LINE Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| BALE - SOLAPUR (PG)                                              | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37) |
| NARANGWADI - SOLAPUR PG CKT - 2                                  | InterState                | 07/08/2024   | 09:25        | 07/08/2024 | 18:27      | PO          | Line terminal equipments AMP at 765kV Solapur Substation                                                                                                                                                                                                                         |
| EKLAHARE (OCR) - NAVASARI CKT - 2                                | IntraState                | 17/06/2024   | 12:50        | 08/08/2024 | 09:53      | HT          | For load management                                                                                                                                                                                                                                                              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 08/Aug/2024

| Name of Line                                    | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                           |
|-------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| OSMANABAD - SOLAPUR (BALE)                      | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                              |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2           | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                                                                                        |
| SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 2 | IntraState                | 23/07/2024   | 10:04        |            |            | PO          | Replacement of existing conductor of 220 kV PGCIL-South Solapur Ckt-II with HTLS Conductor & OPGW.                                                                                                                                                                                                                                                         |
| GHODBUNDER - GORAI                              | IntraState                | 29/07/2024   | 12:14        |            |            | PO          | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                                                                                                        |
| PADGHE - TEMGHAR - 1                            | IntraState                | 05/08/2024   | 06:45        | 08/08/2024 | 01:27      | PO          | 1) 220 kV Padghe & Temghar line 1 CB and Line isolator replacement and wave trap erection work under bay strengthening scheme. 2) Also, work of height raising & shifting of line by erecting 04 nos. Monopoles in b/w existing loc. No. 66-69 due to infringement of Vadodara-Mumbai Expressway SPUR will be carried out by Line maintenance S/Dn , Kalwa |
| EKLAHARE (OCR) - PADGHE                         | IntraState                | 05/08/2024   | 08:21        |            |            | HT          | for load management                                                                                                                                                                                                                                                                                                                                        |
| BORIVALI - CTRLS CKT                            | IntraState                | 06/08/2024   | 22:24        | 07/08/2024 | 04:25      | PO          | For the installation of saver assembly sets at TL no. 27/3, 28 & 43 (Total 9 sets out of 60 sets are to be installed) Total Completed - 36 sets.                                                                                                                                                                                                           |
| KALWA - PAWANE                                  | IntraState                | 06/08/2024   | 22:30        | 07/08/2024 | 05:03      | PO          | For the installation of saver assembly sets at TL no. 27/3, 28 & 43 (Total 9 sets out of 24 sets are to be installed) Total completed - 15 sets                                                                                                                                                                                                            |
| ALEPHATA-PARGAON(KATHAPUR)                      | IntraState                | 07/08/2024   | 09:21        | 07/08/2024 | 19:25      | HT          | Load management                                                                                                                                                                                                                                                                                                                                            |
| VIRUR - VIRUR RLY TSS 2                         | IntraState                | 07/08/2024   | 09:39        | 08/08/2024 | 06:08      | PO          | 1) FOR DIAGNOSTIC TESTING WORK AT 220 KV VIRUR END. 2) DURING OUTAGE PERIOD FLASHOVER DISC REPLACEMENT AT LOC NO. 06 BY AGENCY M/S. R. P. POWER PUNE, WILL BE CARRIED OUT BY ADDL.EE, L.M. S/DN-I BALALRSHAH BEING IN OPPORTUNITY OUTAGE PERIOD.                                                                                                           |
| PARLI NEW TPS - BEED CKT 1                      | IntraState                | 07/08/2024   | 11:52        | 07/08/2024 | 14:23      | EO          | FOR ATTENDING WORK OF R-PH CT JUMP LOOKING STRANDS LOSEN AND BROKEN                                                                                                                                                                                                                                                                                        |
| WALCHANDNAGAR-CSSK BHAVANI NAGAR                | IntraState                | 07/08/2024   | 12:01        | 07/08/2024 | 15:10      | PO          | Quarterly Maintenance, Diagnostic testing Work                                                                                                                                                                                                                                                                                                             |
| EKLAHARA(OCR)-RAYMOND                           | IntraState                | 07/08/2024   | 16:45        | 08/08/2024 | 05:38      | HT          | For load management                                                                                                                                                                                                                                                                                                                                        |
| TROMBAY - VIKHROLI (GIS) CKT - 2                | IntraState                | 07/08/2024   | 23:51        | 08/08/2024 | 06:08      | PO          | NILL                                                                                                                                                                                                                                                                                                                                                       |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Aug/2024**

**Statement-VII**

Position as on 6.30 Hrs of 08/Aug/2024

| Name of Line                                | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                  |
|---------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7 | IntraState                | 08/08/2024   | 00:12        | 08/08/2024 | 06:08      | PO          | Project Work in vicinity to Metro 4 Girder erection work between CP-184 to CP-185 at Sahakar Plaza, Ghatkopar by Metro Team.                                                                                                      |
| KARANJADE - WAGHIVALI 7                     | IntraState                | 08/08/2024   | 00:27        | 08/08/2024 | 05:18      | PO          | PROTECTION TESTING                                                                                                                                                                                                                |
| ALEPHATA-PARGAON(KATHAPUR)                  | IntraState                | 08/08/2024   | 07:11        | 08/08/2024 | 12:02      | HT          | H/T for load Management.                                                                                                                                                                                                          |
| HALKARNI-MAHALAXMI LINE                     | IntraState                | 08/08/2024   | 08:27        |            |            | PO          | OPGW stringing work                                                                                                                                                                                                               |
| OSMANABAD - PARLY (PG)                      | IntraState                | 08/08/2024   | 08:28        |            |            | PO          | FOR AMP WORK                                                                                                                                                                                                                      |
| AMRAPUR - TAPTITANDA CKT - 2                | IntraState                | 08/08/2024   | 12:02        |            |            | PO          | R-Ph Insulator string found broken at Loc No. 36                                                                                                                                                                                  |
| RANJANGAON-LONIKAND                         | IntraState                | 08/08/2024   | 12:27        |            |            | PO          | To carryout the work of replacement of midspan joint at loc no. 372 Y Ph Conductors between Loc No 372(D/C)-11(M/C) of 220kV Ranjangaon-Lonikand II Line.                                                                         |
| PARGAON( KATHAPUR)-LONIKAND                 | IntraState                | 08/08/2024   | 12:35        |            |            | PO          | To carryout the work of replacement of midspan joint at loc no. 372 Y Ph Conductors between Loc No 372(D/C)-11(M/C) of 220kV Ranjangaon-Lonikand II Line. so in view of safety 220kV Kathapur-Lonikand line needs to be kept off. |
| <b>220 KV ICT Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                   |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR      | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.                                                                                                                                                               |
| 220/100 KV 100 MVA ICT 1 @ KANDALGAON       | IntraState                | 15/07/2024   | 05:28        |            |            | T           | Differential Protection                                                                                                                                                                                                           |
| 220/22-22 KV 80 MVA PTR 2 @ COLOURCHEM      | IntraState                | 18/07/2024   | 14:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                               |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2            | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                                                                       |
| 220/132KV 200 MVA ICT 1 @ KANHAN            | IntraState                | 07/08/2024   | 09:55        | 07/08/2024 | 14:58      | PO          | RAPID PRESSURE RISE RELAY (RPRR ) RECTIFICATION WORK BYAGENCY M/S CTR AND ROUTINUE MAINTENANCE WORK                                                                                                                               |
| 220/132 KV 200 MVA ICT - 2 @ CHINCHWAD 2    | IntraState                | 08/08/2024   | 09:14        |            |            | PO          | 1) Replacement of HV ERL back up protection relay.<br>2) To attend false indication 'Fire Detector trip' received on CTR NIFPS panel by CTR team.<br>3) Diagnostic testing & half yearly maintenance.                             |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage