

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Sep/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	119.547	887.095	1) Gujrat	6.027	58.991
2) Hydro	17.478	101.756	2) Madhya Pradesh	0.204	21.891
3) Gas	2.668	26.468	3) Chattisgarh	3.880	23.760
Total MSPGCL	139.693	1015.319	4) Maharashtra	167.232	1169.532
B) 1) APLM	70.841	462.359	5) Goa (Amona)	-1.149	-6.768
2) JSWEL	18.194	137.771	Total	176.194	1267.406
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.647	236.044
4) RPL(AMT)	19.302	100.285	b) Mumbai Drawl	37.155	260.487
5) SWPGPL	4.932	37.249	c) MSEDCL Bilateral *	38.577	324.574
6) Other IPP	6.107	42.001	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.633	235.977
C) 1) TPCL Thermal	13.034	83.050	Include PX	0.000	0.000
2) TPCL Hydro	5.668	38.193	Standby	0.014	0.067
3) TPCL Gas	0.866	7.114	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.927	67.984	1) MSEDCL	403.957	2847.284
D) STATE			2) Mumbai Discoms	67.650	456.827
1) Thermal	262.884	1817.794	3) Other Discoms	9.093	63.458
(A1+C1+C4+(B1-B6))			TOTAL STATE	480.700	3367.569
2) Hydro (A2+C2)	23.146	139.949			
3) Gas (A3+B7+C3)	3.534	33.582			
4) Wind	4.778	42.427			
6) SOLAR	10.164	66.412			
TOTAL STATE	304.506	2100.164			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4783	4854	4840	5093
MSPGCL Hydro	815	397	2175	264
MSPGCL Gas	129	120	96	122
MSPGCL Total Generation	5727	5371	7111	5479
Central Sector Receipt	8575	8293	7287	6436
WIND	107	145	151	289
CPP / IPP Thermal	4256	4287	5339	4977
CPP / IPP Gas	0	0	0	0
SOLAR	1398	1349	0	0
Exchange with Mumbai	-2185	-2033	-1360	-1245
MSEDCL DEMAND MET	17452	17006	18131	15636
Load Shedding	4	35	0	0
MSEDCL DEMAND	17456	17041	18131	15636
TPCL GENERATION	714	846	1215	519
AEML GENERATION	498	494	486	461
MUMBAI DEMAND	3397	3373	3061	2225
OTHER DISCOM DEMAND	426	406	397	300
STATE DEMAND MET	21275	20785	21589	18161
STATE DEMAND	21279	20820	21589	18161
Frequency (Hz)	49.96	49.96	49.96	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.11 Hz at 13:03 Hrs	49.68 Hz at 06:17 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.88	23.09	145	80
Unit 7	0.00	0.00	0	0
Unit 8	10.75	79.32	483	402
Unit 9	0.00	0.00	0	0
Unit 10	10.54	76.04	465	415
Total	24.16	178.45		
Bhusawal				
Unit 3	2.98	19.66	150	110
Unit 4	10.10	63.60	465	380
Unit 5	0.00	0.00	0	0
Total	13.08	83.26		
Parli				
Unit 6	4.95	32.30	221	155
Unit 7	2.62	28.19	122	97
Unit 8	4.55	29.74	200	156
Total	12.12	90.23		
Chandrapur				
Unit 3	0.29	21.48	150	0
Unit 4	3.58	24.30	155	132
Unit 5	7.45	17.74	342	270
Unit 6	8.40	54.29	401	285
Unit 7	7.60	54.20	369	270
Unit 8	0.00	49.00	0	0
Unit 9	10.67	70.76	455	428
Total	37.99	291.78		
Paras				
Unit 3	5.04	31.88	229	182
Unit 4	4.50	30.45	207	170
Total	9.55	62.33		
Khaparkheda				
Unit 1	2.09	17.96	120	55
Unit 2	1.82	16.64	95	40
Unit 3	2.74	22.61	135	98
Unit 4	3.20	24.66	148	105
Unit 5	6.47	57.87	280	260
Total	16.32	139.73		
Nasik				
Unit 3	3.28	21.76	158	128
Unit 4	0.00	0.00	0	0
Unit 5	3.05	19.56	133	117
Total	6.32	41.32		
Uran				
All Units	2.67	26.47	132	0
Total	2.67	26.47		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.56	3.98	27	3
Total	0.56	3.98		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.88	19.62	440	35
Stage 4	4.97	19.95	1005	0
Stage 3	1.71	9.04	240	0
Total	9.56	48.61		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.70	5.13	61	0
TILLARI	0.52	3.54	58	0
BHIRA T.R.	0.47	2.93	77	0
SMLHY_PTN	4.93	34.58	223	192
GHATGHAR	0.74	2.99	125	0
Total	7.36	49.17		
Wind				
Total	4.78	42.43	0	0
Total	4.78	42.43		
CPP				
APML(Mus)	70.84	462.36	0	0
JSWEL(Mus)	18.19	137.77	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.30	100.28	0	0
SWPGPL-Mus	4.93	37.25	0	0
Other(Mus)	6.11	42.00	0	0
Total	119.38	779.66		
SOLAR				
Total	10.16	66.41	0	0
Total	10.16	66.41		
Tata				
Trombay 5	8.75	55.88	448	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.71	4.71	103	0
Trombay 7B	0.16	2.40	54	0
TATA Hydro	5.67	38.19	449	110
Trombay 8	4.28	27.17	234	130
Total	19.57	128.36		
AEML				
DTPS U-1&2	10.93	67.98	498	326
Total	10.93	67.98		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	119.55	887.10	MSPGCL Total	139.69	1015.32
			MSPGCL Thml+Gas	122.22	913.56	Koyna 1,2 & 4 Total	7.85	39.57
			MSPGCL Hydro	17.48	101.76	State Total	304.51	2100.16

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 07/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5309	274	132	5715	341	5192	0	0	6584	6293	-1164	16020	0	16020	2568	357	18945	49.99
2	5254	268	132	5654	242	4961	0	0	6648	6400	-1241	15685	0	15685	2371	331	18387	49.90
3	5093	264	122	5479	289	4977	0	0	6551	6436	-1245	15636	0	15636	2225	300	18161	49.99
4	5083	260	132	5475	216	5179	0	0	6472	6423	-1169	15827	0	15827	2132	297	18256	49.99
5	5093	271	131	5495	150	5264	0	0	6703	6731	-1161	16165	0	16165	2093	314	18572	49.94
6	5111	671	132	5914	151	5288	0	0	7029	7117	-1210	16920	0	16920	2183	340	19443	49.95
7	5049	1527	132	6708	241	5251	0	41	7190	7259	-1168	17948	0	17948	2314	384	20646	49.85
8	5151	771	132	6054	290	5267	0	299	8158	8212	-1457	18271	0	18271	2473	394	21138	49.96
9	5143	492	130	5765	206	4965	0	664	8927	8654	-1942	17884	2	17886	2781	428	21095	50.03
10	5093	520	119	5732	133	4975	0	1087	8614	8126	-2092	17549	25	17574	3092	412	21078	50.02
11	4817	673	128	5618	118	4491	0	1299	8640	8411	-2122	17390	6	17396	3323	425	21144	50.00
12	4783	815	129	5727	107	4256	0	1398	8513	8575	-2185	17452	4	17456	3397	426	21279	49.96
13	4854	397	120	5371	145	4287	0	1349	8425	8293	-2033	17006	35	17041	3373	406	20820	49.96
14	4739	390	128	5257	254	4278	0	1345	8446	8039	-1963	16824	21	16845	3274	386	20505	50.03
15	4847	388	118	5353	192	4766	0	1162	8291	7735	-2012	16796	42	16838	3316	400	20554	49.99
16	4794	418	127	5339	158	4691	0	863	8092	7810	-1925	16551	46	16597	3356	385	20338	49.97
17	4799	495	61	5355	209	4717	0	457	8463	7996	-1823	16512	27	16539	3276	399	20214	49.98
18	4816	578	0	5394	179	5118	0	174	8287	8096	-1906	16647	35	16682	3171	408	20261	49.95
19	4824	1679	76	6579	203	5209	0	26	7413	7422	-1649	17364	10	17374	3140	426	20940	49.94
20	4840	2175	96	7111	151	5339	0	0	6998	7287	-1360	18131	0	18131	3061	397	21589	49.96
21	4915	1478	99	6492	182	5325	0	0	6856	6649	-1178	17092	0	17092	2834	378	20304	49.99
22	4969	1135	97	6201	91	5217	0	0	6404	6362	-1046	16452	0	16452	2709	373	19534	49.99
23	5078	1018	97	6193	164	5188	0	0	6048	5965	-1048	16089	0	16089	2628	373	19090	49.98
24	5093	521	98	5712	366	5175	0	0	6296	5903	-1056	15746	0	15746	2560	354	18660	49.95
MUs	119.55	17.48	2.67	139.69	4.78	119.38	0.00	10.16	180.05	176.19	-37.16	403.96	0.25	404.21	67.65	9.09	480.95	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 07/Sep/2022

Position as on 6.30 Hrs of 08/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	13/09/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03	07/09/2022	02:57	Turbine bearing Vibration high	07/09/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/09/2022	02:24	07/09/2022	20:21	Gas shortage	
MSPGCL	Uran Unit 5	108	05/09/2022	09:20		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	06/09/2022	23:30	07/09/2022	15:30	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Sep/2022

Position as on 6.30 Hrs of 08/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 3	210	07/09/2022	02:04		Continued.	Withdrawn	08/09/2022
IPP	SWPGPL U-2	135	07/09/2022	10:45	07/09/2022	13:24	Electrical Fault.	
MSPGCL	Uran Unit 6	108	07/09/2022	16:30	07/09/2022	18:13	GTPS URAN A0 TURBINE TRIPPED ON HIGH VIBRATIONS AT 16:30 HRS.SUBSEQUENTLY GT6 TRIPPED	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	07/09/2022	21:17	08/09/2022	00:37	ID Fan Problem	
MSPGCL	Khaparkheda Unit 1	210	08/09/2022	06:19		Continued.	Furnace Pressure High	08/09/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 07/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 08/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Tripping							
707 LR (TIRODA CKT - 2) REACTOR @ KORADI 3	IntraState	07/09/2022	07:24	07/09/2022	09:06	PO	For Reactor changeover Activity as per CEA safety regulations. Spare reactor taken into service in place of B ph
765 KV LINE Outages/Tripping							
Tirora-Koradi III ckt - 2	IntraState	07/09/2022	07:21	07/09/2022	09:06	PO	For Reactor changeover Activity as per CEA safety regulations. Spare reactor taken into service in place of B ph
400 KV TIEBAY Outages/Tripping							
TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	07/09/2022	09:22	07/09/2022	11:00	PO	Diagnostic testing and Maintenance
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY- 410 OF KOLHAPUR CKT - 2 @ KOLHAPUR (PG)	InterState	07/09/2022	11:50	07/09/2022	19:13	PO	Bay AMP
400 KV LINE Outages/Tripping							
KOLHAPUR - KOLHAPUR (PG) CKT - 2	InterState	07/09/2022	11:50	07/09/2022	19:13	PO	Bay AMP
WARORA - IEPL	IntraState	01/09/2022	07:36			PO	1. Dis-Connecting Horizontal Jumper and covert 400kv IEPL-PGCIL Deoli Ckt (Temporary Arrangement for 10 Days) 400kv IEPL-Warora Ckt. 2. Connecting 400kv IEPL-Warora through new towers.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/09/2022	18:38			T	Y Phase Ground Fault
LONIKAND I - CHAKAN	IntraState	07/09/2022	02:55	07/09/2022	08:17	EO	Red hot of 170 deg observed on R phase 29 B Isolator Clamp
LONIKAND I - CHAKAN	IntraState	07/09/2022	02:55	07/09/2022	08:17	HT	Emergency outage. Work at Lonikand end
PARLI-SOLAPUR (LAMBOTI)	IntraState	07/09/2022	11:14	07/09/2022	20:53	PO	Hardware Tightening & Fitting Work
KARAD - LONIKAND I	IntraState	07/09/2022	15:01			HT	HT for Load Management
KHADKA-AURANGABAD (WALUJ)	IntraState	07/09/2022	19:46			HT	Due to OV
BUS COUPLER @ KHARGHAR	IntraState	07/09/2022	23:26	08/09/2022	01:23	EO	Hot spot attending work
KHARGHAR - TALEGAON (PG)	IntraState	08/09/2022	01:43	08/09/2022	05:37	EO	Hot spot attending work
400 KV ICT Outages/Tripping							
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	07/09/2022	19:56	07/09/2022	21:17	T	Tripped on Oil temp
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	IntraState	08/09/2022	05:43	08/09/2022	07:51	EO	Hot spot attending work on CT stud clamp which required to be attended on top priority to maintain uninterrupted power supply
400 KV BR Outages/Tripping							
400KV 125 MVAR BUS REACTOR@400KV DHULE SS	InterState	07/09/2022	08:50	07/09/2022	15:01	PO	Routine Maint & testing work
220 KV TBC Outages/Tripping							
AUXILIARY BUS @ MALEGAON	IntraState	29/08/2022	16:50			PO	Shifting of TBC Bay new 50MVA 220/33kv PTR 3
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - PADGHE	IntraState	05/09/2022	09:49			HT	HT for Load Management

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 07/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 08/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SONEWADI - BHOSE CKT - 2	IntraState	06/09/2022	09:45	07/09/2022	01:23	PO	Outage Proposal on 220kV A'Nagar (Sonewadi)- Belwandi (Bhose) Line Ckt II for Stringing work at LILO point of 220kV Ahmednagar Belwandi (Bhose) line at 400kV Karjat Substation.
TILLARI - AMONA LINE	IntraState	07/09/2022	03:33	07/09/2022	04:41	T	Tripped on Distance protection
EKLAHARE (GCR) - GHATGHAR	IntraState	07/09/2022	04:23	07/09/2022	05:04	T	Opened at Ghatghar end
TROMBAY - SALSETTE CKT - 1	IntraState	07/09/2022	06:49	07/09/2022	09:51	PO	OPGW SHIFTING WORK FOR MONOPOLE ERECTION AT LOC -60
OSMANABAD - BARSHI	IntraState	07/09/2022	09:28	07/09/2022	13:36	PO	Outage is required for Quarterly Maintenance
LAMBOTI - PANDHARPUR	IntraState	07/09/2022	10:28	07/09/2022	17:08	PO	Replacement of R-Ph Wave Trap of 220kV LBT-Pandharpur Line due to HOT SPOT.
GHODBUNDER - MSETCL BOISAR	IntraState	07/09/2022	12:21	07/09/2022	14:01	EO	Rph CC By-Passed work due to oil leakage.
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	07/09/2022	12:26	07/09/2022	16:59	EO	Outage for 220 KV Nagothane line 2 (11:00 Hrs to 18:00 Hrs) Jumpers replacement
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	07/09/2022	12:39	07/09/2022	17:53	PO	TRANSFER BREAKER RELATED WIRING AND TRIALS AT MSETCL END
EKLAHARE (GCR) - GHATGHAR	IntraState	07/09/2022	14:55	07/09/2022	17:09	EO	1) Replacement of R phase flashover STN insulator at loc no. 13.
MALHARPETH - KARAD	IntraState	07/09/2022	16:41	07/09/2022	19:52	EO	For attending hotspot at R Ph CT Conductor PG clamp
TROMBAY - KALWA	IntraState	07/09/2022	17:01			T	Distance Protection
URAN - KHARGHAR 1	IntraState	07/09/2022	17:14	07/09/2022	18:30	T	Distance Protection
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	07/09/2022	17:30	07/09/2022	20:05	PO	Outage is required for Relay Testing work at 220 kV VSSSK Substation
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	07/09/2022	17:30	07/09/2022	20:05	PO	Outage is required for Quarterly Maintenance
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/09/2022	18:16			HT	HT for Load Management
KHARGHAR - BORIVALI CKT - 2	IntraState	07/09/2022	20:57	07/09/2022	23:11	T	Tripped on Distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 08/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AMBERNATH - KALYAN CKT - 1	IntraState	07/09/2022	11:30	07/09/2022	17:13	PO	REPAIR TO SLEEVE COMPRESSION OF OFA TAP-1
BHIVPURI - AMBERNATH CKT - 1	IntraState	08/09/2022	08:30			PO	PROVIDE MISSING SPILT PINS AND TREE TRIMMING AT BHIVPURI
110 KV BR Outages/Trippings							
110KV GROUP BREAKER-2 @ TROMBAY	IntraState	07/09/2022	10:44	07/09/2022	18:25	PO	R/M AND TESTING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage