

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Nov/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	103.764	629.199	1) Gujrat	2.199	22.753
2) Hydro	4.834	59.620	2) Madhya Pradesh	8.303	36.521
3) Gas	6.742	67.233	3) Chattisgarh	6.910	51.100
Total MSPGCL	115.340	756.052	4) Maharashtra	113.184	779.626
B) 1) APLM	71.896	507.477	5) Goa (Amona)	-0.550	-3.410
2) JSWEL	20.182	141.884	Total	130.046	886.590
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.335	180.851
4) RPL(AMT)	10.023	23.113	b) Mumbai Drawl	31.411	206.023
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	25.814	154.107
6) Other IPP	8.326	58.697	Include PX	-0.068	-7.332
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.335	180.851
C) 1) TPCL Thermal	12.962	93.322	Include PX	8.818	57.704
2) TPCL Hydro	4.741	28.558	Standby	0.000	0.000
3) TPCL Gas	4.111	29.659	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.615	68.014	1) MSEDCL	337.823	2253.324
D) STATE			2) Mumbai Discoms	62.840	425.571
1) Thermal	236.768	1521.706	TOTAL STATE	400.663	2678.895
(A1+C1+C4+(B1-B6))					
2) Hydro	9.575	88.178			
(A2+C2)					
3) Gas	10.853	96.892			
(A3+B7+C3)					
4) Wind	8.480	49.828			
6) SOLAR	4.941	35.706			
TOTAL STATE	270.617	1792.310			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4199	4412	4505	4202
MSPGCL Hydro	136	125	849	86
MSPGCL Gas	279	280	272	284
MSPGCL Total Generation	4614	4817	5626	4572
Central Sector Receipt	6435	5393	5445	4741
WIND	172	492	604	132
CPP / IPP Thermal	4594	4972	5263	4072
CPP / IPP Gas	0	0	0	0
SOLAR	746	24	0	0
Exchange with Mumbai	-1801	-1443	-1279	-967
MSEDCL DEMAND MET	14760	14255	15659	12550
Load Shedding	0	0	0	0
MSEDCL DEMAND	14760	14255	15659	12550
TPCL GENERATION	940	1128	1222	614
AEML GENERATION	374	375	474	375
MUMBAI DEMAND	3115	2946	2975	1956
STATE DEMAND MET	17875	17201	18634	14506
STATE DEMAND	17875	17201	18634	14506
Frequency (Hz)	50.04	50.07	50.07	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.25 Hz at 13.03 Hrs	49.9 Hz at 14.14 Hrs	50.04	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 07/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.50	74.12	493	350
Unit 9	11.31	79.35	525	400
Unit 10	9.94	68.58	461	340
Total	31.75	222.04		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.82	64.62	450	330
Unit 5	9.14	66.20	450	350
Total	17.95	130.81		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.88	13.50	175	144
Unit 4	0.00	0.00	0	0
Unit 5	8.69	31.40	380	345
Unit 6	9.32	36.06	475	348
Unit 7	0.00	0.00	0	0
Unit 8	9.44	68.51	495	360
Unit 9	9.21	59.18	465	360
Total	40.54	208.64		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	9.50	43.76	485	360
Total	9.50	43.76		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.02	19.04	189	158
Unit 5	0.00	4.91	0	0
Total	4.02	23.94		
Uran				
All Units	6.74	67.23	296	266
Total	6.74	67.23		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.33	3.68	40	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.33	3.68		
Koyna				
Stage 1-2	1.88	19.76	325	35
Stage 4	0.93	18.61	357	0
Stage 3	0.26	8.45	110	0
Total	3.06	46.82		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	1.54	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.35	2.17	80	0
RNGR+BHTSA	0.33	2.63	14	13
BHANDARDRA	0.00	0.00	3	0
ELDARY	0.52	1.54	23	21
SMLHY_PTN	0.43	2.64	19	17
GHATGHAR	0.13	2.28	67	0
Total	1.77	12.80		
Wind				
Total	8.48	49.83	0	0
Total	8.48	49.83		
CPP				
APML(Mus)	71.90	507.48	0	0
JSWEL(Mus)	20.18	141.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	10.02	23.11	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.33	58.70	0	0
Total	110.43	731.17		
SOLAR				
Total	4.94	35.71	0	0
Total	4.94	35.71		
Tata				
Trombay 5	8.19	60.06	483	283
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.60	18.85	116	78
Trombay 7B	1.51	10.81	66	54
Trombay 8	4.77	33.26	201	196
TATA Hydro	4.74	28.56	435	0
Total	21.81	151.54		
AEML				
DTPS U-1&2	9.62	68.01	500	374
Total	9.62	68.01		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	103.76	629.20	MSPGCL Total	115.34	756.05
			MSPGCL Thml+Gas	110.51	696.43	Koyna 1,2 & 4 Total	2.80	38.36
			MSPGCL Hydro	4.83	59.62	State Total	270.62	1792.31

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4122	142	283	4547	140	4454	0	0	5162	5116	-1259	12998	0	12998	2364	15362	50.02
2	4164	86	284	4534	95	4161	0	0	5175	5214	-1160	12844	0	12844	2167	15011	50.01
3	4192	86	284	4562	81	4130	0	0	5041	4929	-1045	12657	0	12657	2035	14692	50.04
4	4202	86	284	4572	132	4072	0	0	4953	4741	-967	12550	0	12550	1956	14506	50.03
5	4305	87	296	4688	228	4154	0	0	4904	5050	-935	13185	0	13185	1925	15110	50.02
6	4635	98	286	5019	265	4592	0	0	5005	5034	-1003	13907	0	13907	2008	15915	50.03
7	4846	453	286	5585	196	4942	0	11	5006	5039	-846	14927	0	14927	2130	17057	50.01
8	4844	584	286	5714	182	4933	0	140	5119	5006	-865	15110	0	15110	2294	17404	50.05
9	4875	160	284	5319	129	4864	0	371	5476	5582	-1116	15149	0	15149	2603	17752	50.04
10	4381	93	280	4754	146	4693	0	577	5877	5909	-1486	14593	0	14593	2908	17501	50.03
11	4199	136	279	4614	172	4594	0	746	6422	6435	-1801	14760	0	14760	3115	17875	50.04
12	4156	169	277	4602	184	4379	0	756	6579	6407	-1881	14447	0	14447	3163	17610	50.03
13	4143	146	266	4555	320	4106	0	709	6550	6095	-1827	13958	0	13958	3105	17063	50.03
14	4156	99	276	4531	344	4077	0	636	6239	5847	-1734	13701	0	13701	2983	16684	50.09
15	4066	134	276	4476	369	4257	0	483	6089	6149	-1745	13989	0	13989	3007	16996	50.00
16	4109	95	266	4470	432	4559	0	321	5881	5766	-1587	13961	0	13961	3013	16974	50.02
17	4211	155	279	4645	473	4713	0	167	5546	5609	-1493	14114	0	14114	2995	17109	50.02
18	4412	125	280	4817	492	4972	0	24	5284	5393	-1443	14255	0	14255	2946	17201	50.07
19	4505	849	272	5626	604	5263	0	0	5192	5445	-1279	15659	0	15659	2975	18634	50.07
20	4507	594	282	5383	672	5298	0	0	5125	5227	-1074	15506	0	15506	2872	18378	50.05
21	4385	90	283	4758	664	5101	0	0	5038	5227	-1158	14592	0	14592	2728	17320	50.04
22	4196	89	283	4568	763	5006	0	0	4982	5017	-1220	14134	0	14134	2594	16728	50.05
23	4137	89	285	4511	705	4853	0	0	5045	5112	-1256	13925	0	13925	2510	16435	50.05
24	4016	189	285	4490	692	4254	0	0	4656	4697	-1231	12902	0	12902	2444	15346	50.04
MUs	103.76	4.83	6.74	115.34	8.48	110.43	0.00	4.94	130.35	130.05	-31.41	337.82	0.00	337.82	62.84	400.66	50.04

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Nov/2019

Position as on 6.30 Hrs of 08/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
MSPGCL	Khaparkheda Unit 4	210	22/10/2019	23.52		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 6	250	23/10/2019	03.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Parli Unit 7	250	23/10/2019	17.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Nov/2019

Position as on 6.30 Hrs of 08/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 4	210	31/10/2019	08.16		Continued.	Excessive Consumption of Hydrogen Cylinder.	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	
MSPGCL	Uran Unit 7	108	05/11/2019	00.17		Continued.	Internal Inspection	
MSPGCL	Uran Unit B0	120	06/11/2019	03.05		Continued.	Bearing vibration high	
MSPGCL	Uran Unit 8	108	06/11/2019	19.23		Continued.	Turbine Vibration	
MSPGCL	Koradi Unit 10	660	08/11/2019	02.42	08/11/2019	21.24	Fire On 11KV Switch Gear.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
400 KV Main Bus II @ Aurangabad (Ektuni)	IntraState	07/11/2019	10.32	07/11/2019	16.17	PO	Routine Maintenance Work
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT I @ Aurangabad (Ektuni)	IntraState	07/11/2019	14.32	07/11/2019	16.18	T	Ektuni-Taptitanda-1 Y-PH Pole Burst At Ektuni S/S
765/400KV 1500MVA ICT-II @ Koradi-III	IntraState	08/11/2019	09.54	08/11/2019	19.26	PO	Bay Maintenance Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	05/11/2019	10.03	07/11/2019	09.36	PO	Maintenance work(RFC 17.20Hrs)
Dhule Sar'Sarovar II	InterState	07/11/2019	19.22		Continued.	HT	Over Voltage
Akola Wardha I	InterState	08/11/2019	14.26		Continued.	T	Distance Protection
Akola II - RPL(Rattanindia) Ckt I	IntraState	27/10/2019	14.07		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	06/11/2019	21.58		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/11/2019	10.24	08/11/2019	08.20	PO	RFC 19.38 Diagnostic Testing Work.
Ektuni-Bableshwar ckt II	IntraState	07/11/2019	14.32	07/11/2019	20.11	T	Ektuni-Taptitanda-1 Y-PH Pole Burst At Ektuni S/S
Khadka-Aurangabad (Waluj)	IntraState	07/11/2019	17.13	08/11/2019	11.46	HT	Over Voltage
Kala Kudus Ckt-I	IntraState	07/11/2019	17.23	08/11/2019	03.23	EO	To Attend Insulator For Flashover Work.
Ektuni - Taptitanda Ckt I	IntraState	07/11/2019	20.35	07/11/2019	21.05	T	Y-Phase Pole CB Burst & Charged Through TIE BREAKER.
Jejuri- Koynastage-IV	IntraState	07/11/2019	22.08	08/11/2019	06.45	T	Distance Protection
Bhusawal-Aurangabad	IntraState	08/11/2019	19.58		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220KV 500MVA ICT-I @Nanded	IntraState	07/11/2019	10.33	07/11/2019	17.40	PO	For ICT TerTiary Insulation Coating Work.
400/220 KV 500MVA ICT II @ Nanded	IntraState	08/11/2019	09.58	08/11/2019	16.48	PO	ICT Tertiry Insulation Coating Work
400/220 KV 500MVA ICT II @ Nanded	IntraState	08/11/2019	17.33	08/11/2019	21.03	T	On Pressure Relief Valve , Oil Surge Relay.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	06/11/2019	15.12		Continued.	T	Distance Protection, R-N, 15.5KM. 2.79KA.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Ranjangaon-Lonikand	IntraState	31/10/2019	15.29		Continued.	PO	Tower jumps opened.
Sawantwadi-Bidri	IntraState	06/11/2019	16.52	07/11/2019	11.42	T	Distance Protection, R-N, 75.43KM. 1.664KA.
220kv Halkarni- Tillary	IntraState	06/11/2019	18.06		Continued.	T	B PH PT Burst.
Trombay - Kalwa	IntraState	06/11/2019	20.13	08/11/2019	11.46	PO	Pilling Work At LOC NO 19.
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	07/11/2019	08.48	07/11/2019	15.38	PO	Hot Line Work, Online Transfer Only.
Lonikand2-Lonikand1 (Interconector)	IntraState	07/11/2019	09.06	07/11/2019	18.23	PO	To MAKE twin Conductor Arrangement.
KORADI 2 - KAULEWADA CKT - I	IntraState	07/11/2019	09.18	07/11/2019	17.56	PO	To DSN AT Various Location
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	07/11/2019	10.07	07/11/2019	19.47	PO	CT replacment Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Walchandnagar-Bhigwan	IntraState	07/11/2019	10.30	07/11/2019	14.36	PO	Replacement Of Flashover String 2 LOC.
Khadka-Bhadli-2	IntraState	07/11/2019	10.42	07/11/2019	14.00	PO	Attending Oil Leakage of R-Phase Metering CT & Routine Maintenance Work.
BOTHE - PHALTAN MIDC	IntraState	07/11/2019	11.30	07/11/2019	13.50	PO	Routine Maintenance Work
Khadka-Chalisgaon-1	IntraState	07/11/2019	12.03	07/11/2019	20.08	PO	SUBSTATION BY M/S. MTCIL. 2) FOR MAKING LILO ARRANGEMENT AT LOC NO:- 238 BY REMOVING THROUGH JUMPERS OF 220KV KHADAKACHALISGAON CKT II FOR 200/132/33KV KEKATNIMBHORA SUBSTATION.
Kandalgaon - Koyna (Pophali)	IntraState	07/11/2019	12.10	07/11/2019	13.00	T	R-PH Distence Protection.
Jejuri- Ismt- Lonand	IntraState	07/11/2019	14.10	07/11/2019	17.52	PO	Routine Maintenance Work
Kalwa1- Airoli Knowledge Park	IntraState	07/11/2019	15.24	07/11/2019	15.52	T	Distance Protection power Swing.
Eklahare (Gcr)(Nashik) - Airoli Know Park	IntraState	07/11/2019	15.24	07/11/2019	17.33	T	Distance Protection Y-B-PH Fault.
Lonikand2-Lonikand1 (Interconector)	IntraState	08/11/2019	08.32	08/11/2019	17.23	PO	Twin Conductor Arrangement.
KORADI 2 - KAULEWADA CKT - II	IntraState	08/11/2019	09.32	08/11/2019	17.45	PO	SSN To DSN Conversion.
Karad(400kv) - Ogalewadi Ckt 1	IntraState	08/11/2019	09.46	08/11/2019	16.03	PO	LA Replacement.
Mahape - TIFIL	IntraState	08/11/2019	09.48	08/11/2019	19.05	PO	AT Mahape SS CB Timing,CRM & Bay Maint Work.
Adlabs - Pedambe	IntraState	08/11/2019	10.00	08/11/2019	17.18	PO	Bay RM Work.
Khadka-Chalisgaon-2	IntraState	08/11/2019	10.09	08/11/2019	17.52	PO	For Making LILO Arrangement At LOC No.238.
Kalwa - Mulund 1	IntraState	08/11/2019	10.09	08/11/2019	12.50	T	Tripped From Kalwa End.
Trombay - Mulund	IntraState	08/11/2019	10.09	08/11/2019	16.22	T	Y-PH Jumper Conductor Broken Tripped At Mulund End, Replaced At Loc.3B.
Khadka-Chalisgaon-2	IntraState	08/11/2019	10.10	08/11/2019	17.07	PO	For Making LILO Arrangement At LOC No.238.
Abhijeet-Wardha-Ii	IntraState	08/11/2019	10.10	08/11/2019	17.42	PO	For Shifting Of 220KV Wardha-Abhijit-1 Ckt From ERs Towers To Dverted/Hight Raised Towers.
Vita Alkud	IntraState	08/11/2019	10.30	08/11/2019	12.32	PO	Tan Delta Testing Of CTS
Akola-Paras Ckt No-I	IntraState	08/11/2019	11.35	08/11/2019	16.15	EO	Attending Hot Spot
Bhigwan-Baramat Iagro	IntraState	08/11/2019	11.45	08/11/2019	17.00	PO	Daignostic Testing Work.
Nanded-Parbhani	IntraState	08/11/2019	12.15	08/11/2019	15.34	EO	Replacement Of Flash String At Loc 71
Ghatghar - Bapgaon	IntraState	08/11/2019	12.30	08/11/2019	16.25	T	Mock Drill Of Ghatghar balck-Start.
Taloja Ii - OCIL-II	IntraState	08/11/2019	13.50	08/11/2019	18.40	PO	Check Meter Installation At Consumer End.
Waluj- Padegaon Ii	IntraState	08/11/2019	13.56	08/11/2019	22.12	PO	220Kv Bus Section 2 Outage For Fixing Of Jumper For Newly Coannected 220Kv Sawangi CKT 2.
Theur-Phursungi ckt-2	IntraState	08/11/2019	16.06	08/11/2019	20.27	PO	Jumper Replacement LOC 18.
Kathapur-Ranjangaon	IntraState	08/11/2019	18.45	08/11/2019	14.40	PO	Taken In Service For 132Kv Theur Sanaswadi Outage Then Out At 18.45.
Taloja II - OCIL-I	IntraState	08/11/2019	20.11	08/11/2019	20.33	PO	Check Meter Installation At Consumer End.
Trombay - Kalwa	IntraState	08/11/2019	21.01		Continued.	PO	Pilling Work At LOC.NO.19
220 KV ICT Outages/Trippings							

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	07/11/2019	10.08	07/11/2019	18.35	PO	TAn delta Testing Work.
220/132 KV 100MVA ICT-I @ Bhokar	IntraState	07/11/2019	11.32	07/11/2019	14.10	PO	C & Tan Delta Testing Of LV CT & Quarterly maintenance Work.
220/132 KV 100MVA ICT-II @ Bhokar	IntraState	07/11/2019	14.12	07/11/2019	16.40	PO	Quarterly Maintainance Work
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	08/11/2019	09.16	08/11/2019	18.35	PO	Attending Oil Leakage
220/132 Kv 200 Mva Bbl lct 4 @Padegaon	IntraState	08/11/2019	14.17	08/11/2019	22.14	PO	220Kv Bus Section 2 Outage For Fixing Of Jumper For Newly Coannected 220Kv Sawangi CKT 2.
220/132 Kv 100 Mva Bhel lct 2 @Padegaon	IntraState	08/11/2019	14.31	08/11/2019	22.15	PO	220Kv Bus Section 2 Outage For Fixing Of Jumper For Newly Coannected 220Kv Sawangi CKT 2.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage