

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Nov/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.070	934.086	1) Gujrat	0.458	12.570
2) Hydro	3.371	33.516	2) Madhya Pradesh	4.129	46.368
3) Gas	6.658	46.480	3) Chattisgarh	5.900	44.540
Total MSPGCL	142.099	1014.082	4) Maharashtra	128.992	865.931
B) 1) APLM	63.537	448.889	5) Goa (Amona)	-1.104	-8.234
2) JSWEL	18.509	121.484	Total	138.375	961.175
3) VIPL	0.000	0.000	a) Mumbai Schedule	18.210	168.875
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	21.494	172.750
5) WPCL	7.188	50.886	c) MSEDCL Bilateral *	29.932	198.553
6) Other IPP	13.429	85.154	Include PX	0.030	2.202
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	18.210	168.875
C) 1) TPCL Thermal	14.738	107.227	Include PX	10.710	108.808
2) TPCL Hydro	2.446	23.796	Standby	0.000	0.000
3) TPCL Gas	4.327	30.581	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.301	39.532	1) MSEDCL	383.512	2633.402
D) STATE			2) Mumbai Discoms	52.305	373.885
1) Thermal	258.772	1787.258	TOTAL STATE	435.817	3007.287
(A1+C1+C4+(B1-B6))					
2) Hydro	5.817	57.312			
(A2+C2)					
3) Gas	10.985	77.061			
(A3+B7+C3)					
4) Wind	15.341	77.799			
6) SOLAR	6.528	46.683			
TOTAL STATE	297.443	2046.113			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6039	6119	6124	4361
MSPGCL Hydro	100	180	264	110
MSPGCL Gas	268	265	279	283
MSPGCL Total Generation	6407	6564	6667	4754
Central Sector Receipt	6438	6673	5752	5037
WIND	540	189	372	1047
CPP / IPP Thermal	4493	4605	4893	3624
CPP / IPP Gas	0	0	0	0
SOLAR	878	528	0	0
Exchange with Mumbai	-1059	-962	-842	-835
MSEDCL DEMAND MET	17697	17597	16842	13627
Load Shedding	0	0	0	0
MSEDCL DEMAND	17697	17597	16842	13627
TPCL GENERATION	880	1022	1195	594
AEML GENERATION	488	498	499	282
MUMBAI DEMAND	2427	2482	2536	1711
STATE DEMAND MET	20124	20079	19378	15338
STATE DEMAND	20124	20079	19378	15338
Frequency (Hz)	50.03	50.01	50.04	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 50.01 Hrs	49.83 Hz at 05.11 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 07/Nov/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.19	79.85	605	370
Unit 9	11.52	44.05	560	375
Unit 10	9.10	62.48	400	365
Total	32.81	186.38		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.22	65.32	495	280
Unit 5	8.96	45.40	485	280
Total	18.18	110.72		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	8.84	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.31	27.96	250	190
Total	5.31	36.80		
Chandrapur				
Unit 3	3.76	26.75	175	118
Unit 4	3.52	25.30	162	118
Unit 5	9.06	63.72	425	275
Unit 6	9.00	64.75	420	277
Unit 7	0.00	0.00	0	0
Unit 8	0.00	61.07	0	0
Unit 9	11.16	78.76	500	283
Total	36.51	320.34		
Paras				
Unit 3	5.58	39.38	250	190
Unit 4	4.61	38.09	254	140
Total	10.19	77.47		
Khaparkheda				
Unit 1	3.71	25.26	170	135
Unit 2	3.92	27.46	180	140
Unit 3	4.00	27.64	185	140
Unit 4	3.98	28.15	185	140
Unit 5	10.26	70.54	490	321
Total	25.87	179.05		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.21	23.33	155	123
Unit 5	0.00	0.00	0	0
Total	3.21	23.33		
Uran				
All Units	6.66	46.48	294	256
Total	6.66	46.48		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	1.14	53	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.15	1.14		
Koyna				
Stage 1-2	1.70	17.44	245	40
Stage 4	0.00	1.87	0	0
Stage 3	0.51	4.80	80	0
Total	2.21	24.11		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.11	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.26	1.45	40	0
RNGR+BHTSA	0.35	2.48	15	14
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.93	0	0
SMLHY_PTN	0.00	0.00	0	0
GHATGHAR	0.55	4.45	198	0
Total	1.16	9.41		
Wind				
Total	15.34	77.80	0	0
Total	15.34	77.80		
CPP				
APML(Mus)	63.54	448.89	0	0
JSWEL(Mus)	18.51	121.48	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	7.19	50.89	0	0
Other(Mus)	13.43	85.15	0	0
Total	102.66	706.41		
SOLAR				
Total	6.53	46.68	0	0
Total	6.53	46.68		
Tata				
Trombay 5	9.74	70.09	456	277
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.75	19.52	118	113
Trombay 7B	1.57	11.06	67	64
Trombay 8	5.00	37.14	234	134
TATA Hydro	2.45	23.80	336	2
Total	21.51	161.60		
AEML				
DTPS U-1&2	9.30	39.53	500	281
Total	9.30	39.53		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.07	934.09	MSPGCL Total	142.10	1014.08
			MSPGCL Thml+Gas	138.73	980.57	Koyna 1,2 & 4 Total	1.70	19.31
			MSPGCL Hydro	3.37	33.52	State Total	297.44	2046.11

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Nov/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4666	60	282	5008	822	3797	0	0	5441	5008	-906	13729	0	13729	2046	15775	49.99
2	4445	65	292	4802	903	3740	0	0	5283	5184	-810	13819	0	13819	1900	15719	49.97
3	4363	160	293	4816	1021	3530	0	0	5135	5203	-859	13711	0	13711	1776	15487	49.95
4	4361	110	283	4754	1047	3624	0	0	4917	5037	-835	13627	0	13627	1711	15338	49.97
5	4650	65	294	5009	1065	3840	0	0	5224	5156	-803	14267	0	14267	1678	15945	49.96
6	5257	70	283	5610	1078	4020	0	0	5247	5359	-842	15225	0	15225	1718	16943	49.96
7	5863	80	294	6237	1053	4442	0	7	5557	5478	-693	16524	0	16524	1744	18268	49.97
8	5909	65	293	6267	982	4924	0	159	5809	5823	-511	17644	0	17644	1838	19482	49.96
9	5945	70	292	6307	693	4896	0	465	5998	6171	-830	17702	0	17702	1998	19700	49.97
10	5966	75	269	6310	669	4764	0	706	6371	6346	-1200	17595	0	17595	2221	19816	50.02
11	6039	100	268	6407	540	4493	0	878	6556	6438	-1059	17697	0	17697	2427	20124	50.03
12	6098	100	267	6465	475	4384	0	983	6697	6273	-1057	17523	0	17523	2493	20016	49.99
13	5969	130	266	6365	313	4022	0	921	6724	6934	-1076	17479	0	17479	2480	19959	49.97
14	5795	280	256	6331	242	3953	0	875	6615	6776	-989	17188	0	17188	2407	19595	49.98
15	6123	344	266	6733	191	4198	0	736	6541	6616	-1016	17458	0	17458	2444	19902	50.01
16	6119	180	265	6564	189	4605	0	528	6578	6673	-962	17597	0	17597	2482	20079	50.01
17	6095	241	257	6593	202	5001	0	236	6032	6224	-825	17431	0	17431	2473	19904	50.00
18	6149	333	267	6749	280	5076	0	34	5744	5473	-763	16849	0	16849	2457	19306	49.99
19	6124	264	279	6667	372	4893	0	0	5861	5752	-842	16842	0	16842	2536	19378	50.04
20	6012	264	280	6556	466	4600	0	0	5617	5343	-784	16181	0	16181	2482	18663	50.05
21	5709	128	279	6116	515	4139	0	0	5514	5130	-954	14946	0	14946	2396	17342	50.00
22	5097	69	271	5437	579	3945	0	0	5539	5380	-943	14398	0	14398	2288	16686	50.03
23	4659	59	281	4999	756	3899	0	0	5465	5561	-961	14254	0	14254	2183	16437	49.99
24	4657	59	281	4997	888	3878	0	0	5370	5037	-974	13826	0	13826	2128	15954	50.01
MUs	132.07	3.37	6.66	142.10	15.34	102.66	0.00	6.53	139.84	138.37	-21.49	383.51	0.00	383.51	52.31	435.82	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Nov/2020

Position as on 6.30 Hrs of 08/Nov/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Parli Unit 7	250	22/10/2020	20.00		Continued.	Zero Schedule By MSEDCL	
IPP	JSW (J) U2	300	01/11/2020	04.44		Continued.	No Schedule	
MSPGCL	Parli Unit 6	250	02/11/2020	23.28		Continued.	Excess DM water consumption.	
MSPGCL	Chandrapur Unit-8	500	06/11/2020	10.56		Continued.	Boiler validity expired.	
MSPGCL	Nasik Unit 4	210	08/11/2020	01.15	08/11/2020	05.45	Due to fire near HP turbine bearing no.2	
MSPGCL	Khaparkheda Unit 5	500	08/11/2020	14.01		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit-8	660	08/11/2020	16.45	08/11/2020	21.25	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	19/10/2020	23.01		Continued.	PO	Abnormal sound from main tank of smoothing reactor at Chandrapur end
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	06/11/2020	09.52	07/11/2020	08.03	PO	Earth Wire replacement work
Dhule Sar'Sarovar I	InterState	07/11/2020	09.14	07/11/2020	17.23	PO	Replacement of Damaged earth wire.
Dhule Sar'Sarovar II	InterState	07/11/2020	19.43		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Khadka-Aurangabad (Waluj)	IntraState	06/11/2020	21.13	07/11/2020	07.45	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	06/11/2020	22.04		Continued.	HT	Over Voltage
Deepnagar - Aurangabad	IntraState	07/11/2020	09.58	07/11/2020	19.51	PO	Replacement of faulty insulator strings work.
Babhaleshwar - Padghe-II	IntraState	07/11/2020	14.04	07/11/2020	20.50	EO	Attending Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	07/11/2020	20.09	08/11/2020	07.57	HT	Over Voltage
Dhule- Bableswhar - I	IntraState	07/11/2020	20.59	08/11/2020	13.16	HT	Over Voltage
Kharghar-Talegaon(PG)	IntraState	08/11/2020	06.06	08/11/2020	12.51	EO	Hot spot at Loc no.1
Babhaleshwar - Padghe-I	IntraState	08/11/2020	13.33	08/11/2020	19.11	EO	To attend Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	08/11/2020	19.21		Continued.	HT	Over Voltage
Dhule - Bableswhar - II	IntraState	08/11/2020	19.56		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	01/11/2020	03.34		Continued.	T	Differential protection
400/220 Kv 500 MVA ICT II @Jejuri	IntraState	07/11/2020	14.46	08/11/2020	03.35	PO	ICT-2 R phase 4 bushing replacement work.
400/220kv 315MVA ICT-III @ Kharghar	IntraState	08/11/2020	08.11	08/11/2020	18.40	PO	Diagnostic testing and Routine Maint.work
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Tillari Amona	InterState	02/11/2020	14.30		Continued.	PO	220 kv Amona Bay old CB Replacement (civil,Erection & Commissioning,testing)Work at 220 kv Tillari Switch yard.
PARLY (PG) - OSMANABAD	InterState	07/11/2020	11.22	07/11/2020	12.00	T	Distance Protection
Boiser(M)-Boiser(PG) -III	InterState	07/11/2020	12.18	07/11/2020	16.29	PO	Maintenance work.
EKLAHARE (OCR) Nasik - Navsari I	InterState	07/11/2020	13.59		Continued.	HT	Outage at navsari end.
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Special Repair Cable work.
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Lonikand1 (400 Kv)-Theur II	IntraState	06/10/2020	08.54		Continued.	PO	HTLS Stringing work
Trombay - Kalwa	IntraState	07/11/2020	06.31	08/11/2020	21.39	PO	Replacement of existing conductor by HTLS conductor
Khadka-Bhadli-1	IntraState	07/11/2020	08.19	07/11/2020	18.32	PO	Diagnostic testing & Isolator work.
Badnera-Akola I	IntraState	07/11/2020	09.11	07/11/2020	16.06	PO	Routine diagnostic testing and maintenance work.
Nagothane - Ipcl	IntraState	07/11/2020	09.25	07/11/2020	15.35	PO	At Loc no.62 jumper nut bolt tightening work.
Lamboti - Pandharpur li	IntraState	07/11/2020	09.30	07/11/2020	16.22	PO	Line signature analysis test to be performed. Insulator string replacement work at Loc no. 524, 523, 517, 515, 506, 489.
Parli 3 (Old Gcr)-Girwali Ckt 2	IntraState	07/11/2020	09.42	07/11/2020	16.52	EO	Attending hot spot and jumper replacement work SF6 gas low.
Balapur-Malegaon	IntraState	07/11/2020	10.08	07/11/2020	16.50	PO	Testing Work
Vita Alkud	IntraState	07/11/2020	10.26	07/11/2020	12.59	PO	C & Tan delta testing of CTs of line bay
Wardha-Dhamangaon	IntraState	07/11/2020	10.28	07/11/2020	19.27	PO	Tan Delta Measurment of CTs
Kandalgaon - Koyna (Pophali)	IntraState	07/11/2020	10.47	08/11/2020	06.25	T	Y & B phase LA burst at Kandalgaon sub.
Jamde-Dondaicha 2	IntraState	07/11/2020	10.57	07/11/2020	15.53	PO	The replacement of control cable as it found damaged in cable trench
Taptitanda-Jalna ckt II	IntraState	07/11/2020	11.03	07/11/2020	15.55	PO	Diagnostic testing work.
Lonikand2 - Bhosari1	IntraState	07/11/2020	11.09	07/11/2020	15.02	PO	CT tan delta measurment work.
220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 1	IntraState	07/11/2020	11.17	07/11/2020	13.50	PO	CRM testing of CB tan-D testing of CT.
Boisar Versova Line	IntraState	07/11/2020	11.26	07/11/2020	17.06	HT	Load Management
Gadchandur-Ultratech I	IntraState	07/11/2020	12.02	07/11/2020	16.33	PO	Diagnostic testing work.
Nanded - Parli Ext. Ckt II	IntraState	07/11/2020	13.55	07/11/2020	18.32	PO	Diagnostic testing work at both end.
Wada - Bhaveghar	IntraState	07/11/2020	14.30	07/11/2020	22.32	T	Distance Protection
Padghe - Wada	IntraState	07/11/2020	14.30	07/11/2020	15.05	T	Distance Protection
Chakan-Bhosari	IntraState	07/11/2020	15.40	07/11/2020	18.55	PO	Tan Delta Measurment of CTs
Chikhli-Jalna-I	IntraState	07/11/2020	16.16	07/11/2020	18.03	PO	Tan delta of CT, CRM/Timing and routine maintenance work.
Baramati - Kurkumbh	IntraState	08/11/2020	10.16	08/11/2020	13.02	PO	Annual Diagnostic testing
Boisar(M) - Ghodbunder I	IntraState	08/11/2020	14.22	08/11/2020	18.33	PO	Testing Work
BHUGAON WARORA CKT-I	IntraState	08/11/2020	14.51	08/11/2020	15.35	PO	MFM Meter, BCU & Distance relay is showing incorrect MW direction
Talegaon (Ambi)-General Motors	IntraState	08/11/2020	15.15	08/11/2020	16.32	PO	Diagnostic testing
BHUGAON WARORA CKT-II	IntraState	08/11/2020	15.44	08/11/2020	16.27	PO	MFM Meter, BCU & Distance relay is showing incorrect MW direction
220 KV ICT Outages/Trippings							
220kV 200MVA ICT IV @ OCR Nashik	IntraState	07/11/2020	09.41	07/11/2020	15.59	PO	Replacement of LA R & B ph diagnostic testing of ICT work.
220/132-110/11kv 200mva Aditya Vid Ptr 3 @Miraj	IntraState	07/11/2020	09.50		Continued.	PO	OLTC overhauling work.
220/132kv 200mva Vijai Ptr 2 @Lonand	IntraState	07/11/2020	11.15	07/11/2020	13.50	PO	ICT & HV CT Tan delta testing work.
220/132kv 200 Mva Aditya Vidyut Ict 2 @Kanhana	IntraState	07/11/2020	11.15	07/11/2020	17.46	PO	Diagnostic testing work.
220/132 kV 200MVA ICT II @ Girwali	IntraState	07/11/2020	11.31	07/11/2020	17.02	PO	Tan delta testing of bushing winding, HV & LV CTS of ICT 2.
220/132 Kv 200 Mva Emco Ict 2	IntraState	07/11/2020	11.40	07/11/2020	18.15	PO	OLTC overhauling.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2020

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
@Raymond (Nasik 2)							
220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	IntraState	07/11/2020	12.05	07/11/2020	17.47	PO	Diagnostic testing work
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	07/11/2020	14.48	08/11/2020	00.37	PO	Tan Delta Measurment of CTs