

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 07/Nov/2022 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 150.243        | 995.924         | 1) Gujrat                      | -9.227         | -68.164         |
| 2) Hydro            | 11.191         | 57.744          | 2) Madhya Pradesh              | -6.061         | -14.402         |
| 3) Gas              | 1.771          | 11.707          | 3) Chattisgarh                 | 5.740          | 40.830          |
| <b>Total MSPGCL</b> | <b>163.205</b> | <b>1065.375</b> | 4) Maharashtra                 | 164.160        | 1135.286        |
| B) 1) APML          | 72.142         | 418.257         | 5) Goa (Amona)                 | -1.517         | -10.523         |
| 2) JSWEL            | 14.045         | 90.354          | <b>Total</b>                   | <b>153.095</b> | <b>1083.027</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 31.618         | 219.749         |
| 4) RPL(AMT)         | 25.547         | 178.591         | b) Mumbai Drawl                | 34.935         | 246.867         |
| 5) SWPGPL           | 5.709          | 39.056          | c) MSEDCL Bilateral *          | 59.703         | 450.106         |
| 6) Other IPP        | 30.688         | 192.093         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 31.618         | 219.749         |
| C) 1) TPCL Thermal  | 11.936         | 74.172          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 4.640          | 26.759          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 0.000          | 6.990           | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.320          | 59.141          | 1) MSEDCL                      | 438.247        | 2929.972        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 60.831         | 413.929         |
| 1) Thermal          | 319.630        | 2047.588        | 3) Other Discoms               | 9.295          | 65.091          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>508.373</b> | <b>3408.992</b> |
| 2) Hydro            | 15.831         | 84.503          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 1.771          | 18.697          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 5.990          | 88.526          |                                |                |                 |
| 6) SOLAR            | 12.056         | 86.651          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>355.278</b> | <b>2325.965</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 1 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6437                      | 6274                  | 6290                      | 5540                      |
| MSPGCL Hydro               | 296                       | 505                   | 1757                      | 159                       |
| MSPGCL Gas                 | 61                        | 61                    | 61                        | 90                        |
| MSPGCL Total Generation    | 6794                      | 6840                  | 8108                      | 5789                      |
| Central Sector Receipt     | 7393                      | 7313                  | 6056                      | 5917                      |
| WIND                       | 421                       | 188                   | 245                       | 233                       |
| CPP / IPP Thermal          | 6306                      | 6298                  | 6498                      | 5485                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1701                      | 1327                  | 2                         | 0                         |
| Exchange with Mumbai       | -1630                     | -1580                 | -1354                     | -1388                     |
| <b>MSEDCL DEMAND MET</b>   | <b>20569</b>              | <b>19970</b>          | <b>19121</b>              | <b>15701</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 20569                     | 19970                 | 19121                     | 15701                     |
| TPCL GENERATION            | 945                       | 917                   | 1061                      | 502                       |
| AEML GENERATION            | 495                       | 498                   | 491                       | 291                       |
| <b>MUMBAI DEMAND</b>       | <b>3070</b>               | <b>2995</b>           | <b>2906</b>               | <b>2181</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>416</b>                | <b>416</b>            | <b>434</b>                | <b>335</b>                |
| STATE DEMAND MET           | 24055                     | 23381                 | 22461                     | 18217                     |
| <b>STATE DEMAND</b>        | <b>24055</b>              | <b>23381</b>          | <b>22461</b>              | <b>18217</b>              |
| Frequency (Hz)             | 50.00                     | 49.89                 | 50.02                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 06.03 Hrs | 49.77 Hz at 16.52 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 07/Nov/2022

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 5.08         | 31.94         | 220      | 210      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 12.63        | 83.13         | 608      | 452      |
| Unit 9             | 13.46        | 85.85         | 604      | 516      |
| Unit 10            | 9.50         | 64.18         | 401      | 377      |
| <b>Total</b>       | <b>40.68</b> | <b>265.10</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.36         | 61.48         | 425      | 290      |
| Unit 5             | 9.38         | 64.91         | 415      | 340      |
| <b>Total</b>       | <b>18.74</b> | <b>126.40</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.38         | 24.58         | 220      | 149      |
| Unit 7             | 4.42         | 23.36         | 241      | 148      |
| Unit 8             | 3.90         | 17.33         | 180      | 145      |
| <b>Total</b>       | <b>12.69</b> | <b>65.28</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.43         | 22.91         | 170      | 120      |
| Unit 4             | 2.95         | 20.45         | 131      | 118      |
| Unit 5             | 5.00         | 46.06         | 284      | 100      |
| Unit 6             | 7.13         | 43.28         | 345      | 260      |
| Unit 7             | 7.07         | 48.90         | 354      | 268      |
| Unit 8             | 10.39        | 65.69         | 457      | 286      |
| Unit 9             | 9.41         | 63.10         | 431      | 301      |
| <b>Total</b>       | <b>45.39</b> | <b>310.39</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.43         | 35.15         | 196      | 168      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>4.43</b>  | <b>35.15</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.50         | 18.58         | 115      | 90       |
| Unit 2             | 2.24         | 17.90         | 100      | 90       |
| Unit 3             | 3.32         | 23.32         | 152      | 123      |
| Unit 4             | 3.41         | 22.15         | 154      | 125      |
| Unit 5             | 10.32        | 68.06         | 455      | 285      |
| <b>Total</b>       | <b>21.79</b> | <b>150.00</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.35         | 22.58         | 172      | 115      |
| Unit 5             | 3.17         | 21.03         | 158      | 112      |
| <b>Total</b>       | <b>6.52</b>  | <b>43.62</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 1.77         | 11.71         | 91       | 60       |
| <b>Total</b>       | <b>1.77</b>  | <b>11.71</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.08         | 6.94          | 48       | 42       |
| <b>Total</b>       | <b>1.08</b>  | <b>6.94</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.94          | 17.59         | 440      | 35       |
| Stage 4         | 3.57          | 12.24         | 1008     | 0        |
| Stage 3         | 1.40          | 6.66          | 240      | 0        |
| <b>Total</b>    | <b>7.92</b>   | <b>36.49</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.00          | 0.00          | 0        | 0        |
| VTRNA           | 0.00          | 0.00          | 0        | 0        |
| TILLARI         | 0.00          | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.20          | 1.08          | 77       | 0        |
| SMLHY_PTN       | 1.72          | 11.49         | 78       | 68       |
| GHATGHAR        | 0.27          | 1.74          | 125      | 0        |
| <b>Total</b>    | <b>2.19</b>   | <b>14.31</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 5.99          | 88.53         | 0        | 0        |
| <b>Total</b>    | <b>5.99</b>   | <b>88.53</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 72.14         | 418.26        | 0        | 0        |
| JSWEL(Mus)      | 14.04         | 90.35         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 25.55         | 178.59        | 0        | 0        |
| SWPGPL-Mus      | 5.71          | 39.06         | 0        | 0        |
| Other(Mus)      | 30.69         | 192.09        | 0        | 0        |
| <b>Total</b>    | <b>148.13</b> | <b>918.35</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 12.06         | 86.65         | 0        | 0        |
| <b>Total</b>    | <b>12.06</b>  | <b>86.65</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 8.06          | 50.34         | 456      | 266      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 0.00          | 3.91          | 0        | 0        |
| Trombay 7B      | 0.00          | 3.08          | 0        | 0        |
| TATA Hydro      | 4.64          | 26.76         | 401      | 7        |
| Trombay 8       | 3.87          | 23.83         | 236      | 128      |
| <b>Total</b>    | <b>16.58</b>  | <b>107.92</b> |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 9.32          | 59.14         | 500      | 282      |
| <b>Total</b>    | <b>9.32</b>   | <b>59.14</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 150.24      | 995.92        | MSPGCL Total        | 163.20      | 1065.38       |
|                |             |         | MSPGCL Thml+Gas | 152.01      | 1007.63       | Koyna 1,2 & 4 Total | 6.51        | 29.83         |
|                |             |         | MSPGCL Hydro    | 11.19       | 57.74         | State Total         | 355.28      | 2325.96       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 07/Nov/2022

### Annexure-2

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | LOAD SHED DING | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|----------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |      | THM       | GAS  |       |          |          |                |                  |                |                      |               |                     |              |            |
| 1            | 5540        | 159   | 90   | 5789   | 233  | 5485      | 0    | 0     | 5621     | 5917     | -1388          | 15701            | 0              | 15701                | 2181          | 335                 | 18217        | 50.01      |
| 2            | 5897        | 159   | 91   | 6147   | 243  | 5499      | 0    | 0     | 5495     | 5668     | -1322          | 15921            | 0              | 15921                | 2039          | 314                 | 18274        | 50.01      |
| 3            | 6221        | 164   | 91   | 6476   | 277  | 5637      | 0    | 0     | 5390     | 5221     | -1243          | 16067            | 0              | 16067                | 1940          | 301                 | 18308        | 50.01      |
| 4            | 6188        | 165   | 91   | 6444   | 264  | 5496      | 0    | 0     | 5394     | 5671     | -1170          | 16400            | 0              | 16400                | 1860          | 305                 | 18565        | 50.00      |
| 5            | 6218        | 210   | 90   | 6518   | 284  | 5960      | 0    | 0     | 5392     | 5761     | -1136          | 17079            | 0              | 17079                | 1834          | 308                 | 19221        | 50.01      |
| 6            | 6462        | 279   | 90   | 6831   | 293  | 6357      | 0    | 0     | 5755     | 6049     | -1201          | 17983            | 0              | 17983                | 1923          | 346                 | 20252        | 50.03      |
| 7            | 6528        | 164   | 91   | 6783   | 360  | 6346      | 0    | 42    | 7042     | 6633     | -1248          | 18542            | 0              | 18542                | 2034          | 374                 | 20950        | 50.01      |
| 8            | 6576        | 161   | 91   | 6828   | 332  | 6391      | 0    | 378   | 6946     | 7137     | -1368          | 19317            | 0              | 19317                | 2206          | 381                 | 21904        | 50.01      |
| 9            | 6614        | 150   | 91   | 6855   | 251  | 6344      | 0    | 876   | 6841     | 7024     | -1554          | 19381            | 0              | 19381                | 2505          | 415                 | 22301        | 49.97      |
| 10           | 6405        | 417   | 90   | 6912   | 287  | 6242      | 0    | 1331  | 6936     | 6987     | -1575          | 19762            | 0              | 19762                | 2810          | 422                 | 22994        | 49.97      |
| 11           | 6455        | 266   | 68   | 6789   | 372  | 6321      | 0    | 1635  | 7434     | 7520     | -1637          | 20577            | 0              | 20577                | 3003          | 423                 | 24003        | 50.00      |
| 12           | 6437        | 296   | 61   | 6794   | 421  | 6306      | 0    | 1701  | 7412     | 7393     | -1630          | 20569            | 0              | 20569                | 3070          | 416                 | 24055        | 50.00      |
| 13           | 6359        | 149   | 60   | 6568   | 344  | 6240      | 0    | 1749  | 7377     | 6992     | -1676          | 19808            | 0              | 19808                | 3051          | 409                 | 23268        | 50.03      |
| 14           | 6398        | 233   | 61   | 6692   | 241  | 6189      | 0    | 1619  | 7112     | 7039     | -1706          | 19677            | 0              | 19677                | 2946          | 397                 | 23020        | 49.93      |
| 15           | 6274        | 505   | 61   | 6840   | 188  | 6298      | 0    | 1327  | 7070     | 7313     | -1580          | 19970            | 0              | 19970                | 2995          | 416                 | 23381        | 49.89      |
| 16           | 6222        | 696   | 62   | 6980   | 156  | 6285      | 0    | 922   | 7562     | 7289     | -1591          | 19623            | 0              | 19623                | 3016          | 418                 | 23057        | 49.88      |
| 17           | 6265        | 1074  | 61   | 7400   | 133  | 6382      | 0    | 415   | 6671     | 6832     | -1547          | 19187            | 0              | 19187                | 2985          | 428                 | 22600        | 49.90      |
| 18           | 6271        | 1617  | 62   | 7950   | 141  | 6595      | 0    | 59    | 5991     | 5683     | -1530          | 18460            | 0              | 18460                | 2922          | 438                 | 21820        | 49.92      |
| 19           | 6290        | 1757  | 61   | 8108   | 245  | 6498      | 0    | 2     | 5867     | 6056     | -1354          | 19121            | 0              | 19121                | 2906          | 434                 | 22461        | 50.02      |
| 20           | 6239        | 1219  | 62   | 7520   | 215  | 6382      | 0    | 0     | 6047     | 5930     | -1403          | 18206            | 0              | 18206                | 2791          | 438                 | 21435        | 50.01      |
| 21           | 6238        | 551   | 61   | 6850   | 165  | 6288      | 0    | 0     | 6207     | 5960     | -1544          | 17305            | 0              | 17305                | 2625          | 414                 | 20344        | 49.99      |
| 22           | 6116        | 397   | 61   | 6574   | 164  | 6285      | 0    | 0     | 5998     | 5763     | -1543          | 16836            | 0              | 16836                | 2489          | 407                 | 19732        | 50.02      |
| 23           | 6099        | 251   | 62   | 6412   | 190  | 6226      | 0    | 0     | 5700     | 5595     | -1471          | 16556            | 0              | 16556                | 2381          | 396                 | 19333        | 49.98      |
| 24           | 5931        | 152   | 62   | 6145   | 191  | 6079      | 0    | 0     | 5738     | 5662     | -1518          | 16200            | 0              | 16200                | 2319          | 359                 | 18878        | 50.00      |
| MUs          | 150.24      | 11.19 | 1.77 | 163.21 | 5.99 | 148.13    | 0.00 | 12.06 | 153.00   | 153.09   | -34.94         | 438.25           | 0.00           | 438.25               | 60.83         | 9.30                | 508.37       | 49.98      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 07/Nov/2022**

**Position as on 6.30 Hrs of 08/Nov/2022**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                | Koyna Unit 9            | 80       | 15/06/2022   | 08:00        |            | Continued. | Capital Overhaul                                                                                                                                        | 15/11/2022    |
| MSPGCL                | Bhusawal Unit 3         | 210      | 15/10/2022   | 15:10        |            | Continued. | ZERO SCHEDULE                                                                                                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                                                                                   | 30/12/2022    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      | 15/11/2022    |
| MSPGCL                | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      |               |
| IPP                   | RPL(AMT) U-5            | 270      | 06/10/2022   | 21:33        |            | Continued. | Furnace Pressure High(converted into coal shortage from 15-10-2022)                                                                                     |               |
| MSPGCL                | Nasik Unit 3            | 210      | 08/10/2022   | 20:05        |            | Continued. | PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)          |               |
| MSPGCL                | Uran Unit B0            | 120      | 09/10/2022   | 11:53        |            | Continued. | TURBINE PROTECTION OPERATED                                                                                                                             | 14/11/2022    |
| MSPGCL                | Uran Unit 8             | 108      | 09/10/2022   | 12:30        |            | Continued. | BOILER PROBLEM                                                                                                                                          | 14/11/2022    |
| IPP                   | JSW (J) U1              | 300      | 11/10/2022   | 02:40        |            | Continued. | No Schedule                                                                                                                                             |               |
| IPP                   | SWPGPL U-3              | 135      | 21/10/2022   | 01:33        |            | Continued. | Coal Shortage                                                                                                                                           |               |
| MSPGCL                | Paras Unit 4            | 250      | 22/10/2022   | 16:51        |            | Continued. | Turbine Vibration                                                                                                                                       | 15/11/2022    |
| IPP                   | SWPGPL U-1              | 135      | 23/10/2022   | 20:29        | 08/11/2022 | 12:56      | PA Fan Vibration Problem                                                                                                                                | 06/11/2022    |
| MSPGCL                | Uran Unit 5             | 108      | 02/11/2022   | 17:35        |            | Continued. | Gas shortage                                                                                                                                            |               |
| TPC-G                 | Trombay 7B              | 60       | 04/11/2022   | 04:22        |            | Continued. | Gas shortage                                                                                                                                            |               |
| TPC-G                 | Trombay 7A              | 120      | 04/11/2022   | 19:53        |            | Continued. | Gas shortage                                                                                                                                            |               |
| CENT.SECTOR           | Tarapur 3               | 540      | 07/11/2022   | 02:00        |            | Continued. | For maintenance on reactor side                                                                                                                         |               |
| MSPGCL                | Koyna Unit 6            | 80       | 07/11/2022   | 08:00        | 08/11/2022 | 15:10      | INJECTOR REPLACEMENT                                                                                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 07/Nov/2022**

**Position as on 6.30 Hrs of 08/Nov/2022**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage            | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|-----------------------------|---------------|
| IPP                | IEPL Unit 1             | 270      | 08/11/2022   | 03:17        |           | Continued. | Due to clinkering in Boiler |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Nov/2022**

**Statement-VII**

**Position as on 6.30 Hrs of 08/Nov/2022**

| Name of Line                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                      |
|------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV MAINBAY Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                       |
| MAIN BAY (707) OF TIRORA CKT - 2 @ KORADI 3    | IntraState                | 08/11/2022   | 09:19        | 08/11/2022 | 17:48      | PO          | Annual Maintenance of Bay Equipment                                                                                                                                                                                                                                                                                                                                                                   |
| <b>500 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                       |
| CHANDRAPUR - PADGHE HVDC POLE 2                | IntraState                | 05/11/2022   | 12:21        |            |            | PO          | Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc                                                                                                                                                                                                                                                                                                  |
| CHANDRAPUR - PADGHE HVDC POLE 2                | IntraState                | 05/11/2022   | 12:21        |            |            | PO          | Annual Maintenance work AC & DC yard Equipment, Valve Hall,Diagnostic testing, Line Maintenance, etc.                                                                                                                                                                                                                                                                                                 |
| <b>400 KV MAINBAY Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                       |
| 400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2 | InterState                | 23/06/2022   | 20:33        |            |            | EO          | for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425                                                                                                                                                                                                                                                                                       |
| <b>400 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                       |
| AKOLA - WARDHA(PG) CKT - 2                     | InterState                | 07/11/2022   | 08:06        | 07/11/2022 | 14:11      | PO          | Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV-WARDHA-AKOLA-1                                                                                                                                                                                                                                                               |
| AKOLA - WARDHA(PG) CKT - 1                     | InterState                | 07/11/2022   | 15:35        | 07/11/2022 | 19:51      | PO          | Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV-WARDHA-AKOLA-2                                                                                                                                                                                                                                                               |
| DHULE - SSNNL CKT - 2                          | InterState                | 08/11/2022   | 11:41        | 08/11/2022 | 15:34      | T           | Distance Protection                                                                                                                                                                                                                                                                                                                                                                                   |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1            | IntraState                | 20/10/2022   | 10:27        | 08/11/2022 | 06:57      | HT          | For Load management                                                                                                                                                                                                                                                                                                                                                                                   |
| TBC @ KOLHAPUR(TALANDGE)                       | IntraState                | 03/11/2022   | 16:15        |            |            | PO          | Overhauling of A bus, B Bus, C Bus PG isolators.                                                                                                                                                                                                                                                                                                                                                      |
| PADGHE - PADGHE HVDC CKT- 2                    | IntraState                | 05/11/2022   | 12:21        |            |            | PO          | 1. Bay maint. work<br>2. Diagnostic testing work<br>3. Bhel CB Pole Overhauling work<br>4. A bus PG Isolator Replacement work under LES<br>5. If pole Overhauling work not completed due to any reason line will be charge on TBC.<br>6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator<br>7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change . |
| JAIGAD - KARAD CKT - 1                         | IntraState                | 07/11/2022   | 00:33        | 07/11/2022 | 09:25      | HT          | H/T DUE TO O/V                                                                                                                                                                                                                                                                                                                                                                                        |
| THAPTI TANDA - AURANGABAD (WALUJ)              | IntraState                | 07/11/2022   | 06:35        | 07/11/2022 | 18:28      | PO          | Replacement of faulty Disc Insulator strings by LRP strings                                                                                                                                                                                                                                                                                                                                           |
| RPL(AMT) NANDGAON PETH - AKOLA II LINE II      | IntraState                | 07/11/2022   | 14:56        | 07/11/2022 | 19:32      | EO          | To attend hotspot(Temperature-130°C) in Line Isolator(B Phase) at Akola-II SS                                                                                                                                                                                                                                                                                                                         |
| KARAD - TALANDGE CKT - 2                       | IntraState                | 07/11/2022   | 16:49        | 07/11/2022 | 21:32      | EO          | Hotspot at Y ph C bus Isolator                                                                                                                                                                                                                                                                                                                                                                        |
| THAPTI TANDA - AURANGABAD (WALUJ)              | IntraState                | 08/11/2022   | 07:05        | 08/11/2022 | 17:26      | PO          | Replacement of faulty Disc Insulator strings by LRP strings                                                                                                                                                                                                                                                                                                                                           |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2            | IntraState                | 08/11/2022   | 07:32        |            |            | HT          | For Load Management                                                                                                                                                                                                                                                                                                                                                                                   |
| JAIGAD - KARAD CKT - 1                         | IntraState                | 08/11/2022   | 08:41        |            | Continued. | PO          | CVT replacement work                                                                                                                                                                                                                                                                                                                                                                                  |
| NEW KOYNA - DABHOL CKT - 1                     | IntraState                | 08/11/2022   | 12:43        | 08/11/2022 | 19:24      | PO          | Cold washing work                                                                                                                                                                                                                                                                                                                                                                                     |
| <b>400 KV ICT Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                       |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Nov/2022**

**Statement-VII**

Position as on 6.30 Hrs of 08/Nov/2022

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                      |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 400/132 KV 200 MVA ICT - 1 @ KHADKA          | IntraState                | 07/11/2022   | 02:28        | 07/11/2022 | 02:55      | T           | TRIPPED ON PDR                                                                                                                                                                                                                        |
| 500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2   | IntraState                | 07/11/2022   | 10:06        | 07/11/2022 | 18:19      | PO          | Diagnostic testing & allied bay maintenance work                                                                                                                                                                                      |
| 400/220/33 KV 315 MVA ICT - 2 @ PARLI        | IntraState                | 07/11/2022   | 10:17        |            |            | PO          | Overhauling of 400kV Circuit Breaker (CGL Make) of 400/220kV, 315 MVA ICT-2 @ Girwali. 400/220kV, 315 MVA ICT-2 @ Girwali will remain charged through TBC                                                                             |
| 400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI      | IntraState                | 07/11/2022   | 12:47        | 07/11/2022 | 15:28      | EO          | For attending HOTSPOT on LV side R-ph CT                                                                                                                                                                                              |
| <b>220 KV TBC Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                                       |
| BUS COUPLER @ JEJURI                         | IntraState                | 08/11/2022   | 10:59        |            |            | PO          | CB Mechanism overhauling work                                                                                                                                                                                                         |
| <b>220 KV MAINBAY Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                       |
| BUS SECTION 3 @ MUDSHINGI                    | IntraState                | 07/11/2022   | 09:33        | 07/11/2022 | 18:30      | PO          | Half yearly maint. 220 kV Bus section III isolators.                                                                                                                                                                                  |
| BUS SECTION 2 @ MUDSHINGI                    | IntraState                | 07/11/2022   | 14:34        | 07/11/2022 | 18:30      | PO          | Half yearly Maintenance of bus isolators .                                                                                                                                                                                            |
| <b>220 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                       |
| ACCIL - APTA                                 | IntraState                | 02/11/2022   | 15:57        | 08/11/2022 | 11:29      | EO          | CB DC leakage attending work by testing divison panvel.                                                                                                                                                                               |
| HALKARNI - TILARI LINE                       | IntraState                | 07/11/2022   | 00:08        | 07/11/2022 | 14:43      | T           | TRIPPED ON DIST. PROTECTION                                                                                                                                                                                                           |
| EKLAHARE (OCR) - PADGHE                      | IntraState                | 07/11/2022   | 07:42        |            |            | HT          | For Overloading of 220kV Nashik-BBLR Line                                                                                                                                                                                             |
| EKLAHARE (OCR) - NAVASARI CKT - 1            | IntraState                | 07/11/2022   | 08:24        |            |            | HT          | For Load Management                                                                                                                                                                                                                   |
| URAN - KHARGHAR 1                            | IntraState                | 07/11/2022   | 08:28        | 08/11/2022 | 16:26      | EO          | Humming noise observed from B ph CB pole hence checking & overhauling ,Testing of CB                                                                                                                                                  |
| MUDSHINGI - CHIKODI                          | IntraState                | 07/11/2022   | 08:44        | 07/11/2022 | 18:26      | PO          | For insulator strings cleaning at T.L no 282 to 295 in MIDC area.                                                                                                                                                                     |
| KANDALGAON - KOYNA (POPHALI)                 | IntraState                | 07/11/2022   | 11:52        | 07/11/2022 | 15:45      | T           | Tripped on Dist Protection                                                                                                                                                                                                            |
| JEJURI ( 400 KV)-JEJURI- II                  | IntraState                | 07/11/2022   | 17:07        | 07/11/2022 | 19:32      | EO          | To attend Hotspot on Wavetrap by replacement of Palm.                                                                                                                                                                                 |
| ALKUD - VITA                                 | IntraState                | 08/11/2022   | 10:23        | 08/11/2022 | 13:16      | PO          | Damaged conductor replacement work at Loc no.61 Y ph                                                                                                                                                                                  |
| MALHARPETH SATARA MIDC                       | IntraState                | 08/11/2022   | 10:25        | 08/11/2022 | 13:50      | PO          | Quarterly Maintenance Work                                                                                                                                                                                                            |
| BABLESHWAR-BABLESHWAR(400KV)-II              | IntraState                | 08/11/2022   | 10:36        | 08/11/2022 | 17:15      | PO          | CB,CT Tan D                                                                                                                                                                                                                           |
| NAGOTHANE - SPCL                             | IntraState                | 08/11/2022   | 10:45        | 08/11/2022 | 21:55      | PO          | For jumper tightening and cable termination work                                                                                                                                                                                      |
| EKLAHARE (GCR) - AIROLI KNOW PARK            | IntraState                | 08/11/2022   | 12:22        | 08/11/2022 | 22:03      | HT          | For Load Management                                                                                                                                                                                                                   |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                                       |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE    | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                      |
| 220/132KV 100MVA PTR 1 @ KHAREPATAN          | IntraState                | 22/09/2022   | 16:35        |            |            | T           | ICT bursted                                                                                                                                                                                                                           |
| 220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II | IntraState                | 07/11/2022   | 09:27        | 07/11/2022 | 15:20      | PO          | 1)Quarterly bay maintenance work of TF and 33 kV Bus section II and its outgoing feeders 2) Diagnostic testing work of TF and bay equipment 3) Hot spot attending 4) Attending LV-1 CB Overhauling work and CB pole replacemnet work. |
| 220/100 KV 200 MVA ICT 4 @ KALWA             | IntraState                | 07/11/2022   | 11:12        | 07/11/2022 | 17:48      | EO          | For attending hot-spots for-Line iso Rph jaw CT side. Line iso Bph jaw CT side.                                                                                                                                                       |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 07/Nov/2022**

**Statement-VII**

**Position as on 6.30 Hrs of 08/Nov/2022**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                      |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220/132KV 100MVA ICT 2 @ KATHAPUR                 | IntraState                | 07/11/2022   | 12:01        | 07/11/2022 | 17:35      | PO          | Diagnostic testing work and Half yearly maintenance work                                                                                                                                                                                                                                                              |
| 220/33-33KV 100MVA TF NO. - 1 @ ICHALKARANJI - II | IntraState                | 07/11/2022   | 15:42        | 07/11/2022 | 18:31      | PO          | 1)Quarterly bay maintenance work 2) T/F HV Bay insulator string replacement work 3) Relay testing work                                                                                                                                                                                                                |
| <b>110 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                       |
| DHARAVI POWAI                                     | IntraState                | 30/08/2021   | 00:03        |            |            | PO          | Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai. |
| DHARAVI VIKHROLI                                  | IntraState                | 30/08/2021   | 00:03        |            |            | PO          | Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai. |
| KALYAN KALWA SALSETTE 2                           | IntraState                | 07/11/2022   | 10:02        | 07/11/2022 | 19:31      | PO          | Opening, coil back and safe guarding of loops at loc. 43 (Towards Salsette) for project work of 220KV Kalwa-Salsette-5 line.                                                                                                                                                                                          |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage