

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Nov/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	183.648	1200.519	1) Gujrat	1.714	15.753
2) Hydro	8.228	55.463	2) Madhya Pradesh	2.826	34.538
3) Gas	6.809	44.027	3) Chattisgarh	7.940	53.500
Total MSPGCL	198.685	1300.009	4) Maharashtra	205.082	1481.375
B) 1) APLM	53.663	427.337	5) Goa (Amona)	-1.444	-10.611
2) JSWEL	26.036	182.805	Total	216.118	1574.555
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.211	266.431
4) RPL(AMT)	25.437	178.817	b) Mumbai Drawl	38.663	278.870
5) SWPGPL	11.313	75.425	c) MSEDCL Bilateral *	98.591	748.874
6) Other IPP	22.680	122.876	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.211	266.431
C) 1) TPCL Thermal	14.202	92.369	Include PX	0.000	0.000
2) TPCL Hydro	3.011	19.676	Standby	0.000	0.000
3) TPCL Gas	2.609	17.103	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.207	72.415	1) MSEDCL	527.957	3678.153
D) STATE			2) Mumbai Discoms	69.692	480.430
1) Thermal	348.186	2352.563	3) Other Discoms	10.670	73.416
(A1+C1+C4+(B1-B6))			TOTAL STATE	608.319	4231.999
2) Hydro	11.239	75.139			
(A2+C2)					
3) Gas	9.418	61.130			
(A3+B7+C3)					
4) Wind	10.208	75.771			
6) SOLAR	13.150	92.844			
TOTAL STATE	392.201	2657.447			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7863	7710	7783	7426
MSPGCL Hydro	431	433	951	204
MSPGCL Gas	281	272	277	292
MSPGCL Total Generation	8575	8415	9011	7922
Central Sector Receipt	10707	10143	8588	8075
WIND	388	275	415	477
CPP / IPP Thermal	5304	5370	6827	5441
CPP / IPP Gas	0	0	0	0
SOLAR	1820	1953	3	0
Exchange with Mumbai	-2065	-2141	-1661	-1036
MSEDCL DEMAND MET	24260	23543	22685	20538
Load Shedding	0	0	0	0
MSEDCL DEMAND	24260	23543	22685	20538
TPCL GENERATION	749	779	1213	654
AEML GENERATION	497	499	502	470
MUMBAI DEMAND	3311	3419	3376	2160
OTHER DISCOM DEMAND	469	472	498	341
STATE DEMAND MET	28040	27434	26559	23039
STATE DEMAND	28040	27434	26559	23039
Frequency (Hz)	49.99	50.01	50.03	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 06:01 Hrs	49.76 Hz at 20:37 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Nov/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.50	30.11	195	180
Unit 8	12.88	42.77	630	32
Unit 9	14.82	95.20	627	603
Unit 10	14.20	98.32	615	560
Total	46.40	266.40		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.96	70.38	450	340
Unit 5	10.12	70.83	470	365
Total	20.08	141.21		
Parli				
Unit 6	5.24	34.43	242	165
Unit 7	5.34	21.58	241	173
Unit 8	5.35	38.41	240	176
Total	15.93	94.42		
Chandrapur				
Unit 3	3.66	24.41	163	119
Unit 4	3.65	25.61	155	140
Unit 5	10.42	73.43	450	415
Unit 6	8.99	59.75	395	346
Unit 7	7.97	54.91	359	301
Unit 8	11.02	76.13	485	420
Unit 9	11.20	78.74	478	430
Total	56.91	392.98		
Paras				
Unit 3	5.77	37.32	250	232
Unit 4	5.73	36.20	252	209
Total	11.50	73.51		
Khaparkheda				
Unit 1	3.60	19.80	170	115
Unit 2	2.92	18.42	130	106
Unit 3	3.72	24.00	174	137
Unit 4	4.14	26.93	186	152
Unit 5	9.76	74.03	435	390
Total	24.13	163.17		
Nasik				
Unit 3	3.63	25.40	167	135
Unit 4	2.28	22.55	148	0
Unit 5	2.79	20.88	127	112
Total	8.70	68.83		
Uran				
All Units	6.81	44.03	298	270
Total	6.81	44.03		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.07	6.48	45	44
Total	1.07	6.48		
Koyna				
Stage 1-2	1.59	13.20	245	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.46	8.99	252	0
Stage 3	0.91	5.43	240	0
Total	3.95	27.63		
Hydro				
KDPH	0.43	4.09	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.14	1.24	40	0
SMLHY_PTN	2.26	15.64	104	88
GHATGHAR	0.37	0.39	125	0
Total	3.21	21.36		
Wind				
Total	10.21	75.77	0	0
Total	10.21	75.77		
CPP				
APML(Mus)	53.66	427.34	0	0
JSWEL(Mus)	26.04	182.80	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.44	178.82	0	0
SWPGPL-Mus	11.31	75.42	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.35	37.84	267	202
Other(Mus)	17.33	79.23	0	0
JPL	0.00	5.81	0	0
Total	139.13	987.26		
SOLAR				
Total	13.15	92.84	0	0
Total	13.15	92.84		
Tata				
Trombay 5	9.14	59.81	451	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.51	10.08	108	39
Trombay 7B	1.10	7.03	64	35
TATA Hydro	3.01	19.68	371	30
Trombay 8	5.06	32.56	235	133
Total	19.82	129.15		
AEML				
DTPS U-1&2	11.21	72.42	502	303
Total	11.21	72.42		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	183.65	1200.52	MSPGCL Total	198.68	1300.01
			MSPGCL Thml+Gas	190.46	1244.55	Koyna 1,2 & 4 Total	3.05	22.19
			MSPGCL Hydro	8.23	55.46	State Total	392.20	2657.45

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Nov/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7020	198	291	7509	552	5599	0	0	8786	8283	-1362	20171	0	0	20171	2634	410	23215	49.98
2	7115	193	291	7599	569	5663	0	0	8635	8035	-1192	20291	0	0	20291	2446	383	23120	49.98
3	7283	196	292	7771	529	5493	0	0	8561	8111	-1079	20465	0	0	20465	2283	360	23108	50.02
4	7426	204	292	7922	477	5441	0	0	8539	8075	-1036	20538	0	0	20538	2160	341	23039	50.01
5	7552	197	292	8041	472	5497	0	0	8910	8701	-1232	21114	0	0	21114	2123	365	23602	50.01
6	7724	198	293	8215	431	5584	0	0	9335	9161	-1257	21754	0	1	21754	2171	380	24305	49.96
7	7782	312	293	8387	455	5726	0	32	9520	9153	-1281	22051	0	1	22051	2273	421	24745	49.96
8	7804	261	298	8363	403	6301	0	320	8990	8871	-1324	22494	0	0	22494	2444	440	25378	50.02
9	7880	407	297	8584	380	5877	0	891	9633	9098	-1679	22683	0	0	22683	2752	469	25903	49.99
10	7748	402	285	8435	378	5357	0	1439	10450	10150	-1970	23301	0	39	23301	3065	488	26854	49.96
11	7863	431	281	8575	388	5304	0	1820	10978	10707	-2065	24260	0	126	24260	3311	469	28040	49.99
12	7531	571	278	8380	336	5151	0	1936	11045	10816	-2144	23989	0	47	23989	3416	486	27891	49.99
13	7710	433	272	8415	275	5370	0	1953	10567	10143	-2141	23543	0	39	23543	3419	472	27434	50.01
14	7686	288	271	8245	252	5321	0	1770	10778	10316	-2071	23354	0	40	23354	3349	479	27182	49.97
15	7725	270	271	8266	206	5277	0	1435	11320	10836	-2111	23429	0	72	23429	3411	480	27320	49.96
16	7810	274	270	8354	208	5834	0	1022	10921	10303	-2062	23186	0	114	23186	3468	473	27127	49.98
17	7789	372	272	8433	212	6323	0	453	9877	9349	-1826	22457	0	68	22457	3429	487	26373	49.96
18	7717	794	275	8786	258	6819	0	76	8644	8320	-1635	22129	0	0	22129	3363	495	25987	49.94
19	7783	951	277	9011	415	6827	0	3	8962	8588	-1661	22685	0	0	22685	3376	498	26559	50.03
20	7750	432	278	8460	511	6680	0	0	9031	8557	-1693	22032	0	0	22032	3223	484	25738	50.01
21	7781	223	285	8289	485	6354	0	0	7850	7380	-1566	20479	0	0	20479	3050	463	23992	49.90
22	7844	203	283	8330	566	6132	0	0	7688	7391	-1474	20497	0	0	20497	2911	448	23856	50.00
23	7759	205	285	8249	729	5634	0	0	8096	7841	-1476	20526	0	0	20526	2828	451	23805	50.02
24	7566	206	287	8059	721	5563	0	0	8138	7940	-1326	20528	0	0	20528	2787	429	23744	49.99
MUs	183.65	8.23	6.81	198.68	10.21	139.13	0.00	13.15	225.25	216.12	-38.66	527.96	0.00	0.55	527.96	69.69	10.67	608.32	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) DLS done due to 220kV Jejuri-Baramati Line overload.(2) DLS done due to 132kV Nagar-Supa, MIDC-Sonewadi,BBLR-Rahuri,220kV Nashik-BBLR 1& 2 overload.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Nov/2023

Position as on 6.30 Hrs of 08/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyana Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	20/11/2023
MSPGCL	Bhusawal Unit 3	210	31/10/2023	23:45		Continued.	ID Fan Problem	11/11/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	For attending Hotspot of 220 KV Evacuation Line	09/11/2023
MSPGCL	Koradi Unit 8	660	03/11/2023	06:14	07/11/2023	00:18	Boiler Tube Leakage	07/11/2023
MSPGCL	Nasik Unit 4	210	06/11/2023	20:00	07/11/2023	06:15	Boiler Validity extension.	
MSPGCL	Nasik Unit 3	210	08/11/2023	00:55		Continued.	Boiler Tube Leakage	10/11/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	IntraState	06/11/2023	10:59	07/11/2023	16:20	EO	To attend Nitrogen Gas leakage in Spare ICT CTR at 765KV R.S. Ektuni
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
MAIN BAY (433) OF 500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	IntraState	08/11/2023	10:01			PO	Diagnostic testing and allied bay maintenance
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
PADGHE - BOISAR (PG)	InterState	27/10/2023	12:32			HT	Outage proposed by Powergrid.
KALWA - TALEGAON (PG)	InterState	07/11/2023	23:15	08/11/2023	03:33	PO	for opening of bunching in between location 153-154 after erection of newly proposed 2 no. tower in between loc no. 195 to 197
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 4Y4 phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/10/2023	08:04			HT	H/T for load management.
KHARGHAR - VIKHROLI GIS CKT - 1	IntraState	29/10/2023	04:43			HT	Line Hand tripped for safety purpose during tap period of Katai nakka.
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	29/10/2023	04:45			HT	Line Hand tripped for safety purpose during tap period of Katai nakka.
KHADKA- DEEPNAGAR CKT 2	IntraState	06/11/2023	08:20			PO	Main - 2 distance relay retrofitting work under MTAMC Projeet.
DHULE - DHULE(BDTCL) CKT - 2	IntraState	06/11/2023	11:35			PO	Circuit Breaker overhauling work by OEM. Line will be shifted on 400kV TBC
BABHALESHWAR - PADGHE CKT- 1	IntraState	06/11/2023	23:46	07/11/2023	04:01	EO	Emergency outage proposal on 400 KV Babhaleshwar-Padghe I for attending damaged conductor between tower location No.85-86
LONIKAND 2 - KARJAT CKT - 2	IntraState	07/11/2023	04:19	07/11/2023	06:39	EO	For attending hot spot on Yph CT (Iso side)-78.6 deg celsius & Yph CB (CT side)- 126 deg celsius
KALWA - KHARGHAR	IntraState	07/11/2023	23:15	08/11/2023	03:17	PO	for opening of bunching in between location 153-154 after erection of newly proposed 2 no. tower in between loc no. 195 to 197
PARLI-SOLAPUR (LAMBOTI)	IntraState	08/11/2023	09:36			PO	1) String replacement work. (2) Bay maintenance work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	23/10/2023	00:10			EO	CHECKING AND TESTING OF TRANSFORMER
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	28/10/2023	22:20			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	28/10/2023	22:27			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	28/10/2023	22:32			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400 KV BR Outages/Trippings							
BUS REACTOR (125 MVAR) @ LONIKAND 2	IntraState	07/11/2023	10:30	07/11/2023	18:32	PO	For relay testing kit demo by agencies
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	26/10/2023	20:16			HT	Charged from Navsary end only
220 KV KALMESHVAR WARUD CKT I	IntraState	01/11/2023	00:05			T	BPH CT Blast.
VERSOVA - GHODBUNDER	IntraState	06/11/2023	20:15			EO	Outage required for attending hotspot on B-phase isolator
VITA - GHATNANDRE	IntraState	07/11/2023	09:02	07/11/2023	17:34	PO	Cold Washing of Insulator
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	07/11/2023	11:10	07/11/2023	16:40	PO	To attend Hot Spot
CHAKAN-BHOSARI 1	IntraState	08/11/2023	09:40			PO	220 kV Chakan Line Bay CB Overhauling work - Siemens Make CB
BABLESHWAR -BHENDA	IntraState	08/11/2023	10:00			PO	For Disconnection of 220 Main Bus-II Jumper for section separation for the work of Erection of Stub Bus for 501 MVA ICT-5
LOTEPARSHURAM- DASTURI LINE	IntraState	08/11/2023	10:11			PO	C-Tan delta testing of R,Y,B phase CTs of 220KV Dasturi-Lote line & replacement of one insulator string found faulty in PID.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 200 MVA ICT 1 @ BORIVALI	IntraState	12/10/2023	10:19		Continued.	PO	For replacement of various EHV equipments under LE Scheme. The old EHV equipments are to be replaced under LE Scheme whose details are as given below - 1. 220 kV Circuit Breaker - 1 No. 2. 220 kV Lightning Arrestors - 3 Nos. 3. 100 kV Potential Transformers - 6 Nos. 4. 100 kV Isolators - 9 Nos. Also the Anti Corrosive Painting of ICT-1 will be carried out in this outage.
220/132 KV 100 MVA ICT I	IntraState	01/11/2023	11:19	07/11/2023	12:37	HT	Attending oil leakages at various joints by agency. (m/s. shrikant traders).
220/132KV 100MVA ICT - 2 @ KALWAN	IntraState	07/11/2023	10:11	07/11/2023	15:51	PO	Diagnostic Testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100MVA PTR NO 6 @CHINCHWAD	IntraState	07/11/2023	10:16	07/11/2023	19:24	PO	Commissioning of NIFPS & Diagnostic Testing work
220/33KV 50MVA BBL T/F @ OGLEWADI	IntraState	07/11/2023	10:25	07/11/2023	19:25	PO	Retrofitting of faltering T60 GE Make Differential protection relay
220/132 100MVA ICT-2 @ AMRAPUR	IntraState	07/11/2023	11:28	07/11/2023	14:48	PO	Outage is required for NIFPS oil leakage attend work by Agency & Quarterly Maintenance work
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	IntraState	07/11/2023	12:07	07/11/2023	14:26	PO	for attending hotspot by Hotline unit
220/132 100MVA ICT-1 @ AMRAPUR	IntraState	07/11/2023	14:51	07/11/2023	17:29	PO	For Quarterly Maintenance work
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIRA (T) - KHOPOLI 2	IntraState	08/11/2023	06:55	08/11/2023	07:36	PO	Bird nest removal from tower body of loc no 180,181 & 188

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage