

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Nov/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	154.586	956.204	1) Gujrat	1.440	7.855
2) Hydro	5.423	43.909	2) Madhya Pradesh	6.144	37.257
3) Gas	6.925	48.825	3) Chattisgarh	7.430	48.320
Total MSPGCL	166.934	1048.938	4) Maharashtra	223.946	1436.930
B) 1) APLM	53.134	354.603	5) Goa (Amona)	-2.002	-13.726
2) JSWEL	24.742	171.058	Total	236.958	1516.636
3) VIPL	0.000	0.000	a) Mumbai Schedule	42.072	299.003
4) RPL(AMT)	25.487	167.826	b) Mumbai Drawl	50.361	344.577
5) SWPGPL	9.286	63.486	c) MSEDCL Bilateral *	103.257	627.624
6) Other IPP	7.783	49.877	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	42.072	299.003
C) 1) TPCL Thermal	4.019	27.253	Include PX	0.000	0.000
2) TPCL Hydro	4.173	26.365	Standby	0.000	0.000
3) TPCL Gas	4.207	28.127	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.451	52.362	1) MSEDCL	487.222	3122.970
D) STATE			2) Mumbai Discoms	70.211	478.672
1) Thermal	286.488	1842.669	3) Other Discoms	12.557	86.469
(A1+C1+C4+(B1-B6))			TOTAL STATE	569.990	3688.111
2) Hydro	9.596	70.274			
(A2+C2)					
3) Gas	11.132	76.952			
(A3+B7+C3)					
4) Wind	6.821	46.003			
6) SOLAR	18.995	135.589			
TOTAL STATE	333.032	2171.487			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6421	6717	7094	6050
MSPGCL Hydro	200	167	328	171
MSPGCL Gas	284	274	282	297
MSPGCL Total Generation	6905	7158	7704	6518
Central Sector Receipt	10885	10798	10186	8930
WIND	195	135	283	462
CPP / IPP Thermal	4756	5289	6148	4542
CPP / IPP Gas	0	0	0	0
SOLAR	2609	1547	4	0
Exchange with Mumbai	-2508	-2587	-2065	-1555
MSEDCL DEMAND MET	22278	21783	21691	18460
Load Shedding	0	0	0	0
MSEDCL DEMAND	22278	21783	21691	18460
TPCL GENERATION	479	531	782	436
AEML GENERATION	320	289	446	306
MUMBAI DEMAND	3307	3407	3293	2297
OTHER DISCOM DEMAND	564	557	569	437
STATE DEMAND MET	26149	25747	25553	21194
STATE DEMAND	26149	25747	25553	21194
Frequency (Hz)	49.99	50.00	50.02	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 06.02 Hrs	49.79 Hz at 17.41 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Nov/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.10	27.85	184	154
Unit 8	0.00	22.77	0	0
Unit 9	14.33	62.18	622	556
Unit 10	13.84	91.26	610	485
Total	32.27	204.07		
Bhusawal				
Unit 3	3.12	7.27	150	120
Unit 4	8.78	59.06	495	290
Unit 5	8.20	45.03	455	285
Total	20.10	111.37		
Parli				
Unit 6	3.80	8.60	197	139
Unit 7	3.39	8.33	205	102
Unit 8	3.79	26.40	213	144
Total	10.97	43.33		
Chandrapur				
Unit 3	4.02	26.51	186	130
Unit 4	3.15	22.23	143	97
Unit 5	8.66	56.43	405	275
Unit 6	7.76	52.32	385	275
Unit 7	8.78	56.72	418	312
Unit 8	7.81	54.99	350	281
Unit 9	6.65	61.39	295	248
Total	46.82	330.59		
Paras				
Unit 3	4.88	32.52	234	152
Unit 4	3.99	30.57	202	135
Total	8.87	63.08		
Khaparkheda				
Unit 1	3.82	28.75	180	130
Unit 2	4.25	29.59	195	159
Unit 3	3.18	11.49	141	130
Unit 4	4.34	29.63	189	174
Unit 5	11.20	60.34	485	425
Total	26.79	159.80		
Nasik				
Unit 3	3.20	12.64	161	50
Unit 4	3.49	23.38	177	120
Unit 5	2.06	7.94	95	73
Total	8.76	43.96		
Uran				
All Units	6.92	48.82	298	273
Total	6.92	48.82		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.55	2.02	45	0
Total	0.55	2.02		
Koyna				
Stage 1-2	1.54	12.96	300	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	1.24	0	0
Stage 3	0.35	3.46	80	0
Total	1.89	17.66		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.26	1.26	62	0
BHIRA T.R.	0.28	1.56	40	0
SMLHY_PTN	3.00	22.38	134	119
GHATGHAR	0.00	1.06	0	0
Total	3.53	26.25		
Wind				
Total	6.82	46.00	0	0
Total	6.82	46.00		
CPP				
APML(Mus)	53.13	354.60	0	0
JSWEL(Mus)	24.74	171.06	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.49	167.83	0	0
SWPGPL-Mus	9.29	63.49	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.20	30.97	265	158
Other(Mus)	0.94	6.15	0	0
JPL	1.64	12.76	123	0
Total	120.43	806.85		
SOLAR				
Total	19.00	135.59	0	0
Total	19.00	135.59		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.67	17.70	112	109
Trombay 7B	1.54	10.43	65	64
TATA Hydro	4.17	26.36	387	91
Trombay 8	4.02	27.25	220	136
Total	12.40	81.74		
AEML				
DTPS U-1&2	7.45	52.36	446	284
Total	7.45	52.36		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	154.59	956.20	MSPGCL Total	166.93	1048.94
			MSPGCL Thml+Gas	161.51	1005.03	Koyna 1,2 & 4 Total	1.54	14.19
			MSPGCL Hydro	5.42	43.91	State Total	333.03	2171.49

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Nov/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6034	174	296	6504	442	4894	0	0	9292	9205	-1965	18594	0	0	18594	2787	486	21867	50.00
2	6018	180	297	6495	470	4544	0	0	9149	9332	-1821	18561	0	0	18561	2589	459	21609	49.98
3	6019	164	298	6481	458	4555	0	0	8942	9060	-1674	18446	0	0	18446	2415	434	21295	49.98
4	6050	171	297	6518	462	4542	0	0	8883	8930	-1555	18460	0	0	18460	2297	437	21194	49.99
5	6270	174	298	6742	365	4676	0	0	8919	9184	-1471	19059	0	0	19059	2227	437	21723	50.02
6	6685	168	298	7151	339	5141	0	0	9005	9363	-1494	20024	0	0	20024	2258	476	22758	50.02
7	6889	230	298	7417	310	5441	0	44	9051	9246	-1570	20379	0	0	20379	2333	509	23221	50.06
8	6639	334	298	7271	279	5335	0	478	9233	9428	-1717	20535	0	0	20535	2483	539	23557	50.01
9	6284	464	297	7045	173	4938	0	1208	9476	9827	-2036	20612	0	0	20612	2763	543	23918	50.01
10	6423	324	295	7042	190	4850	0	2040	10130	10421	-2339	21634	0	0	21634	3080	570	25284	49.98
11	6421	200	284	6905	195	4756	0	2609	10889	10885	-2508	22278	0	0	22278	3307	564	26149	49.99
12	6099	170	278	6547	237	4555	0	2709	10792	10608	-2585	21524	0	0	21524	3394	547	25465	50.00
13	5970	165	278	6413	190	4548	0	2803	10505	10426	-2582	21251	0	0	21251	3382	547	25180	49.95
14	5909	167	276	6352	153	4497	0	2657	10365	10374	-2514	20977	0	0	20977	3286	542	24805	50.03
15	6193	159	273	6625	150	4732	0	2104	10618	10953	-2543	21482	0	0	21482	3347	539	25368	50.03
16	6717	167	274	7158	135	5289	0	1547	10725	10798	-2587	21783	0	0	21783	3407	557	25747	50.00
17	6892	172	275	7339	139	5497	0	665	10610	10673	-2487	21279	0	0	21279	3357	547	25183	50.04
18	6937	182	279	7398	214	5852	0	127	10145	10267	-2289	20995	0	0	20995	3286	574	24855	49.96
19	7094	328	282	7704	283	6148	0	4	9809	10186	-2065	21691	0	0	21691	3293	569	25553	50.02
20	6864	359	286	7509	280	5736	0	0	9989	10116	-2159	20919	0	0	20919	3189	563	24671	49.98
21	6796	291	287	7374	245	5315	0	0	9425	9538	-2165	19769	0	0	19769	3033	538	23340	49.98
22	6530	285	292	7107	225	5073	0	0	9337	9355	-2087	19140	0	0	19140	2938	533	22611	50.02
23	6488	225	294	7007	343	4828	0	0	9272	9512	-2077	19084	0	0	19084	2882	529	22495	50.01
24	6365	170	295	6830	544	4690	0	0	9296	9271	-2071	18748	0	0	18748	2878	516	22142	49.96
MUs	154.59	5.42	6.92	166.93	6.82	120.43	0.00	19.00	233.86	236.96	-50.36	487.22	0.00	0.00	487.22	70.21	12.56	569.99	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 07/Nov/2024		
State Demand	MSEDC Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
26149 MW	22278 MW	3407 MW
11 Hrs	11 Hrs	16 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Nov/2024

Position as on 6.30 Hrs of 08/Nov/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/11/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/11/2024
MSPGCL	Chandrapur Unit 9	500	08/11/2024	00.15		Continued.	Suspected BTL.	10/11/2024
MSPGCL	Khaparkheda Unit 3	210	08/11/2024	00:08		Continued.	Boiler Tube Leakage	11/11/2024
Total Capacity MSPGCL		955						
TPC-G								
TPC-G	Trombay 5	500	22/09/2024	16:14		Continued.	Emergency withdrwan due to fire in cable vault.	
Total Capacity TPC-G		500						
IPP								
IPP	RPL(AMT) U-3	270	23/07/2024	00:47		Continued.	Turbine Vibration High	20/11/2024
IPP	JPL Unit 1	150	20/10/2024	15:11		Continued.	Turbine bearing Vabration high	15/11/2024
IPP	JPL Unit 2	150	07/11/2024	14:57	07/11/2024	17:45	Emergency Board trip.	
Total Capacity IPP		570						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2345						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	06/11/2024	19:19		Continued.	Due to no schedule from MSEDCL.	
MSPGCL	Uran Unit 5	108	06/11/2024	19:28		Continued.	Due to no schedule from MSEDCL.	
Total Capacity MSPGCL		216						
IPP								
IPP	SWPGPL U-1	135	30/10/2024	00:00		Continued.	Unit Out due to Non-avaialbility of Schedule	
Total Capacity IPP		135						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		351						
FORCED OUTAGE DUE TO NO PPA								
IPP								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Nov/2024

Position as on 6.30 Hrs of 08/Nov/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 702 OF BUS REACTOR AND 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	08/11/2024	10:28	08/11/2024	19:48	PO	Bay Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 701 OF 765/400kV 1500MVA ICT-1 @ KORADI 3	IntraState	08/11/2024	09:06	08/11/2024	16:42	PO	Bay Outage
765 KV LINE Outages/Trippings							
MAIN BUS - 1 @ AKOLA 2	IntraState	07/11/2024	10:20	07/11/2024	18:54	PO	Bus Outage
400 KV TBC Outages/Trippings							
220 KV TBC @ DHULE	IntraState	07/11/2024	09:30	07/11/2024	11:30	HT	Diagnostic testing of cb ct bay maintenance work in 220kv tbc bay.
400 KV MAINBAY Outages/Trippings							
220 KV BUS COUPLER @ DHULE	IntraState	07/11/2024	11:52	07/11/2024	13:52	HT	Diagnostic testing of cb,ct & bay maintenance work.
MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	IntraState	08/11/2024	11:26	08/11/2024	15:51	PO	Diagnostic Testing of CB
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - AURANGABAD(PG) CKT -1	InterState	08/11/2024	11:46	08/11/2024	16:51	PO	For AMP
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/10/2024	08:31			HT	H/T for load management.
DABHOL - NEW KOYNA CKT - 2	IntraState	07/11/2024	09:15	07/11/2024	22:14	PO	BAY MAINTENANCE AND TESTING
DABHOL - NEW KOYNA CKT - 2	IntraState	07/11/2024	09:15	07/11/2024	22:14	PO	REPLACEMENT OF LA MORE THAN 20 YRS OLD
220KV GEORAI	IntraState	07/11/2024	10:16	07/11/2024	16:19	HT	Outage for routine maintenance & diagnostic testing.
KORADI II - IEPL	IntraState	07/11/2024	10:46	07/11/2024	14:52	EO	Attending hot spot on Rph Line CT
NEW KOYNA-KARAD CKT - 1	IntraState	08/11/2024	08:47	08/11/2024	19:21	PO	Diagnostic testing & Relay testing work , Routine maint. Work
DABHOL - NAGOTHANE CKT - 1	IntraState	08/11/2024	09:20		Continued.	PO	REPLACEMENT OF LA MORE THAN 20 YRS OLD
220 KV TAPTITANDA WALUJ	IntraState	08/11/2024	13:06	08/11/2024	17:29	HT	H/T FOR OUTAGE ON TAPTITANDA ICT
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2024	16:09			HT	For load management
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	07/11/2024	08:12	07/11/2024	18:41	PO	For Routine maintenance & Diagnostic work.
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	07/11/2024	11:39	07/11/2024	19:07	PO	Annual maintenance work & testing work
400/220/33 KV 500MVA ICT - 1 @ WARORA	IntraState	07/11/2024	12:31		Continued.	PO	Supervisory and Protection trials, Relay Testing work of Main & Tie bay of ICT-I, and diagnostic Testing of Main & Tie Bay CB, Isolator Maintenance, Routine maintenance etc.
400/220KV 500MVA ICT - 2 @ KARJAT	IntraState	07/11/2024	20:41	07/11/2024	22:09	EO	Testing of LTS feature in backup relay.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	08/11/2024	00:12	08/11/2024	23:13	PO	1)Replacement of Rph IV Bushing due to oil leakage from tand point. 2) Bay Maintenance Work HV & LV side. 3) Diagonostic Testing Work. 4) MTAMC Work.
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	08/11/2024	13:52	08/11/2024	17:17	PO	Outage required for routine maintenance and routine testing work.
400 KV BR Outages/Trippings							
BUS REACTOR (80 MVar) - 1 @ BABHALESHWAR	IntraState	07/10/2024	09:40			PO	The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshevar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order
BUS REACTOR (125 MVar) - 2 @ KOLHAPUR (TALANDGE)	IntraState	05/11/2024	08:47			PO	Main Bay AMP and CB Overhauling work
220 KV TBC Outages/Trippings							
220 KV TBC - I @ TADALI	IntraState	07/11/2024	09:30	07/11/2024	13:30	HT	Diagnostic testing & allied bay maintenance work.
BUS COUPLER @ MULUND	IntraState	07/11/2024	11:12	07/11/2024	16:33	PO	1. CT Diagnostic testing work 2. CB Diagnostic work. 3. Bay Maintenance work.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
GHODBUNDER - GORAI	IntraState	29/07/2024	12:14			PO	Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.
220kV Koradi-2 - Uppalwadi ckt 2	IntraState	28/08/2024	00:14			T	Distance Protection
EKLAHARE (OCR) - PADGHE	IntraState	24/09/2024	07:48			HT	For load mgmt

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KARAD - DASGAON	IntraState	14/10/2024	15:46			PO	i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line. ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3). iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyna line
KALWA - PRINT HOUSE LINE	IntraState	15/10/2024	16:31			HT	Hand tripped at Kalwa end for load management.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	16/10/2024	16:01			HT	Line Hand tripped for load management on 220kv Ulve - Waghivali ckt no 1.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	17/10/2024	06:26			HT	H/T for controlling load of 220kv Ulve-Waghivali ckt-1
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kv Taloja.
KALWA - PRINT HOUSE LINE	IntraState	17/10/2024	12:23			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kv Taloja.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	05/11/2024	17:03			HT	Line hand trip for load management on 220kv Nashik Babhaleshawr ckt 1,2.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	05/11/2024	20:07			HT	Line hand trip for load management on 220kv Nashik Babhaleshawr ckt 1,2.
HINJAWADI I- CHINCHWAD	IntraState	07/11/2024	07:53	07/11/2024	20:41	HT	Load management.
KHARGHAR - NET MAGIC GIS	IntraState	07/11/2024	08:27	07/11/2024	16:36	EO	For Attending the Air leakage problem from 220kv Netmagic Breaker R phase pole
BOISAR II - TARAPUR	IntraState	07/11/2024	08:35	08/11/2024	18:46	PO	Boisar feeder outage is required to carry out routine Annual Maintenance of bay equipments
JEJURI (400kv) - LONAND CKT - 1	IntraState	07/11/2024	09:03	07/11/2024	10:16	EO	For attending hotspot of 82 deg. on R-ph CT to 29D isolator clamp.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	07/11/2024	09:15	07/11/2024	20:34	HT	Load management.
CHINCHWAD-2 - TELCO	IntraState	07/11/2024	09:56	07/11/2024	18:53	PO	Diagnostic Testing, Relay Testing and LA Replacement of R ph &Yph, Half Yearly Maintenance
NEW KOYNA - PEDAMBE	IntraState	07/11/2024	10:13	07/11/2024	14:30	EO	B phase CT to line side isolator conductor strands broken & Y phase main bus isolator to breaker conductor strand broken.
THEUR-PHURSUNGI CKT I	IntraState	07/11/2024	11:08	07/11/2024	19:44	EO	restoration of snapped earth wire at loc. no. 16 and 17
THEUR-PHURSUNGI CKT II	IntraState	07/11/2024	11:08	07/11/2024	19:44	EO	restoration of snapped earth wire at loc. no. 16 and 17
NEW TPS - WAGHALA CKT 1	IntraState	07/11/2024	12:10	07/11/2024	15:42	HT	Replacement of flash over disk.
ONI KHAREPATAN LINE	IntraState	07/11/2024	16:10	07/11/2024	22:08	T	Tripped on distance protection.
KALWA - BORIVALI	IntraState	07/11/2024	23:16		Continued.	PO	For Stringing of conductor on newly erected Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
BORIVALI - CTRLS CKT	IntraState	07/11/2024	23:19		Continued.	PO	For Stringing of conductor on newly erected Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ABHIJEET-WARDHA-II	IntraState	08/11/2024	07:45	08/11/2024	21:47	PO	1) RESTRINGING WORK FROM LOC NO 103 TO LOC NO 118.
ADLABS - PEDAMBE	IntraState	08/11/2024	08:33	08/11/2024	16:56	PO	For Cold washing of insulator strings, replacement of string, rusted/damaged nut bolts and other line maintenance work.
WATHAR - MUDSHINGI 3 LINE	IntraState	08/11/2024	10:28	08/11/2024	16:58	PO	B Ph LA IR value testing. Quarterly maintenance Work
220 KV GHUGGUS - ACC CKT	IntraState	08/11/2024	11:08	08/11/2024	18:22	PO	FOR REPLACEMENT OF R-PH 220 KV METERING PT DUE TO OIL LEAKAGE.
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	08/11/2024	16:45	08/11/2024	17:27	HT	TO CONTROL LOADING ON TAPTITANDA ICT II AS ICT I UNDER OUTAGE
KAMBA - VASAI	IntraState	08/11/2024	16:53		Continued.	T	Tripped on R to Y ph fault
220 KV ICT Outages/Trippings							
220/22KV 50MVA PTR 3 @ BHOSARI 2	IntraState	24/07/2024	23:02			T	Tripped due to caught fire.
220/132 KV 100 MVA ICT I @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/132 KV 100 MVA ICT II @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	29/10/2024	14:20			EO	To check I.R. value for Core to frame of 200MVA 220/100kV ICT-4
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	07/11/2024	08:57	07/11/2024	11:53	PO	For diagnostic testing work
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	07/11/2024	09:02	07/11/2024	14:54	HT	Attending oil leakage of ICT.
220/132 KV 200 MVA ICT 3 @ AMBAZARI	IntraState	07/11/2024	09:28	07/11/2024	19:20	HT	Yearly diagnostic testing work ,ctr fire protection maintenance, cold trail work.
220/132 KV 200 MVA ICT 3 @ WAGHALA NANDED	IntraState	07/11/2024	10:21	07/11/2024	17:49	HT	Tan delta test of winding, bushing , hv /lv cts.
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	07/11/2024	12:48	07/11/2024	16:54	PO	For Diagnostic testing
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	08/11/2024	08:37	08/11/2024	15:21	PO	Diagnostic work
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	08/11/2024	09:12	08/11/2024	17:40	PO	ATTENDING OIL LEAKAGE OF ICT.
220/33KV 50MVA TF NO.2 @ SAYNE	IntraState	08/11/2024	11:10	08/11/2024	17:17	PO	OLTC O/H work & diagnostic work of PTRII
40 MVA STATION TF - 1 @ KHAPERKHEDA	IntraState	08/11/2024	14:05	08/11/2024	16:08	PO	RENOVATION OF CT MBS & CB MB PANELS (4 NOS) , PROVIDING HINGES, CLEANING OF CB MB PANELS OF 220KV STN-1 BY NCCC TECH
220 KV BUSBAR Outages/Trippings							
MAIN BUS-1 @ EKLAHRE (GCR)-220 KV	IntraState	07/11/2024	13:25	07/11/2024	14:03	EO	Attending DC Leakage work
132 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 08/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MANSAR-PENCH	InterState	26/09/2024	14:40			HT	H/T at 132KV Pench end
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
110 KV LINE Outages/Trippings							
KHOPOLI - BHIVPURI CKT - 1	IntraState	08/11/2024	11:11	08/11/2024	16:29	PO	40/25

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage