

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Dec/2021 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.062	918.210	1) Gujrat	-6.596	-48.146
2) Hydro	7.432	52.501	2) Madhya Pradesh	3.625	35.378
3) Gas	3.477	27.440	3) Chattisgarh	5.100	38.040
Total MSPGCL	150.971	998.151	4) Maharashtra	133.520	887.914
B) 1) APLM	50.899	363.181	5) Goa (Amona)	-2.084	-12.321
2) JSWEL	14.381	99.916	Total	133.565	900.865
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.871	167.351
4) RPL(AMT)	24.608	164.429	b) Mumbai Drawl	29.584	176.768
5) SWPGPL	7.529	49.387	c) MSEDCL Bilateral *	54.939	249.918
6) Other IPP	37.119	231.577	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.871	167.351
C) 1) TPCL Thermal	8.134	72.385	Include PX	0.000	1.590
2) TPCL Hydro	5.260	28.971	Standby	0.000	0.000
3) TPCL Gas	2.380	18.983	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.422	67.073	1) MSEDCL	395.236	2653.854
D) STATE			2) Mumbai Discoms	54.780	364.177
1) Thermal	292.154	1966.158	3) Other Discoms	9.977	68.113
(A1+C1+C4+(B1-B6))			TOTAL STATE	459.993	3086.144
2) Hydro	12.692	81.472			
(A2+C2)					
3) Gas	5.857	46.423			
(A3+B7+C3)					
4) Wind	9.900	57.348			
6) SOLAR	5.825	33.881			
TOTAL STATE	326.428	2185.282			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6147	5185	6847	4766
MSPGCL Hydro	338	381	621	205
MSPGCL Gas	152	140	142	147
MSPGCL Total Generation	6637	5706	7610	5118
Central Sector Receipt	6395	7065	5791	4770
WIND	413	214	231	534
CPP / IPP Thermal	5849	5167	6105	5212
CPP / IPP Gas	0	0	0	0
SOLAR	821	939	0	0
Exchange with Mumbai	-1259	-1341	-1221	-977
MSEDCL DEMAND MET	6599	6683	6285	6057
Load Shedding	0	0	0	0
MSEDCL DEMAND	6599	6683	6285	6057
TPCL GENERATION	993	941	987	357
AEML GENERATION	500	471	488	348
MUMBAI DEMAND	2752	2753	2696	1682
OTHER DISCOM DEMAND	383	346	382	269
STATE DEMAND MET	21608	20503	21212	16339
STATE DEMAND	21608	20503	21212	16339
Frequency (Hz)	50.04	49.98	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 23.59 Hrs	49.75 Hz at 06.26 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.42	24.29	190	120
Unit 7	0.00	0.00	0	0
Unit 8	13.71	96.13	660	370
Unit 9	13.63	33.63	659	373
Unit 10	12.55	92.40	630	370
Total	43.30	246.46		
Bhusawal				
Unit 3	0.00	6.30	0	0
Unit 4	8.13	60.12	420	280
Unit 5	8.03	59.84	430	280
Total	16.16	126.26		
Parli				
Unit 6	0.00	3.90	0	0
Unit 7	0.00	0.00	0	0
Unit 8	2.72	7.14	198	0
Total	2.72	11.04		
Chandrapur				
Unit 3	2.91	3.51	140	106
Unit 4	3.37	15.47	159	124
Unit 5	7.98	40.56	390	295
Unit 6	1.91	36.23	315	0
Unit 7	7.81	56.14	364	284
Unit 8	9.14	65.04	405	337
Unit 9	8.52	65.25	380	317
Total	41.64	282.19		
Paras				
Unit 3	3.84	28.04	208	134
Unit 4	4.10	28.51	226	141
Total	7.94	56.55		
Khaparkheda				
Unit 1	2.96	22.10	145	110
Unit 2	3.17	22.14	160	120
Unit 3	3.34	23.92	161	120
Unit 4	3.21	17.71	150	123
Unit 5	9.60	66.74	500	282
Total	22.29	152.61		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.00	21.13	141	119
Unit 5	3.01	21.97	166	115
Total	6.01	43.10		
Uran				
All Units	3.48	27.44	157	138
Total	3.48	27.44		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.17	0.50	47	0
Total	0.17	0.50		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.28	15.22	460	40
Stage 4	0.12	4.26	85	0
Stage 3	0.30	4.66	160	0
Total	2.70	24.14		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.66	0.66	58	0
BHIRA T.R.	0.30	1.74	80	0
SMLHY_PTN	3.77	25.97	160	147
GHATGHAR	0.00	0.00	0	0
Total	4.73	28.36		
Wind				
Total	9.90	57.35	0	0
Total	9.90	57.35		
CPP				
APML(Mus)	50.90	363.18	0	0
JSWEL(Mus)	14.38	99.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.61	164.43	0	0
SWPGPL-Mus	7.53	49.39	0	0
Other(Mus)	37.12	231.58	0	0
Total	134.54	908.49		
SOLAR				
Total	5.82	33.88	0	0
Total	5.82	33.88		
Tata				
Trombay 5	8.13	50.58	474	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.31	11.46	69	49
Trombay 7B	1.07	7.52	53	40
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.26	28.97	439	0
Total	15.77	120.34		
AEMIL				
DTPS U-1&2	9.42	67.07	500	320
Total	9.42	67.07		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.06	918.21	MSPGCL Total	150.97	998.15
			MSPGCL Thml+Gas	143.54	945.65	Koyna 1,2 & 4 Total	2.40	19.48
			MSPGCL Hydro	7.43	52.50	State Total	326.43	2185.28

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 07/Dec/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4673	204	146	5023	349	5243	0	0	5067	5110	-1109	14309	0	14309	1887	307	16503	50.01
2	4706	205	156	5067	470	5246	0	0	4955	5017	-1029	14484	0	14484	1767	287	16538	49.99
3	4766	205	147	5118	534	5212	0	0	4884	4770	-977	14388	0	14388	1682	269	16339	50.00
4	4841	209	146	5196	623	5232	0	0	4905	4718	-917	14571	0	14571	1633	281	16485	50.02
5	5397	219	144	5760	701	5191	0	0	4935	4524	-929	14959	0	14959	1633	288	16880	50.05
6	5654	199	157	6010	794	5314	0	0	5508	5191	-990	16009	0	16009	1706	310	18025	49.96
7	6157	279	147	6583	863	5725	0	3	5345	5343	-922	17269	0	17269	1820	326	19415	49.88
8	6471	263	148	6882	832	6195	0	89	5551	5622	-1031	18239	0	18239	2017	350	20606	50.00
9	6513	232	146	6891	593	6505	0	315	5842	5716	-1320	18341	0	18341	2294	359	20994	50.02
10	6532	257	144	6933	471	6393	0	599	6377	5931	-1344	18605	0	18605	2570	378	21553	50.03
11	6147	338	152	6637	413	5849	0	821	6771	6395	-1259	18473	0	18473	2752	383	21608	50.04
12	5792	349	141	6282	373	5595	0	970	6702	6126	-1292	17682	0	17682	2795	372	20849	50.00
13	5185	381	140	5706	214	5167	0	939	6776	7065	-1341	17404	0	17404	2753	346	20503	49.98
14	5187	483	139	5809	150	5073	0	819	6685	6634	-1460	16673	0	16673	2631	352	19656	49.99
15	5632	665	138	6435	110	5208	0	661	6609	6905	-1627	17339	0	17339	2626	353	20318	49.98
16	6491	265	138	6894	68	5779	0	406	6162	5991	-1568	17210	0	17210	2648	360	20218	49.97
17	6520	265	139	6924	92	5951	0	176	5881	5847	-1374	17249	0	17249	2639	367	20255	50.01
18	6644	257	150	7051	155	6110	0	27	5461	5390	-1172	17173	0	17173	2651	388	20212	50.00
19	6847	621	142	7610	231	6105	0	0	5682	5791	-1221	18134	0	18134	2696	382	21212	50.00
20	6846	337	143	7326	284	6313	0	0	5653	5257	-1286	17510	0	17510	2604	384	20498	50.03
21	6556	209	143	6908	376	5881	0	0	5126	4800	-1334	16261	0	16261	2455	370	19086	50.00
22	5717	358	143	6218	374	5370	0	0	5266	5386	-1481	15518	0	15518	2307	349	18174	50.03
23	5577	379	143	6099	391	5183	0	0	5301	5097	-1364	15048	0	15048	2166	358	17572	50.04
24	5211	253	145	5609	439	4696	0	0	5174	4939	-1237	14110	0	14110	2048	336	16494	50.03
MUs	140.06	7.43	3.48	150.97	9.90	134.54	0.00	5.82	136.62	133.57	-29.58	396.96	0.00	396.96	54.78	8.26	459.99	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 07/Dec/2021

Position as on 6.30 Hrs of 08/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-4	660	10/11/2021	23.58		Continued.	Capital Overhauling	10/12/2021
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09.55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Koyna Unit 4	70	08/12/2021	12:00	08/12/2021	17:20	TESTING WORK	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Uran Unit 5	108	07/11/2021	23.28		Continued.	Turbine problem.	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Parli Unit 7	250	28/11/2021	23.57		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	02/12/2021	00:00		Continued.	ZERO SCHEDULE	
MSPGCL	Parli Unit 8	250	02/12/2021	04:00	07/12/2021	04:01	ZERO SCHEDULE	07/12/2021
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	02/12/2021	23:25		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	05/12/2021	10:08	07/12/2021	16:35	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 5	500	08/12/2021	02:31	08/12/2021	05:38	ID Fan Problem	08/12/2021
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00		Continued.	CHP coal feeding problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 07/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 08/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Tripping							
765/400KV 1500MVA ICT-1 @ KORADI 3	IntraState	07/12/2021	09:36	07/12/2021	19:37	PO	Annual Maintenance of 765/400KV ICT-1
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	08/12/2021	21:05	08/12/2021	22:36	EO	For Attending RED HOT at pole-1 base filter z11- z2 at jumper connecting to IPS
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	08/12/2021	21:05	08/12/2021	22:36	HT	base filter hot spot attending work
400 KV TIEBAY Outages/Tripping							
TIE BAY (414) OF PADGHE PG CKT - 1 @ KUDUS	InterState	08/12/2021	11:49	08/12/2021	18:04	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV LR Outages/Tripping							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	07/12/2021	10:37	07/12/2021	18:37	PO	To attend hot spot (71 o C) at 29D line isolator centre contact
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	08/12/2021	09:40	08/12/2021	13:38	PO	For attending hot spot at 29A Y phase isolator by Hot line unit Nagpur. Also, replacement of hanger rod of isolator.A/R required in non auto mode.The ckt will be shifted on TBC
400 KV LINE Outages/Tripping							
DHULE - KHANDWA CKT - 1	InterState	08/12/2021	08:53		Continued.	PO	Simultaneous outage of 400kV Khandwa-Dhule-1 & 2 for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam
DHULE - KHANDWA CKT - 2	InterState	08/12/2021	08:53		Continued.	PO	Simultaneous outage of 400kV Khandwa-Dhule-1 & 2 for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam
JAIGAD - KARAD CKT - 1	IntraState	02/12/2021	22:21	07/12/2021	10:08	HT	HT FOR OVERVOLTAGE
EKTUNI - BABLESHWAR CKT - 1	IntraState	06/12/2021	20:02	07/12/2021	00:59	EO	Attending red hot spots of Ektuni Babhaleshwar ckt 1
KARAD - TALANDGE CKT - 1	IntraState	06/12/2021	22:50	08/12/2021	08:26	HT	Handtripped for Over Voltage
LONIKAND I - KOYNA STAGE-IV	IntraState	06/12/2021	22:54	07/12/2021	09:48	HT	Handtripped for Over Voltage
EKTUNI - TAPTITANDA CKT - 2	IntraState	07/12/2021	11:41	07/12/2021	17:35	PO	Relay testing, CT CAP , Tan delta measurement
PADGHE - NAGOTHANE CKT - 2	IntraState	07/12/2021	13:07	07/12/2021	19:22	PO	earth wire Replacement and jumper tightening work
TBC @ BABHALESHWAR	IntraState	07/12/2021	14:04	07/12/2021	17:50	PO	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work
JAIGAD - KARAD CKT - 2	IntraState	07/12/2021	22:13	08/12/2021	10:22	HT	HT for Overvoltage
KARAD - TALANDGE CKT - 2	IntraState	07/12/2021	23:27	08/12/2021	08:26	HT	HT for OVERVOLTAGE
BUS REACTOR 50MVAR @ PARLI	IntraState	08/12/2021	09:51	08/12/2021	15:46	PO	1) C & tan delta measurement of reactor. (2) Reactor maintenance work.
JAIGAD - KARAD CKT - 1	IntraState	08/12/2021	23:03		Continued.	HT	over voltage control
LONIKAND I - KOYNA STAGE-IV	IntraState	08/12/2021	23:06		Continued.	HT	over voltage control
400 KV ICT Outages/Tripping							
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	07/12/2021	10:26	07/12/2021	16:14	PO	Outage for 400 kV side CB timing,CRM & DCRM

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 07/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 08/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	IntraState	07/12/2021	13:43		Continued.	EO	Retrofitting of Numerical REF relay & Trip relay under MTAMC project work.
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	08/12/2021	11:00	08/12/2021	18:32		1) For Diagnostic Testing Work 2) Bay Maint work
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	08/12/2021	05:02	08/12/2021	10:40	PO	For safety purpose for the scheme of Replacement of TOP phase conductor of 220kv Boisar - PGCIL line no.02 at loc. No07 -08 & 08-09.
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
BIDRI - SAWANTWADI	IntraState	06/12/2021	22:15	07/12/2021	09:45	HT	Over Voltage of 238 kV at Bidri
LOTEPARSHURAM- DASTURI LINE	IntraState	07/12/2021	10:06	07/12/2021	17:33	PO	1) New Earth wire stringing work over 220KV Bus section-II. 2) 220KV Lote-Dasturi line isolator alignment work
NAGOTHANE - SPCL	IntraState	07/12/2021	10:19	07/12/2021	18:04	PO	for Diagnostic testing work at Nagothane s/s
KHARGHAR - BORIVALI CKT - 2	IntraState	07/12/2021	13:33	07/12/2021	18:27	PO	For carrying out the bunching work at Loc. No 48 to LILO LOC. No 01 of Tiffil S/St it will form 220 KV Kharghar Tifil Borivali TAP Line for the period of outage.
KHARGHAR - BORIVALI CKT - 2	IntraState	08/12/2021	07:20	08/12/2021	12:34	PO	For carrying out the bunching work at Loc. No 48 to LILO LOC. No 01 of Tiffil S/St it will form 220 KV Kharghar Tifil Borivali TAP Line for the period of outage.
KALWA - TFIPL	IntraState	08/12/2021	08:13		Continued.	PO	For carrying out jumpering at Loc. 48 to LILO Loc. No 01 to form 220 KV Kharghar Tiffil Borivali TAP Line during the period 07.12.2021 to 09.12.2021.
KHAREPATAN -PAWAS LINE	IntraState	08/12/2021	08:22	08/12/2021	18:28	PO	Replacement of insulators, detected faulty in PID testing.
OSMANABAD - BARSHI	IntraState	08/12/2021	09:48	08/12/2021	14:10	PO	Outage is required for Quarterly Maintenance
NERLE - PEDAMBE	IntraState	08/12/2021	09:50	08/12/2021	18:40	PO	For replacement of damaged conductor at both side of Y-ph at Loc no.64.
NAGOTHANE - IPCL	IntraState	08/12/2021	09:50	08/12/2021	15:38	PO	for Diagnostic testing work at Nagothane s/s.
ANANDNAGAR - PALAVA	IntraState	08/12/2021	11:11	08/12/2021	13:35	PO	For replacement of faulty Air pressure switch
KHARGHAR - BORIVALI CKT - 1	IntraState	08/12/2021	13:02		Continued.	PO	For carrying out the Jumpering for making LILO at Loc. No 48 of 220 KV Kharghar Borivali Ckt-1 Line for Power supply of 30 MVA (1 50MVA) to Newly proposed 220/22 KV GIS S/St at M/S CTRLS Mahape
TROMBAY SALSETTE LINE-2	IntraState	08/12/2021	15:12	08/12/2021	17:28	EO	For removing hanging object
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB
VANKUSWADE - AJINKYATARA	IntraState	08/12/2021	18:25		Continued.	EO	Attending hot spot at Loc No-97 B ph
TROMBAY - SALSETTE CKT - 1	IntraState	08/12/2021	22:52		Continued.		Metro work
TROMBAY SALSETTE LINE-2	IntraState	08/12/2021	23:23		Continued.		Metro work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 08/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	07/12/2021	09:18	07/12/2021	17:34	PO	Diagnostic Testing work & oil leakage attending work.
220/132-110 KV 200MVA ICT @ OGLEWADI	IntraState	07/12/2021	10:02	07/12/2021	16:09	PO	1. Q.M work 2. Diagnostic testing work
220/33 KV 50 MVA PTR 2	IntraState	07/12/2021	10:02	07/12/2021	16:10	PO	1) New Earth wire stringing work over 220KV Bus section-II. 2) 220/33 KV 50 MVA CGL TF no 2 quarterly maintenance work
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	07/12/2021	11:03		Continued.	PO	CB pole overhauling work by agency.
220/22 KV 50 MVA PTR 1 @ MULUND	IntraState	07/12/2021	11:37	07/12/2021	14:57	EO	For Replacement of B Phase LV Bushing dropper jumper.
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	08/12/2021	14:18	08/12/2021	18:30	PO	220kV CB diagnostic testing and for attending TC2 unhealthy status
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	08/12/2021	06:14		Continued.		For formation of three terminal line Kalyan Mukund Kalwa line

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage