

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 07/Dec/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.229	1040.689	1) Gujrat	-4.131	-33.840
2) Hydro	19.600	86.479	2) Madhya Pradesh	4.852	4.352
3) Gas	5.543	39.044	3) Chattisgarh	6.690	35.660
Total MSPGCL	165.372	1166.212	4) Maharashtra	167.726	1148.459
B) 1) APLM	76.061	515.804	5) Goa (Amona)	-1.629	-10.069
2) JSWEL	11.752	83.623	Total	173.508	1144.562
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.498	191.999
4) RPL(AMT)	25.524	203.951	b) Mumbai Drawl	33.530	227.316
5) SWPGPL	7.865	54.225	c) MSEDCL Bilateral *	73.443	439.437
6) Other IPP	46.956	315.438	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.498	191.999
C) 1) TPCL Thermal	12.291	77.984	Include PX	0.000	0.000
2) TPCL Hydro	4.544	26.067	Standby	0.000	0.000
3) TPCL Gas	1.983	12.229	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.276	69.745	1) MSEDCL	482.506	3313.594
D) STATE			2) Mumbai Discoms	62.622	413.338
1) Thermal	330.954	2361.459	3) Other Discoms	9.578	65.796
(A1+C1+C4+(B1-B6))			TOTAL STATE	554.706	3792.728
2) Hydro	24.144	112.546			
(A2+C2)					
3) Gas	7.526	51.273			
(A3+B7+C3)					
4) Wind	8.667	49.748			
6) SOLAR	9.909	73.143			
TOTAL STATE	381.200	2648.169			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6164	6143	5846	5582
MSPGCL Hydro	1660	504	1841	164
MSPGCL Gas	230	225	226	234
MSPGCL Total Generation	8054	6872	7913	5980
Central Sector Receipt	8831	8626	6801	5566
WIND	223	251	221	623
CPP / IPP Thermal	6932	6958	7315	6974
CPP / IPP Gas	0	0	0	0
SOLAR	1387	1592	0	0
Exchange with Mumbai	-1802	-1766	-1400	-1473
MSEDCL DEMAND MET	23176	22107	20408	17276
Load Shedding	0	0	0	0
MSEDCL DEMAND	23176	22107	20408	17276
TPCL GENERATION	881	864	1099	613
AEML GENERATION	500	501	498	325
MUMBAI DEMAND	3183	3131	2997	2411
OTHER DISCOM DEMAND	449	426	442	394
STATE DEMAND MET	26808	25664	23847	20081
STATE DEMAND	26808	25664	23847	20081
Frequency (Hz)	49.94	50.01	50.11	49.92

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 24:00 Hrs	49.61 Hz at 16:30 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 07/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.00	35.38	215	190
Unit 7	0.00	0.00	0	0
Unit 8	13.50	91.48	587	539
Unit 9	13.33	93.21	570	540
Unit 10	13.02	92.42	575	515
Total	44.84	312.48		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.80	68.10	475	310
Unit 5	10.98	70.34	495	360
Total	21.78	138.44		
Parli				
Unit 6	4.61	30.34	233	147
Unit 7	4.95	30.80	248	144
Unit 8	2.09	23.29	177	0
Total	11.64	84.43		
Chandrapur				
Unit 3	3.74	24.78	170	125
Unit 4	3.41	23.03	163	121
Unit 5	7.15	48.70	320	275
Unit 6	6.56	46.01	290	260
Unit 7	0.00	0.00	0	0
Unit 8	0.95	32.78	281	0
Unit 9	10.33	70.62	495	335
Total	32.15	245.92		
Paras				
Unit 3	5.01	35.52	222	195
Unit 4	5.02	36.13	219	199
Total	10.02	71.65		
Khaparkheda				
Unit 1	3.14	19.58	140	115
Unit 2	3.22	19.70	150	110
Unit 3	3.70	25.81	180	130
Unit 4	3.50	23.50	161	125
Unit 5	0.00	54.80	0	0
Total	13.56	143.38		
Nasik				
Unit 3	3.02	23.31	158	0
Unit 4	3.21	21.08	148	114
Unit 5	0.00	0.00	0	0
Total	6.24	44.39		
Uran				
All Units	5.54	39.04	241	219
Total	5.54	39.04		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.20	0.87	47	0
Total	0.20	0.87		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.82	23.38	510	35
Stage 4	7.10	25.93	753	0
Stage 3	2.70	10.69	298	0
Total	15.62	60.00		
Hydro				
KDPH	0.43	3.02	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.52	3.65	58	0
BHIRA T.R.	0.28	1.36	80	0
SMLHY_PTN	1.81	14.26	79	73
GHATGHAR	0.73	3.31	125	0
Total	3.77	25.62		
Wind				
Total	8.67	49.75	0	0
Total	8.67	49.75		
CPP				
APML(Mus)	76.06	515.80	0	0
JSWEL(Mus)	11.75	83.62	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.52	203.95	0	0
SWPGPL-Mus	7.86	54.22	0	0
Other(Mus)	46.96	315.44	0	0
Total	168.16	1173.04		
SOLAR				
Total	9.91	73.14	0	0
Total	9.91	73.14		
Tata				
Trombay 5	8.38	52.24	479	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.07	6.69	49	40
Trombay 7B	0.91	5.54	41	35
TATA Hydro	4.54	26.07	361	11
Trombay 8	3.91	25.74	225	129
Total	18.82	116.28		
AEMIL				
DTPS U-1&2	10.28	69.74	502	320
Total	10.28	69.74		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.23	1040.69	MSPGCL Total	165.37	1166.21
			MSPGCL Thml+Gas	145.77	1079.73	Koyna 1,2 & 4 Total	12.92	49.31
			MSPGCL Hydro	19.60	86.48	State Total	381.20	2648.17

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 07/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5333	126	236	5695	530	7030	0	0	6448	6321	-1324	17900	0	17900	2214	352	20466	50.07
2	5473	127	237	5837	617	7004	0	0	6171	6025	-1190	17952	0	17952	2060	341	20353	50.03
3	5507	127	238	5872	594	7001	0	0	6161	6143	-1112	18176	0	18176	1949	322	20447	49.94
4	5611	127	239	5977	578	6993	0	0	6130	6237	-1054	18409	0	18409	1877	322	20608	49.83
5	5804	189	238	6231	508	7010	0	0	6387	6542	-1050	18904	0	18904	1872	337	21113	49.93
6	5991	408	237	6636	413	7014	0	0	6974	7243	-1138	19823	0	19823	1983	345	22151	49.98
7	6049	1229	241	7519	360	6972	0	4	6703	7333	-1159	20644	0	20644	2165	385	23194	50.01
8	6060	1632	238	7930	325	7049	0	155	6097	7312	-981	21393	0	21393	2384	397	24174	49.90
9	6080	1666	237	7983	252	6967	0	522	7214	7562	-1106	21755	0	21755	2731	425	24911	50.02
10	6107	1778	234	8119	222	6942	0	953	7875	8441	-1646	22589	0	22589	2994	442	26025	49.93
11	6164	1660	230	8054	223	6932	0	1387	8668	8831	-1802	23176	0	23176	3183	449	26808	49.94
12	6168	495	228	6891	253	6940	0	1451	9358	9185	-1782	22505	0	22505	3158	433	26096	49.93
13	6143	504	225	6872	251	6958	0	1592	8731	8626	-1766	22107	0	22107	3131	426	25664	50.01
14	6074	349	222	6645	183	6975	0	1460	8530	8522	-1662	21700	0	21700	3014	423	25137	50.11
15	5941	716	219	6876	180	6987	0	1198	8971	8868	-1670	22017	0	22017	3029	422	25468	49.99
16	5865	1166	220	7251	155	6980	0	807	8572	8676	-1638	21794	0	21794	3062	437	25293	50.02
17	5830	1577	223	7630	165	7018	0	284	7411	7742	-1505	20902	0	20902	3024	432	24358	49.83
18	5837	1692	225	7754	135	7223	0	96	7064	7003	-1401	20378	0	20378	2965	432	23775	50.01
19	5846	1841	226	7913	221	7315	0	0	6616	6801	-1400	20408	0	20408	2997	442	23847	50.11
20	5904	1363	224	7491	271	7005	0	0	6431	6302	-1269	19368	0	19368	2859	432	22659	50.03
21	5856	282	227	6365	432	6972	0	0	6534	6236	-1470	18128	0	18128	2690	407	21225	49.99
22	5510	175	230	5915	566	6917	0	0	6369	6208	-1511	17695	0	17695	2539	400	20634	49.99
23	5582	164	234	5980	623	6974	0	0	5952	5566	-1473	17276	0	17276	2411	394	20081	49.92
24	5494	207	235	5936	610	6980	0	0	5815	5783	-1421	17506	0	17506	2333	382	20221	50.00
MUs	140.23	19.60	5.54	165.37	8.67	168.16	0.00	9.91	171.18	173.51	-33.53	482.51	0.00	482.51	62.62	9.58	554.71	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 07/Dec/2022

Position as on 6.30 Hrs of 08/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	07/12/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	UNIT IS READY(UNIT UNDER TOLLING from 20.11.2022)	07/12/2022
MSPGCL	Koyna Unit 4	70	28/11/2022	10:20	07/12/2022	22:00	Due to Injector No 1 Coller ring Broken.	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
MSPGCL	Chandrapur Unit 8	500	04/12/2022	14:12	07/12/2022	19:19	CONDENSER TUBE LEAKAGE (SILICA ON HIGHER SIDE)	07/12/2022
IPP	RPL(AMT) U-3	270	05/12/2022	12:00		Continued.	Coal Shortage	08/12/2022
MSPGCL	Khaparkheda Unit 5	500	06/12/2022	12:50		Continued.	Boiler Tube Leakage	09/12/2022
MSPGCL	Parli Unit 8	250	07/12/2022	13:28		Continued.	Boiler Tube Leakage	09/12/2022
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage	08/12/2022
MSPGCL	Uran Unit B0	120	08/12/2022	09:37		Continued.	tripped on Generator exciter end vibration high	
IPP	SWPGPL U-3	135	08/12/2022	09:56		Continued.	BOILER SSC CHAIN PROBLEM	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 07/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 08/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BR Outages/Tripping							
BUS REACTOR (240 MVar) @ EKTUNI	IntraState	08/12/2022	11:15			PO	Diagnostic, Relay Testing & Routine Maintenance
400 KV TIEBAY Outages/Tripping							
TIE BAY (417) OF ST - 3 AND ST-5 @ TIRORA	IntraState	08/12/2022	09:00			PO	For bay equipment maintenance and testing work
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (415) OF PADGHE PG CKT - 1 @ KUDUS	InterState	08/12/2022	11:00			PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
MAIN BAY (406) OF LINE- 3 @ KORADI 3	IntraState	08/12/2022	08:54			PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
JAIGAD - KARAD CKT - 1	IntraState	07/12/2022	19:25	08/12/2022	09:55	HT	to control overvoltage
PARLI-SOLAPUR (LAMBOTI)	IntraState	08/12/2022	08:06			PO	Replacement of string
LONIKAND - JEJURI CKT - 1	IntraState	08/12/2022	08:47			PO	DT and Line Maintenance
CHANDRAPUR 2 - WARORA CKT-2	IntraState	08/12/2022	08:48			PO	Conductor & Earthwire Hardware tightening work
400 KV ICT Outages/Tripping							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	03/12/2022	09:20			PO	FOR CB replacemnt work
400/220/33 KV 500 MVA ICT - 2 @ DHULE	IntraState	06/12/2022	10:57			PO	400/220/33kv 501MVA ICT 2 HV side 400kV Circuit breaker mechanism Overhauling & servicing work
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	07/12/2022	21:00	08/12/2022	04:11	PO	Oil pump replacement work and Bay maintenance and diagnostic work. chemical washing of equipment.
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	08/12/2022	11:20			PO	For Overhauling of Bus B 89B Rph, Yph, Bph and Bus C 89C Rph, Yph, Bph PG Isolators and Routine Testing and Maintenance Wodrk.
220 KV LINE Outages/Tripping							
NALASOPARA - BOISAR PG	InterState	07/12/2022	21:55	08/12/2022	07:37	HT	Attending hot spot work
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KALWA SALSETTE - 3	IntraState	01/12/2022	22:23			EO	Interchanging of BUS of 220KV Kalwa-Salshette-3 & 220KV Kalwa -Salshette-4 to free 220 kv TBC. 220 kv Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 07/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 08/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA SALSETTE - 4	IntraState	01/12/2022	22:42			EO	Interchanging of BUS of 220 kV Kalwa-Salsette-3 & 220 kV Kalwa-Salsette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
EKLAHARE (OCR) - PADGHE	IntraState	06/12/2022	09:19			HT	to control overloading
KARAD - DASGAON	IntraState	06/12/2022	10:23	07/12/2022	18:18	PO	For CT Tan Delta & quarterly Maintenance work.
RANJANGAON - U TECH SUGAR CKT	IntraState	06/12/2022	10:55	07/12/2022	17:45	PO	220kV CB Mechanisam oherhuling work
BHUGAON - WARDHA (PG)	IntraState	07/12/2022	07:30	07/12/2022	11:07	HT	For controlling OD
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	07/12/2022	07:43	07/12/2022	10:54	HT	For controlling OD
SHEDYAL-JATH	IntraState	07/12/2022	10:15	07/12/2022	18:25	PO	Cold line washing work
WARDHA - WARDHA (PG)	IntraState	07/12/2022	10:22	07/12/2022	11:10	HT	For controlling OD
KARAD - VITA CKT- 1	IntraState	07/12/2022	12:15	07/12/2022	15:46	PO	Quarterly maintenance work of Auxilairy isolator and line isolator of line bay at 220kV Vita end.
PEDAMBE-KALAMBANI(TSS)	IntraState	07/12/2022	13:02	07/12/2022	15:48	EO	For replacement of flashover string loc no 111B Y ph top ph Kalambani side
OSMANABAD - PARLY (PG)	IntraState	07/12/2022	14:01	07/12/2022	19:05	PO	LINE/ s/s maintenance
BHUGAON - WARDHA (PG)	IntraState	07/12/2022	16:28	07/12/2022	20:21	HT	For controlling OD
PUSAD - WARDHA (PG)	IntraState	07/12/2022	16:36	07/12/2022	17:49	HT	For controlling OD
WALUJ - CHITEGAON II	IntraState	07/12/2022	16:47	07/12/2022	20:21	HT	For controlling OD
NEW KOYNA - LOTEPARSHURAM	IntraState	07/12/2022	16:50	07/12/2022	20:27	PO	For Cold washing of insulator strings
MHAISHAL - SHEDYAL	IntraState	08/12/2022	09:25			PO	Cold line washing work
EKLAHARA(OCR)-RAYMOND	IntraState	08/12/2022	10:20			PO	attending red hot at locn no. 4,7,1 & 2 of LIL0 of 220kV Raymond OCR line. temp at locn 1-Rph 83.4degC. locn 2 Rph 97.8DegC, locn no.4-70.8degC, locn no.7-80.4Deg C
BIDRI - SAWANTWADI	IntraState	08/12/2022	10:33			PO	Replacement of flashover string at Loc. No.30 Y Ph & insulator cleaning at loc.No.29 & 31
BARAMATI- KALYANI	IntraState	08/12/2022	11:40	08/12/2022	12:37	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK.
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	IntraState	08/12/2022	12:26			PO	Replacement of Jumper of B phase wavetrap
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	07/12/2022	09:25	07/12/2022	19:13	PO	Diagnostic testing and RM Work.
220/132 KV 200 MVA ICT 2@ BALE(SOLAPUR)	IntraState	07/12/2022	09:33	07/12/2022	18:34	PO	Outage is required for Seperation of LA & ICT bushing jumps
220/22kV 25 MVA TF - 1 @ VILE-BHAGAD	IntraState	07/12/2022	10:10	07/12/2022	14:38	PO	1.Winding resistance testing work & Other maintenance work.
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	07/12/2022	11:15	07/12/2022	17:05	PO	For attending oil leakage work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 07/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 08/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	07/12/2022	12:25	07/12/2022	21:44		1. For replacement of punctured Aircell. 2. Attending hotspot on B Phase CT. Temp. 114 Degr. C. 3. Replacement of Broken Jumper of B Phase CT 4. Diagnostic testing work. 5. Pending MTAMC work
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	08/12/2022	10:00			PO	220kV CB Mechanism Overhauling work
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	08/12/2022	12:04			PO	Hot spots attending work
220 KV BUSBAR Outages/Trippings							
GIS MAIN BUS @ HINJEWADI 2	IntraState	07/12/2022	09:55	07/12/2022	13:38	PO	M 2 maintenance of GIS Bus by M/s GE
132 KV TBC Outages/Trippings							
INTERCONNECTOR @ EKLAHARE (GCR)	IntraState	07/12/2022	13:44	07/12/2022	15:48	EO	Hotspot attending work, Diagnostic Testing work and Bay maintenance work.
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	08/12/2022	10:46			PO	AATENDING HOT SPOT AT LOC -111

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage