

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 08/Feb/2018 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	120.638	956.519	1) Gujrat	1.251	2.811
2) Hydro	11.836	88.575	2) Madhya Pradesh	17.658	141.344
3) Gas	8.298	68.133	3) Chattisgarh	7.000	64.240
Total MSPGCL	140.772	1113.227	4) Maharashtra Net	105.524	863.530
B) 1) APML	52.320	409.489	5) Goa (Amona)	-0.682	-5.258
2) JSWEL	18.117	141.341	Total	130.751	1066.667
3) VIPL	6.176	48.825	a) Mumbai Schedule	21.677	174.254
4) RPL(AMT)	22.235	179.517	b) Mumbai Drawl	25.712	193.950
5) WPCL	4.461	33.808	c) MSEDCL Bilateral *	21.671	182.931
6) PGPL	0.000	0.000	Include PX	3.315	35.703
7) Other IPP	12.146	99.614	d) Mumbai Bilateral *	21.677	170.441
C) 1) TPCL Thermal	14.246	116.708	Include PX	9.702	70.891
2) TPCL Hydro	4.259	21.893	Include Standby	0.000	3.813
3) TPCL Gas	2.953	29.381	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	6.347	52.136	1) MSEDCL	370.487	2965.173
D) STATE			2) Mumbai Discoms	53.517	414.069
1) Thermal	256.686	2037.957	TOTAL STATE	424.004	3379.242
(A1+C1+C4+(B1-B6))					
2) Hydro	16.095	110.468			
(A2+C2)					
3) Gas	11.251	97.514			
(A3+B6+C3)					
4) Wind	5.760	40.616			
6) SOLAR	3.461	26.019			
TOTAL STATE	293.253	2312.574			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5325	5430	4911	4422
MSPGCL Hydro	1140	949	497	219
MSPGCL Gas	420	283	288	411
MSPGCL Total Generation	6885	6662	5696	5052
Central Sector Receipt	6450	6306	5395	4534
WIND	125	176	405	128
CPP / IPP Thermal	5428	5259	4530	4128
CPP / IPP Gas	0	0	0	0
SOLAR	381	505	0	0
Exchange with Mumbai	-1296	-1367	-1189	-685
MSEDCL DEMAND MET	17973	17541	14837	13157
Load Shedding	0	0	0	0
MSEDCL DEMAND	17973	17541	14837	13157
TPCL GENERATION	1210	1125	1006	624
R-INFRA GENERATION	251	250	377	195
MUMBAI DEMAND	2757	2742	2572	1504
STATE DEMAND MET	20730	20283	17409	14661
STATE DEMAND	20730	20283	17409	14661
Frequency (Hz)	49.97	50.01	49.93	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 13.00 Hrs	49.74 Hz at 16.21 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 08/Feb/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.75	88.62	486	346
Unit 9	0.00	0.00	0	0
Unit 10	13.11	87.88	660	460
Total	23.86	176.50		
Bhusawal				
Unit 3	4.29	24.39	200	160
Unit 4	10.03	80.97	495	350
Unit 5	10.04	81.33	490	350
Total	24.36	186.69		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.74	41.76	248	143
Unit 7	0.00	0.00	0	0
Unit 8	4.88	39.74	233	182
Total	9.62	81.50		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	52.70	0	0
Unit 6	0.00	0.00	0	0
Unit 7	9.97	79.93	450	355
Unit 8	10.90	62.53	499	360
Unit 9	10.82	86.25	497	361
Total	31.70	281.41		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.47	43.43	254	186
Total	5.47	43.43		
Khaparkheda				
Unit 1	3.78	28.82	165	150
Unit 2	0.00	7.54	0	0
Unit 3	0.00	0.00	0	0
Unit 4	3.72	29.66	160	150
Unit 5	10.00	55.48	480	356
Total	17.51	121.50		
Nasik				
Unit 3	4.14	33.44	192	157
Unit 4	4.00	32.06	178	153
Unit 5	0.00	0.00	0	0
Total	8.13	65.49		
Uran				
All Units	8.30	68.13	460	272
Total	8.30	68.13		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	0.92	21	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.10	0.92		
Koyna				
Stage 1-2	3.16	21.04	445	40
Stage 4	2.55	19.70	611	0
Stage 3	1.45	9.21	160	0
Total	7.15	49.96		
Hydro				
KDPH	0.63	6.50	36	18
VTRNA	1.07	8.98	61	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.12	0.85	80	0
RNGR+BHTSA	0.34	2.92	15	14
BHANDARDRA	0.48	3.58	30	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.84	6.94	45	32
GHATGHAR	1.21	8.84	125	0
Total	4.68	38.62		
Wind				
Total	5.76	40.62	0	0
Total	5.76	40.62		
CPP				
APML(Mus)	52.32	409.49	0	0
JSWEL(Mus)	18.12	141.34	0	0
VIPL(Mus)	6.18	48.82	0	0
RPLAMT(Mus)	22.24	179.52	0	0
WPCL(Mus)	4.46	33.81	0	0
Other(Mus)	12.15	99.61	0	0
Total	115.46	912.59		
SOLAR				
Total	3.46	26.02	0	0
Total	3.46	26.02		
Tata				
Trombay 5	9.09	74.94	491	299
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.67	17.75	72	65
Trombay 7B	1.28	11.63	55	52
Trombay 8	5.15	41.76	240	198
TATA Hydro	4.26	21.89	363	0
Total	21.46	167.98		
R-INFRA				
DTPS U-1&2	6.35	52.14	378	193
Total	6.35	52.14		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	120.64	956.52	MSPGCL Total	140.77	1113.23
			MSPGCL Thml+Gas	128.94	1024.65	Koyna 1,2 & 4 Total	5.71	40.75
			MSPGCL Hydro	11.84	88.58	State Total	293.25	2312.57

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Feb/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4414	205	340	4959	153	4126	0	0	4956	5106	-962	13382	0	13382	1778	15160	49.95
2	4415	214	386	5015	137	4142	0	0	4829	4841	-818	13317	0	13317	1636	14953	49.98
3	4413	225	401	5039	118	4121	0	0	4836	4652	-732	13198	0	13198	1549	14747	49.99
4	4422	219	411	5052	128	4128	0	0	4851	4534	-685	13157	0	13157	1504	14661	50.02
5	4524	214	417	5155	189	4179	0	0	4936	4880	-689	13715	0	13715	1509	15224	50.01
6	4991	257	406	5654	212	4488	0	0	5143	5420	-805	14969	0	14969	1626	16595	49.95
7	5348	501	438	6287	172	5167	0	2	5572	5479	-806	16301	0	16301	1841	18142	49.93
8	5434	1447	460	7341	134	5448	0	38	5503	5468	-673	17756	0	17756	2030	19786	49.93
9	5445	1083	457	6985	63	5475	0	165	5688	5789	-894	17583	0	17583	2290	19873	49.97
10	5450	734	444	6628	106	5479	0	285	5908	6090	-1141	17446	0	17446	2565	20011	49.96
11	5325	1140	420	6885	125	5428	0	381	6099	6450	-1296	17973	0	17973	2757	20730	49.97
12	5373	1351	275	6999	162	5254	0	474	6430	6343	-1400	17832	0	17832	2792	20624	49.96
13	5430	949	283	6662	176	5259	0	505	6402	6306	-1367	17541	0	17541	2742	20283	50.01
14	5459	513	279	6251	208	5243	0	504	6164	6108	-1253	17061	0	17061	2607	19668	50.00
15	5511	484	280	6275	293	5214	0	436	6187	6254	-1278	17194	0	17194	2629	19823	49.93
16	5505	364	281	6150	341	5304	0	351	6190	6066	-1352	16860	0	16860	2615	19475	49.94
17	5414	316	272	6002	424	5168	0	218	6051	5793	-1380	16225	0	16225	2577	18802	49.89
18	5144	130	294	5568	424	4890	0	91	5903	5356	-1393	14936	0	14936	2566	17502	49.98
19	4787	245	287	5319	430	4569	0	11	5696	5439	-1242	14526	0	14526	2564	17090	49.92
20	4911	497	288	5696	405	4530	0	0	5434	5395	-1189	14837	0	14837	2572	17409	49.93
21	4964	179	290	5433	326	4578	0	0	5269	5124	-1242	14219	0	14219	2444	16663	49.94
22	4787	179	301	5267	302	4574	0	0	4937	4786	-1180	13749	0	13749	2273	16022	49.99
23	4725	190	292	5207	326	4447	0	0	4687	4549	-1017	13512	0	13512	2107	15619	49.97
24	4447	200	296	4943	406	4243	0	0	4659	4522	-918	13196	0	13196	1944	15140	49.98
MUs	120.64	11.84	8.30	140.77	5.76	115.45	0.00	3.46	132.33	130.75	-25.71	370.49	0.00	370.49	53.52	424.00	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Feb/2018

Position as on 6.30 Hrs of 09/Feb/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
CENT.SECTOR	Tarapur 2	160	26/12/2017	10.51		Continued.	AOH	
MSPGCL	Koyna Unit 4	75	20/01/2018	08.50		Continued.	Thrust Bearing Temperature Problem, converted to COH w.e.f 25.01.2018	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	De-commissioned on dt. 01.04.2017	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	De-commissioned on dt.02.03.2017	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
MSPGCL	Khaparkheda Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
IPP	Dhariwal	300	27/10/2017	17.31		Continued.	Drum level Not Maintained	
IPP	JSW (J) U2	300	01/12/2017	24.00		Continued.	no schedule.	
MSPGCL	Chandrapur Unit 3	210	03/12/2017	01.35		Continued.	Water Shortage	
MSPGCL	Chandrapur Unit 4	210	03/12/2017	14.17		Continued.	Water Shortage	
MSPGCL	Parli Unit 7	250	03/12/2017	23.35		Continued.	Poor Coal Receipt.	
CPP	IEPL Unit 1	270	30/12/2017	23.58		Continued.	No Schedule	
IPP	Adani U-2	660	02/01/2018	15.26		Continued.	HPBP Bonnet leakage	
MSPGCL	Chandrapur Unit 6	500	04/01/2018	13.30		Continued.	Water Shortage	
MSPGCL	Nasik Unit 5	210	06/01/2018	06.30		Continued.	PA Fan Problem (Not available due to Coal shortage from 07.01.2018, 14:00Hrs)	
MSPGCL	Koradi Unit 7	210	07/01/2018	17.00		Continued.	Poor Coal Receipt.	
MSPGCL	Uran Unit 8	108	17/01/2018	13.41		Continued.	vibration testing.	
IPP	RPL(AMT) U-2	270	19/01/2018	06.50		Continued.	Cooling Water Line Leakage (not available due	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Feb/2018

Position as on 6.30 Hrs of 09/Feb/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							to coal shortage w.e.f 28.01.2018)	
MSPGCL	Paras Unit 3	250	21/01/2018	06.45		Continued.	Boiler Tube Leakage	
IPP	VIPL U-1	300	30/01/2018	22.55		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 9	660	31/01/2018	14.31		Continued.	poor coal receipt.	
MSPGCL	Khaparkheda Unit 2	210	02/02/2018	23.57		Continued.	poor coal receipt.	
RINFRA-G	REL Unit 2	250	07/02/2018	07.23	08/02/2018	17.00	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 5	500	07/02/2018	12.00		Continued.	Water Shortage	
MSPGCL	Uran Unit B0	120	08/02/2018	10.57		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	08/02/2018	11.07		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Feb/2018

Statement-VII

Position as on 6.30 Hrs of 09/Feb/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar II	InterState	06/02/2018	09.00		Continued.	PO	Line Maint.work(RFC 17.00 Hrs)
Dhule Sar'Sarovar II	InterState	08/02/2018	09.00	08/02/2018	19.00	OO	Line Maintenance work
Karad - Jaigad - II	IntraState	07/02/2018	17.27	08/02/2018	09.33	HT	Over Voltage
karad -kolhapur-I	IntraState	07/02/2018	17.29	08/02/2018	09.37	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	07/02/2018	17.33	08/02/2018	07.06	HT	Over Voltage
Lonikand 1 - Chakan	IntraState	08/02/2018	09.20	08/02/2018	18.20	PO	Half yearly maintenance work
Padghe - Kalwa-II	IntraState	08/02/2018	13.30	08/02/2018	18.32	PO	attending b ph ips tube problem.
Pune(GIS)-Talegaon(PG) Ckt 2	IntraState	08/02/2018	16.06	08/02/2018	17.09	T	dt received bus fault at pune gis.
Pune(GIS)-Talegaon(PG) Ckt 4	IntraState	08/02/2018	16.06	08/02/2018	20.41	T	DT received bus fault at pune gis.
Pune(GIS)-A'bad(Waluj) Ckt 1	IntraState	08/02/2018	16.06	08/02/2018	22.08	T	dt received bus fault at pune gis
Pune(GIS)-Parli(PG) Ckt 2	IntraState	08/02/2018	16.06	08/02/2018	21.09	T	DT received bus fault at pune gis.
Khadka-Aurangabad (Waluj)	IntraState	08/02/2018	19.35	09/02/2018	06.21	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	08/02/2018	21.00		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	08/02/2018	21.13	09/02/2018	06.19	HT	Over Voltage
karad -kolhapur-II	IntraState	08/02/2018	21.17		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	08/02/2018	10.43	08/02/2018	19.52	PO	painting work.
400/220/33 Kv 500 Mva Ict-3 @Nagothane	IntraState	08/02/2018	21.01		Continued.	EO	due to negative dga report.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Talegaon(PG)-Talegaon(Ambi)-II	InterState	08/02/2018	12.37	08/02/2018	17.01	EO	Attending Hot Spot
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Pedambe-Nerle	IntraState	23/09/2017	00.50		Continued.	T	'B'Phase CT Burst
Mumewadi -Halkarni II	IntraState	17/11/2017	10.00		Continued.	PO	Tower erection work (temporarily line would be Mumewadi-Tillari)
Halkarni - Tillari II	IntraState	17/11/2017	12.25		Continued.	PO	Tower erection work. (temporarily line would be Mumewadi-Tillari)
Kharghar-Borivali ckt II	IntraState	07/12/2017	12.23		Continued.	T	Distance Protection
Deoli(Pgcil)-Badnera	IntraState	05/02/2018	10.24	08/02/2018	23.10	PO	Replacement of Line Isolator
Boisar II - Tarapur	IntraState	06/02/2018	08.59		Continued.	PO	Line Maintenance work
Sawantwadi-Bidri	IntraState	07/02/2018	09.04	08/02/2018	10.05	PO	Insulator Cleaning Work.
Dahanu-Viraj	IntraState	08/02/2018	00.02	08/02/2018	15.08	T	Distance Protection
Deepnagar Amalner	IntraState	08/02/2018	09.19	08/02/2018	20.33	PO	Insulator Replacement Work
Parli 2 (Girwali)- Parbhani	IntraState	08/02/2018	09.31	08/02/2018	11.45	PO	Measurement of ir values of ct.
Parly-Parly Extn.-II	IntraState	08/02/2018	09.57	08/02/2018	15.05	PO	Distance Relay Testing Work
Karad -Mudshingi Ckt- IV	IntraState	08/02/2018	10.06	08/02/2018	18.00	PO	cold line insulator cleaning work.
Loteparshuram- Dasturi Line	IntraState	08/02/2018	11.00	08/02/2018	14.00	PO	Attending red Hot Spot.
Lonand-Baramati	IntraState	08/02/2018	11.05	08/02/2018	14.00	PO	Routine Maintenance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Feb/2018

Statement-VII

Position as on 6.30 Hrs of 09/Feb/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Lonikand-II- Kathapur	IntraState	08/02/2018	12.40	08/02/2018	15.09	T	Distance Protection
Lamboti(solapur)-Karkamb	IntraState	08/02/2018	15.07	08/02/2018	15.28	T	Distance Protection
Dhule-Amalner(220kv)	IntraState	08/02/2018	15.19	08/02/2018	20.54	T	dt received.
New Koyna - Loteparshuram	IntraState	08/02/2018	22.10	08/02/2018	22.57	T	Distance Protection
Mahad - Pedambe	IntraState	09/02/2018	02.22		Continued.	T	Distance Protection
Adlabs - Pedambe	IntraState	09/02/2018	02.22	09/02/2018	03.27	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/100 Kv 200 MVA ICT-IV@Kalwa	IntraState	24/11/2017	01.58		Continued.	T	Buchholz PRV Operated(Failed on Internal Fault)
220 / 110 / 33 250 MVA ICT 2 @ Borivli(T)	IntraState	31/01/2018	10.40		Continued.	T	220 kv bus 2 fault.
220/132 Kv 100 Mva Cgl lct 1 @Dondaicha	IntraState	08/02/2018	08.21	08/02/2018	23.11	PO	overhauling of load tap changer.
220/33 Kv 100 Mva Alstom Ptr 1 @Valve	IntraState	08/02/2018	08.31	08/02/2018	12.08	PO	bay maintenance work.
220/132 Kv 200 Mva Bbl lct 1 @Beed	IntraState	08/02/2018	11.05	08/02/2018	12.50	PO	sfra kit demo.
220/33 Kv 100 Mva Bbl Ptr 2 @Valve	IntraState	08/02/2018	13.21	08/02/2018	17.18	PO	bay maintenance work.
220/132/11 Kv 200 Mva Cgl lct 2 @Amravati	IntraState	08/02/2018	13.37	08/02/2018	18.35	PO	jumper connecting work.
132 KV LINE Outages/Trippings							
Amalner(220kv)-Chopda	IntraState	08/02/2018	14.15		Continued.	HT	y ph open.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage