

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 08/Apr/2019 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	147.663	1173.236	1) Gujrat	1.868	7.569
2) Hydro	15.563	112.344	2) Madhya Pradesh	15.020	128.855
3) Gas	6.901	52.134	3) Chattisgarh	4.770	34.920
Total MSPGCL	170.127	1337.714	4) Maharashtra	119.565	920.469
B) 1) APML	77.456	602.518	5) Goa (Amona)	-0.374	-4.202
2) JSWEL	23.405	186.311	Total	140.849	1087.611
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.590	223.235
4) RPL(AMT)	11.394	92.333	b) Mumbai Drawl	30.283	244.978
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	16.726	104.250
6) Other IPP	13.411	109.671	Include PX	-5.664	-69.815
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.590	223.235
C) 1) TPCL Thermal	15.628	112.561	Include PX	19.476	155.732
2) TPCL Hydro	4.082	27.098	Standby	0.000	0.000
3) TPCL Gas	4.052	32.850	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.442	80.432	1) MSEDCL	431.884	3368.133
D) STATE			2) Mumbai Discoms	65.488	497.920
1) Thermal	300.399	2357.062	TOTAL STATE	497.372	3866.053
(A1+C1+C4+(B1-B6))					
2) Hydro	19.645	139.442			
(A2+C2)					
3) Gas	10.953	84.984			
(A3+B7+C3)					
4) Wind	18.372	140.642			
6) SOLAR	7.153	56.311			
TOTAL STATE	356.522	2778.441			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6216	6285	6179	5872
MSPGCL Hydro	708	910	1705	227
MSPGCL Gas	278	269	287	295
MSPGCL Total Generation	7202	7464	8171	6394
Central Sector Receipt	6632	6596	5184	5604
WIND	406	541	775	1035
CPP / IPP Thermal	5418	5468	5322	4810
CPP / IPP Gas	0	0	0	0
SOLAR	956	659	3	0
Exchange with Mumbai	-1535	-1557	-1312	-1028
MSEDCL DEMAND MET	19079	19171	18143	16815
Load Shedding	0	0	0	0
MSEDCL DEMAND	19079	19171	18143	16815
TPCL GENERATION	1275	1208	1162	615
AEML GENERATION	498	500	500	374
MUMBAI DEMAND	3308	3265	2974	2017
STATE DEMAND MET	22387	22436	21117	18832
STATE DEMAND	22387	22436	21117	18832
Frequency (Hz)	49.99	50.00	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 18:03 Hrs	49.81 Hz at 01:07 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 08/Apr/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.86	30.83	175	145
Unit 7	0.00	0.00	0	0
Unit 8	9.70	68.21	434	370
Unit 9	0.00	0.00	0	0
Unit 10	10.16	81.80	510	298
Total	23.72	180.84		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.10	85.32	510	355
Unit 5	11.13	85.02	505	355
Total	22.24	170.34		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.56	42.66	250	198
Total	5.56	42.66		
Chandrapur				
Unit 3	4.25	33.44	195	0
Unit 4	4.32	35.09	183	170
Unit 5	9.93	79.70	425	390
Unit 6	0.00	0.00	0	0
Unit 7	10.58	84.41	450	412
Unit 8	11.37	86.76	490	450
Unit 9	11.38	89.75	483	465
Total	51.82	409.16		
Paras				
Unit 3	6.02	44.97	256	240
Unit 4	5.86	48.04	250	240
Total	11.88	93.02		
Khaparkheda				
Unit 1	4.14	29.96	190	160
Unit 2	0.00	22.81	0	0
Unit 3	4.42	34.57	195	170
Unit 4	4.27	33.77	185	172
Unit 5	10.64	87.01	460	430
Total	23.46	208.13		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.53	34.75	210	158
Unit 5	4.45	34.34	204	160
Total	8.98	69.09		
Uran				
All Units	6.90	52.13	305	269
Total	6.90	52.13		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	1.22	22	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.10	1.22		
Koyna				
Stage 1-2	4.66	40.82	525	40
Stage 4	5.68	29.98	967	0
Stage 3	2.26	15.49	160	0
Total	12.60	86.29		
Hydro				
KDPH	0.86	7.07	36	36
VTRNA	0.80	7.54	61	0
TILLARI	0.42	3.58	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.13	1.34	40	0
RNGR+BHTSA	0.29	2.28	12	11
BHANDARDRA	0.00	0.62	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.46	3.01	20	19
GHATGHAR	0.00	0.63	0	0
Total	2.96	26.05		
Wind				
Total	18.37	140.64	0	0
Total	18.37	140.64		
CPP				
APML(Mus)	77.46	602.52	0	0
JSWEL(Mus)	23.40	186.31	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	11.39	92.33	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	13.41	109.67	0	0
Total	125.67	990.83		
SOLAR				
Total	7.15	56.31	0	0
Total	7.15	56.31		
Tata				
Trombay 5	10.26	72.15	479	300
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.55	20.74	116	63
Trombay 7B	1.50	12.11	66	49
Trombay 8	5.36	40.41	233	202
TATA Hydro	4.08	27.10	396	0
Total	23.76	172.51		
AEML				
DTPS U-1&2	11.44	80.43	502	374
Total	11.44	80.43		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	147.66	1173.24	MSPGCL Total	170.13	1337.71
			MSPGCL Thml+Gas	154.56	1225.37	Koyna 1,2 & 4 Total	10.34	70.80
			MSPGCL Hydro	15.56	112.34	State Total	356.52	2778.44

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Apr/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5949	431	293	6673	961	4882	0	0	6024	6312	-1283	17545	0	17545	2477	20022	49.96
2	5900	451	292	6643	1071	4857	0	0	5878	5622	-1164	17029	0	17029	2260	19289	49.92
3	5880	332	304	6516	1081	4825	0	0	5749	5698	-1095	17025	0	17025	2099	19124	49.92
4	5872	227	295	6394	1035	4810	0	0	5683	5604	-1028	16815	0	16815	2017	18832	49.98
5	5864	187	295	6346	1062	4779	0	0	5657	5673	-989	16871	0	16871	1981	18852	50.00
6	6086	636	305	7027	967	5002	0	0	5747	5434	-1021	17409	0	17409	2049	19458	49.95
7	6268	527	296	7091	992	5334	0	23	5942	5571	-821	18190	0	18190	2148	20338	50.02
8	6218	195	296	6709	786	5202	0	203	6009	6530	-890	18540	0	18540	2280	20820	50.05
9	6192	306	302	6800	581	5119	0	495	6155	5980	-1135	17840	0	17840	2591	20431	50.00
10	6209	358	276	6843	546	5247	0	698	6337	6246	-1287	18293	0	18293	2923	21216	49.99
11	6287	264	282	6833	493	5443	0	868	6393	6397	-1481	18553	0	18553	3201	21754	50.01
12	6216	708	278	7202	406	5418	0	956	6572	6632	-1535	19079	0	19079	3308	22387	49.99
13	6216	614	269	7099	456	5417	0	936	6574	6569	-1569	18908	0	18908	3286	22194	50.07
14	6209	498	278	6985	407	5442	0	909	6472	6413	-1480	18676	0	18676	3168	21844	50.03
15	6233	814	278	7325	493	5412	0	826	6505	6580	-1532	19104	0	19104	3237	22341	49.97
16	6285	910	269	7464	541	5468	0	659	6519	6596	-1557	19171	0	19171	3265	22436	50.00
17	6306	810	280	7396	648	5468	0	405	6340	6273	-1437	18753	0	18753	3184	21937	49.98
18	6312	506	281	7099	677	5406	0	156	6318	6218	-1352	18204	0	18204	3079	21282	50.05
19	6003	625	285	6913	640	5066	0	16	6061	5846	-1257	17224	0	17224	2946	20170	50.01
20	6179	1705	287	8171	775	5322	0	3	5141	5184	-1312	18143	0	18143	2974	21117	50.01
21	6328	846	289	7463	808	5369	0	0	5345	5086	-1304	17422	0	17422	2856	20278	50.00
22	6305	721	289	7315	973	5375	0	0	5043	4946	-1254	17355	0	17355	2751	20106	50.00
23	6195	1386	290	7871	1013	5454	0	0	4600	4796	-1262	17872	0	17872	2715	20587	49.99
24	6151	1506	292	7949	960	5549	0	0	4625	4643	-1238	17863	0	17863	2692	20555	49.97
MUs	147.66	15.56	6.90	170.13	18.37	125.67	0.00	7.15	141.69	140.85	-30.28	431.88	0.00	431.88	65.49	497.37	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Apr/2019

Position as on 6.30 Hrs of 09/Apr/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn Due To B0 & U-7	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/01/2019	19.30		Continued.	Zero Schedule	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	19/01/2019	18.21		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 6	500	20/02/2019	22.07		Continued.	Rotor Earth Fault	
MSPGCL	Koradi Unit 9	660	31/03/2019	15.13		Continued.	Furnace Pressure High	
IPP	RPL(AMT) U-1	270	06/04/2019	00.00		Continued.	No Schedule By MSEDCL.	
MSPGCL	Khaparkheda Unit 2	210	07/04/2019	03.20		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 3	210	08/04/2019	22.14	09/04/2019	04.48	Attending Pressure Sensing Line Heavy Leakage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	03/04/2019	18.27	08/04/2019	06.21	HT	Over Voltage
Parli(MS)-Parli (PG) II	InterState	08/04/2019	16.12	08/04/2019	20.50	T	Distance Protection
Dhule Sar'Sarovar I	InterState	08/04/2019	17.52		Continued.	HT	Over Voltage
Parli(MS)-Parli (PG) I	InterState	08/04/2019	21.29	09/04/2019	00.03	PO	IR Value of CT Secondary Cable Upto Relay Panel.
Khadka-Aurangabad (Waluj)	IntraState	05/04/2019	17.01	08/04/2019	08.24	HT	Over Voltage
Kala Kudus Ckt-II	IntraState	08/04/2019	03.16	08/04/2019	19.29	T	Distance Protection Zone 1 B Phase
Kala Kudus Ckt-I	IntraState	08/04/2019	03.18	08/04/2019	06.36	T	Distance Protection Zone 1 Y phase
Padghe - Kalwa- I	IntraState	08/04/2019	05.05	08/04/2019	07.09	T	Distance Protection
Kalwa - Talegaon(PG)	IntraState	08/04/2019	06.58	08/04/2019	07.45	T	Distance Protection
Padghe - Kalwa-II	IntraState	08/04/2019	07.14	08/04/2019	08.16	T	Distance Protection
Deepnagar Taptitanda	IntraState	08/04/2019	07.24	08/04/2019	21.03	PO	Replacement of Faulty Dead End.
Nagothane - Dabhol I	IntraState	08/04/2019	09.40	08/04/2019	19.55	PO	Insulator String Replacement Work.
Chandrapur-II - Nanded ckt II	IntraState	08/04/2019	10.37	08/04/2019	18.13	PO	Replacement of Broken Spacer.
Bus Coupler @ New Koyna	IntraState	08/04/2019	11.17	08/04/2019	18.06	PO	Fixing of Repair Sleeve.
Kala Kudus Ckt-I	IntraState	08/04/2019	14.01	08/04/2019	19.12	PO	Attending Fault of Ckt-2 Which is Under Breakdown.
Padghe - Kalwa-II	IntraState	08/04/2019	17.47	08/04/2019	22.00	EO	Replacement of Decapped String At LOC.111.
Khadka - Bableshwar	IntraState	08/04/2019	18.16	08/04/2019	19.22	T	Distance Protection
Bhusawal-Aurangabad	IntraState	08/04/2019	21.12		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	26/03/2019	11.02		Continued.	PO	Overhauling work
400/220kv 315 Mva ICT II @Karad	IntraState	08/04/2019	09.03		Continued.	PO	OLTC Overhauling Work.
400/220KV 500MVA ICT-I @Nanded	IntraState	08/04/2019	10.45	08/04/2019	11.18	HT	Due To Sparking On Bus Isolator.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Boisar(MS) - Boisar (PG) - I	InterState	07/04/2019	06.58	08/04/2019	00.11	PO	Erection of Cross Arm and Stringing work
Boiser(M)-Boiser(PG) -III	InterState	07/04/2019	07.28	08/04/2019	00.43	PO	Erection of Cross Arm and Stringing work
Borivali - Tarapur	InterState	08/04/2019	01.10	08/04/2019	06.50	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading.
Uran - Kharghar I	IntraState	06/04/2019	10.22	08/04/2019	20.08	PO	Re-orientation work of line
Boisar Versova Line	IntraState	07/04/2019	06.16	08/04/2019	00.50	HT	Outage on Boisar PG CKT 1&3

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Boisar(M) - Ghodbunder	IntraState	07/04/2019	06.19	08/04/2019	00.54	HT	Outage on Boisar PG CKT 1&3
Boisar-Viraj	IntraState	07/04/2019	06.25	08/04/2019	00.48	HT	Outage on Boisar PG CKT 1&3
Gorai MSETCL Borivali Line-2	IntraState	08/04/2019	01.10	08/04/2019	07.36	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
REL Borivali MSETCL Borivali Line-2	IntraState	08/04/2019	01.10	08/04/2019	07.34	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
Tata Borivli MSETCL Borivli 4	IntraState	08/04/2019	01.10	08/04/2019	06.25	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
Kharghar-Borivali ckt II	IntraState	08/04/2019	01.10	08/04/2019	06.30	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
Kalwa - Borivali	IntraState	08/04/2019	01.10	08/04/2019	03.27	T	Bus Bar Protection Operated
GIS Bhandup - Borivali	IntraState	08/04/2019	01.10	08/04/2019	06.56	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
Kharghar-Borivali ckt I	IntraState	08/04/2019	02.14	08/04/2019	10.10	T	Distance Protection
Nalasopara-Boisar	IntraState	08/04/2019	04.40	08/04/2019	06.23	T	Distance Protection R Phase to E/F
Boisar(M) - Ghodbunder	IntraState	08/04/2019	05.46	08/04/2019	11.42	T	Distance Protection
Mumewadi -Halkarni II	IntraState	08/04/2019	09.46	08/04/2019	15.43	PO	Quarterly & Pre Monsoon Maintenance Work.
Bhandara-Sunflag 2	IntraState	08/04/2019	10.08	08/04/2019	15.15	PO	Erection And Commissioning Work of 220KV B Phase Metering PT of Main Metering In R/O EHV Consumer M/S Sunflag Iron And Steel Co.Ltd. By MSEDCL.
Koradi-Ambazari-I	IntraState	08/04/2019	10.12	08/04/2019	15.02	PO	Diagnostic Testing Work.
Adlabs - Pedambe	IntraState	08/04/2019	10.25		Continued.	PO	Preventive Maintenance Work.
Uran - Ongc Uran	IntraState	08/04/2019	10.28	08/04/2019	20.40	PO	C&R Panel Replacement Work.
Main Bus @ Lote	IntraState	08/04/2019	10.45	08/04/2019	16.37	PO	Chemical Washing of Bus Insulators.
Kharepatan -Pawas Line	IntraState	08/04/2019	13.00	08/04/2019	13.16	T	Distance Protection
Mahad-Kandalgaon	IntraState	08/04/2019	15.12	08/04/2019	15.51	T	Distance Protection
Mahad - Pedambe	IntraState	08/04/2019	15.15	08/04/2019	16.35	T	Distance Protection
PANDHARPUR BHALVANI	IntraState	08/04/2019	17.05		Continued.	HT	Attending Hot Spot
Waluj- Padegaon li	IntraState	08/04/2019	20.44	08/04/2019	21.03	T	B-Ph, SOTF, 1.675KA, No Tripping At Waluj.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Buccholz Trip.
220/110 Kv 200 MVA ICT-III @Kolhapur-II (Mudshingi)	IntraState	05/04/2019	10.03		Continued.	PO	Quarterly Maintenance Work
220/132 KV ICT-2 @Nagar	IntraState	05/04/2019	10.45		Continued.	PO	oil Filtration.
220/100 Kv 200 MVA ICT-I @Borivali	IntraState	08/04/2019	01.10	08/04/2019	08.20	T	Bus Bar Protection Operated at Borivali due to REL GIS Bus Coupler CT Problem
132 KV LINE Outages/Trippings							
Mansar Pench	InterState	07/03/2019	15.40		Continued.	HT	Hand trip Form Pench end for system requirment.
Kanhan-Pench	IntraState	22/01/2019	18.44		Continued.	HT	After Completion of Outage.
Morshi-Warud	IntraState	08/04/2019	00.36	08/04/2019	00.45	T	Distance Protection
Paithan-Rajpimpri	IntraState	08/04/2019	19.37	08/04/2019	20.00	T	Distance Protection
Harsool-Chikalthana I	IntraState	08/04/2019	21.05	08/04/2019	22.40	T	Distance Protection
110 KV LINE Outages/Trippings							
Tata Borivli MSETCL Borivli 2	IntraState	08/04/2019	01.10	08/04/2019	08.24	T	Bus Bar Protection Operated at

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Apr/2019

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Borivali due to REL GIS Bus Coupler CT Problem