

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 08/Apr/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	163.771	1322.232	1) Gujrat	-3.774	-36.553
2) Hydro	42.915	285.991	2) Madhya Pradesh	10.849	85.042
3) Gas	6.619	49.771	3) Chattisgarh	5.230	40.580
Total MSPGCL	213.305	1657.994	4) Maharashtra	159.387	1319.600
B) 1) APLM	75.940	601.893	5) Goa (Amona)	-1.723	-13.999
2) JSWEL	19.661	141.223	Total	169.969	1394.670
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.319	237.287
4) RPL(AMT)	31.652	239.843	b) Mumbai Drawl	34.082	261.683
5) SWPGPL	9.502	71.259	c) MSEDCL Bilateral *	66.314	539.347
6) Other IPP	35.031	281.283	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.319	237.281
C) 1) TPCL Thermal	16.545	124.012	Include PX	0.000	0.000
2) TPCL Hydro	5.282	26.212	Standby	0.000	0.006
3) TPCL Gas	2.901	22.753	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.909	92.210	1) MSEDCL	531.919	4232.211
D) STATE			2) Mumbai Discoms	70.719	526.873
1) Thermal	364.011	2873.955	3) Other Discoms	9.168	71.224
(A1+C1+C4+(B1-B6))			TOTAL STATE	611.806	4830.308
2) Hydro (A2+C2)	48.197	312.203			
3) Gas (A3+B7+C3)	9.520	72.524			
4) Wind	11.952	104.440			
6) SOLAR	8.157	72.513			
TOTAL STATE	441.837	3435.635			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6833	7010	6858	6811
MSPGCL Hydro	1472	1457	2080	2003
MSPGCL Gas	267	258	281	282
MSPGCL Total Generation	8572	8725	9219	9096
Central Sector Receipt	9401	9607	5820	5830
WIND	194	599	938	394
CPP / IPP Thermal	6841	6890	7023	7150
CPP / IPP Gas	0	0	0	0
SOLAR	1132	876	0	0
Exchange with Mumbai	-2045	-1961	-1356	-858
MSEDCL DEMAND MET	23811	24466	21354	21450
Load Shedding	0	0	0	24
MSEDCL DEMAND	23811	24466	21354	21474
TPCL GENERATION	923	1004	1229	939
AEML GENERATION	498	491	501	502
MUMBAI DEMAND	3466	3456	3086	2299
OTHER DISCOM DEMAND	415	402	422	295
STATE DEMAND MET	27692	28324	24862	24044
STATE DEMAND	27692	28324	24862	24068
Frequency (Hz)	50.01	49.99	49.99	49.88

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 11.06 Hrs	49.57 Hz at 05.26 Hrs	49.94	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 08/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.46	25.31	200	165
Unit 7	0.00	0.00	0	0
Unit 8	14.35	108.32	605	589
Unit 9	14.35	108.53	611	571
Unit 10	0.00	60.94	0	0
Total	33.16	303.10		
Bhusawal				
Unit 3	3.34	5.26	155	120
Unit 4	9.13	79.00	455	350
Unit 5	9.11	77.33	470	350
Total	21.58	161.59		
Parli				
Unit 6	4.45	29.02	194	171
Unit 7	4.34	30.35	187	174
Unit 8	3.34	27.58	152	130
Total	12.14	86.95		
Chandrapur				
Unit 3	4.57	36.20	194	189
Unit 4	4.02	32.59	175	149
Unit 5	8.75	70.62	378	355
Unit 6	8.91	49.25	420	320
Unit 7	9.54	69.64	413	380
Unit 8	10.73	82.46	462	430
Unit 9	10.41	81.06	441	426
Total	56.92	421.82		
Paras				
Unit 3	5.01	43.49	228	196
Unit 4	4.00	40.22	216	0
Total	9.01	83.71		
Khaparkheda				
Unit 1	2.78	26.00	155	75
Unit 2	2.83	26.94	150	95
Unit 3	3.64	32.36	186	132
Unit 4	3.43	31.64	159	123
Unit 5	10.03	86.00	435	390
Total	22.71	202.94		
Nasik				
Unit 3	4.25	29.66	192	139
Unit 4	4.00	32.47	186	121
Unit 5	0.00	0.00	0	0
Total	8.25	62.13		
Uran				
All Units	6.62	49.77	293	257
Total	6.62	49.77		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.17	1.02	44	0
Total	0.17	1.02		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	7.81	56.89	530	55
Stage 4	21.68	127.12	1037	513
Stage 3	6.24	39.32	320	80
Total	35.73	223.33		
Hydro				
KDPH	0.86	6.91	36	36
VTRNA	0.82	5.64	60	0
TILLARI	0.31	3.96	58	0
BHIRA T.R.	0.25	1.13	80	0
SMLHY_PTN	4.78	43.99	218	164
GHATGHAR	0.00	0.00	0	0
Total	7.02	61.64		
Wind				
Total	11.95	104.44	0	0
Total	11.95	104.44		
CPP				
APML(Mus)	75.94	601.89	0	0
JSWEL(Mus)	19.66	141.22	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.65	239.84	0	0
SWPGPL-Mus	9.50	71.26	0	0
Other(Mus)	35.03	281.28	0	0
Total	171.79	1335.50		
SOLAR				
Total	8.16	72.51	0	0
Total	8.16	72.51		
Tata				
Trombay 5	10.89	83.82	483	422
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.67	13.18	114	51
Trombay 7B	1.24	9.57	66	42
TATA Hydro	5.28	26.21	435	92
Trombay 8	5.66	40.20	242	218
Total	24.73	172.98		
AEML				
DTPS U-1&2	11.91	92.21	503	464
Total	11.91	92.21		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	163.77	1322.23	MSPGCL Total	213.30	1657.99
			MSPGCL Thml+Gas	170.39	1372.00	Koyna 1,2 & 4 Total	29.49	184.01
			MSPGCL Hydro	42.92	285.99	State Total	441.84	3435.64

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 08/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6822	2077	281	9180	714	7308	0	0	6144	5986	-1199	21655	171	21826	2806	334	24966	49.77
2	6848	2091	281	9220	561	7293	0	0	6137	5894	-1038	21628	146	21774	2574	302	24650	49.78
3	6847	2079	281	9207	479	7301	0	0	5951	5857	-931	21614	82	21696	2413	299	24408	49.91
4	6811	2003	282	9096	394	7283	0	0	6001	5830	-858	21450	24	21474	2299	295	24068	49.88
5	6829	1926	291	9046	441	7304	0	0	6055	5980	-832	21632	0	21632	2254	307	24193	49.88
6	6818	2050	272	9140	472	7318	0	0	6186	6256	-888	21965	0	21965	2322	333	24620	49.85
7	6728	1992	293	9013	366	7299	0	22	6276	6168	-990	21514	224	21738	2394	364	24496	49.95
8	6589	1525	292	8406	320	7264	0	214	6225	6216	-1077	20951	584	21535	2492	392	24419	50.02
9	6591	1431	281	8303	222	6986	0	538	7290	7768	-1400	22003	0	22003	2772	414	25189	50.01
10	6593	1869	270	8732	231	7195	0	840	7654	7926	-1709	22800	0	22800	3110	415	26325	49.97
11	6596	1967	278	8841	189	7138	0	1060	8571	8700	-1890	23618	0	23618	3361	420	27399	49.99
12	6833	1472	267	8572	194	6972	0	1132	9606	9401	-2045	23811	0	23811	3466	415	27692	50.01
13	6844	1551	257	8652	179	6668	0	1200	9852	9796	-2035	24066	0	24066	3471	394	27931	50.02
14	6927	1622	267	8816	341	6687	0	1097	9605	9392	-1952	23996	0	23996	3349	385	27730	50.07
15	7010	1457	258	8725	599	7022	0	876	9663	9607	-1961	24466	0	24466	3456	402	28324	49.99
16	7035	1795	267	9097	584	7191	0	664	8948	8628	-1955	23798	0	23798	3511	411	27720	49.86
17	6897	1641	268	8806	693	7162	0	373	8071	7877	-1763	22715	0	22715	3428	433	26576	49.88
18	6857	1290	269	8416	818	7122	0	129	6830	6679	-1567	21169	0	21169	3281	428	24878	50.01
19	6853	1576	270	8699	783	7117	0	12	5633	5790	-1385	20589	0	20589	3113	427	24129	49.98
20	6858	2080	281	9219	938	7155	0	0	5548	5820	-1356	21354	0	21354	3086	422	24862	49.99
21	6876	1575	280	8731	975	7215	0	0	5769	5729	-1362	20867	0	20867	3007	421	24295	50.01
22	6885	1696	271	8852	642	7262	0	0	5663	5722	-1319	20753	0	20753	2929	406	24088	49.92
23	6905	2067	281	9253	389	7230	0	0	6064	6280	-1258	21503	0	21503	2901	391	24795	49.87
24	6919	2083	281	9283	428	7294	0	0	6479	6667	-1312	22001	363	22364	2924	359	25647	49.82
MUs	163.77	42.92	6.62	213.30	11.95	171.79	0.00	8.16	170.22	169.97	-34.08	531.92	1.59	533.51	70.72	9.17	613.40	49.94

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Apr/2022

Position as on 6.30 Hrs of 09/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25		Continued.	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	12/04/2022
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Nasik Unit 5	210	22/03/2022	23:40		Continued.	Withdrawn	
MSPGCL	Uran Unit B0	120	01/04/2022	19:02		Continued.	Filter Replacement work(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Uran Unit 8	108	01/04/2022	19:21		Continued.	Filter Replacement work.(Converted on gas shortage from 00:00 hrs of dt.03.04.2022)	
MSPGCL	Koradi Unit-10	660	07/04/2022	08:08		Continued.	Condenser Cleaning work.	
MSPGCL	Paras Unit 4	250	08/04/2022	06:32	08/04/2022	10:22	Furnace Pressure High	08/04/2022
MSPGCL	Bhusawal Unit 3	210	09/04/2022	14:20	09/04/2022	16:10	PA Fan problem	
MSPGCL	Koyna STG-IV Unit-1	250	09/04/2022	21:55		Continued.	Guide vanes Control Fault attending work	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 08/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	29/03/2022	13:28			T	HT FOR LOAD MANAGEMENT
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	02/04/2022	12:00	09/04/2022	16:07	T	TRIPPED ON DIST. PROTN
CHANDRAPUR-PARLI CKT-3	IntraState	07/04/2022	16:21	08/04/2022	00:38	T	Distance Protection
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	07/04/2022	17:48	09/04/2022	16:05	EO	The Rectification/ replacing work of jointing plate of cross arm of twin monopole for Samruddhi Mahamarg Crossing work.
PADGHE - KALWA CKT - 1	IntraState	09/04/2022	15:04	09/04/2022	18:00	EO	Replacement of Decapped insulator string at loc.no. 1067 Y-phase
400 KV ICT Outages/Tripping							
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	23/03/2022	10:14			EO	Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in ICT-I R ph unit
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	08/04/2022	16:02	08/04/2022	21:02	PO	Inspection & Maintenance work of OLTC Diverter switch
167 MVA SPARE ICT @ TALANDGE	IntraState	09/04/2022	13:25			PO	Isolator, BPI erection for Rapid Restoration scheme at 400 KV Talandage S/stn.
220 KV MAINBAY Outages/Tripping							
TBC @ HINJEWADI-2	IntraState	09/04/2022	10:00	09/04/2022	15:00	PO	CT tan delta & CB CRM & Yearly maintenance work
220 KV LINE Outages/Tripping							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GOREGAON - AAREY CKT - 1	IntraState	31/03/2022	10:50		Continued.	PO	Under MMRC Line Diversion scheme for Metro-3 project, 220kV Outdoor termination at 220kV AEML Aarey and
EKLAHARE (GCR) - GHATGHAR	IntraState	02/04/2022	12:29		Continued.	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	02/04/2022	12:51		Continued.	PO	Samruddhi Highway Monopole work, 13 No's (4 In line) All cut points , 4.28 km Stretch , Erection ,Stringing of new conductor and de stringing of old earth wire and conductor.
TROMBAY - KALWA	IntraState	07/04/2022	09:00	08/04/2022	19:59	PO	Stringing of HTLS conductor from Loc no.76 to 220KV Trombay ss Gantry.
URAN - APTA 4	IntraState	08/04/2022	09:04	08/04/2022	18:18	PO	For Taking Auto reclosed scheme in service & Diagnostic testing work at uran end
ONI KHAREPATAN LINE	IntraState	08/04/2022	09:05	08/04/2022	21:39	PO	For bay maintenance work, hotspot attending & CRM test of CB.
HALKARNI - TILARI LINE	IntraState	08/04/2022	10:32	09/04/2022	18:26	PO	245kv CGL make CB overhauling work
CHAKAN-BHOSARI 1	IntraState	08/04/2022	11:11	08/04/2022	15:22	T	LTS operated on 400KV Chakan Talegaon PG

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 08/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VITA - GHATNANDRE	IntraState	08/04/2022	11:56	08/04/2022	16:00	PO	String replacement at Loc No.22 Y Ph pilot string by HLU
BHOSARI 2 - TELCO	IntraState	08/04/2022	13:32	08/04/2022	15:41	HT	HT for Load Management
BABLESHWAR AHAMADNAGAR-II	IntraState	08/04/2022	14:24	08/04/2022	14:45	T	tripped on dist prot
PADGHE - WADA	IntraState	08/04/2022	14:32	08/04/2022	19:03	PO	1) Replacement of Faulty insulator strings at loc. No. 91(B-PH). 2) Cold line washing of insulator strings at loc. No. 87, 88, 89, 90, 91, 92, 93
KURKUMBH - RELIANCE RETAIL LIMITED (RIL)	IntraState	08/04/2022	15:25	08/04/2022	21:05	PO	Reconnection of jumpers of 29A isolator of ICT 1 at 220kV Kurkumbh ss.
MUMEWADI - HALKARNI 2 LINE	IntraState	08/04/2022	17:22	08/04/2022	18:07	T	Distance Protection
LAMBOTI - TULJAPUR CKT - 1	IntraState	08/04/2022	21:04	08/04/2022	21:53	T	Distance Protection
WAGHIVALI - DHARAVI 7	IntraState	09/04/2022	00:41	09/04/2022	03:12	PO	WORK IN VICINITY OF TROMBAY SALSETTE-2
TROMBAY SALSETTE LINE-2	IntraState	09/04/2022	00:51	09/04/2022	03:01	PO	ATTENDING CRITICAL HOT SPOT AT TROMBAY
HINJAWADI I- CHINCHWAD	IntraState	09/04/2022	06:50	09/04/2022	17:12	HT	220KV CHINCHWAD-HINJEWADI -1 WAS H/T FOR LOAD MANAGEMENT AND 220KV KANDALGAON- PIRANGUT CKT H/T DUE TO FOREST FIRE .
SIEMENS - RELIANCE GIS	IntraState	09/04/2022	09:29	09/04/2022	11:14	PO	Tree cutting work at 220KV Siemens S/s
KADEGAON-MIRAJ	IntraState	09/04/2022	09:50	09/04/2022	18:49	PO	Tower painting
MALEGAON-SATANA	IntraState	09/04/2022	09:54	09/04/2022	19:49	PO	Outage proposal for the replacement of faulty disc insulators found in PID testing at various locations.
KALWA - SIEMENS	IntraState	09/04/2022	14:46	09/04/2022	16:36	PO	Tree cutting work at 220KV Siemens S/s by M/s Siemens consumer of 220KV Siemens-Kalwa line side (Safety Outage)
INFOSYS - HINJEWADI	IntraState	09/04/2022	17:02	09/04/2022	17:15	T	220KV CHINCHWAD-HINJEWADI -1 WAS H/T FOR LOAD MANAGEMENT AND 220KV KANDALGAON- PIRANGUT CKT H/T DUE TO FOREST FIRE .
INFOSYS - PIGASUS	IntraState	09/04/2022	17:02	09/04/2022	17:30	T	220KV CHINCHWAD-HINJEWADI -1 WAS H/T FOR LOAD MANAGEMENT AND 220KV KANDALGAON- PIRANGUT CKT H/T DUE TO FOREST FIRE .
HINJEWADI 2 - PEGASUS	IntraState	09/04/2022	17:02	09/04/2022	17:30	T	220KV CHINCHWAD-HINJEWADI -1 WAS H/T FOR LOAD MANAGEMENT AND 220KV KANDALGAON- PIRANGUT CKT H/T DUE TO FOREST FIRE .
PIRANGUT - HINJAWADI 2	IntraState	09/04/2022	17:02	09/04/2022	17:30	T	220KV CHINCHWAD-HINJEWADI -1 WAS H/T FOR LOAD MANAGEMENT AND 220KV KANDALGAON- PIRANGUT CKT H/T DUE TO FOREST FIRE .
KANDALGAON - PIRANGUT	IntraState	09/04/2022	17:02	09/04/2022	17:32	HT	CKT H/T DUE TO FOREST FIRE
BABLESHWAR -BHENDA	IntraState	09/04/2022	19:20	09/04/2022	20:55	EO	To attend Yph CT oil leakage
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 2	IntraState	09/04/2022	21:51		Continued.	HT	HT FOR OVERDRAWAL

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	09/04/2022	21:52		Continued.	HT	HT FOR OVERDRAWAL
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	09/04/2022	22:40		Continued.	HT	HT for Overdrawal
BHUGAON - WARDHA (PG)	IntraState	09/04/2022	23:20		Continued.	HT	HT FOR OVERDRAWAL
WARDHA (PG) - BADNERA	IntraState	09/04/2022	23:31		Continued.	HT	HT FOR OVERDRAWAL
OSMANABAD - PARLY (PG)	IntraState	09/04/2022	23:36		Continued.	HT	HT FOR OVERDRAWAL
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 1	IntraState	09/04/2022	23:44		Continued.	HT	HT FOR OVERDRAWAL
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	25/03/2022	11:32	09/04/2022	11:47	PO	1.Retrofiting of 86M Relay, BO/BI LVCT/PT connection to BCU under MTAMC work. 2.Arresting oil leakage from Top cover of Body by replacing all gaskets at site by opening /dismantling of accessories & installation of DM of 50MVA BHEL make Tf. 3.After complete work oil filtration & vacuum cycle will be done by pursing/injecting N2 gas .
220 / 110 / 33kV 315 MVA ICT 6 @ CARNAC	IntraState	03/04/2022	11:00			PO	FOR SHIFTING ON NEW 110 KV GIS
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	08/04/2022	09:26	08/04/2022	15:33	PO	Quarterly Maintenance Work.
220/22 KV 50 MVA PTR 5 @ TEMGHAR	IntraState	08/04/2022	09:54	08/04/2022	19:02	PO	OLTC Overhauling work & oil leakage attending work.
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	08/04/2022	10:40	08/04/2022	15:11	PO	1. Annual relay testing work 2. Quarterly maintenance work
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	09/04/2022	09:18	09/04/2022	18:05	PO	1. DIGANOSTIC TESTING WORK 2. ATTENDING CTR TROUBLE SHOOTING PROBLEM 3. ATTENDING RED HOT SPOTS 4. PREMONSOON MAINTENANCE WORK
220/22 KV 50 MVA PTR 2 @ WADKHAL (GIS)	IntraState	09/04/2022	14:24	09/04/2022	20:56	PO	HV Y Ph and B Ph Bushing replacement work
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	09/04/2022	19:35	09/04/2022	21:52	EO	1) For attending oil leakage from Yph OLTC
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 09/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage