

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 08/May/2022 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 172.030        | 1279.584        | 1) Gujrat                      | -4.166         | -33.733         |
| 2) Hydro            | 14.497         | 166.943         | 2) Madhya Pradesh              | 7.248          | 64.705          |
| 3) Gas              | 7.366          | 50.484          | 3) Chattisgarh                 | 3.960          | 33.420          |
| <b>Total MSPGCL</b> | <b>193.893</b> | <b>1497.011</b> | 4) Maharashtra                 | 185.180        | 1526.493        |
| B) 1) APLM          | 61.115         | 559.701         | 5) Goa (Amona)                 | -1.154         | -12.523         |
| 2) JSWEL            | 21.675         | 154.229         | <b>Total</b>                   | <b>191.068</b> | <b>1578.362</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 28.033         | 272.330         |
| 4) RPL(AMT)         | 31.218         | 234.389         | b) Mumbai Drawl                | 33.137         | 295.866         |
| 5) SWPGPL           | 9.293          | 72.756          | c) MSEDCL Bilateral *          | 75.003         | 597.343         |
| 6) Other IPP        | 22.398         | 190.165         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 28.033         | 272.330         |
| C) 1) TPCL Thermal  | 13.553         | 116.661         | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 1.253          | 24.391          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.679          | 25.416          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 11.536         | 92.352          | 1) MSEDCL                      | 521.072        | 4173.227        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 63.158         | 554.685         |
| 1) Thermal          | 342.818        | 2699.837        | 3) Other Discoms               | 8.931          | 74.368          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>593.161</b> | <b>4802.280</b> |
| 2) Hydro            | 15.750         | 191.334         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.045         | 75.900          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 23.899         | 179.545         |                                |                |                 |
| 6) SOLAR            | 8.581          | 77.303          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>402.093</b> | <b>3223.919</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 8 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 7169                      | 7153                  | 7153                      | 6913                      |
| MSPGCL Hydro               | 396                       | 528                   | 1094                      | 278                       |
| MSPGCL Gas                 | 256                       | 261                   | 400                       | 282                       |
| MSPGCL Total Generation    | 7820                      | 7942                  | 8648                      | 7474                      |
| Central Sector Receipt     | 8964                      | 9508                  | 7524                      | 7384                      |
| WIND                       | 849                       | 713                   | 651                       | 1027                      |
| CPP / IPP Thermal          | 5335                      | 6016                  | 5839                      | 6140                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1246                      | 859                   | 0                         | 325                       |
| Exchange with Mumbai       | -1540                     | -1551                 | -1488                     | -1004                     |
| <b>MSEDCL DEMAND MET</b>   | <b>22286</b>              | <b>23116</b>          | <b>20776</b>              | <b>20957</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 22286                     | 23116                 | 20776                     | 20957                     |
| TPCL GENERATION            | 686                       | 790                   | 695                       | 760                       |
| AEML GENERATION            | 436                       | 493                   | 476                       | 499                       |
| <b>MUMBAI DEMAND</b>       | <b>2662</b>               | <b>2834</b>           | <b>2659</b>               | <b>2263</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>389</b>                | <b>370</b>            | <b>398</b>                | <b>389</b>                |
| STATE DEMAND MET           | 25337                     | 26320                 | 23832                     | 23608                     |
| <b>STATE DEMAND</b>        | <b>25337</b>              | <b>26320</b>          | <b>23832</b>              | <b>23608</b>              |
| Frequency (Hz)             | 49.97                     | 49.94                 | 49.78                     | 50.08                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 09.01 Hrs | 49.58 Hz at 19.27 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 08/May/2022

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.83         | 32.74         | 185      | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 13.35        | 106.29        | 588      | 475      |
| Unit 9             | 11.46        | 96.90         | 528      | 441      |
| Unit 10            | 13.12        | 104.77        | 561      | 520      |
| <b>Total</b>       | <b>41.76</b> | <b>340.70</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.12         | 24.77         | 145      | 120      |
| Unit 4             | 10.18        | 32.45         | 460      | 335      |
| Unit 5             | 9.26         | 67.56         | 435      | 310      |
| <b>Total</b>       | <b>22.56</b> | <b>124.78</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.24         | 15.22         | 250      | 0        |
| Unit 7             | 4.84         | 30.82         | 223      | 148      |
| Unit 8             | 0.00         | 21.19         | 0        | 0        |
| <b>Total</b>       | <b>9.07</b>  | <b>67.23</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.41         | 32.26         | 153      | 130      |
| Unit 4             | 3.59         | 29.86         | 166      | 131      |
| Unit 5             | 7.55         | 67.07         | 335      | 290      |
| Unit 6             | 9.00         | 47.80         | 400      | 320      |
| Unit 7             | 9.29         | 74.00         | 419      | 338      |
| Unit 8             | 10.80        | 65.40         | 460      | 437      |
| Unit 9             | 9.73         | 80.29         | 427      | 383      |
| <b>Total</b>       | <b>53.36</b> | <b>396.67</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.76         | 36.89         | 223      | 145      |
| Unit 4             | 4.67         | 34.53         | 219      | 149      |
| <b>Total</b>       | <b>9.44</b>  | <b>71.42</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.55         | 22.12         | 130      | 80       |
| Unit 2             | 2.72         | 28.00         | 160      | 0        |
| Unit 3             | 4.18         | 20.54         | 181      | 145      |
| Unit 4             | 3.58         | 27.87         | 161      | 140      |
| Unit 5             | 11.29        | 88.96         | 480      | 460      |
| <b>Total</b>       | <b>24.32</b> | <b>187.48</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.84         | 31.61         | 188      | 121      |
| Unit 4             | 3.89         | 30.88         | 186      | 137      |
| Unit 5             | 3.78         | 28.80         | 180      | 113      |
| <b>Total</b>       | <b>11.51</b> | <b>91.29</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.37         | 50.48         | 422      | 197      |
| <b>Total</b>       | <b>7.37</b>  | <b>50.48</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.10         | 0.88          | 24       | 0        |
| <b>Total</b>       | <b>0.10</b>  | <b>0.88</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 3.22          | 33.48          | 435      | 40       |
| Stage 4         | 2.05          | 50.60          | 500      | 0        |
| Stage 3         | 1.54          | 18.99          | 160      | 0        |
| <b>Total</b>    | <b>6.82</b>   | <b>103.07</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.35          | 3.58           | 15       | 15       |
| VTRNA           | 0.84          | 6.75           | 60       | 0        |
| TILLARI         | 0.58          | 4.63           | 58       | 0        |
| BHIRA T.R.      | 0.10          | 0.99           | 57       | 0        |
| SMLHY_PTN       | 5.24          | 42.93          | 223      | 209      |
| GHATGHAR        | 0.48          | 4.10           | 125      | 0        |
| <b>Total</b>    | <b>7.58</b>   | <b>62.99</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 23.90         | 179.54         | 0        | 0        |
| <b>Total</b>    | <b>23.90</b>  | <b>179.54</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 61.12         | 559.70         | 0        | 0        |
| JSWEL(Mus)      | 21.68         | 154.23         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 31.22         | 234.39         | 0        | 0        |
| SWPGPL-Mus      | 9.29          | 72.76          | 0        | 0        |
| Other(Mus)      | 22.40         | 190.16         | 0        | 0        |
| <b>Total</b>    | <b>145.70</b> | <b>1211.24</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 8.58          | 77.30          | 0        | 0        |
| <b>Total</b>    | <b>8.58</b>   | <b>77.30</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.12          | 76.67          | 427      | 277      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.25          | 15.01          | 114      | 61       |
| Trombay 7B      | 1.43          | 10.40          | 66       | 50       |
| TATA Hydro      | 1.25          | 24.39          | 228      | 0        |
| Trombay 8       | 4.44          | 39.99          | 233      | 129      |
| <b>Total</b>    | <b>18.48</b>  | <b>166.47</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.54         | 92.35          | 500      | 346      |
| <b>Total</b>    | <b>11.54</b>  | <b>92.35</b>   |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 172.03      | 1279.58       | MSPGCL Total        | 193.89      | 1497.01       |
|                |             |         | MSPGCL Thml+Gas | 179.40      | 1330.07       | Koyna 1,2 & 4 Total | 5.27        | 84.08         |
|                |             |         | MSPGCL Hydro    | 14.50       | 166.94        | State Total         | 402.09      | 3223.92       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 08/May/2022

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | LOAD<br>SHED<br>DING | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        |                      |                               |                      |                               |                 |               |
| 1                  | 7296        | 1358  | 197  | 8850   | 1168  | 6766      | 0    | 0     | 7337        | 7379        | -1418                | 22402                  | 0                    | 22402                         | 2928                 | 343                           | 25674           | 49.96         |
| 2                  | 7269        | 1428  | 258  | 8954   | 1205  | 6767      | 0    | 0     | 7246        | 7340        | -1294                | 22657                  | 0                    | 22657                         | 2751                 | 315                           | 25724           | 50.01         |
| 3                  | 7385        | 1202  | 271  | 8858   | 1289  | 6748      | 0    | 0     | 7085        | 7208        | -1174                | 22638                  | 0                    | 22638                         | 2576                 | 291                           | 25506           | 49.98         |
| 4                  | 7398        | 714   | 282  | 8394   | 1307  | 6742      | 0    | 0     | 7270        | 7466        | -1154                | 22450                  | 0                    | 22450                         | 2451                 | 304                           | 25206           | 49.99         |
| 5                  | 7466        | 436   | 281  | 8184   | 1482  | 6740      | 0    | 0     | 7289        | 7191        | -1073                | 22206                  | 0                    | 22206                         | 2362                 | 318                           | 24886           | 50.00         |
| 6                  | 7427        | 438   | 282  | 8146   | 1363  | 6712      | 0    | 0     | 7421        | 7535        | -1076                | 22342                  | 0                    | 22342                         | 2350                 | 338                           | 25030           | 49.99         |
| 7                  | 7397        | 400   | 272  | 8070   | 1138  | 6711      | 0    | 66    | 7271        | 7016        | -1035                | 21604                  | 0                    | 21604                         | 2279                 | 361                           | 24244           | 50.03         |
| 8                  | 6913        | 278   | 282  | 7474   | 1027  | 6140      | 0    | 325   | 7562        | 7384        | -1004                | 20957                  | 0                    | 20957                         | 2263                 | 389                           | 23608           | 50.08         |
| 9                  | 6627        | 510   | 270  | 7408   | 994   | 5534      | 0    | 621   | 7282        | 7853        | -1077                | 20938                  | 0                    | 20938                         | 2331                 | 395                           | 23664           | 50.05         |
| 10                 | 6982        | 456   | 268  | 7706   | 1144  | 5577      | 0    | 928   | 7386        | 7749        | -1396                | 21299                  | 0                    | 21299                         | 2415                 | 409                           | 24123           | 50.06         |
| 11                 | 6919        | 426   | 267  | 7612   | 1064  | 5312      | 0    | 1160  | 8489        | 8383        | -1471                | 21655                  | 0                    | 21655                         | 2547                 | 406                           | 24608           | 50.02         |
| 12                 | 7169        | 396   | 256  | 7820   | 849   | 5335      | 0    | 1246  | 8883        | 8964        | -1540                | 22286                  | 0                    | 22286                         | 2662                 | 389                           | 25337           | 49.97         |
| 13                 | 7337        | 400   | 265  | 8002   | 662   | 5702      | 0    | 1183  | 8657        | 8709        | -1558                | 22319                  | 0                    | 22319                         | 2740                 | 381                           | 25440           | 49.97         |
| 14                 | 7262        | 394   | 265  | 7922   | 706   | 5970      | 0    | 948   | 9179        | 8948        | -1542                | 22583                  | 0                    | 22583                         | 2762                 | 369                           | 25714           | 50.01         |
| 15                 | 7153        | 528   | 261  | 7942   | 713   | 6016      | 0    | 859   | 9525        | 9508        | -1551                | 23116                  | 0                    | 23116                         | 2834                 | 370                           | 26320           | 49.94         |
| 16                 | 7042        | 394   | 321  | 7758   | 710   | 6078      | 0    | 661   | 9871        | 9722        | -1748                | 22808                  | 0                    | 22808                         | 2864                 | 373                           | 26045           | 49.98         |
| 17                 | 6811        | 418   | 326  | 7555   | 890   | 5834      | 0    | 411   | 9111        | 9032        | -1681                | 21637                  | 0                    | 21637                         | 2763                 | 404                           | 24804           | 50.06         |
| 18                 | 6911        | 383   | 346  | 7640   | 911   | 5477      | 0    | 149   | 8303        | 8248        | -1504                | 20502                  | 0                    | 20502                         | 2618                 | 418                           | 23538           | 50.03         |
| 19                 | 7035        | 444   | 367  | 7846   | 663   | 5447      | 0    | 24    | 7534        | 7572        | -1406                | 19729                  | 0                    | 19729                         | 2547                 | 417                           | 22692           | 50.00         |
| 20                 | 7153        | 1094  | 400  | 8648   | 651   | 5839      | 0    | 0     | 7298        | 7524        | -1488                | 20776                  | 0                    | 20776                         | 2659                 | 398                           | 23832           | 49.78         |
| 21                 | 7137        | 518   | 422  | 8078   | 833   | 6020      | 0    | 0     | 7555        | 7522        | -1569                | 20490                  | 0                    | 20490                         | 2756                 | 394                           | 23640           | 49.99         |
| 22                 | 7197        | 468   | 391  | 8056   | 1005  | 6040      | 0    | 0     | 7320        | 7312        | -1483                | 20530                  | 0                    | 20530                         | 2806                 | 399                           | 23736           | 49.99         |
| 23                 | 7348        | 470   | 403  | 8221   | 1071  | 6089      | 0    | 0     | 7440        | 7944        | -1441                | 21505                  | 0                    | 21505                         | 2904                 | 379                           | 24788           | 49.97         |
| 24                 | 7396        | 942   | 413  | 8752   | 1054  | 6103      | 0    | 0     | 7422        | 7559        | -1454                | 21644                  | 0                    | 21644                         | 2990                 | 370                           | 25004           | 49.98         |
| MUs                | 172.03      | 14.50 | 7.37 | 193.89 | 23.90 | 145.70    | 0.00 | 8.58  | 189.74      | 191.07      | -33.14               | 521.07                 | 0.00                 | 521.07                        | 63.16                | 8.93                          | 593.16          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 08/May/2022**

**Position as on 6.30 Hrs of 09/May/2022**

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                  | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                                                 |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                                                                                  |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR          | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                                                                                   |               |
| CENT.SECTOR          | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL               | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| IPP                  | JSW (J) U1              | 300      | 16/03/2022   | 23:16        |            | Continued. | Turbine Vibration                                                                                                                                       | 03/05/2022    |
| MSPGCL               | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      |               |
| MSPGCL               | Parli Unit 6            | 250      | 03/05/2022   | 12:13        | 08/05/2022 | 01:45      | Boiler Tube Leakage                                                                                                                                     | 06/05/2022    |
| MSPGCL               | Parli Unit 8            | 250      | 07/05/2022   | 12:25        |            | Continued. | Boiler Tube Leakage                                                                                                                                     |               |
| MSPGCL               | Uran Unit 8             | 108      | 07/05/2022   | 19:08        | 08/05/2022 | 14:10      | Generator Protection operated                                                                                                                           |               |
| MSPGCL               | Uran Unit B0            | 120      | 07/05/2022   | 19:08        | 08/05/2022 | 17:43      | Generator Protection operated                                                                                                                           |               |
| IPP                  | Adani U-2               | 660      | 08/05/2022   | 08:48        |            | Continued. | APH-A high vibration and gearbox abnormal sound                                                                                                         |               |
| MSPGCL               | Koradi Unit 6           | 210      | 08/05/2022   | 14:15        | 08/05/2022 | 16:22      | TRIPPED ON MAIN OIL TANK LUBE OIL PRESSURE LOW                                                                                                          |               |
| MSPGCL               | Khaparkheda Unit 2      | 210      | 08/05/2022   | 15:30        | 08/05/2022 | 21:45      | TRIPPED DUE TO SUSPECTED AC SUPPLY FAILURE                                                                                                              |               |
| IPP                  | SWPGPL U-3              | 135      | 09/05/2022   | 09:30        |            | Continued. | due to Boiler SSC chain broken problem                                                                                                                  |               |
| MSPGCL               | Paras Unit 4            | 250      | 09/05/2022   | 12:15        | 09/05/2022 | 15:12      | Furnace Pressure High                                                                                                                                   |               |
| MSPGCL               | Paras Unit 3            | 250      | 09/05/2022   | 12:29        |            | Continued. | ATTEND HP BYPASS BP2 V/V HEAVY GLAND LEAKAGE .                                                                                                          |               |
| MSPGCL               | Nasik Unit 5            | 210      | 09/05/2022   | 16:15        |            | Continued. | Generator protection                                                                                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2022**

**Statement-VII**

Position as on 6.30 Hrs of 09/May/2022

| Name of Line                                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                   |
|----------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV MAINBAY Outages/Trippings</b>                        |                           |              |              |            |            |             |                                                                                                                                                                                    |
| MAIN BAY (704) OF EKTUNI CKT - 1 @ AKOLA 2                     | IntraState                | 09/05/2022   | 09:42        | 09/05/2022 | 16:28      | PO          | Circuit Breaker SF6 gas analysis                                                                                                                                                   |
| <b>765 KV BR Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                    |
| Main bay 711 of 765 kv Bus Reactor @ Ektuni                    | IntraState                | 09/05/2022   | 15:06        | 09/05/2022 | 18:02      | PO          | Diagnostic Testing of CT & Routine Maintenance                                                                                                                                     |
| <b>400 KV TIEBAY Outages/Trippings</b>                         |                           |              |              |            |            |             |                                                                                                                                                                                    |
| TIE BAY (418) OF CHANDRAPUR CKT & STATION TF - B @ KHAPARKHEDA | IntraState                | 09/05/2022   | 11:48        | 09/05/2022 | 12:41      | PO          | Tie Bay CTs Diagnostic Testing Work                                                                                                                                                |
| <b>400 KV MAINBAY Outages/Trippings</b>                        |                           |              |              |            |            |             |                                                                                                                                                                                    |
| MAIN BAY (417) OF CHANDRPUR CKT @ KHAPARKHEDA                  | IntraState                | 09/05/2022   | 10:25        | 09/05/2022 | 11:36      | PO          | Main Bay CTs Diagnostic Testing Work                                                                                                                                               |
| <b>400 KV LINE Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                    |
| KALWA - TALEGAON (PG)                                          | InterState                | 08/05/2022   | 00:36        | 08/05/2022 | 08:00      | EO          | Chemical cleaning of insulators in the fog prone region.                                                                                                                           |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                            | IntraState                | 30/04/2022   | 11:21        |            |            | HT          | HT for Load Management                                                                                                                                                             |
| JEJURI- KOYNA STAGE-IV                                         | IntraState                | 07/05/2022   | 22:49        | 08/05/2022 | 11:05      | EO          | Oil leakage of 400 KV Breaker at GIS                                                                                                                                               |
| AKOLA - KHADKA (BHUSAWAL)                                      | IntraState                | 08/05/2022   | 08:02        | 08/05/2022 | 17:13      | T           | Distance Protection                                                                                                                                                                |
| NAGOTHANE - DABHOL CKT - 1                                     | IntraState                | 08/05/2022   | 12:00        | 08/05/2022 | 12:37      | T           | Distance Protection                                                                                                                                                                |
| PADGHE - KALWA CKT - 1                                         | IntraState                | 08/05/2022   | 22:36        | 09/05/2022 | 05:28      | EO          | Cold line and chemical cleaning of insulators at various locations in Mumbra Hill, Shilfata, Diagar area                                                                           |
| NAGOTHANE - DABHOL CKT - 1                                     | IntraState                | 09/05/2022   | 05:15        | 09/05/2022 | 06:14      | T           | Distance Tripped from Dabhol end only AR success from Nagothane side.<br>Dabhol indication- 5.5 KM, 15 KAm, B-Phase.                                                               |
| JAIGAD - KARAD CKT - 2                                         | IntraState                | 09/05/2022   | 10:45        |            |            | PO          | BAY MAINTENANCE WORK AT MSETCL KARAD                                                                                                                                               |
| KARAD - TALANDGE CKT - 1                                       | IntraState                | 09/05/2022   | 19:48        |            |            | EO          | To attend hot spot                                                                                                                                                                 |
| <b>220 KV TBC Outages/Trippings</b>                            |                           |              |              |            |            |             |                                                                                                                                                                                    |
| BUS COUPLER @ BACKBAY                                          | IntraState                | 08/05/2022   | 10:45        | 08/05/2022 | 17:58      | PO          | PROJECT WORK-HYDRAULIC CYLINDER REPLACEMENT                                                                                                                                        |
| <b>220 KV LINE Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                    |
| MULUND - GIS BHANDUP                                           | IntraState                | 29/01/2022   | 15:44        |            |            | T           | cABLE FAULT                                                                                                                                                                        |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 2                              | IntraState                | 27/04/2022   | 12:21        |            |            | EO          | Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.                                                                                                                                |
| BOISAR II - TARAPUR                                            | IntraState                | 30/04/2022   | 11:32        |            |            | PO          | Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth-wire and all insulator strings of the line      |
| TALANDGE - ICHALKARANJI 2                                      | IntraState                | 07/05/2022   | 22:52        | 08/05/2022 | 00:31      | EO          | Attending Hotspot on tower loc no- 8 B Phase                                                                                                                                       |
| ADLABS - PEDAMBE                                               | IntraState                | 08/05/2022   | 08:57        | 08/05/2022 | 21:22      | PO          | Outage for replacement of flashover insulator string at Loc. No. 35 Top phase Adlabs side & 41 Top phase (string found flashover during aerial patrolling done on Dtd. 01.05.2022) |
| TROMBAY - ANTOP HILL CKT - 1                                   | IntraState                | 08/05/2022   | 11:28        | 08/05/2022 | 17:10      | PO          | CVT TESTING AT TROMBAY                                                                                                                                                             |
| KANDALGAON - PIRANGUT                                          | IntraState                | 08/05/2022   | 11:57        | 08/05/2022 | 18:22      | PO          | 1) Providing by pass jump by PG clamps<br>2) Nut bolt tightening at tension location. loc no-1-17                                                                                  |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2022**

**Statement-VII**

**Position as on 6.30 Hrs of 09/May/2022**

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                      |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BORIVALI - TARAPUR                           | IntraState                | 08/05/2022   | 12:37        | 08/05/2022 | 20:33      | EO          | Replacement of heavily Rusted earth-wire between Loc No.11 to 28.                                                                                                                                                                                                                                                     |
| TALANDGE - SAWANTWADI                        | IntraState                | 09/05/2022   | 08:17        | 09/05/2022 | 17:51      | PO          | Cold washing of line insulators.                                                                                                                                                                                                                                                                                      |
| CHEMBUR (AEML) - NERUL (M)                   | IntraState                | 09/05/2022   | 09:30        | 09/05/2022 | 22:26      | T           | DP                                                                                                                                                                                                                                                                                                                    |
| NAGOTHANE - MSL                              | IntraState                | 09/05/2022   | 09:36        | 09/05/2022 | 22:40      | PO          | R ph metering CT replacement work at consumer end                                                                                                                                                                                                                                                                     |
| NAGOTHANE - MSL                              | IntraState                | 09/05/2022   | 09:36        | 09/05/2022 | 22:40      | PO          | CONSUMER END METERING CT REPLACEMENT WORK WILL BE. CARRIED OUT. LINE IS RADIAL.                                                                                                                                                                                                                                       |
| LAMBOTI - TULJAPUR CKT - 1                   | IntraState                | 09/05/2022   | 11:50        | 09/05/2022 | 18:00      | PO          | CB overhauling work to be done from external agency.                                                                                                                                                                                                                                                                  |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                       |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE    | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                                                                                                      |
| 220/22 KV 50 MVA PTR 1 @ KANDALGAON          | IntraState                | 14/12/2021   | 16:55        |            |            | EO          | For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s                                                                                                                                                                                                                                                                 |
| 220/22 KV 50 MVA PTR 1 @ VASAI               | IntraState                | 08/05/2022   | 09:56        | 08/05/2022 | 17:35      | PO          | Dismantling of 22kV GIS Outgoing feeder -1 due to CB issue by Agency & Pre-monsoon maintenance & diagnostic work.                                                                                                                                                                                                     |
| 220 / 110 / 23kV 250 MVA ICT 3 @ SALSETTE    | IntraState                | 08/05/2022   | 10:42        | 08/05/2022 | 16:03      | PO          | R/M AND TESTING                                                                                                                                                                                                                                                                                                       |
| 220/22 KV 50 MVA PTR 2 @ MAHAD               | IntraState                | 09/05/2022   | 08:27        | 09/05/2022 | 18:28      | PO          | Premonsoon maintance work & painting work.Daignosis test work.                                                                                                                                                                                                                                                        |
| 220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II | IntraState                | 09/05/2022   | 09:13        | 09/05/2022 | 16:55      | PO          | 1)Quaterly bay maintenance work of TF and 33 kV Bus section II and its outgoing feeders 2) Diagnostic testing work of TF and bay equipment 3) Hot spot attending work                                                                                                                                                 |
| 220/132-110KV 200MVA ICT 2 @ MIRAJ           | IntraState                | 09/05/2022   | 09:38        | 09/05/2022 | 16:32      | PO          | TO check auxiliary protection & Q.M.W                                                                                                                                                                                                                                                                                 |
| <b>132 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                       |
| SOLAPUR 2(BALE)-NALDURG                      | IntraState                | 09/05/2022   | 16:25        | 09/05/2022 | 20:38      | PO          | DI Replacement at loc. no. 153R,Y phase,154 y phase                                                                                                                                                                                                                                                                   |
| <b>110 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                       |
| DHARAVI VIKHROLI                             | IntraState                | 30/08/2021   | 00:03        |            |            | PO          | Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai. |
| DHARAVI POWAI                                | IntraState                | 30/08/2021   | 00:03        |            |            | PO          | Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai. |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2022**

**Statement-VII**

Position as on 6.30 Hrs of 09/May/2022

| Name of Line         | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                  |
|----------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| WAGHIVALI - CHEMBUR  | IntraState                   | 04/02/2022      | 10:30           |            |               | PO             | Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi. |
| WAGHIVALI - MANKHURD | IntraState                   | 04/02/2022      | 10:30           |            |               | PO             | Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi. |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage