

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 08/May/2024 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 172.877        | 1377.983        | 1) Gujrat                      | 3.327          | 20.556          |
| 2) Hydro            | 21.318         | 125.872         | 2) Madhya Pradesh              | 6.436          | 53.995          |
| 3) Gas              | 6.899          | 54.741          | 3) Chattisgarh                 | 4.740          | 25.960          |
| <b>Total MSPGCL</b> | <b>201.094</b> | <b>1558.596</b> | 4) Maharashtra                 | 198.291        | 1519.491        |
| B) 1) APLM          | 63.341         | 511.879         | 5) Goa (Amona)                 | -1.867         | -15.952         |
| 2) JSWEL            | 28.494         | 225.210         | <b>Total</b>                   | <b>210.927</b> | <b>1604.050</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 43.920         | 327.938         |
| 4) RPL(AMT)         | 30.608         | 243.707         | b) Mumbai Drawl                | 44.009         | 345.342         |
| 5) SWPGPL           | 12.196         | 97.573          | c) MSEDCL Bilateral *          | 95.506         | 725.975         |
| 6) Other IPP        | 18.563         | 148.472         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 43.920         | 327.938         |
| C) 1) TPCL Thermal  | 12.533         | 102.447         | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 5.365          | 38.607          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.396          | 28.897          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 11.092         | 75.327          | 1) MSEDCL                      | 541.064        | 4253.125        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 76.395         | 590.619         |
| 1) Thermal          | 349.704        | 2782.598        | 3) Other Discoms               | 11.484         | 90.728          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>628.943</b> | <b>4934.472</b> |
| 2) Hydro (A2+C2)    | 26.683         | 164.479         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 10.295         | 83.638          |                                |                |                 |
| 4) Wind             | 13.414         | 149.688         |                                |                |                 |
| 6) SOLAR            | 17.920         | 150.020         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>418.016</b> | <b>3330.423</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 8 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6516                      | 7336                  | 7457                      | 6948                      |
| MSPGCL Hydro               | 781                       | 1583                  | 1341                      | 874                       |
| MSPGCL Gas                 | 283                       | 282                   | 287                       | 293                       |
| MSPGCL Total Generation    | 7580                      | 9201                  | 9085                      | 8115                      |
| Central Sector Receipt     | 9905                      | 9454                  | 8582                      | 8479                      |
| WIND                       | 173                       | 270                   | 1009                      | 150                       |
| CPP / IPP Thermal          | 5423                      | 6322                  | 6932                      | 5868                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2400                      | 1454                  | 0                         | 648                       |
| Exchange with Mumbai       | -2168                     | -2058                 | -2013                     | -1452                     |
| <b>MSEDCL DEMAND MET</b>   | <b>22778</b>              | <b>24110</b>          | <b>23054</b>              | <b>21332</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 22778                     | 24110                 | 23054                     | 21332                     |
| TPCL GENERATION            | 986                       | 1196                  | 877                       | 703                       |
| AEML GENERATION            | 503                       | 503                   | 437                       | 503                       |
| <b>MUMBAI DEMAND</b>       | <b>3657</b>               | <b>3757</b>           | <b>3327</b>               | <b>2658</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>535</b>                | <b>533</b>            | <b>541</b>                | <b>476</b>                |
| STATE DEMAND MET           | 26970                     | 28400                 | 26922                     | 24466                     |
| <b>STATE DEMAND</b>        | <b>26970</b>              | <b>28400</b>          | <b>26922</b>              | <b>24466</b>              |
| Frequency (Hz)             | 49.94                     | 50.02                 | 50.04                     | 50.06                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 17:02 Hrs | 49.83 Hz at 14:20 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 08/May/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.38         | 34.14         | 195      | 165      |
| Unit 8             | 0.19         | 35.31         | 146      | 0        |
| Unit 9             | 13.52        | 110.79        | 585      | 522      |
| Unit 10            | 13.66        | 112.96        | 625      | 515      |
| <b>Total</b>       | <b>31.75</b> | <b>293.21</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.34         | 20.91         | 170      | 125      |
| Unit 4             | 11.04        | 85.28         | 485      | 330      |
| Unit 5             | 11.14        | 58.03         | 490      | 315      |
| <b>Total</b>       | <b>25.52</b> | <b>164.22</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.02         | 35.99         | 235      | 139      |
| Unit 7             | 4.07         | 35.39         | 234      | 144      |
| Unit 8             | 4.07         | 35.50         | 235      | 141      |
| <b>Total</b>       | <b>12.16</b> | <b>106.87</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.52         | 28.33         | 160      | 125      |
| Unit 4             | 3.62         | 29.47         | 165      | 128      |
| Unit 5             | 9.30         | 68.06         | 440      | 280      |
| Unit 6             | 8.59         | 65.82         | 415      | 280      |
| Unit 7             | 9.02         | 73.69         | 438      | 288      |
| Unit 8             | 10.33        | 83.74         | 456      | 255      |
| Unit 9             | 11.42        | 88.76         | 484      | 468      |
| <b>Total</b>       | <b>55.81</b> | <b>437.86</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.45         | 41.73         | 245      | 186      |
| Unit 4             | 5.55         | 44.42         | 255      | 175      |
| <b>Total</b>       | <b>11.00</b> | <b>86.15</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.25         | 26.66         | 170      | 105      |
| Unit 2             | 3.78         | 32.21         | 198      | 115      |
| Unit 3             | 3.88         | 30.46         | 179      | 110      |
| Unit 4             | 3.70         | 28.85         | 173      | 126      |
| Unit 5             | 11.59        | 88.76         | 498      | 440      |
| <b>Total</b>       | <b>26.20</b> | <b>206.95</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.48         | 23.34         | 175      | 121      |
| Unit 4             | 3.63         | 31.44         | 181      | 126      |
| Unit 5             | 3.33         | 27.94         | 162      | 118      |
| <b>Total</b>       | <b>10.44</b> | <b>82.72</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.90         | 54.74         | 294      | 280      |
| <b>Total</b>       | <b>6.90</b>  | <b>54.74</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.25         | 1.74          | 39       | 0        |
| <b>Total</b>       | <b>0.25</b>  | <b>1.74</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 4.18         | 27.50         | 445      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 10.42         | 50.93          | 999      | 23       |
| Stage 3         | 3.07          | 17.59          | 316      | 78       |
| <b>Total</b>    | <b>17.67</b>  | <b>96.02</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.68          | 5.63           | 29       | 28       |
| VTRNA           | 0.88          | 7.13           | 60       | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 1.76          | 15.20          | 81       | 69       |
| GHATGHAR        | 0.32          | 1.90           | 250      | 0        |
| <b>Total</b>    | <b>3.65</b>   | <b>29.86</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 13.41         | 149.69         | 0        | 0        |
| <b>Total</b>    | <b>13.41</b>  | <b>149.69</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 63.34         | 511.88         | 0        | 0        |
| JSWEL(Mus)      | 28.49         | 225.21         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 30.61         | 243.71         | 0        | 0        |
| SWPGPL-Mus      | 12.20         | 97.57          | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.46          | 43.04          | 268      | 176      |
| Other(Mus)      | 7.40          | 61.63          | 0        | 0        |
| JPL             | 5.70          | 43.80          | 463      | 164      |
| <b>Total</b>    | <b>153.20</b> | <b>1226.84</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 17.92         | 150.02         | 0        | 0        |
| <b>Total</b>    | <b>17.92</b>  | <b>150.02</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.32          | 66.77          | 461      | 261      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.03          | 17.62          | 108      | 60       |
| Trombay 7B      | 1.36          | 11.27          | 64       | 49       |
| TATA Hydro      | 5.36          | 38.61          | 358      | 106      |
| Trombay 8       | 4.21          | 35.68          | 226      | 131      |
| <b>Total</b>    | <b>21.29</b>  | <b>169.95</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.09         | 75.33          | 503      | 285      |
| <b>Total</b>    | <b>11.09</b>  | <b>75.33</b>   |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 172.88      | 1377.98       | MSPGCL Total        | 201.09      | 1558.60       |
|                |             |         | MSPGCL Thml+Gas | 179.78      | 1432.72       | Koyna 1,2 & 4 Total | 14.60       | 78.43         |
|                |             |         | MSPGCL Hydro    | 21.32       | 125.87        | State Total         | 418.02      | 3330.42       |

## Hourly Load Data As on 08/May/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 7440        | 638   | 292  | 8370   | 1011  | 7052      | 0    | 0     | 8646        | 8569        | -1919                | 22645                  | 0                | 0                           | 22645                         | 3129             | 438                       | 26212           | 50.04         |
| 2                  | 7240        | 533   | 292  | 8065   | 916   | 6939      | 0    | 0     | 8775        | 8351        | -1720                | 22157                  | 0                | 0                           | 22157                         | 2901             | 394                       | 25452           | 49.98         |
| 3                  | 7131        | 543   | 292  | 7966   | 859   | 6542      | 0    | 0     | 8611        | 8503        | -1665                | 21836                  | 0                | 0                           | 21836                         | 2687             | 370                       | 24892           | 49.95         |
| 4                  | 7151        | 1149  | 293  | 8593   | 936   | 6308      | 0    | 0     | 8306        | 8054        | -1630                | 21893                  | 0                | 0                           | 21893                         | 2548             | 368                       | 24809           | 50.01         |
| 5                  | 7298        | 712   | 293  | 8303   | 734   | 6706      | 0    | 0     | 8132        | 7942        | -1562                | 21732                  | 0                | 0                           | 21732                         | 2489             | 391                       | 24612           | 50.03         |
| 6                  | 7241        | 732   | 292  | 8265   | 587   | 6753      | 0    | 0     | 8350        | 7994        | -1330                | 21840                  | 0                | 0                           | 21840                         | 2512             | 430                       | 24781           | 50.01         |
| 7                  | 7326        | 721   | 294  | 8341   | 311   | 6685      | 0    | 137   | 8206        | 8100        | -1253                | 21871                  | 0                | 15                          | 21871                         | 2509             | 450                       | 24830           | 50.01         |
| 8                  | 6948        | 874   | 293  | 8115   | 150   | 5868      | 0    | 648   | 8433        | 8479        | -1452                | 21332                  | 0                | 16                          | 21332                         | 2658             | 476                       | 24466           | 50.06         |
| 9                  | 6939        | 286   | 289  | 7514   | 140   | 5742      | 0    | 1326  | 9198        | 9096        | -1790                | 21522                  | 0                | 6                           | 21522                         | 2972             | 506                       | 25000           | 50.04         |
| 10                 | 6821        | 305   | 287  | 7413   | 177   | 5518      | 0    | 1851  | 9959        | 9469        | -2040                | 21874                  | 0                | 0                           | 21874                         | 3294             | 515                       | 25682           | 50.00         |
| 11                 | 6630        | 486   | 282  | 7398   | 203   | 5430      | 0    | 2211  | 10421       | 9709        | -2109                | 22348                  | 0                | 0                           | 22348                         | 3545             | 494                       | 26387           | 49.96         |
| 12                 | 6516        | 781   | 283  | 7580   | 173   | 5423      | 0    | 2400  | 10559       | 9905        | -2168                | 22778                  | 0                | 28                          | 22778                         | 3657             | 535                       | 26970           | 49.94         |
| 13                 | 6742        | 761   | 281  | 7784   | 176   | 5465      | 0    | 2415  | 10316       | 9810        | -2175                | 22980                  | 0                | 25                          | 22980                         | 3655             | 495                       | 27130           | 49.95         |
| 14                 | 6821        | 664   | 280  | 7765   | 133   | 5402      | 0    | 2248  | 10166       | 9673        | -2157                | 22552                  | 0                | 7                           | 22552                         | 3590             | 512                       | 26654           | 49.99         |
| 15                 | 6951        | 945   | 281  | 8177   | 110   | 5546      | 0    | 1912  | 10403       | 10263       | -2167                | 23338                  | 0                | 17                          | 23338                         | 3680             | 503                       | 27521           | 49.94         |
| 16                 | 7336        | 1583  | 282  | 9201   | 270   | 6322      | 0    | 1454  | 9954        | 9454        | -2058                | 24110                  | 0                | 26                          | 24110                         | 3757             | 533                       | 28400           | 50.02         |
| 17                 | 7646        | 1475  | 281  | 9402   | 447   | 6594      | 0    | 892   | 9568        | 9177        | -2065                | 23931                  | 0                | 24                          | 23931                         | 3690             | 516                       | 28137           | 50.01         |
| 18                 | 7456        | 1138  | 282  | 8876   | 523   | 6800      | 0    | 372   | 9235        | 8698        | -2000                | 22747                  | 0                | 23                          | 22747                         | 3552             | 521                       | 26821           | 50.03         |
| 19                 | 7242        | 911   | 287  | 8440   | 831   | 6858      | 0    | 54    | 8936        | 8716        | -1903                | 22463                  | 0                | 14                          | 22463                         | 3355             | 534                       | 26352           | 49.99         |
| 20                 | 7457        | 1341  | 287  | 9085   | 1009  | 6932      | 0    | 0     | 8805        | 8582        | -2013                | 23054                  | 0                | 0                           | 23054                         | 3327             | 541                       | 26922           | 50.04         |
| 21                 | 7583        | 944   | 286  | 8813   | 968   | 7044      | 0    | 0     | 8611        | 8297        | -1959                | 22636                  | 0                | 0                           | 22636                         | 3270             | 527                       | 26433           | 50.05         |
| 22                 | 7623        | 697   | 287  | 8607   | 972   | 7092      | 0    | 0     | 8294        | 8270        | -1670                | 22775                  | 0                | 0                           | 22775                         | 3182             | 496                       | 26453           | 50.02         |
| 23                 | 7689        | 1332  | 291  | 9312   | 967   | 7087      | 0    | 0     | 7900        | 7956        | -1598                | 23247                  | 0                | 0                           | 23247                         | 3190             | 478                       | 26914           | 50.06         |
| 24                 | 7650        | 1767  | 292  | 9709   | 811   | 7093      | 0    | 0     | 7853        | 7860        | -1606                | 23405                  | 0                | 0                           | 23405                         | 3246             | 461                       | 27113           | 50.07         |
| MUs                | 172.88      | 21.32 | 6.90 | 201.09 | 13.41 | 153.20    | 0.00 | 17.92 | 217.64      | 210.93      | -44.01               | 541.06                 | 0.00             | 0.20                        | 541.06                        | 76.39            | 11.48                     | 628.94          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

- 1) ELR carried out due to Overload of 132kV BBLR-Rahuri line and 220kV Alephata line Overload at 132kV Ghargaon S/stn.
- 2) DLS carried out due to Overloading of 220kV Alephata-BBLR line.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 08/May/2024

Position as on 6.30 Hrs of 09/May/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| FORCED OUTAGE                                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/08/2024    |
| MSPGCL                                        | Koradi Unit 8           | 660      | 04/05/2024   | 01:08        | 08/05/2024 | 22:16      | Boiler Tube Leakage                                                                                                                                     | 08/05/2024    |
| MSPGCL                                        | Paras Unit 3            | 250      | 09/05/2024   | 00:45        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 10/05/2024    |
| Total Capacity MSPGCL                         |                         | 1030     |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                                         | Trombay 8               | 250      | 09/05/2024   | 01:24        |            | Continued. | To attend both debris filter chocking due to shell & barnacles.                                                                                         | 10/05/2024    |
| Total Capacity TPC-G                          |                         | 250      |              |              |            |            |                                                                                                                                                         |               |
| IPP                                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                                           | RPL(AMT) U-2            | 270      | 08/05/2024   | 14:38        | 08/05/2024 | 16:41      | Tripped due to loss of fuel MSF                                                                                                                         |               |
| Total Capacity IPP                            |                         | 270      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/08/2024    |
| CENT.SECTOR                                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/09/2024    |
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE                  |                         | 1870     |              |              |            |            |                                                                                                                                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 06/05/2024   | 23:54        |            | Continued. | Zero Schedule given by MSEDCL                                                                                                                           |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 07/05/2024   | 00:09        |            | Continued. | Zero Schedule given by MSEDCL                                                                                                                           |               |
| Total Capacity MSPGCL                         |                         | 216      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 216      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| Total Capacity IPP                            |                         | 988      |              |              |            |            |                                                                                                                                                         |               |

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 08/May/2024**

**Position as on 6.30 Hrs of 09/May/2024**

| Generating Company                                | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage | Expected Date |
|---------------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------|---------------|
| <b>Total Capacity FORCED OUTAGE DUE TO NO PPA</b> |                         | 988      |              |              |           |            |                  |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2024**

**Statement-VII**

Position as on 6.30 Hrs of 09/May/2024

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                             |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV MAINBAY Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                              |
| TBC @ KARAD                                | IntraState                | 06/05/2024   | 11:15        |            |            | PO          | For Panel rewiring work and retrofitting of LBB Relay                                                                                                                                        |
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                              |
| DHULE - SSNNL CKT - 1                      | InterState                | 08/05/2024   | 10:22        | 08/05/2024 | 20:38      | PO          | For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNL CKT 2 Auto Reclose switchwill be kept on Non Auto mode during Outage |
| PADGHE (GIS) PG - KUDUS CKT - 2            | InterState                | 08/05/2024   | 16:48        | 08/05/2024 | 18:12      | T           | Tripped on distannce protection.                                                                                                                                                             |
| BUS REACTOR (50MVAR) @ PARLI               | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                                                                          |
| CHANDRAPUR 2 - WARORA CKT-2                | IntraState                | 22/04/2024   | 17:27        |            |            | T           | Tripped on distance protection.                                                                                                                                                              |
| CHANDRAPUR 2 - WARORA CKT-1                | IntraState                | 22/04/2024   | 17:27        |            |            | T           | Tripped on distance protection.                                                                                                                                                              |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2        | IntraState                | 01/05/2024   | 22:11        |            |            | HT          | For facilitating outage on 765 Kv Aurangabad - Padghe line.                                                                                                                                  |
| CHANDRAPUR 2 - DHARIWAL CKT - 1            | IntraState                | 08/05/2024   | 06:41        | 08/05/2024 | 18:39      | PO          | FOR 400 KV LINE MAINTENANCE WORK AND BAY EQUIPMENTS TESTING AND PM WORK AT DHARIWAL END AND DIAGONOSTIC TESTING WORK AT C2 END                                                               |
| DEEPNAGAR - AURANGABAD (WALUJ)             | IntraState                | 08/05/2024   | 06:47        | 08/05/2024 | 14:35      | PO          | FOR STRING REPLACEMENT WORK                                                                                                                                                                  |
| JAIGAD - NEW KOYNA CKT - 1                 | IntraState                | 08/05/2024   | 12:07        | 08/05/2024 | 20:38      | PO          | Diagnostic testing & Relay testing work , Routine maint. Work                                                                                                                                |
| TBC 2 @ CHANDRAPUR                         | IntraState                | 08/05/2024   | 15:15        | 08/05/2024 | 21:50      | PO          | TO ATTEND THE CLOSING PROBLEM OF B-PH PENTAGRAPH ISOLATOR -2 (BUS-2 ISOLATOR) OF TBC-2 BAY.                                                                                                  |
| KHADKA-AURANGABAD (WALUJ)                  | IntraState                | 08/05/2024   | 16:58        | 08/05/2024 | 18:17      | T           | Tripped on distannce protection.                                                                                                                                                             |
| CHANDRAPUR-PARLI CKT-3                     | IntraState                | 09/05/2024   | 05:34        |            |            | PO          | For replacement of insulator strings of Y & B ph at loc. No. 99 for found faulty in online PID and also replacement of polymer insulator strings by long rod porcelain at LOC 75.            |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                              |
| STATION TF No 3 @ CHANDRAPUR GCR           | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                               |
| 400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS   | IntraState                | 10/02/2024   | 17:40        |            |            | HT          | H/T For LV only.                                                                                                                                                                             |
| 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA | IntraState                | 08/05/2024   | 08:15        | 08/05/2024 | 18:15      | PO          | Premonsoon Maintenance Work                                                                                                                                                                  |
| <b>220 KV TIEBAY Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2024**

**Statement-VII**

Position as on 6.30 Hrs of 09/May/2024

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                        |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220 KV BUS COUPLER                      | IntraState                | 08/05/2024   | 10:45        | 08/05/2024 | 18:20      | PO          | URGENT REPLACEMENT OF DETRORATED TYPE CLAMPS & JUMPERS FROM BUS 2 ISO. TO CB AND CTS AT 220KV AMBAZARI SS.                                                                                                                                              |
| <b>220 KV MAINBAY Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                                                                                                                         |
| 220KV BUS SECTION BAY @ PEDAMBE         | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                            |
| <b>220 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                         |
| JEUR - SOLAPUR PG                       | InterState                | 08/05/2024   | 11:22        | 08/05/2024 | 18:39      | PO          | Replacement of faulty strings found in PID testing.                                                                                                                                                                                                     |
| KHARGHAR - ULWE GIS CKT-1               | IntraState                | 19/04/2024   | 15:22        | 08/05/2024 | 13:20      | T           | Wavetrap uncoiled at Kharghar end                                                                                                                                                                                                                       |
| BOISAR II - BOISAR (PG) CKT - 1         | IntraState                | 08/05/2024   | 05:21        | 08/05/2024 | 09:22      | PO          | work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only. |
| GADCHANDUR - GRACE                      | IntraState                | 08/05/2024   | 07:25        | 08/05/2024 | 10:26      | PO          | FOR RELAY TESTING WORK BY TESTING TEAM.                                                                                                                                                                                                                 |
| 220KV PARANDA -BARSHI CKT               | IntraState                | 08/05/2024   | 09:26        | 08/05/2024 | 13:12      | PO          | OUTAGE IS REQUIRED FOR QUARTERLY BAY MAINTENANCE WORK AT BARSHI END                                                                                                                                                                                     |
| PARANDA-BARSHI                          | IntraState                | 08/05/2024   | 09:26        |            |            | PO          | Outage is required for Quarterly bay maintenance work                                                                                                                                                                                                   |
| 220 KV KARJAT-BELWANDI-CKT-1            | IntraState                | 08/05/2024   | 10:00        | 08/05/2024 | 19:23      | PO          | For Bus Side Jump replacement work of bus Isolator of all 3 phase of 220 kV Karjat-Belwandi Ckt.                                                                                                                                                        |
| WARDHA - WARDHA RLY TSS 1               | IntraState                | 08/05/2024   | 10:12        | 08/05/2024 | 13:57      | PO          | REPLACEMENT OF SF6 DENSITY MONITORING SWITCH                                                                                                                                                                                                            |
| VIRUR - VIRUR RLY TSS 2                 | IntraState                | 08/05/2024   | 10:38        | 08/05/2024 | 21:39      | PO          | FOR RELAY RETROFITTING WORK BY TESTING TEAM                                                                                                                                                                                                             |
| AAREY - AEML SAKI CKT - 2               | IntraState                | 08/05/2024   | 21:48        |            |            | T           | Tripped on Yph to ground fault                                                                                                                                                                                                                          |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2024**

**Statement-VII**

Position as on 6.30 Hrs of 09/May/2024

| Name of Line                                | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|---------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| JEJURI - KONDHWA                            | IntraState                | 09/05/2024   | 00:40        |            |            | PO          | Double Jumepring work due to Hotspot<br>1) L. N -7 (M /C tower )-Y Phase - 64 degree<br>2) L. N -31 (M/ C tower )-Y Phase , -61 degree<br>3) L.N.-98 (M/C tower)-Y Phase,58 Degree<br>4) L.N.-86 ( M/c tower ) &#65533;Y Phase-54 Degree<br>5) L.N- 1( D/C tower) &#65533; R,Y, B Phase-63,42,92 Degree<br><br>Replacements of String due to broken<br>L.N.-12- R, Phase Suspension string<br><br>Double Jumepring work due to Hotspot<br><br>6) L.N.-97 (M/C tower)-Y Phase,52 Degree.<br>7) L. N -49 (M/ C tower)-Y Phase, Kondhawa side -51 Degree.<br>8) L.N.-98(M/C tower)-B Phase,73 Degree & 47 Degree |
| BOISAR II - BOISAR (PG) CKT - 1             | IntraState                | 09/05/2024   | 04:58        |            |            | PO          | work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.                                                                                                                                                                                                                                                                                                                                                       |
| <b>220 KV ICT Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| 100 MVA 220/132 KV ICT - II                 | IntraState                | 08/05/2024   | 06:35        | 08/05/2024 | 08:22      | PO          | PREMONSOON MAINTENANCE WORK                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| 220/132 KV 200 MVA ICT - 1 @ HARANGUL       | IntraState                | 08/05/2024   | 07:44        | 08/05/2024 | 17:11      | PO          | PREMONSOON MAINTENANCE WORK                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| 220/100 KV 100 MVA ICT 2 @ KANDALGAON       | IntraState                | 08/05/2024   | 08:47        |            |            | PO          | Replacement of HV/LV bushing work to be carried out.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| 220/132KV 100MVA ICT 1 @ KATHAPUR           | IntraState                | 08/05/2024   | 09:23        | 08/05/2024 | 19:24      | PO          | Replacement of Yph HV High LCM value LA and and routine maintenance work.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 220/132 KV 100 MVA ICT 2 @ PUSAD            | IntraState                | 08/05/2024   | 09:45        | 08/05/2024 | 19:26      | PO          | DIAGNOSTIC TESTING AND BAY MAINTENANCE WORK                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| 100 MVA 220/132 KV ICT - I                  | IntraState                | 08/05/2024   | 10:02        | 08/05/2024 | 12:21      | PO          | FOR PRE-MANSOON MAINTENANCE WORK                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| 220/132kv 100MVA ICT-3 @ SATARA MIDC-220 KV | IntraState                | 08/05/2024   | 15:51        | 08/05/2024 | 19:25      | PO          | 1.Relay Testing Work<br>2.Pre- Monsoon Maintenance Work                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| <b>132 KV LINE Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| 132 KV KANHAN (220 KV) - PENCH CKT          | InterState                | 08/05/2024   | 06:43        | 08/05/2024 | 17:11      | PO          | FOR EARTHWIRE REPLACEMENT AND ROUTINE MAINTENANCE WORK                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 08/May/2024**

**Statement-VII**

**Position as on 6.30 Hrs of 09/May/2024**

| Name of Line                         | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                 |
|--------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------------------------------------------------------------------------------------------|
| KANHAN-PENCH                         | IntraState                   | 08/05/2024      | 06:43           | 08/05/2024 | 17:11         | PO             | For earthwire replacement & routine maintenance work                                                             |
| KANHAN-PENCH                         | IntraState                   | 09/05/2024      | 06:47           |            |               | PO             | For earthwire replacement & routine maintenance work                                                             |
| <b>110 KV LINE Outages/Trippings</b> |                              |                 |                 |            |               |                |                                                                                                                  |
| SALSETTE POWAI                       | IntraState                   | 27/03/2023      | 11:04           |            |               | PO             | Replacement of tower number 77 & 78 for TDS project work.                                                        |
| KHOPOLI - BHOKARPADA                 | IntraState                   | 08/05/2024      | 06:27           | 08/05/2024 | 11:58         | PO             | 1. C Phase Line IVT R/M and test<br>2. Line Side GOD to CT jumper disconnection for facilitating CT replacement. |
| KHOPOLI - BHOKARPADA                 | IntraState                   | 08/05/2024      | 06:27           | 08/05/2024 | 11:58         | PO             | Repairing of C Phase damaged conductor in span 278-279<br>(Compression of Repair sleeve)                         |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage