

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 08/Jun/2019 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	150.982	1306.197	1) Gujrat	-2.357	-12.546
2) Hydro	4.745	34.310	2) Madhya Pradesh	4.050	60.214
3) Gas	3.400	50.422	3) Chattisgarh	3.450	28.400
Total MSPGCL	159.127	1390.929	4) Maharashtra	123.236	906.255
B) 1) APML	74.221	576.570	5) Goa (Amona)	-0.352	-3.036
2) JSWEL	24.611	194.062	Total	128.027	979.287
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.157	249.824
4) RPL(AMT)	25.682	198.130	b) Mumbai Drawl	39.524	312.831
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	10.257	85.664
6) Other IPP	7.493	58.250	Include PX	-5.113	-30.113
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.157	249.824
C) 1) TPCL Thermal	13.319	107.075	Include PX	13.142	111.045
2) TPCL Hydro	2.837	23.273	Standby	0.000	0.000
3) TPCL Gas	4.311	34.584	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.686	75.857	1) MSEDCL	403.011	3377.764
D) STATE			2) Mumbai Discoms	69.677	553.621
1) Thermal	305.994	2516.141	TOTAL STATE	472.688	3931.385
(A1+C1+C4+(B1-B6))					
2) Hydro	7.582	57.583			
(A2+C2)					
3) Gas	7.711	85.006			
(A3+B7+C3)					
4) Wind	17.670	244.264			
6) SOLAR	5.704	49.103			
TOTAL STATE	344.661	2952.097			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6375	6484	6384	6005
MSPGCL Hydro	106	325	253	129
MSPGCL Gas	142	141	134	146
MSPGCL Total Generation	6623	6950	6771	6280
Central Sector Receipt	5741	5973	5054	4747
WIND	458	770	855	627
CPP / IPP Thermal	5368	5869	5947	5268
CPP / IPP Gas	0	0	0	0
SOLAR	745	435	0	0
Exchange with Mumbai	-2004	-1802	-1457	-1427
MSEDCL DEMAND MET	16931	18195	17170	15495
Load Shedding	0	0	0	0
MSEDCL DEMAND	16931	18195	17170	15495
TPCL GENERATION	812	1117	1120	656
AEML GENERATION	375	428	377	376
MUMBAI DEMAND	3191	3347	2954	2459
STATE DEMAND MET	20122	21542	20124	17954
STATE DEMAND	20122	21542	20124	17954
Frequency (Hz)	49.96	49.98	49.90	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.13 Hz at 10.00 Hrs	49.64 Hz at 22.12 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 08/Jun/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.66	31.47	190	125
Unit 7	3.36	22.07	160	106
Unit 8	8.54	68.76	450	277
Unit 9	9.67	83.55	520	300
Unit 10	9.28	83.34	455	320
Total	34.49	289.19		
Bhusawal				
Unit 3	0.00	12.44	0	0
Unit 4	10.21	80.48	505	350
Unit 5	0.00	61.55	0	0
Total	10.21	154.46		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	11.77	0	0
Total	0.00	11.77		
Chandrapur				
Unit 3	4.51	34.47	193	163
Unit 4	3.93	31.26	168	157
Unit 5	9.47	76.34	415	365
Unit 6	9.40	80.12	420	355
Unit 7	9.05	77.00	420	350
Unit 8	11.66	88.33	496	395
Unit 9	11.35	84.11	485	395
Total	59.38	471.64		
Paras				
Unit 3	6.02	46.77	260	186
Unit 4	4.40	44.26	252	0
Total	10.42	91.02		
Khaparkheda				
Unit 1	3.14	25.54	140	105
Unit 2	2.70	24.06	140	110
Unit 3	3.36	26.78	150	110
Unit 4	3.38	26.76	144	138
Unit 5	11.50	88.15	493	460
Total	24.07	191.29		
Nasik				
Unit 3	4.14	33.03	197	154
Unit 4	4.23	31.02	204	159
Unit 5	4.04	32.78	195	126
Total	12.41	96.83		
Uran				
All Units	3.40	50.42	147	130
Total	3.40	50.42		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.01	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.01		
Koyna				
Stage 1-2	1.22	10.18	150	20
Stage 4	0.00	0.00	0	0
Stage 3	0.08	2.17	76	0
Total	1.29	12.35		
Hydro				
KDPH	0.42	3.46	18	17
VTRNA	1.09	7.77	61	0
TILLARI	0.00	0.97	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.18	1.18	40	0
RNGR+BHTSA	0.20	1.71	9	0
BHANDARDRA	0.00	1.07	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.11	1.46	5	4
GHATGHAR	1.46	4.34	250	0
Total	3.45	21.96		
Wind				
Total	17.67	244.26	0	0
Total	17.67	244.26		
CPP				
APML(Mus)	74.22	576.57	0	0
JSWEL(Mus)	24.61	194.06	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	25.68	198.13	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	7.49	58.25	0	0
Total	132.01	1027.01		
SOLAR				
Total	5.70	49.10	0	0
Total	5.70	49.10		
Tata				
Trombay 5	8.40	67.54	482	305
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.74	22.08	117	90
Trombay 7B	1.58	12.51	67	59
Trombay 8	4.91	39.53	232	199
TATA Hydro	2.84	23.27	322	3
Total	20.47	164.93		
AEML				
DTPS U-1&2	9.69	75.86	499	374
Total	9.69	75.86		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	150.98	1306.20	MSPGCL Total	159.13	1390.93
			MSPGCL Thml+Gas	154.38	1356.62	Koyna 1,2 & 4 Total	1.22	10.18
			MSPGCL Hydro	4.74	34.31	State Total	344.66	2952.10

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 08/Jun/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6793	129	135	7057	914	5830	0	0	5141	4625	-1763	16663	0	16663	3044	19707	49.97
2	6655	129	146	6930	1263	5749	0	0	5135	4784	-1727	16999	0	16999	2825	19824	49.99
3	6186	129	147	6462	1244	5149	0	0	4876	4790	-1598	16047	0	16047	2660	18707	49.95
4	6003	129	147	6279	905	4960	0	0	5061	4995	-1465	15674	0	15674	2526	18200	49.96
5	6005	129	146	6280	627	5268	0	0	5055	4747	-1427	15495	0	15495	2459	17954	49.93
6	6013	134	137	6284	482	5503	0	0	5049	5117	-1399	15987	0	15987	2440	18427	49.96
7	6106	140	146	6392	329	5511	0	46	5196	5247	-1307	16218	0	16218	2371	18589	49.95
8	6064	109	147	6320	219	5252	0	162	5052	5015	-1340	15628	0	15628	2402	18030	50.02
9	5995	119	146	6260	420	4926	0	361	5083	5437	-1472	15932	0	15932	2541	18473	50.00
10	6193	114	145	6452	441	4906	0	509	5306	5581	-1655	16234	0	16234	2792	19026	49.99
11	6356	92	134	6582	475	5071	0	683	5561	5850	-1921	16740	0	16740	3059	19799	50.01
12	6375	106	142	6623	458	5368	0	745	5961	5741	-2004	16931	0	16931	3191	20122	49.96
13	6299	111	142	6552	542	5462	0	841	5989	5766	-1982	17181	0	17181	3232	20413	49.94
14	6115	126	130	6371	635	5399	0	807	5864	6101	-1908	17405	0	17405	3189	20594	49.94
15	6337	362	140	6839	669	5673	0	652	5951	5884	-1864	17853	0	17853	3297	21150	49.88
16	6484	325	141	6950	770	5869	0	435	5985	5973	-1802	18195	0	18195	3347	21542	49.98
17	6481	272	132	6885	1027	5615	0	289	5927	6230	-1804	18242	0	18242	3267	21509	49.99
18	6283	258	143	6684	1168	5355	0	129	5484	5655	-1790	17201	0	17201	3112	20313	49.98
19	6130	248	143	6521	1008	5311	0	45	4976	4906	-1662	16129	0	16129	2962	19091	49.94
20	6282	267	143	6692	908	5899	0	0	4835	4924	-1538	16885	0	16885	2965	19850	49.83
21	6384	253	134	6771	855	5947	0	0	4834	5054	-1457	17170	0	17170	2954	20124	49.90
22	6461	367	145	6973	744	5904	0	0	4822	4881	-1507	16995	0	16995	2945	19940	49.93
23	6463	282	144	6889	754	6072	0	0	5170	5369	-1490	17594	0	17594	3001	20595	49.87
24	6519	415	145	7079	813	6008	0	0	5271	5355	-1642	17613	0	17613	3096	20709	49.89
MUs	150.98	4.75	3.40	159.13	17.67	132.01	0.00	5.70	127.58	128.03	-39.52	403.01	0.00	403.01	69.68	472.69	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 08/Jun/2019

Position as on 6.30 Hrs of 09/Jun/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	20/05/2019	16.01		Continued.	Gas shortage	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 3	210	04/06/2019	20.15		Continued.	Zero Schedule	
MSPGCL	Bhusawal Unit 5	500	07/06/2019	06.17	09/06/2019	00.10	Ash Feed Gate replacement work	
MSPGCL	Koyana STG-IV Unit-3	250	07/06/2019	10.00		Continued.	Stepup T/F Oil Leakage and Shaft Seal replacement	
MSPGCL	Uran Unit 5	108	07/06/2019	23.45		Continued.	Air Filter Replacement & Allied Work.	
MSPGCL	Paras Unit 4	250	08/06/2019	02.36	08/06/2019	07.30	Auxiliary supply failure	
MSPGCL	Koradi Unit 6	210	09/06/2019	08.24	09/06/2019	14.50	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Akola-II ckt-I	IntraState	08/06/2019	16.16	08/06/2019	16.58	T	Distance Protection:3.8 KAMP 156 KM:Z-1:B-PH 56.1.5.3 KAMP.
Koradi III - Akola II- ckt-II	IntraState	08/06/2019	16.16	08/06/2019	16.31	T	Distance Protection, Tripped From Koradi3 end.
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	08/06/2019	15.42	08/06/2019	21.48	PO	Insulator Chemical Washing.
Chandrapur - Padghe Hvdc Pole 1	IntraState	09/06/2019	15.09	09/06/2019	21.31	PO	CHEMICAL WASHING OF INSULATORS.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	04/06/2019	18.55		Continued.	HT	Over Voltage
Chandrapur Bhadravati IV	InterState	07/06/2019	18.34	08/06/2019	21.39	T	DT Sent, Over Voltage Trip. CVT Suspected.
Koradi Bhilai	InterState	08/06/2019	17.12	08/06/2019	18.03	T	Distance Protection: Y-Phase Z-1,IF15.8KA.
Khadka-Aurangabad (Waluj)	IntraState	07/06/2019	21.13		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	07/06/2019	21.23	08/06/2019	02.18	T	Y-Ph CVT Jump Break (Tripped 21.23HRS)
Lonikand I - Koyna stage-IV	IntraState	08/06/2019	03.32	08/06/2019	04.15	T	Distance Protection, Y Ph, E/F.
Lonikand I - Koyna stage-IV	IntraState	08/06/2019	11.14	08/06/2019	14.40	EO	Decapping attending work.
N.Koyna-Karad -Ckt II	IntraState	08/06/2019	14.56	08/06/2019	21.19	EO	Flashover String Replacement.
Akola II - RPL(Rattanindia) Ckt-II	IntraState	08/06/2019	16.16	08/06/2019	19.12	T	Distance Protection:B-PH:IF2.7 KAMP.
Koradi III(Adani)-Korad II Ckt-I	IntraState	08/06/2019	16.16	08/06/2019	17.56	T	DT RECeived:Trip Protection Operated ON High Lightening
Koradi-RattanIndia	IntraState	08/06/2019	17.07	08/06/2019	17.31	T	Distance Protection:B-PH:IF2.7 KAMP.
Koradi III(Adani)-Koradi II ckt 2	IntraState	08/06/2019	17.09	08/06/2019	17.40	T	Distance Protection:B-PH:IF2.7 KAMP.
New Koyna - Dabhol - II	IntraState	09/06/2019	03.34	09/06/2019	04.05	T	Distance Protection tripped at Dabhol end only.
New Koyna - Dabhol - II	IntraState	09/06/2019	04.30	09/06/2019	09.45	T	Distance Protection tripped at Dabhol end only.
Lonikand I - Koyna stage-IV	IntraState	09/06/2019	05.13	09/06/2019	14.42	T	Distance Protection
Padghe - Kalwa-II	IntraState	09/06/2019	05.26	09/06/2019	10.28	EO	Replacement of decapped insulator string at location number 1029.
Nagothane - Dabhol I	IntraState	09/06/2019	06.02	09/06/2019	11.22	T	Distance Protection tripped at Dabhol end only.
N.Koyna-Karad -Ckt I	IntraState	09/06/2019	06.07	09/06/2019	14.40	T	Distance Protection
Chakan-Talegaon (Pgcil)	IntraState	09/06/2019	20.03		Continued.	T	TRIPPED FROM CHAKAN END Z1,Y-E,4KM,20KA FROM TALEGAON PG 1.03KM,18.70KAMP.
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	09/06/2019	09.08	09/06/2019	17.3	PO	OLTC Overhauling.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Boiser(M)-Boiser(PG) -III	InterState	09/06/2019	09.21	09/06/2019	21.25	PO	Construction work
Khaparkheda-Butibori 3	InterState	09/06/2019	10.47	09/06/2019	12.54	EO	Removal of Earthwire.
Boisar(MS) - Boisar (PG) - I	InterState	09/06/2019	12.02	09/06/2019	17.16	PO	CONSTRUCTION WORK.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 08/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Warora - Hinganghat	IntraState	07/06/2019	17.16		Continued.	T	Tower Collapsed At Location No.327, RYB 3.94KA, 4.41KA, 4.11KA.
Warora - Wardha	IntraState	07/06/2019	17.16		Continued.	T	Wrora-Y PH Pick, B PH Pick Up,Z1.Wardha-Y PH B PH, Z1-B 91.8 KM.3.31KAMP.3.24KAMP.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	08/06/2019	03.09	08/06/2019	03.47	T	Trip From Navasari End Only.
Sadawaghapur Karad Ckt 2	IntraState	08/06/2019	04.49	08/06/2019	14.32	T	Distance Protection,Z-1,RYB Trip,R-4.23AMP,Y-1.75,B-680,D-31KM,B-phase 29A-29B T Section To Stub Bus Insulator Flashover.
Karad - Sadawagpur I	IntraState	08/06/2019	04.49	08/06/2019	14.30	T	Distance Protection,Z-1,RYB Trip,R-4.23AMP,Y-1.75,B-680,D-31KM,B-phase 29A-29B T Section To Stub Bus Insulator Flashover.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	08/06/2019	05.39	08/06/2019	14.00	T	Distance Protection,Z-1 R-G,D-66.91KM.IA-2437 AMP.
Kalwa-TIFIL	IntraState	08/06/2019	07.04	08/06/2019	12.17	PO	Replacement of rusted bolted tension clamp by dead end.
Pophali - Nerale	IntraState	08/06/2019	07.10	08/06/2019	19.50	PO	Bus section outage.
Pophali - New Koyna	IntraState	08/06/2019	08.00	08/06/2019	19.30	PO	Bus section outage.
Tata Borivli MSETCL Borivli 4	IntraState	08/06/2019	08.16	08/06/2019	13.02	PO	Tree trimming.
Bus Section II @ Pophali	IntraState	08/06/2019	08.45	08/06/2019	20.20	PO	Pre-monsoon maintenance work.
Kharghar-Panvel TSS	IntraState	08/06/2019	08.49	08/06/2019	16.34	PO	Replacement work
Vasai Kamba	IntraState	08/06/2019	09.20	08/06/2019	16.11	PO	Insulator Replacement Work
Malegaon-Satana	IntraState	08/06/2019	09.42	08/06/2019	18.33	PO	Insulator Replacement Work
Pophali - Pedambe II	IntraState	08/06/2019	10.45	08/06/2019	18.40	PO	Bus section outage.
Pegasus - Infosys	IntraState	08/06/2019	10.46	08/06/2019	15.01	PO	Premonsoon Work.
Nerle - Dasgaon	IntraState	08/06/2019	11.30	08/06/2019	13.51	PO	String Replacment.
Eklahara(Ocr)(Nashik)-Navasari II	IntraState	08/06/2019	11.34	08/06/2019	14.00	T	Loc No.204 RPH Decapping.
Eklahara(Ocr)(Nashik)-Navasari II	IntraState	08/06/2019	14.20	08/06/2019	16.27	EO	Replacement Of Flashover String.
Kandalgaon - Koyna (Pophali)	IntraState	09/06/2019	06.50	09/06/2019	07.50	T	Distance Protection
Midc Chandrapur-Gadchandur	IntraState	09/06/2019	07.46	09/06/2019	16.50	PO	FOR CRIMPING OF CONDUCTOR WITH REPAIR SLEEVES AT LOC.123&124 AND SIGNATURE TEST.
Boisar(M) - Ghodbunder	IntraState	09/06/2019	08.56	09/06/2019	09.43	HT	LOAD MANAGEMENT ON BOISAR-BOISAR-PG OUTAGE.
Boisar Versova Line	IntraState	09/06/2019	09.05	09/06/2019	09.41	HT	Load Management On Boisar-PG Outage.
Balapur-Akola I	IntraState	09/06/2019	10.35	09/06/2019	13.33	PO	Line Maintenance work
Khaparkheda-Ambazari-Ii	IntraState	09/06/2019	10.42	09/06/2019	12.25	PO	REMOVAL OF EARTHWIRE FROM LOCATION NO.29-30 OF 220KV NEW KHAPERKHEDA-AMBAZARI-1&220KV KHAPERKHEDA-BUTTIBORI 3CKT.
Boisar-Viraj	IntraState	09/06/2019	11.27	09/06/2019	17.25	HT	LOAD MANAGMENT ON

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 08/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 09/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							BOISAR-BOISAR-PG OUTAGE.
Lonikand-VSNL	IntraState	09/06/2019	17.27		Continued.	T	Distance Protection
Loteparshuram- Dasturi Line	IntraState	09/06/2019	18.06		Continued.	T	INSULATOR BROKEN AT LOC. NO.97.
Kandalgaon - Koyna (Pophali)	IntraState	09/06/2019	18.55	09/06/2019	21.05	T	TRIPPED FROM POPHALI END ONLY.
Parly-Parly Extn.-II	IntraState	09/06/2019	19.48	09/06/2019	21.25	T	Y-PHASE CT BRUST: ALL 220KV LINE AFFECTED.
Trombay Salsette 1 Backbay	IntraState	09/06/2019	23.22	09/06/2019	23.53	T	Distance Protection
220 KV ICT Outages/Tripping							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Bucchoz Trip.
220/100 Kv 100 MVA ICT II @Kandalgaon	IntraState	01/06/2019	11.30		Continued.	PO	Oil Filtration Work.(Charged On Humming).
220/33 Kv 100 Mva Ptr 2 @Sadawaghapur	IntraState	08/06/2019	00.41	08/06/2019	14.31	T	B-PH C.B. To Stub Bus Insulator Flashover.
220/33 Kv 100 Mva Ptr 1 @Sadawaghapur	IntraState	08/06/2019	00.41	08/06/2019	14.51	T	Y-PH C.B. To Stub Bus Insulator Flashover.
220/33 Kv 50 Mva Imp Ptr 1 @Sonkar	IntraState	08/06/2019	08.35	08/06/2019	12.35	PO	Premonsoon Maintence.
220kv 200MVA ICT IV @ OCR Nashik	IntraState	08/06/2019	08.47	08/06/2019	10.26	PO	Premonsoon Maintence.
220/132 KV ICT-2 @Nagar	IntraState	08/06/2019	10.17	08/06/2019	15.53	PO	Oil leakage attending work.
220/132 kv 200MVA ICT-V @ Nashik	IntraState	08/06/2019	10.31	08/06/2019	11.57	PO	Premonsoon Maintence.
220/132 KV ICT III @ Nasik OCR	IntraState	08/06/2019	11.58	08/06/2019	13.04	PO	Premonsoon Maintence.
220/100 Kv 100 Mva Cgl Ict 1 @Taloja	IntraState	08/06/2019	12.00	08/06/2019	12.58	PO	Premonsoon Maintence.
220/33kv 100 Mva Transformer 3 @Ghodbunder R/S	IntraState	08/06/2019	15.25	08/06/2019	16.58	PO	Removal OF Birdnet.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage